



## A note on wind generator interaction

**Jensen, N.O.**

*Publication date:*  
1983

*Document Version*  
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

*Citation (APA):*  
Jensen, N. O. (1983). *A note on wind generator interaction*. Risø National Laboratory. Risø-M No. 2411

---

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

J. Højstrup

# A Note on Wind Generator Interaction

N.O. Jensen

Fig 1  
Fig 5 p12

RISØ-M-2411

A NOTE ON WIND GENERATOR INTERACTION

N.O. Jensen

Abstract. A simple model for the wake behind a wind generator is given. The model is compared to some full scale experimental results. The model is then used in an example where the production from a circular cluster of 10 wind generators is calculated. Next the simple wake model is extended to deal with a number of aligned generators, and finally an example is given where the production from a linear cluster of 10 generators is calculated.

EDB descriptors: ENERGY PARKS; TURBULENCE; WIND; WIND TURBINES

UDC 621.548 : 533.69.048.3

November 1983

Risø National Laboratory, DK-4000 Roskilde, Denmark

ISBN 87-550-0971-9

ISSN 0106-2840

Risø Repro 1983

CONTENTS

	Page
1. WAKE MODEL .....	5
2. EXAMPLE WITH 10 GENERATORS IN A CIRCLE .....	9
3. MULTIPLE WAKES .....	12
4. EXAMPLE WITH 10 GENERATORS IN A ROW .....	14
5. REFERENCES .....	16

### 1. WAKE MODEL

If we neglect the near field behind a wind generator, where periodic and deterministic swirling vortices make a special contribution, it might be possible to treat the resulting wake behind the generator as a turbulent wake or negative jet. The areal spread of momentum deficit of a feature like this is such that linear dimension (radius  $r$ ) is proportional to down-wind distance,  $x$ . A balance of momentum gives (see Fig. 1)

$$\pi r_0^2 v_0 + \pi(r^2 - r_0^2)u = \pi r^2 v, \quad (1)$$

where  $v_0$  is the velocity just behind the rotor,  $u$  is the ambient wind velocity, and  $v$  is the velocity in the wake at distance  $x$  from the generator. Solving for  $v$ , and further assuming a linear




Fig. 1. Schematic wake model with definition of symbols used in the text.

wake ( $r = x$ ), and that the velocity just behind the rotor is  $\frac{1}{3}u$  in accordance with classical theory, gives

$$v = u \left\{ 1 - \frac{2}{3} \left( \frac{r_0}{r_0 + \alpha x} \right)^2 \right\} . \quad (2)$$

For usual wakes the entrainment constant  $\alpha$  is approximately 0.1. Using this value, and relevant values of  $x$  and  $r_0$ , Eq. (2) is plotted on Fig. 2, where it might be compared to actual measurements by Vermeulen (1979). The agreement is seen to be excellent in regard to the observed centerline retardation.

Another source that the simple model can be checked against is the early results from the Nibe-wake project (Højstrup, 1983). Table I compares model prediction and experimental results. Again the agreement is seen to be very satisfactory.

Table I. Wind measurements (approximately 1 hr averages) in the center of the wake of Nibe-A (Højstrup 1983), which has a rotor radius of  $r = 20$  m. The wind speed 100 m upwind was reported to  $u = 8.10$  m/s. The numbers given under the heading "Model" is results from Eq. (2) with  $\alpha = 0.1$ . Using the measurements to calibrate  $\alpha$  produces  $\alpha = 0.070$ . However, this refinement is probably not justified as the assumption of  $\frac{1}{3}u$  just behind the rotor is fairly uncertain and in reality is dependent on the loading of the turbine.

Downwind distance [m]	Wind velocity in the wake	
	Observed [m/s]	Model [m/s]
40	3.95	4.35
100	5.03	5.70

+




Fig. 2. Measured wake profiles (256 sec average values) after Vermeulen et al. (1979), along with predictions according to Eq. (2) with and without a cosine-bell (Eq. (3)) employed.



Regarding the cross-wind variation, the present simple model prescribes a "top-hat" distribution while the real distribution appears to be more Gaussian or bell-shaped. The difference is shown in Fig. 2, where the width of the bell-shape is taken from Vermeulen (1979), and the width of the top-hat corresponds to  $\alpha = 0.1$  as used above. In a climatological appraisal of the wake effect on an other object (e.g. another wind generator) this difference is probably not too important as the regions of over- and under-estimation may cancel, but of course it is possible to apply a modulation such as

$$f(\theta) = \frac{1+\cos(9\theta)}{2} \quad ; \quad \theta < 20^\circ , \quad (3)$$

to be applied onto the  $x$  and  $r_0$  dependent part of Eq. (2) to comprise a deficit we shall call the wake function. Here  $\theta$  is the off-axis angle in degrees. For  $\theta > 20^\circ$  of course  $f(\theta) = 0$ . In the example to follow in the next section we shall apply this. To show its degree of fit to reality it is plotted on top of Vermeulen's results in Fig. 2.

Further, in the above simple model it is assumed that the wake expands freely (the presence of the solid earth surface is neglected). This causes an overestimated rate of recovery of velocity in the wake. If a more realistic, and pessimistic, estimation of the development of the wake is wanted, it is possible to incorporate it by using an imaginary wind generator at the negative hub height of the actual generator. This technique is well-known in calculations of stack plume development. However, in the present analytical treatment this slight complication is avoided.

## 2. EXAMPLE WITH 10 GENERATORS IN A CIRCLE

The immediate reaction to a proposition for a number of generators to be put in a circular array is that it might not be beneficial. Of course, it all depends on the size of the generators (wing length or rotor radius) and the diameter of the array. Here we shall examine the output of 10 generators with  $r = 10$  m, placed on circle of diameter  $D = 200$  m as a function of wind direction. The problem with a circular array is that some generator will always be in the lee in contrast to a simple line of generators which will only interact when the wind is in a certain sector (to be arranged as the less frequent).

Fig. 3 shows a schematic outline of the array in question. Wakes corresponding to Eq. (2) are shown as cross hatched areas. If the wind direction corresponds to the direction of the A-B sector, which has a length of  $\sim 60$  m, the B and F generators will have a much reduced output, and in addition the C, D and E generators will have a slightly reduced output too. According to Eq. (2) the wind velocity at B and F will be approximately  $0.74u$  while at C, D and E it will be about  $0.93u$ . Thus the total output  $E$  relative to the output of 10 non-interacting generators  $E_0$  may be estimated as

$$\frac{E}{E_0} = \frac{5u^3 + 2(0.74u)^3 + 3(0.93u)^3}{10u^3} \approx 0.82 . \quad (4)$$

This reduction will prevail for a range of wind directions corresponding to the spreading angle of the wake. At a wind direction  $\theta = 18^\circ$  (see Fig. 3) C and F will be in the wake of A and H, and the wind velocity at C and F will be approximately  $0.86u$ . In this situation we have

$$\frac{E}{E_0} = \frac{6u^3 + 2(0.86u)^3 + 2(0.93u)^3}{10u^3} \approx 0.89 . \quad (5)$$




Fig. 3. Schematic outline of a circular array of 10 turbines, with definition of wake direction relative to array orientation.

For a further change in direction, C will gradually become directly in the wake of B, and the situation will then become equivalent to the situation first described. It is easily seen that the problem is symmetric with a period of  $36^\circ$ .

Although the above simplified calculations give a good idea of the order of magnitude of the reduction of the production to be expected from a circular array, a more precise calculation is warranted. Such a calculation is performed here in which the bell shape given by Eq. (3) is used and the calculation is done for steps of  $1^\circ$  in the wind direction. For certain wind directions it happens that the fringes of different wakes overlap at generator sites downstream. In such cases the wake functions are added (in analogy with two plumes of passive tracer where the overlapping region is the sum of the concentrations of the two single plumes, calculated as if the other was not present). The relative energy production thus calculated is shown in Fig. 4 as a function of wind direction. Results are only shown for a range of  $36^\circ$ ; beyond this range the curve repeats itself. The level of  $E/E_0$  is seen to agree well with the above estimates. The average reduction can be computed to be 0.83.




Fig. 4. Calculated output of the circular array mentioned in the text, relative to the output of an equal number of non-interacting generators, given as a function of the wake direction defined in Fig. 3.

### 3. MULTIPLE WAKES

The above wake model can be applied to the case in which multiple wake interaction occurs, i.e. the case in which a wind generator is in the wake of a generator, which in turn is in the wake of another and so forth. Such an arrangement is pictured in Fig. 5 along with a definition of essential variables. The velocity  $v_1$  in front of generator 2 is given directly by Eq. (2). To find the velocity  $v_2$  in front of generator 3 we apply a balance similar to Eq. (1) immediately using that the velocity directly behind generator 2 is  $\frac{1}{3}v_1$ :

$$r_0^2(\frac{1}{3}v_1) + (r^2 - r_0^2)\bar{v}_1 = r^2v_2, \quad (6)$$

where  $\bar{v}_1$  is the weighted velocity of air entrained from wake 1 into wake 2 en route from generator 2 to generator 3, and  $r$  is the radius of the wake from generator 2 at generator 3.




Fig. 5. Schematic multiple wake model with definition of symbols used in the text.

In the spirit of the present model it is possible to compute  $\bar{v}_1$  exactly, but the expression is rather complicated and does not lend itself to the further calculations we intend to do. The results of such calculations are that  $\bar{v}_1$  is equal to  $u$  less a small amount on the order of  $0.3(r_0/\alpha x_0)^2 u$ , which shows that as distance becomes large compared to rotor dimension, the small fraction might be neglected. In any case, assuming  $\bar{v}_1 = u$  is conservative in the sense that it will not underestimate the output of the linear array (the entrainment of momentum is assumed slightly larger than in reality). Thus solving Eq. (6) for  $v_2$  gives approximately

$$\frac{v_2}{u} = 1 - (1 - \frac{1}{3} \frac{v_1}{u}) \left( \frac{r_0}{r_0 + \alpha x_0} \right)^2, \quad (7)$$

which is seen to be analogous to Eq. (2): the factor  $2/3 = (1 - \frac{1}{3})$  has been substituted by  $1 - \frac{1}{3}(v_1/u)$ . It is easy to show that in general, to the same approximation,

$$\frac{v_N}{u} = 1 - (1 - \frac{1}{3} \frac{v_{N-1}}{u}) \left( \frac{r_0}{r_0 + \alpha x_0} \right)^2. \quad (8)$$

Introducing the following simplification in notation:

$$\left. \begin{aligned} Y_N &= v_N/u \\ k &= (r_0/(r_0 + \alpha x_0))^2 \end{aligned} \right\}, \quad (9)$$

we get

$$Y_N = 1 - k(1 - \frac{1}{3} Y_{N-1}), \quad (10)$$

which means that

\* NOJ claims that  $\bar{v}_1 = v_1(x=2x_0)$  (off rotor plane #2) would be more appropriate.

$$\begin{aligned}
 y_1 &= 1 - k\frac{2}{3} ; \\
 y_2 &= 1 - k\frac{2}{3} - k^2\frac{2}{9} ; \\
 y_3 &= 1 - k\frac{2}{3} - k^2\frac{2}{9} - k^3\frac{2}{27} ;
 \end{aligned}$$

and in general

$$y_N = y_{n-1} - 2\left(\frac{k}{3}\right)^N . \quad (11)$$

Combination of Eqs. (10) and (11) gives the explicit expression

$$y_N = 1 - 2\frac{k}{3} \frac{1-(k/3)^N}{1-k/3} .$$

As  $k$  is of order unity or less, the term  $(k/3)^N$  vanishes very quickly with  $N$  increasing, and we get the asymptotic expression

$$\frac{v_\infty}{u} = 1 - \frac{2x}{1-x} ; \quad x \equiv \frac{1}{3} \left( \frac{r_0}{r_0 + \alpha x_0} \right)^2 . \quad (12)$$

#### 4. EXAMPLE WITH 10 GENERATORS IN A ROW

Let us again choose a rotor radius of  $r_0 = 10\text{m}$ . The asymptotic value of velocity in front of the downwind generators of course depends on the distance  $x_0$  between generators in the array: For  $x_0 = 50\text{m}$ ,  $v_\infty \cong 0.65u$  and for  $x_0 = 100\text{m}$ ,  $v_\infty \cong 0.82u$ . In fact already in front of the third generator the wind is down to these values, while in front of the second the speed is  $0.70u$  and  $0.83u$  for  $x_0 = 50$  and  $100$  m respectively. Thus the energy estimates for these two arrays relative to undisturbed generators are

$$\frac{E}{E_0} = \begin{cases} \frac{u^3 + (0.70u)^3 + 8(0.65u)^3}{10u^3} = 0.35 & ; \quad x_0/r_0 = 5 \\ \frac{u^3 + (0.83u)^3 + 8(0.82u)^3}{10u^3} = 0.60 & ; \quad x_0/r_0 = 10 \end{cases} .$$

Hence it is realized that the dependence on  $x_0$  is quite marked. However, this is only of importance in a quite narrow ( $\alpha=0.1$  corresponds to  $12^\circ$ ) wind direction sector; for other wind directions the generators are not interacting.

To be sure of not favouring the linear array above the circular, let us say that the whole of one standard wind sector of  $30^\circ$  is affected. If the wind rose is assumed to be circular, the average output becomes

$$\left\langle \frac{E}{E_0} \right\rangle = \begin{cases} \frac{10 + 2 \cdot 0.35}{12} \sim 0.89 \\ \frac{10 + 2 \cdot 0.60}{12} \sim 0.93 \end{cases}$$

for the two sets of distances. The thing to note here is that  $x_0$  is not a very important parameter when it comes to the average output, because the generators are not interacting for most of the time.

In the case where the generators are only 50 m apart, the power production is seen to be only  $\sim 10\%$  down, even with the angle of the affected sector overestimated a factor of order two ( $30^\circ$  instead of  $12^\circ$ ). But, the point I finally want to make is that  $10\%$  is an overestimate also for another reason: prevailing wind direction. Thus in Denmark northerly and southerly winds are only half as frequent as westerly winds, which put another factor of 2 decrease on the  $10\%$  figure.



## 5. REFERENCES

- Vermeulen P., Builtjes, P., Dekker, J. and van Bueren, G.L.  
(1979): An experimental study of the wake behind a full  
scale vertical-axis wind turbine. TNO-report, No. 79-06118.  
Laan van Westenenk 501, Apeldoorn, The Netherlands.
- Højstrup, J. (1983): Nibe Wake, part one. Internal technical  
report, Risø.

Risø - M - 2411

<p>Title and author(s)</p> <p>A note on wind generator interaction</p> <p>N.O. Jensen</p>	<p>Date November 1983</p> <p>Department or group Physics Dept.</p> <p>Group's own registration number(s)</p>
<p>16 pages + tables + illustrations</p>	
<p>Abstract</p> <p>A simple model for the wake behind a wind generator is given. The model is compared to some full scale experimental results. The model is then used in an example where the production from a circular cluster of 10 wind generators is calculated. Next the simple wake model is extended to deal with a number of aligned generators, and finally an example is given where the production from a linear cluster of 10 generators is calculated.</p> <p>Available on request from Risø Library, Risø National Laboratory (Risø Bibliotek), Forsøgslæg Risø), DK-4000 Roskilde, Denmark Telephone: (02) 3712 12, ext. 2262. Telex: 43116</p>	<p>Copies to</p>