

A structure-preserving energy function for stability analysis of AC/DC systems

K R PADIYAR¹ and H S Y SASTRY²

¹Department of Electrical Engineering, Indian Institute of Science, Bangalore 560012, India

²Karnataka Regional Engineering College, Srinivasanagar 574 157, India

Abstract. Direct stability analysis of AC/DC power systems using a structure-preserving energy function (SPEF) is proposed in this paper. The system model considered retains the load buses thereby enabling the representation of nonlinear voltage dependent loads. The HVDC system is represented with the same degree of detail as is normally done in transient stability simulation. The converter controllers can be represented by simplified or detailed models. Two or multi-terminal DC systems can be considered. The stability analysis is illustrated with a 3-machine system example and encouraging results have been obtained.

Keywords. Direct stability analysis; structure-preserving energy function; nonlinear voltage dependent loads.

1. Introduction

The application of energy functions for direct stability analysis of AC power systems has now reached a certain level of maturity (see Pai 1989, Ribbens-Pavella & Evans 1985) where it can be used as a screening tool for both on-line and off-line studies. However, there are several issues that are yet to be fully resolved – detailed system modelling, fast computation of critical energy, accuracy of prediction and correlation of energy margins to stability limits. The present state-of-the-art application of energy functions involves prediction of either critical clearing times or energy margin for a three-phase fault at a bus followed by clearing of the fault with or without line tripping. Whereas the formulation of the energy function is relatively straightforward, the computation of critical energy is either based on (a) evaluation of unstable equilibrium point (UEP) or (b) potential energy boundary surface (PEBS) method. Both methods are strictly approximations as the trajectory of the system does not necessarily pass through the UEP. However, practical experience shows the accuracy of the results.

While most of the work on energy functions is based on the reduced model of the system assuming constant impedance loads, recent developments in defining energy functions on a structure preserving model are promising as (a) realistic load models can be considered, (b) the problem of transfer conductances is eliminated. The reader is referred to Bergen & Hill (1981), Narasimhamurthi & Musavi (1984), Tsolas *et al*

(1985), Varaiya *et al* (1985), Padiyar & Sastry (1983, 1987), Padiyar & Ghosh (1987), Hiskens & Hill (1989) for details. The structure preserving energy function (SPEF) has been developed for a two-axis generator model with excitation system (see Padiyar & Ghosh 1989).

The application of energy functions for AC/DC system was first attempted by Pai *et al* (1981) by using a simplified DC link model. The dynamic loads due to the DC link along with other loads were represented as current injections at generator internal buses of the reduced system using distribution factors. The application of SPEF with realistic DC link models was reported by Padiyar & Sastry (1984). Ni & Fouad (1987) have applied energy functions neglecting the DC link dynamics and assuming strong voltage support at the converter bus. DeMarco & Canizares (1992) have recently proposed a vector energy function for AC/DC systems with two components, one for AC and the other for DC.

This paper presents an SPEF for AC/DC systems with two or multiterminal DC links. The energy function incorporates the DC system as dynamic loads at converter buses. Detailed or simplified converter control models can be used. Voltage dependent non-linear loads are considered. The analysis is illustrated by an example of a 3-generator system.

2. HVDC system model

The HVDC system consists of two or more converters (if multiterminal operation is to be considered). A converter terminal is shown in figure 1. In general, there is more than one bridge connected in series. All the bridges at a terminal are identical and operate at the same value of the control angle θ (delay or extinction angle).

2.1 Converter model

In transient stability studies, it is adequate to represent the converter by a simplified model in which the valve switchings are ignored. This is equivalent to ignoring the AC and DC harmonics.

From converter theory (see Padiyar 1991) the average DC voltage (pole to ground) per unit at a converter terminal is given by

$$V_d = kaV \cos \theta - R_c I_d, \quad (1)$$

where

$$k = 3\sqrt{2}N_s n_b V_{acb} / (\pi N_p V_{db}),$$

$$R_c = \pm (3n_b X_c / \pi Z_{db}), \quad Z_{db} = (V_{db} / I_{db}).$$




Figure 1. Single line diagram of converter station.




Figure 2. Norton's equivalent of a converter.

V_{acb} , V_{db} , I_{db} and Z_{db} are base AC voltage, DC voltage, DC current and DC impedance, respectively. n_b is the number of bridges per terminal, X_c is the converter transformer leakage reactance (on valve side).

For a rectifier, $\theta = \alpha$, while for an inverter, $\theta = \gamma$. I_d and R_c are assumed to be positive for the rectifier and negative for the inverter. The per unit system used here is more general than that used earlier (for example in Fudeh & Ong 1981). This is because V_{acb} can be chosen independently of V_{db} and can assume different values for different terminals. Similarly n_b , N_s and N_p can vary depending on the terminal. The effect of these parameters is included in a single parameter k which can vary. From (1), the converter terminal can be represented by Norton's equivalent of a current source I in parallel with R_c (see figure 2). The power (P_d) and reactive power (Q_d) are given by

$$P_d = pV_d I_d, \tag{2}$$

$$Q_d = P_d \tan \zeta, \tag{3}$$

$$\cos \zeta = V_d / kaV, \tag{4}$$

where p is the number of poles (one or two).

2.2 DC network equations

Unlike in AC networks, transients in a DC network are sometimes taken into account. However, it is simple to ignore fast transients and model only the resistive DC network. The use of Norton's equivalent circuits for converters, enables the DC network equations to be expressed with ground as reference node. The resistive DC network is modelled as

$$[G] V_d = I, \tag{5}$$

where $[G]$ is a conductance matrix of size n_d where n_d is the number of converter terminals. It is assumed that non-converter buses are absent or are eliminated.

2.3 Converter control model

There are three types of controller models.

(1) Detailed models which represent the dynamics of controllers and the parameters are tuned for particular system requirements. The use of such a model requires a knowledge of the actual system conditions for authenticity. The detailed controller model has to be interfaced with the network model considering the transients.

(2) A performance model assumes that the controllers are adequately designed to carry out the objectives of the control. For example, it is assumed that the actual DC current in the link faithfully follows the current reference instantaneously or with




Figure 3. Control characteristics.

prespecified time delay. In the former case, it is equivalent to ignoring the controller dynamics and modelling the performance of the controller using steady-state control characteristics. Typical control characteristics in $V_d - I_d$ plane for a two-terminal system are shown in figure 3. The intersection of the rectifier and inverter characteristics defines the operating point. The operations at 'A' corresponds to current control at the rectifier and constant extinction angle (CEA) control at the inverter. This is the normal operating mode. However, voltage dip at the rectifier converter bus results in the mode shift where current control is transferred to the inverter and the rectifier operates at minimum α (delay angle). Figure 3 also shows the influence of voltage-dependent current order limiter (VDCOL) which is mainly provided for preventing voltage instability and as a back-up protection against commutation failures.

The use of a performance model requires the use of mode shift logic to identify the transition from one mode to another. In multiterminal DC systems, the prediction of mode-shifts can be cumbersome. Hence, a variation of the performance model has been developed and is termed (Lefebvre *et al* 1991) a firing angle based simplified model.

(3) In the firing angle based simplified model the identity of the DC network is explicitly retained. The network model can be only resistive or include inductances also.

3. AC system model

The following assumptions are made in modelling the AC system:

- (i) the synchronous machine is represented by classical model;
- (ii) the AC network is assumed to be lossless;
- (iii) machine damping is neglected.

The assumption (i) is made here only for convenience and can be relaxed for detailed analysis including the effects of AVR (see Padiyar & Ghosh 1989).

3.1 Generator model

The swing equation for the i th generator, using centre of inertia (COI) variables, can be written as

$$M_i \dot{\omega}_i = P_{mi} - P_{ei} - (M_i/M_T) P_{COI}, \quad (6)$$

$$\dot{\theta} = \omega_i, \quad (7)$$

where

$$P_{ei} = E_i V_i \sin(\theta_i - \phi_i)/x'_{di}, \quad i = 1, 2, \dots, m, \quad (8)$$

$$P_{COI} = \sum_{i=1}^m (P_{mi} - P_{ei}), \quad (9)$$

m is the number of machines.

3.2 Load model

The loads are modelled as arbitrary functions of the respective bus voltages. Thus,

$$P_{ij} = f_{pj}(V_j), \quad (10)$$

$$Q_{ij} = f_{qj}(V_j). \quad (11)$$

3.3 AC network equations

The AC network is described by the power flow equations at each bus. At converter buses, P_d and Q_d are treated as dynamic loads.

The power flow equations at bus i are given by

$$P_i + P_{li} + e_i P_{di} = 0, \quad (12)$$

$$Q_i + Q_{li} + e_i Q_{di} = 0, \quad (13)$$

where $e_i = 1$, if $i \in D$ (where D is the set of converter buses), and $e_i = 0$, otherwise. P_i and Q_i are the injected power and reactive power given by the following expressions.

$$P_i = m_i E_i V_i \sin(\phi_i - \theta_i)/x'_{di} + \sum_{j=1}^N B_{ij} V_i V_j \sin \phi_{ij}, \quad (14)$$

$$Q_i = m_i (V_i^2 - E_i V_i \cos(\theta_i - \phi_i))/x'_{di} - \sum_{j=1}^N B_{ij} V_i V_j \cos \phi_{ij}, \quad (15)$$

where $m_i = 1$, if $i \in G$ (where G is the set of generator terminal buses), and $m_i = 0$, otherwise.

4. Structure preserving energy function

Consider the following SPEF defined on the post-fault system.

$$W(\omega, \theta, \mathbf{V}, \phi, t) = W_1(\omega) + W_2(\theta, \mathbf{V}, \phi, t), \quad (16)$$

where

$$W_1(\omega) = \sum_{i=1}^m \frac{1}{2} M_i \omega_i^2, \quad (17)$$

$$W_2 = W_{21}(\theta) + W_{22}(t) + W_{23}(\mathbf{V}) + W_{24}(\theta, \phi, v) + W_d(\mathbf{V}, t), \quad (18)$$

$$W_{21}(\theta) = - \sum_{i=1}^m P_{mi}(\theta_i - \theta_{i0}), \quad (19)$$

$$W_{22}(t) = \sum_{i=1}^N \int_{t_0}^t P_{li}(d\phi_i/dt) dt, \quad (20)$$

$$W_{23}(V) = \sum_{i=1}^N \int_{V_{i0}}^{V_i} f_{qi}(x_i)/x_i dx_i, \quad (21)$$

$$W_{24}(\theta, \phi, V) = \sum_{i=1}^m [((V_i^2/2) - E_i V_i \cos(\theta_i - \phi_i))x'_{di} - ((V_{i0}^2/2) - E_i V_{i0} \cos(\theta_{i0} - \phi_{i0}))/x'_{di}] - \sum_{i=1}^N \sum_{j=1}^N \frac{1}{2} B_{ij} [V_i V_j \cos \phi_{ij} - V_{i0} V_{j0} \cos \phi_{ij0}], \quad (22)$$

$$W_d(V, t) = \sum_{j \in D} [\int_{t_0}^t P_{dj}(d\phi_j/dt) dt + \int_{V_{j0}}^{V_j} (Q_{dj}/V_j) dV_j]. \quad (23)$$

It can be shown that the derivative of W is zero along the system trajectory. For,

$$\begin{aligned} \sum_{i=1}^m (\partial W_i / \partial \omega_i) (d\omega_i / dt) + (\partial W_2 / \partial \theta_i) \cdot (d\theta_i / dt) \\ = \sum_{i=1}^m (M_i \omega_i \dot{\omega}_i - P_{mi} \omega_i + P_{ei} \omega_i) = 0, \end{aligned} \quad (24)$$

$$\sum_{i=1}^N (\partial W_2 / \partial \phi_i) (d\phi_i / dt) + (\partial W_2 / \partial t) = \sum_{i=1}^N (P_i + P_{li} + e_i P_{di}) (d\phi_i / dt) = 0, \quad (25)$$

$$\sum_{i=1}^N (\partial W / \partial V_i) = \sum (1/V_i) (Q_{li} + Q_i + e_i Q_{di}) = 0. \quad (26)$$

Comments

(1) It is assumed that the system models are well-defined in the sense that the voltages at the load buses can be solved in a continuous manner at any given time during the transient. This means that the system trajectories are smooth and there are no jumps in the energy function.

(2) Consider the terms

$$\int_{t_0}^t P_{li} (d\phi_i / dt) dt \text{ or } \int_{t_0}^t P_{di} (d\phi_i / dt) dt.$$

These can be expressed as

$$\int_{t_0}^t P_{li} (d\phi_i / dt) dt = P_{li} (\phi_i - \phi_{i0}) - \int_{t_0}^t (dP_{li} / dt) \phi_i dt, \quad (27)$$

$$\int_{t_0}^t P_{di} (d\phi_i / dt) dt = P_{di} (\phi_i - \phi_{i0}) - \int_{t_0}^t (dP_{di} / dt) \phi_i dt. \quad (28)$$

If (dP_{li} / dt) and (dP_{di} / dt) are small, the second terms on the RHS of the above equations can be neglected. This approximation has the advantage of making the SPEF path-independent.

(3) It can be shown that

$$W_{24}(\theta, \phi, V) = \sum_{k=1}^{n_s} \frac{1}{2} (Q_k - Q_{k0}), \quad (29)$$

where n_e is the number of elements of the AC network including machine reactances and Q_k is the reactive power loss in element k . From conservation of energy

$$\sum_{k=1}^{n_e} \frac{1}{2} Q_k = \frac{1}{2} \left[\sum_{i=1}^m Q_{Gi} - \sum_{j=1}^N Q_{Lj} - \sum_{k=1}^{n_d} Q_{dk} \right], \tag{30}$$

where Q_{Gi} is the reactive power generation at the internal bus of generator i . Equation (30) can be used to simplify the computation of SPEF.

(4) The component $W_d(V, t)$ of the energy function, which is attributed to the DC system, follows from treating P_d and Q_d at each converter bus as dynamic loads. The effect of the DC link controller is handled indirectly influencing P_d and Q_d . Thus any controller model can be considered.

For a two-terminal DC system, neglecting DC system losses, W_d can be expressed approximately as

$$W_d = W_{d1} + W_{d2} + W_{d3}, \tag{31}$$

where

$$W_{d1} = P_d [(\phi_r - \phi_i) - (\phi_{r0} - \phi_{i0})], \tag{32}$$

$$W_{d2} = k_r a_r I_d \int_{V_{r0}}^{V_r} \sin \zeta_r dV_r, \tag{33}$$

$$W_{d3} = K_i a_i I_d \int_{V_{i0}}^{V_i} \sin \zeta_i dV_i, \tag{34}$$

ϕ_i and ϕ_r refer to the bus angles at rectifier and converter buses, respectively.

Assuming that the inverter controls the power factor angle ζ_i (by keeping it constant)

$$W_{d2} = k_r a_r I_d \int_{V_{r0}}^{V_r} [(k_r^2 a_r^2 V_r^2 - V_d^2)^{1/2} / (k_r a_r V_r)] dV_r, \tag{35}$$

$$W_{d3} = k_i a_i I_d \sin \zeta_i (V_i - V_{i0}). \tag{36}$$

By noting that

$$\int [(x^2 - a^2)^{1/2} / x] dx = (x^2 - a^2)^{1/2} - a \sec^{-1}(x/a),$$

the integral in (35) can be expressed as

$$W_{d2} = k_r a_r I_d [V_r \sin \zeta_r - V_{r0} \sin \zeta_{r0} - (V_r \zeta_r \cos \zeta_r - V_{r0} \zeta_{r0} \cos \zeta_{r0})]. \tag{37}$$

It is to be noted that during a transient, the DC current I_d is regulated by the rectifier and is assumed to be independent of V_r and V_i . V_d is dependent on V_i .

If there is a mode shift resulting in current control at the inverter and power factor control at the rectifier, the subscripts 'r' and 'i' are to be interchanged in (36) and (37).

If γ (extinction angle) is to be maintained constant at the inverter, then W_{d3} can be expressed as

$$W_{d3} = I_d \int_{V_{i0}}^{V_i} [(A + BV_i + CV_i^2)^{1/2} / V_i] dV_i, \tag{38}$$

$$A = -R_{ci}^2 I_d^2,$$

$$B = 2k_i a_i R_{ci} I_d \cos \gamma_i,$$

$$C = (1 - \cos \gamma_i^2) k_i^2 a_i^2.$$

An explicit expression for the integral of (38) can be obtained.




Figure 4. Block diagram of auxiliary controller.

5. A numerical example

For illustration, a 3-machine system example is adapted from Anderson & Fouad (1977). The single line diagram of the system is shown in figure 6. DC link is connected between buses 6 and 9. The controller model is assumed to be performance model based on DC current and current modulation using an auxiliary controller (see figure 4) or emergency controller (see figure 5) is considered. The control signal for the auxiliary controller is taken from the difference in the phase angles of the two converter buses. A washout circuit is included to eliminate steady-state offset and filter out very low frequency components that occur normally. The equations of the auxiliary controller and the emergency controller are given next.

5.1 Auxiliary controller

The block diagram of this controller is shown in figure 4.

The dynamic and algebraic equations for this controller are given below.

$$\dot{I}_d = (Z_4 - I_d) / T_d, \tag{39}$$

$$\dot{y}_1 = [(\phi_r - \phi_i) - y_1] / T_1, \tag{40}$$

$$\dot{y}_2 = [(1 - T_2/T_3)Z_1 - y_2] / T_3, \tag{41}$$

$$Z_1 = (\theta_r - \theta_i) - y_1, \tag{42}$$

$$Z_2 = Z_1 + y_2, \tag{43}$$

$$\Delta I = K_w Z_2, \tag{44}$$

$$Z_3 = I_{ref} + \Delta I, \tag{45}$$

$$Z_4 = \begin{cases} Z_3, & \text{if } I_{ref}^{min} \leq Z_3 \leq I_{ref}^{max}, \\ I_{ref}^{max}, & \text{if } Z_3 > I_{ref}^{max}, \\ I_{ref}^{min}, & \text{if } Z_3 < I_{ref}^{min}. \end{cases} \tag{46}$$




Figure 5. Block diagram of emergency controller.




Figure 6. Single-line diagram of 3-machine system.

5.2 Emergency controller

This is shown in figure 5. Here the change in the current reference ΔI increases from zero to ΔI_{\max} linearly with time, when a disturbance in the AC system is sensed.

The dynamic and algebraic equations are given below.

$$\dot{I}_d = (Z_4 - I_d)/T_d, \quad (47)$$

$$\begin{aligned} \Delta I &= 0, \text{ for } 0 \leq t \leq t_1, \\ &= \Delta I_{\max}(t - t_1)/(t_2 - t_1), \text{ for } t_1 \leq t \leq t_2, \\ &= \Delta I_{\max}, \text{ for } t > t_2. \end{aligned} \quad (48)$$

The expressions for Z_3 and Z_4 are the same as given earlier.

It is assumed that the disturbance originates at $t = 0^+$ and the time required to sense this is t_1 . In this type of controller, additional capacitors are switched on at time t_2 to meet the increased reactive power requirements at the converter buses due to increased current order.

5.3 Case study and results

The disturbance considered is a 3-phase-fault at $t = 0$ at bus 5 followed by clearing of the fault by switching lines 5-7 off. For simplicity, the load characteristics are assumed to be of constant impedance type. The following cases are considered:

- case 1 – with constant current reference (no modulation),
- case 2 – with auxiliary controller $K_w = 3$,
- case 3 – with emergency controller.

In case 3, it is assumed that an additional capacitor bank (of 0.25 p.u.) is added at both converter buses after time t_2 to account for the increased reactive power requirements.

The critical clearing time (T_{cr}) obtained by digital simulation is 0.164–0.165 s for case 1, 0.161–0.162 s for case 2 and 0.173–0.174 s for case 3. The corresponding value of T_{cr} obtained by prediction (using the PEBS method) is 0.159–0.160, 0.158–0.159




Figure 7. Variation of DC quantities. (a) Case 1 (stable); (b) case 2 (stable); (c) case 3 (stable).

and 0.175–0.176 s, respectively. The corresponding value of critical energy is 0.594, 0.569 and 0.813 p.u., respectively. It is observed that T_{cr} obtained by prediction agrees well with that obtained by digital simulation. T_{cr} is slightly reduced for case 2 compared to that for case 1. It is to be noted that the auxiliary controller is provided primarily for damping oscillations in the system. The effectiveness of this controller also depends on the choice of control parameters and the reactive power constraints. The latter can be explained as follows: As DC current is increased, the reactive power requirements are also increased. If adequate reactive power is not available, the AC voltage will drop, thus (partially) nullifying the effect of the controller.

As expected, the emergency controller helps in improving the transient stability. The results obtained by TEF are accurate enough to predict the effect of controllers. Figures 7a–c show, for the post-fault system, the DC voltage $V_d (= V_{dr} = V_{di}$ since R is assumed to be zero), the DC link current I_d , the reactive power Q_{dr} , Q_{di} and the active DC power $P_d (= P_{dr} = P_{di})$, for cases 1–3, respectively, when the fault is assumed to be cleared critically. It is observed in the cases considered that V_d decreases initially and then increases. The variation is greater in case 3 as compared to that in the other two cases. This is due to the variation in the AC bus voltages. The DC link current I_d varies as expected in cases 2 and 3; however, its magnitude in case 2 is controlled by the AC bus frequency signal. In this case, it is observed that the current increases initially and, sometime after the fault clearance, falls till it is limited to a minimum value by the limiter.

DC power increase is not so significant because of reduction of DC voltage even when the DC current is increased in case 3. Yet, when compared to cases 1 and 2, the transient stability is improved. In case 2, even though the current is initially increased, it decreases due to the control signal becoming negative, and the current is prevented from going below the minimum value by the limiter. This shows that the auxiliary controller considered here has not helped in improving the transient stability.

Figures 8a and b show the variation of the total, potential and kinetic energies for case 3 for (a) stable, and (b) unstable conditions. In general, the total energy increases from its initial value ($= 0$) till the fault is cleared and remains constant afterwards, as expected. However, a slight increase in the total energy can be observed some time after the fault clearance. This may be due to the numerical errors (truncation and round-off) introduced in the evaluation of the energy function. In the cases depicted, it can be observed that the potential energy is initially negative and then increases. This is because the post-fault configuration considered is different from the prefault one because of line switching. As regards the kinetic energy, it can be observed that when the system is stable, this energy increases until the fault is cleared and then reduces to zero after some time. This is expected for the first swing stability.

6. Conclusions

A structure-preserving energy function is proposed for AC/DC systems, which is general enough to cover two or multiterminal DC links, simplified or detailed converter controller models. As a first approximation, the energy function can be formulated as path-independent.




Figure 8. Variation of total, kinetic and potential energies. Case 3 – stable (a) and unstable (b).

Stability analysis carried out on a 3-machine system indicates the following.

- (1) A DC link can improve the transient stability of the overall system. However, proper controllers have to be used to exploit this advantage of DC links;
- (2) T_{cr} predicted by the direct method using SPEF gives accurate results.

References

- Anderson P M, Fouad A A 1977 *Power system control and stability* (Iowa: State University Press)
- Bergen A R, Hill D J 1981 A structure preserving model for power system stability analysis. *IEEE Trans. Power Appar. Syst.* PAS-100: 25–35
- DeMarco C L, Canizares C A 1992 A vector energy function approach for security analysis of AC/DC systems. *IEEE Trans. Power Syst.* PWR-7: 1000–1011
- Fudeh H, Ong C M 1981 A simple and efficient AC-DC load flow method for multiterminal DC systems. *IEEE Trans. Power Appar. Syst.* PAS-100: 4389–4396
- Hiskens I A, Hill D J 1989 Energy functions, transient stability and voltage behaviour in power systems with nonlinear loads. *IEEE Trans. Power. Syst.* PWR-4: 1525–1533

- Lefebvre S, Wang W K, Reeve J, Gagnon J, Johnson B K 1991 Experience with modelling MTDC systems in transient stability programs. *IEEE Trans. Power Delivery* PWRD-6: 405–413
- Narasimhamurthi N, Musavi M T 1984 A general energy function for transient stability analysis of power systems. *IEEE Trans. Circuits. Syst.* CAS-31: 637–645
- Ni Y-X, Fouad A A 1987 A simplified two-terminal HVDC model and its use in direct transient stability assessment. *IEEE Trans. Power Syst.* PWRS-2: 1006–1012
- Padiyar K R 1991 *HVDC power transmission systems – Technology and system interactions* (New Delhi: Wiley Eastern)
- Padiyar K R, Ghosh K K 1987 A novel structure preserving energy function for dynamic stability evaluation of power systems with known modes of instability. *Elec. Mach. Power Syst.* 13: 135–148
- Padiyar K R, Ghosh K K 1989 Direct stability evaluation of power systems with detailed generator models using structure-preserving energy functions. *Int. J. Elec. Power Energy Syst.* 11: 47–56
- Padiyar K R, Sastry H S Y 1983 Application of topological energy function for the direct stability evaluation of power systems with voltage dependent loads. *Proc. Int. Conf. on Systems, Man and Cybernetics* (New York: IEEE Press)
- Padiyar K R, Sastry H S Y 1984 Direct stability analysis of AC/DC power systems using a structure preserving energy function. *Proc. Int. Conf. Comput. Syst. Signal Process.* Bangalore, India
- Padiyar K R, Sastry H S Y 1987 Topological energy-function analysis of stability of power systems. *Int. J. Elec. Power Energy Syst.* 9: 9–16
- Pai M A 1989 *Energy function analysis for power system stability* (Boston: Kluwer)
- Pai M A, Padiyar K R, Radhakrishna C 1981 Transient stability of multimachine AC/DC power systems via energy function method. *IEEE Trans. Power Appar Syst.* PAS-100: 5027–5035
- Ribbens-Pavella M, Evans F J 1985 Direct methods for studying dynamics of large-scale electric power systems – A survey. *Automatica* 21: 1–21
- Tsolas N, Arapostathis A, Varaiya P 1985 A structure-preserving energy function for power system transient stability analysis. *IEEE Trans. Circuits Syst.* CAS-32: 1041–1049
- Varaiya P P, Chen R L, Wu F F 1985 Direct methods for transient stability analysis of power systems – Recent results. *Proc. IEEE* 73: 1703–1715