

AUTOMATIC FAULT ANALYSIS IN POWER SYSTEMS VIA APPLICATION SERVICE PROVIDER

A Dissertation

by

Mustarum Musaruddin

Submitted to the Office of Graduate Centre of
The University of Adelaide

in partial fulfilment of the requirements for the degree of

Doctor of Philosophy

in

The School of Electrical and Electronic Engineering
The Faculty of Engineering, Computer and Mathematical Sciences
The University of Adelaide, Australia

February 2011

AUTOMATIC FAULT ANALYSIS IN POWER SYSTEMS VIA APPLICATION SERVICE PROVIDER

by

Mustarum Musaruddin

B. Eng. (Electrical Engineering),
Hasanuddin University, Indonesia, 1999

MIT. (Electrical & Computer Engineering),
The University of Newcastle, Australia, 2003

Dissertation submitted in partial fulfilment
of the requirements for the Degree of

Doctor of Philosophy

in

The School of Electrical and Electronic Engineering
The Faculty of Engineering, Computer and Mathematical Sciences
The University of Adelaide, Australia

Supervisor : Dr. Rastko Zivanovic
Co-supervisor: Assoc. Prof. Nesimi Ertugrul

February 2011

Table of Contents

Table of Contents.....	ii
Abstract	v
Statement of Originality.....	vi
List of Figures.....	vii
List of Tables.....	x
List of Abbreviations	xi
Acknowledgments	xiv
List of Publications	xv
Chapter 1: Introduction.....	1
1.1 Background.....	1
1.2 Research Objectives	4
1.3 Major Contributions	5
1.4 Organisation of the Dissertation.....	5
Chapter 2: Review of Transmission System Fault Analysis.....	7
2.1 Introduction.....	7
2.2 Infrastructure for Collecting Fault Data	7
2.2.1 Remote Terminal Unit (RTU)	8
2.2.2 Intelligent Electronic Devices (IEDs)	8
2.2.3 Substation Communication Infrastructure.....	9
2.2.4 Supervisory Control and Data Acquisition (SCADA) Systems	10
2.3 Fault Investigation Scenario.....	12
2.4 Fault Analysis Functions	14
2.4.1 Signal Segmentation.....	15
2.4.2 Fault Type Classification.....	16
2.4.3 Fault Location.....	17
2.5 Fault Analysis Techniques.....	21
2.6 Overview of the Fault and Disturbance Analysis Tools.....	23
2.6.1 Wavewin.....	23

2.6.2 SIGRA.....	24
2.6.3 SEL-PROFILE.....	26
2.6.4 DFR Assistant.....	27
2.6.5 TransView	27
2.7 Chapter Summary.....	30
Chapter 3: Application Service Provider and IEC 61850 Technologies	31
3.1 Introduction.....	31
3.2 Application Service Provider (ASP)	31
3.3 Web Services.....	33
3.3.1 Extensible Markup Language (XML).....	34
3.3.2 Simple Object Access Protocol (SOAP)	35
3.3.3 Web Services Description Language (WSDL).....	37
3.3.4 Universal Discovery, Description and Integration (UDDI)	37
3.4 Thin Client Computing	39
3.5 Impact of the IEC-61850 Standard on Disturbance Recording	40
3.5.1 Information Models of IEC 61850 for Disturbance Recording.....	42
3.5.2 Information Exchange Model.....	46
3.5.3 Mapping to Communication profile.....	47
3.6 Ole for Process Control (OPC).....	47
3.7 Manufacturing Message Specification (MMS).....	50
3.8 Chapter Summary.....	51
Chapter 4: Automated Fault and Disturbance Analysis Service (AFAS).....	52
4.1 Introduction.....	52
4.2 AFAS System Overview.....	52
4.3 Signal Segmentation Service	59
4.4 Signal Modelling Service.....	71
4.5 Fault Type Classification Service.....	71
4.6 Fault Location Service.....	74
4.7 Illustrative Examples of Using Services.....	74
4.7.1 Simulated PSCAD Fault Records	74
4.7.2 Real Disturbance Records from Power Utilities.....	81

4.8 Implementing the AFAS	85
4.8.1 The ASP Server.....	88
4.8.2 Signal Processing Module	89
4.8.3 Automated IED File Retrieval	92
4.8.4 Triggering Method using GOOSE message	93
4.8.5 Database for System and Event Related Data Storage.....	99
4.8.6 Development of COMTRADE viewer.....	99
4.8.7 The Automated Fault Analysis Client.....	108
4.9 Chapter Summary	109
Chapter 5: Remote Relay Testing Service (RRTS)	111
5.1 Introduction.....	111
5.2 Relay Testing Overview	111
5.3 RRTS Architecture	114
5.4 RRTS Procedures	117
5.4.1 Client	117
5.4.2 Server	117
5.5 RRTS Implementation	118
5.6 RRTS Case Study and Application Results	121
5.7 Chapter Summary	126
Chapter 6: Conclusions	127
6.1 Expected Benefits.....	127
6.2 Future Work	128
References:	130
Appendix A. Wavelet and Empirical Mode Decomposition.....	146
A.1. Wavelet Transform Method	146
A.2. Empirical Mode Decomposition Method.....	151

Abstract

Automatic Fault Analysis in Power Systems via Application Service Provider

Mustarum Musaruddin, B.Eng., Hasanuddin University, Indonesia;

MIT., The University of Newcastle, Australia

This dissertation presents a new approach to automated fault analysis in electrical power systems. New contributions to the fault and disturbance investigation topic are automated fault analysis service (AFAS) via application service provider (ASP) and remote relay testing service (RRTS). The implementation of AFAS complies with the new international standard of communication network and system in substations (IEC-61850).

The signal processing approaches in an automated fault analysis service are based on the wavelet transform and empirical mode decomposition methods. Several case studies have been carried out to test the performance of the signal segmentation technique. The data for analyses are from simulated fault data and from real disturbance records obtained from the intelligent electronic devices (IEDs) in substations.

The implementation of AFAS and RRTS was developed using C# with .NET technologies, MATLAB and open source software. Signal segmentation, signal modelling, fault type classification, fault location service, a web-based COMTRADE viewer and remote relay test service have been developed in this dissertation. Such services are designed to enhance manual investigations performed by engineers. The services have been tested extensively using disturbance records from power utilities and a power system simulation model.

Statement of Originality

This work contains no material which has been accepted for the award of any other degree or diploma in any university or other tertiary institution and, to the best of my knowledge and belief, contains no material previously published or written by another person, except where due reference has been made in the text.

I give consent to this copy of my thesis, when deposited in the Adelaide University library, being made available for loan and photocopying, subject to the provisions of the Copyright Act 1998.

I also give permission for the digital version of my thesis to be made available on the web, via the University's digital research repository, the Library catalogue, the Australasian Digital Theses Program (ADTP) and also through web search engines, unless permission has been granted by the university to restrict access for a period of time.

Mustarum Musaruddin

Date

List of Figures

Figure 2-1. Single line diagram representation of line fault	19
Figure 2-2. Fault locator in SIGRA	25
Figure 2-3. Waveforms viewer in SIGRA	25
Figure 2-4. SEL-PROFILE software running under DOS	26
Figure 2-5. Fault locator in TransView.....	29
Figure 2-6. Waveforms viewer in TransView	29
Figure 3-1. Web services architecture model.....	33
Figure 3-2. Example of web services.....	34
Figure 3-3. SOAP structure.....	36
Figure 3-4. SOAP example	36
Figure 3-5. WSDL example	37
Figure 3-6. IEC 61850 according to OSI layer [7]	41
Figure 3-7. Example of logical devices and logical nodes from SEL421 relay	43
Figure 3-8. SEL-421 relay logical nodes	44
Figure 3-9. Logical Nodes for Disturbance record.....	45
Figure 3-10. ACSI communication method [7].....	46
Figure 4-1. Fault analysis scenario	53
Figure 4-2. An example of the investigation procedure and required services ...	54
Figure 4-3. Architecture of AFAS model complying with IEC 61850	57
Figure 4-4. Matrikon OPC server for IEC61850.....	57
Figure 4-5. AX4-MMS OPC server.....	58
Figure 4-6. Web client for IEC 61850 explorer.....	58
Figure 4-7. Signal segmentation algorithm using wavelet.....	61
Figure 4-8. Signal decomposition using wavelet method with <i>db4</i> as a mother wavelet, the original Blue phase current and its approximation coefficient (<i>a6</i>) and detail coefficients (<i>d1</i> to <i>d6</i>), signals recorded at Delphi substation on 11/01/2002.	62

Figure 4-9. AFAS database (table: waveletdata).....	63
Figure 4-10. The segmented disturbance signal (I_c) using wavelet method (signals recorded at Delphi substation on 11/01/2002).....	63
Figure 4-11. Signal segmentation algorithm using EMD	66
Figure 4-12. IMF components of Blue phase current in the single-phase-to- ground fault, signals recorded at Delphi substation on 11/01/2002.	68
Figure 4-13. Instantaneous Amplitude (IA) corresponding to each IMF	69
Figure 4-14. Hilbert spectrum of $d1-d11$ IMFs	70
Figure 4-15. The segmented Blue phase current (I_c) using EMD method (signals recorded at Delphi substation on 11/01/2002)	70
Figure 4-16. Fault type classification algorithm.....	73
Figure 4-17. Example of segmented signal using EMD Method in the single- phase-to-ground Fault (AG fault) where the fault resistance (R_F) = 0.001 Ω and 20% fault location.	76
Figure 4-18. Comparison time segment using wavelet and EMD methods in the single-phase-to-ground fault (AG fault) where the fault resistance (R_F) = 0.001 Ω	77
Figure 4-19. Comparison of time segment between wavelet and EMD methods in the phase A for the case of an ABG fault.....	78
Figure 4-20. Time segment in phase A using wavelet and EMD methods for variations in fault resistance (R_F) in the three-phase fault where the fault location is 50 %.....	81
Figure 4-21. The segmented current (I_C) signals in the faulty phase, (signals recorded at Delphi substation on 11/01/2002).....	83
Figure 4-22. The segmented disturbance signals using wavelet method (signal recorded from Bulukumba substation on 16/09/2008)	84
Figure 4-23. The segmented disturbance signal using EMD method (signal recorded from Bulukumba substation on 16/09/2008)	85
Figure 4-24. AFAS implementation process.....	87
Figure 4-25. Automated fault analysis service model	88

Figure 4-26. Successful compilation of signal processing module (AbruptChange.dll)	90
Figure 4-27. Integrate signal processing module (AbruptChange.dll)	91
Figure 4-28. Automated fault analysis service running on server.	91
Figure 4-29. Example interface of AFAS web client for IEC 61850 explorer	93
Figure 4-30. Typical system configuration	96
Figure 4-31. Disturbance data retrieval and pre-processing for automated fault and disturbance analysis	98
Figure 4-32. AFAS database (Table: Station)	99
Figure 4-33. Java Internet Matlab (JIM) server interface	101
Figure 4-34. Example of web based COMTRADE viewer interface	102
Figure 4-35. Example of AFAS COMTRADE viewer interface with the automated signal segmentation for two-phase fault (AC fault).....	105
Figure 4-36. Example of zooming functions in the AC fault.....	107
Figure 4-37. Example of simple AFAS report	109
Figure 5-1. Remote relay testing system via ASP	115
Figure 5-2. Remote relay testing architecture	116
Figure 5-3. RRTS console running on server.....	120
Figure 5-4. RRTS job notification sent to user via email	121
Figure 5-5. Example of power system simulation model using PSCAD.....	122
Figure 5-6. Fault control in PSCAD	122
Figure 5-7. COMTRADE recorder model in PSCAD	122
Figure A-1. DWT algorithm [122]	148
Figure A-2. Multiresolution signal decomposition realised by QMF [91].	150
Figure A-3. Signal X with the local extrema identification	154
Figure A-4. Signal X with the upper and lower envelope.....	154
Figure A-5. Signal X with the average value and residual.....	155
Figure A-6. Iteration 1 with the average value and residual	155

List of Tables

Table 3-1. Example IEC 61850 descriptor components [7].....	42
Table 3-2. Example of SEL-421 Logical Devices [7]	43
Table 4-1. Segmented signal estimation based on wavelet and EMD when.....	76
Table 4-2. Segmented signal estimation based on wavelet and EMD in the two- phase-to-ground fault (ABG Fault) where fault resistance (R_F) is 0.001 Ω	78
Table 4-3. Segmentation time of disturbance record using wavelet and EMD methods for variation of fault resistance in the three-phase fault where fault location is 50 %	80
Table 4-4. Segmented signal estimation based on wavelet and EMD method in the Blue phase current (I_C) obtained from Delphi substation on 11/01/2002.....	82
Table 4-5. Segmented signal estimation based on wavelet and EMD, disturbance record obtained from Bulukumba substation Indonesia on 16/09/2008.	84
Table 5-1. Relay response times.....	125

List of Abbreviations

ACSI	Abstract Communication Service Interface
AFAS	Automated Fault and disturbance Analysis Service
ANN	Annunciator elements
API	Application Program Interfaces
ASP	Application Service Provider
ATP	Alternative Transient Program
CB	Circuit Breaker
CBMA	Circuit Breaker Monitor Analysis
CFG	Configuration elements
COMTRADE	Common format for Transient Data Exchange
CON	Control elements
CT	Current Transformer
CWT	Continuous Wavelet Transform
DFRs	Digital Fault Recorders
DFRA	Digital Fault Recorders Analysis
DPRA	Digital Protective Relay Analysis
DFT	Discrete Fourier Transform
DPRs	Digital Protective Relays
DWT	Discrete Wavelet Transform
EJS	Easy Java Simulation
EMD	Empirical Mode Decomposition
EMS	Energy Management System
FAFL	Fault Analysis with Fault Location
FFT	Fast Fourier Transform
FTP	File Transfer Protocol
GOOSE	Generic Object Oriented Substation Event
GUI	Graphical User Interface

HPF	High Pass Filter
ICA	Independent Computing Architecture
IEDs	Intelligent Electronic Devices
ISP	Internet Service Providers
ISVs	Independent Software Vendors
IA	Instantaneous Amplitude
IMFs	Intrinsic Mode Functions
IT	Information Technology
JIM	Java Internet Matlab
LAN	Local Area Network
LD	Logical Devices
LN	Logical Nodes
LPF	Low Pass Filter
MET	Metering and measurement elements
MMI	Man Machine Interface
MMS	Manufacturing Message Specification
MSD	Multi-resolution Signal Decomposition
OLE	Object Linking and Embedding
OPC	Ole for Process Control
PHP	PHP Hypertext Pre-processor
PRO	Protection elements
PSCAD	Power System Computer Aided Design
QMF	Quadrature Mirror Filter
RDP	Remote Desktop Protocol
RF	Fault Resistance
RMS	Root Mean Square
RPC	Remote Procedure Calls
RRTS	Remote Relay Testing Service
RTS	Relay Test System
SAS	Substation Automation System
SCADA	Supervisory Control and Data Acquisition

SD	Standard Deviation
SEL	Schweitzer Engineering Laboratories
SER	Sequence of Event Recorder
SOA	Service Oriented Architecture
SOAP	Simple Object Access Protocol
TimeSeg	Time Segment
TLI	Test Laboratories International
UDDI	Universal Description and Discovery Interface
VNC	Virtual Network Computing
VT	Voltage Transformer
WAN	Wide Area Network
WAP	Wireless Application Protocol
WCF	Windows Communication Foundation
XML	eXtensible Markup Language
WS-AFA	Web Services for Fault Analysis
WSDL	Web Services Description Language

Acknowledgments

Firstly, I want to thank ALLAH the Almighty, the most beneficent, the most compassionate, and the most merciful. I also want to express my deepest gratitude to so many people who had a tremendous effect and notable help, so that this dissertation could be well completed.

In particular, I am indebted to my advisors, Dr. Rastko Zivanovic and Assoc. Prof. Nesimi Ertugrul, for their guidance, nurturing, encouragement, and support in every stage of my study. Their knowledge, kindness, patience, open-mindedness, and vision have provided me with lifetime benefits.

AusAID Australian Development Scholarship provided me with a scholarship during my studies for which I am grateful.

I would like also to thank Dr. Bill Winser at the Centre for Learning and Professional Development, University of Adelaide, for his help in editing this dissertation.

I am grateful to every member of department, and staff of University of Adelaide International student centre, especially Niranjala Seimon, who has help me during my stay in Adelaide.

Acknowledgment is extended to ESKOM Transmission Network South Africa and Indonesian Power Utility for providing the experimental data.

Many thanks are also devoted to my family members: my mother, father, my beloved wife, my daughters, brothers and sisters, for all the support they provided and their patience with all frustration they encountered during my study.

Thanks must go to my friends and colleagues for the constant encouragement, helpful suggestions and the enthusiasm they have shown towards this research during its development.

List of Publications

Journal Papers:

1. M. Musaruddin & R. Zivanovic, "Web Services for Fault Analysis in Smart Grid Applications," *Australian Journal of Electrical and Electronics Engineering, AJEEE* Volume 8, Number 2, 2011, Australia.
2. M. Musaruddin & R. Zivanovic, "Web Services for Automated Fault Analysis in Electrical Power Systems," *International Journal of Advances in Information Sciences and Service Sciences, AISS* Volume 2, Number 3, September 2010, Seoul, Korea.

Conference Papers:

1. M. Musaruddin & R. Zivanovic, "Investigation of Power System Disturbances via Application Service Provider," in *Proceedings IEEE 13th International Conference on Harmonics and Quality of Power (ICHQP 2008)*, Wollongong, Australia.
2. M. Musaruddin , M. Zaporoshenko & R. Zivanovic, "Remote Protective Relay Testing," in *Proceedings IEEE Australasian Universities Power Engineering Conference (AUPEC 2008)*, Sydney, Australia.
3. M. Musaruddin & R. Zivanovic, "Web Services for Automated Fault Analysis in Electrical Power System," in *Proceedings IEEE International Conference on Networked Computing and Advanced Information Management and Services (NCM 2009)*, Seoul, Korea.
4. M. Musaruddin & R. Zivanovic, "Automated Fault Analysis in the Indonesian Power Utility: A Case Study of South Sulawesi Transmission System," in *Proceedings IEEE Australasian Universities Power Engineering Conference (AUPEC 2009)*, Adelaide, Australia.
5. M. Musaruddin & R. Zivanovic, "Signal Segmentation of Fault Records based on Empirical Mode Decomposition," accepted for publication in *IEEE International Technical Conference (TENCON 2011)*, Bali, Indonesia.