

AEDC-TR-93-3



Boiling Heat-Transfer Processes and Their Application in the Cooling of High Heat Flux Devices

G. R. Beitel
Calspan Corporation/AEDC Operations

June 1993

Final Report for Period October 1990 through October 1992

Approved for public release; distribution is unlimited.

**ARNOLD ENGINEERING DEVELOPMENT CENTER
ARNOLD AIR FORCE BASE, TENNESSEE
AIR FORCE MATERIEL COMMAND
UNITED STATES AIR FORCE**

NOTICES

When U. S. Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government thereby incurs no responsibility nor any obligation whatsoever, and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data, is not to be regarded by implication or otherwise, or in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Qualified users may obtain copies of this report from the Defense Technical Information Center.

References to named commercial products in this report are not to be considered in any sense as an endorsement of the product by the United States Air Force or the Government.

This report has been reviewed by the Office of Public Affairs (PA) and is releasable to the National Technical Information Service (NTIS). At NTIS, it will be available to the general public, including foreign nations.

APPROVAL STATEMENT


This report has been reviewed and approved.



PATRICK ZEMAN, 1Lt. USAF
Directorate of Technology -
Deputy for Operations

Approved for publication:

FOR THE COMMANDER



KEITH L. KUSHMAN
Director of Technology
Deputy for Operations

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE June 1993	3. REPORT TYPE AND DATES COVERED Final - October 1990 - October 1992	
4. TITLE AND SUBTITLE Boiling Heat-Transfer Processes and Their Application in the Cooling of High Heat Flux Devices		5. FUNDING NUMBERS PN - 0115 PE - 65807F	
6. AUTHOR(S) Beitel, G. R., Calspan Corporation/AEDC Operations		8. PERFORMING ORGANIZATION REPORT NUMBER AEDC-TR-93-3	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Arnold Engineering Development Center/DOT Air Force Materiel Command Arnold Air Force Base, TN 37389-5000		9. SPONSORING/MONITORING AGENCY NAMES(S) AND ADDRESS(ES) Arnold Engineering Development Center/DO Air Force Materiel Command Arnold Air Force Base, TN 37389-5000	
11. SUPPLEMENTARY NOTES Available in Defense Technical Information Center (DTIC).			
12a. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution is unlimited.		12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) Water cooling is used extensively at AEDC to prevent the failure of high-enthalpy arc heater components at elevated heat loads where cooling by radiation, conduction, and natural convection from air circulation are ineffective. Other cooling techniques such as the use of liquid metals, transpiration, or film cooling pose their own disadvantages or limitations and are certainly possibilities for providing cooling at much more severe heating conditions where water cooling alone may be inadequate. The current interest is in exploiting backside water cooling to the limit of its capability, especially for arc heater nozzles. Such an application requires an understanding of the parameters that affect the cooling processes and the determination of the limiting point where the surface fails due to inadequate cooling. This report reviews the different processes encountered in backside water cooling and identifies those processes that are desirable for effective cooling of high-enthalpy facility components; identifies those parameters which affect the cooling processes of interest and the trend of cooling performance when the parameters are individually varied; and presents a summary of applicable theoretical, analytical, and experimental work in surface cooling performed in the past 50 years.			
14. SUBJECT TERMS boiling heat transfer high enthalpy burnout correlations flow boiling high heat flux subcooled boiling critical heat flux forced convection arc heater nucleate boiling water cooling boiling			15. NUMBER OF PAGES 155
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED			16. PRICE CODE
18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED		19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	
20. LIMITATION OF ABSTRACT SAME AS REPORT			

PREFACE

The work reported herein was performed by Arnold Engineering Development Center (AEDC), Air Force Materiel Command (AFMC), under Program Element 65807F. The Air Force Program Managers were Capt. D. G. Burgess, Capt. H. Martin, and Lt. P. Zeman, DOT. The work was performed by Calspan Corporation/AEDC Operations, technical services contractor for the Aerospace Flight Dynamics testing effort at AEDC, AFMC, Arnold Air Force Base, TN. The work was performed in the Aerospace Systems Facility (ASF) and the Technology and Development Facility (TDF) under AEDC Project Number DD01, Job Number 0115. The work was conducted in conjunction with the development of the High Temperature Wall Laboratory (HTWL) during the period between 1 October 1990 and 16 October 1992. The manuscript was submitted for publication on February 25, 1993.

CONTENTS

	<u>Page</u>
1.0 INTRODUCTION	5
2.0 THE BASIC BOILING CURVE	5
3.0 PARAMETRIC EFFECTS ON THE BOILING CURVE	8
3.1 Important Parameters and Their Effects on Heat Transfer	8
3.2 Summary of Parametric Trends and Implications	25
4.0 THEORETICAL AND CORRELATIONAL PREDICTION OF THE BOILING CURVE	26
4.1 Pure Forced Convection	27
4.2 Transition to Flow Boiling, Flow Boiling, and CHF: Theoretical Models	29
4.3 Transition to Flow Boiling: Correlational Approaches	30
4.4 Flow Boiling: Correlational Approaches	30
4.5 CHF Correlational Approaches	34
4.6 Comparison of Flow Boiling and CHF Correlations	50
5.0 APPLICABLE EXPERIMENTAL APPROACHES AND MEASUREMENT TECHNIQUES FOR BOILING HEAT TRANSFER	51
6.0 SUMMARY	53
REFERENCES	54

ILLUSTRATIONS

<u>Figure</u>	<u>Page</u>
1. Basic Boiling Curve	91
2. Effect of Pressure and Velocity on Subcooled Boiling	92
3. Effect of Velocity and Subcooling	93
4. Effect of Mass Velocity and Vapor Quality	94
5. Effect of Liquid Velocity on Bubble Growth and Collapse	95
6. Effect of Subcooling with Increasing Mass Velocity	96
7. Subcritical Pressure Water Burnout Heat Flux	97
8. Effect of Subcooling on Bubble Characteristics	98
9. Optimum Pressure for the Boiling of n-Pentane	99
10. Effect of Heater Size on Optimum Pressure	99
11. Effect of Mass Velocity on Optimum Pressure	100
12. Effect of Pressure on Bubble Characteristics	101

<u>Figure</u>	<u>Page</u>
13. Effect of Surface Roughness on Heat Transfer	102
14. Roughness Effect on Heat Transfer	103
15. Burnout Heat Flux of Knurled Surfaces	104
16. Effect of a Surface Active Agent on Heat Transfer	105
17. Effect of Binary Mixture Concentrations on Critical Heat Flux (CHF)	106
18. Effect of Wall Material on Heat Transfer	107
19. Effect of Wall Material on CHF	108
20. Effect of Wall Thickness on Heat Transfer	109
21. Influence of Tube Diameter on CHF at Various Subcoolings	110
22. Effect of Tube Diameter on CHF	111
23. Effect of Heated Length on CHF	112
24. Effect of Tube Length on CHF at Various Subcoolings	113
25. Effect of Position of the Heating Surface on CHF	114
26. Effect of Gas Content on Heat Transfer	115
27. Effect of Curved Test Section on CHF	116
28. Effect of Undulating Flow on Heat Transfer	117
29. Pressure Effect with Flow Swirl	118
30. Mass Velocity Effect with Flow Swirl	119
31. Effect of Nonuniform Heating on CHF	120
32. Comparison of Steady-State and Transient Heating Data	121
33. Effect of Transient Heating on Boiling Curve	122
34. Effect of Flow Restriction on Flow Stability and Burnout	123
35. Parametric Trends for Subcooled, Forced-Convection Cooling	124
36. Effect of Heat-Transfer Rate on Bubble Characteristics	125
37. Construction of the Partial Boiling Curve	126
38. Determination of the Coefficient B_L in the Levy Correlation	127
39. Dependence of Overall Pressure Drop on Operating Conditions	128
40. Generalized Wall Superheat at Burnout	129
41. Approximate Limits of Velocity Regimes for Round Tubes	130
42. Constant Inputs for the Thompson and Macbeth Correlation	131
43. Mass Velocity Range for the Becker Burnout Correlation	139

APPENDIXES

A. Table of Conversion Factors	141
B. Forced-Convection Boiling Experiments	143
NOMENCLATURE	149

1.0 INTRODUCTION

The work reported herein was performed by Arnold Engineering Development Center (AEDC), Air Force Materiel Command (AFMC), under Program Element 65807F. The Air Force Program Managers were Capt. D. G. Burgess, Capt. H. Martin, and Lt. P. Zeman, DOT. The work was performed by Calspan Corporation/AEDC Operations, technical services contractor for the Aerospace Flight Dynamics testing effort at AEDC, AFMC, Arnold Air Force Base, TN. The work was performed in the Aerospace Systems Facility (ASF) and the Technology and Development Facility (TDF) under AEDC Project Number DD01, Job Number 0115. The work was conducted during the period between 1 October 1990 and 16 October 1992.

Water cooling is used extensively at AEDC to prevent the failure of high-enthalpy arc heater components at elevated heat loads where cooling by radiation, conduction, and natural convection from air circulation are ineffective. Other cooling techniques such as the use of liquid metals, transpiration or film cooling pose their own set of disadvantages or limitations (Ref. 1) but are certainly possibilities for providing cooling at much more severe heating conditions where water cooling alone may prove to be inadequate. The current interest is in exploiting backside water cooling to the limit of its capability, especially for arc heater nozzles. Such an application requires an understanding of the parameters that affect the cooling processes and the determination of the limiting point* where the surface fails due to inadequate cooling.

The purpose of this report is threefold: (1) to review the different processes encountered in backside water cooling and identify those processes that are desirable for effective cooling of high-enthalpy facility components; (2) to identify those parameters which affect the cooling processes of interest and the trend of cooling performance when the parameters are individually varied; and (3) to present a summary of applicable theoretical, analytical, and experimental work in surface cooling performed in the past 50 years.

2.0 THE BASIC BOILING CURVE

The characteristic temperature response of a surface cooled by an adjacent fluid as heat flux is increased was first proposed by Nukiyama (Ref. 2) in 1934. Figure 1 shows the typical

* The limiting point is also identified as the burnout point, boiling crisis, departure from nucleate boiling (DNB), or critical heat flux (CHF) condition, among other terms by various authors. Terminology for the limiting point will be discussed in Section 2.0.

shape of the curve, known as the boiling curve, obtained when heat flux from a cooled surface is plotted as a function of the liquid superheat (the difference between the surface temperature and the liquid saturation temperature). At low heat flux (segment A-B in Fig. 1), the surface temperature is below the saturation temperature of water and similar liquids at or above atmospheric pressure. Cooling at low heat flux is by pure convection heat transfer and is fairly well understood. In this region, analytical solutions and experimental correlations (for more complex flow geometries) have been derived which allow for accurate prediction of heat transfer in various cooling configurations (see, for example, Chapters 8-9 of Lienhard (Ref. 3), Chapter 6 of White (Ref. 4), or Kays and Crawford (Ref. 5), Chapters 13-14). As heat flux from the surface is increased beyond the point where the surface temperature becomes significantly greater** than the water saturation temperature (point B in Fig. 1), vapor generation, better known as boiling, occurs from discrete nucleation sites on the surface or in the bulk fluid depending on the bulk fluid temperature. The region of boiling from discrete sites is termed nucleate boiling and is shown as segment B-C in Fig. 1.

As the upper limit of nucleate boiling is reached (point C in Fig. 1), a typically undesirable transition to another form of boiling, known as film boiling, begins. Because the boiling near the limit of nucleate boiling becomes so violent, numerous vapor bubbles begin to combine near the surface. Since the vapor has a much lower thermal conductivity than the liquid, the patches of vapor effectively insulate the surface from the efficient heat transfer to the liquid as experienced during nucleate boiling. Unlike a temperature-driven system which would proceed toward point D[†] in Fig. 1, a heat flux-driven system such as a high-enthalpy arc facility would proceed directly toward point E^{††}. The processes involved when a boiling system undergoes the path from the limit of nucleate boiling (point C) toward stable film boiling (point E) are highly unstable, and failure of the surface due to melting occurs in most cases because the melting temperature of the surface material is lower than the temperature associated with stable film boiling at point E. The point at which transition to film boiling begins is often termed the burnout point, even though, in some cases, failure does not occur (e.g., a temperature-driven system or a surface material with a very high melt temperature).

** A certain degree of liquid superheat is required to establish a flow of heat to create vapor bubbles. The superheat can become quite large for very smooth surfaces or highly wettable fluids (e.g., refrigerants or liquid metals) which can lead to explosive boiling (known as bumping) that can lead to structural damage to hardware.

† Transition boiling occurs between the limit of nucleate boiling (point C) and point D, which is known as the Leidenfrost point. The path between the points is dependent on numerous factors and the heat flux becomes a multivalued function of the liquid superheat (e.g., see Witte and Lienhard, Ref. 6). This region is inaccessible with a heat flux controlled system.

†† Point E lies on a portion of the boiling curve known as film boiling. Beginning at the Leidenfrost point (point D), heat transfer across the vapor film adjacent to the surface increases due to radiation from the wall, through the vapor, to the bulk fluid.

The burnout point is known also as the departure from nucleate boiling (DNB), fast burnout, and burnout of the first kind in systems which involve a subcooled* liquid. In saturated liquid boiling systems, another type of burnout occurs (usually at lower heat flux than subcooled boiling), and the terms slow burnout, dryout, or burnout of the second kind are used (see Ref. 8). Boiling crisis and critical heat flux condition are used in a general sense to describe all burnout situations. Because of a lack of standard nomenclature, hereafter the point at which transition to film boiling begins is designated the burnout point or boiling crisis, and the peak, ultimate, or maximum heat flux is termed the critical heat flux (CHF), except where designated differently in the referenced material.

Design of the cooled components of a high-enthalpy facility for safe operation necessitates the cooling processes to lie to the left of, and well below, point C in Fig. 1. High heat-transfer coefficients, hence, efficient energy transfer, can be realized when operating in the nucleate boiling regime rather than the pure convection regime at low-to-moderate coolant pressure and velocity. Any method used to increase the CHF will provide a factor of safety when operating well into the fully developed nucleate boiling regime. The determination of the CHF, along with the shape of the nucleate boiling curve for a given cooling system, remains one of the most challenging areas of research despite the considerable attention it has received in the last 50 years (Ref. 9). Complexity of the boiling mechanisms, their unsteady nature, and the small scale of the heat-transfer processes have hindered the development of theoretical models and understanding of the phenomena from experimental studies. Moreover, the cooling flow structure and, hence, the heat-transfer processes vary depending on the heating condition, fluid properties, and surface geometry. For instance, boiling heat transfer that occurs in a high-enthalpy facility (subcooled flow, surface boiling optimized for effective wall cooling over short lengths at high heat loads) can be quite different than that which occurs in a nuclear reactor (saturated flow with possible slug or annular two-phase flow, bulk boiling optimized for efficient energy transfer over great lengths at low-to-moderate heat loads).

The objective of a large portion of the experimental work undertaken in recent years in the area of boiling heat transfer has been to obtain an empirical or semiempirical correlation for a given cooling configuration and set of test conditions. Many of the correlations have limited application and cannot be generalized for use in analyzing other cooling configurations and conditions. The experiments do provide a qualitative evaluation of what parameters affect the boiling processes of interest and the trend in cooling performance when each of the

* If the cooling fluid bulk temperature is well below the saturation temperature of the fluid, then the fluid is known as subcooled. Boiling that occurs on a surface adjacent to such a fluid is known as subcooled local or surface boiling. If the bulk temperature is at or near the saturation temperature, the fluid is known as saturated. Bulk boiling can occur when the fluid is near saturation, and undergoes various flow regimes in forced flow such as slug, annular, and drop flow. See Collier (Ref. 7) for further discussion of saturated flows.

parameters is varied. Optimizing the influential parameters for high-enthalpy facility component cooling will, in turn, aid in identifying those boiling mechanisms which play a part in the cooling process of interest. Once the mechanisms are identified, appropriate analytical models and experimental data may be assembled.

3.0 PARAMETRIC EFFECTS ON THE BOILING CURVE

More than 20 parameters that affect the cooling process have been identified. Some parameters play an important role from pure convection to boiling crisis while others play intermittent roles. For instance, velocity has a large effect on cooling performance in the pure convection regime and at boiling crisis, but it has virtually no effect in the nucleate boiling regime. Therefore, the contribution of each parameter in each of the three regions of interest (pure convection, nucleate boiling, boiling crisis) will be discussed. The effects of various parameters on the microscopic boiling scale (i.e., bubble characteristics) have not been studied in great detail and are presented here for the more influential parameters. The cooling process is not without parametric distortion; that is, the change in one parameter causes a change in another parameter. Because of the complexity of the boiling process, many of the parametric distortions are ill-defined or unknown; therefore, a discussion of these distortions included here is limited. Several excellent reviews of various parametric effects on boiling are available and are drawn upon in the following review, most notably: boiling in general—Tong (Ref. 10), Westwater (Refs. 11 and 12), Rohsenow (Refs. 13 and 14), Addoms (Ref. 15), and Katto (Ref. 16); convective boiling—Collier (Ref. 7); subcooled flow boiling—Boyd (Refs. 1 and 17), Bergles (Ref. 8), Macbeth (Ref. 18), Hewitt (Ref. 19), Fiori and Bergles (Ref. 20), and Hughes (Ref. 21).

3.1 IMPORTANT PARAMETERS AND THEIR EFFECTS ON HEAT TRANSFER

Velocity

Velocity (or mass velocity, G , when combined with the fluid density), as mentioned previously, plays an intermittent role in the cooling process. Figure 2 (from Kreith and Summerfield, Ref. 22) illustrates the significant effect of fluid (butanol) velocity as heat flux from an adjacent surface increases in pure convection heat transfer. However, as transition to boiling occurs, the effect of velocity diminishes. Clark and Rohsenow (Ref. 23) and Tong (Ref. 10), among others, have noted that velocity has little or no effect on heat transfer in vigorous (or fully developed) nucleate boiling. Analysis of boiling processes is divided into two categories with regard to velocity. Boiling which occurs on a surface or in a fluid initially at rest where only free-convection motion is present is known as pool boiling. Boiling which occurs on a surface or in a fluid where the fluid has a bulk (imposed by some external source such as a pump) and free-convection motion is known as forced-convection boiling or simply

flow boiling. The advantages of flow boiling over pool boiling, when present in a cooling process, become evident as boiling crisis is approached. McAdams, et al. (Ref. 24) showed that the CHF could be increased with increasing velocity (Fig. 3). Grace (Ref. 25) generalized the velocity effect on CHF for various qualities of water liquid/vapor systems as shown in Fig. 4. An inversion in velocity effectiveness occurs at higher vapor qualities (i.e., saturated fluid) as illustrated in Fig. 4; however, as will be discussed next, subcooling (vapor qualities less than zero) provides the largest values of CHF, where increasing mass velocity increases the CHF for a given degree of subcooling (Fig. 4).

Analyzing the boiling process on a microscopic scale, Abdelmessih, et al. (Ref. 26) found that both the maximum bubble radius and the bubble lifespan decrease as the liquid velocity increases (Fig. 5). Gunther (Ref. 27) found, in addition to decreasing the bubble radius and lifetime, that increasing velocity also decreases the bubble population. Tippets (Ref. 28) found that when high velocity is combined with large subcoolings, the flow adjacent to a surface sustaining boiling is an irregular, frothy layer made up of bubbles that grow, slide, and then collapse along the surface. These bubble characteristics make their detection and measurement at high flow velocity difficult.

Subcooling

Subcooling, or the amount that the fluid bulk temperature is below the fluid saturation temperature, has been shown to have an effect similar to velocity on the cooling process. Researchers have correlated experimental data using a fluid bulk temperature measured at various locations in a given apparatus. Generally, for larger length-to-diameter ratios where the bulk fluid may enter at subcooled conditions but reach saturation conditions somewhere along the heated length, the inlet subcooling (inlet saturation temperature minus the inlet bulk temperature) is typically used in analyses. For constant diameter configurations and uniform heating where burnout occurs at or near the exit of the heater, the exit subcooling (exit saturation temperature minus the exit bulk temperature) is typically used. Some researchers have used a mean average bulk temperature (average of the inlet and outlet bulk temperatures) in some instances to define subcooling. In some cases, subcooling is calculated using an inlet bulk temperature and an exit pressure (exit saturation temperature). For a configuration such as an arc heater nozzle where nonuniform heating, velocity, and pressure exist along the length of the nozzle, a local subcooling using a local bulk temperature and saturation temperature is more appropriate. A discussion of the general subcooling effects follows, with an effort made to identify the type of subcooling used in the experimental results cited.

McAdams, et al. (Ref. 24) showed that inlet subcooling has a slight effect on heat transfer in the pure convection and the nucleate boiling regions of the boiling curve because of small variations in physical properties of the fluid at different temperatures. Subcooling, like velocity,

has its primary advantages at boiling crisis. Van Huff and Rousar (Ref. 29) and Kreith (Ref. 30) indicated that subcooling and velocity are the most important variables on burnout (CHF). Green, et al. (Ref. 31) measured burnout heat flux for vertical water flow in a rectangular channel at high pressure and found that increasing both velocity and inlet subcooling increased the burnout heat flux (Fig. 6). Van Huff and Rousar (Ref. 29) combined velocity and an average subcooling and derived a linear fit to previous data (Fig. 7). Macbeth (Ref. 18) found that increasing inlet subcooling increased CHF linearly at constant mass velocity; however, Katto and Yokoya (Ref. 32) indicated that nonlinear regimes can occur at high mass velocity at low-to-moderate inlet subcooling, and Lienhard (Ref. 33) found that the maximum heat flux (CHF) versus degree of subcooling curve "flattens" out for any velocity above a threshold degree of subcooling. In any event, it is likely that the CHF generally can be increased by increasing velocity and subcooling.

On a microscopic scale, Gunther's work (Ref. 27) with a flow boiling apparatus found that the bubble lifetime, surface coverage, and maximum radius decreased with increased exit subcooling, while the bubble population, which initially decreases, increases for subcoolings above 72°C (130°F as shown in Fig. 8). As reported by Westwater (Ref. 12), the motion pictures of Dew (Ref. 34) confirmed Gunther's findings except bubble population, which decreased with increased average subcooling. Ibrahim and Judd (Ref. 35) confirmed that the growth period decreased with increased subcooling and, in addition, found that the waiting period between bubble generations from an active nucleation site also decreased with increased subcooling except at low subcooling (below 22°C). It should be noted, however, that Ibrahim and Judd performed their subcooling studies on a pool boiling apparatus.

Pressure

The primary contribution of pressure on a cooling process is its effect on the saturation temperature of the fluid, although an interesting inversion of pressure effect occurs at boiling crisis. Kreith and Summerfield (Ref. 22), who studied flow boiling with butanol, found that increasing pressure had no effect on heat transfer in the pure convection region, but increased wall temperature for a given heat flux in the nucleate boiling region, as shown in Fig. 2. An increase in wall temperature is not particularly beneficial; however, some improvement to the CHF can be achieved by increasing pressure - up to a point. Cichelli and Bonilla (Ref. 36), while studying pool boiling of organic liquids, found that heat flux increased with increasing pressure to a maximum value which occurred at about one-third of the critical pressure (Fig. 9). Addoms (Ref. 15) obtained similar results from pool boiling of water; however, the maximum peak heat flux varied with heater wire size (Fig. 10). Chang (Ref. 37) suggested a similar maximum CHF in flow boiling that occurs at various pressures between 500 and 1,000 psia, depending on mass velocity and subcooling. Boyd (Ref. 1) suggested a similar "optimum pressure" as shown in Fig. 11.

Tolubinsky and Kostanchuk (Ref. 38) found that increased pressure decreased the maximum bubble diameter and the generation frequency (Fig. 12), although the former appears to remain constant or to begin increasing above a pressure of 8 to 10 bar (120 to 150 psia). The bubble life span is inversely related to the generation frequency, and, therefore, increases with increased pressure.

Surface Roughness

Surface roughness plays a complicated role in cooling efficiency and is divided into micro-roughness (typically smaller than $3\ \mu\text{m}$) and macro-roughness (artificial protrusions such as knurling, fins, or ribs). Corty and Foust (Ref. 39) performed an extensive micro-roughness study of various fluids in pool boiling on copper and nickel surfaces. They found that increased roughness had no effect in the pure convection region, but heat-transfer coefficients were more than doubled in the nucleate boiling region for the roughest surface when compared to the smoothest surface (Fig. 13). Brown (Ref. 40), however, found a modest effect of surface finish in subcooled, low-velocity flow boiling at moderate heat flux (Fig. 14). Berenson (Ref. 41) and later Ramilison and Lienhard (Ref. 42) found a modest surface finish dependence of boiling burnout (up to approximately 20-percent decrease from smooth to rough surface) in pool boiling. Other than Weatherhead (Ref. 43), who concluded that CHF is decreased for very smooth surfaces, other investigators such as Leung, et al. (Ref. 44), Aladyev, et al. (Ref. 45), and Bergles and Morton (Ref. 46) found little or no effect of surface micro-roughness on CHF in flow boiling. Bergles and Morton further determined that any improvements of the burnout heat flux caused by roughness appear to diminish with increasing velocity and subcooling.

Macro-roughness has been found to have a more pronounced effect on forced flow cooling efficiency than the micro-roughness previously discussed. Types of macro-roughness used in forced flow include knurling (Durant, et al., Ref. 47), fins (Kovalev, et al., Ref. 48, and Shim, et al., Ref. 49), and ribs (Ravigururajan and Bergles, Ref. 50, and Akhanda and James, Ref. 51). Durant and his team determined that liquid film heat-transfer coefficients of knurled surfaces were up to 75-percent higher than those of smooth surfaces. Burnout heat flux was shown to increase by as much as 80 percent (Fig. 15). The types of roughness investigated by Durant's team were comparatively large (greater than $130\ \mu\text{m}$) over those discussed in the previous paragraph. Macro-roughness is considered a heat-transfer enhancement technique rather than a basic parameter affecting heat transfer that would be inherent in a given system. An excellent review of this enhancement technique is presented by Webb (Ref. 52); however, most of the surface geometries have been developed for pool boiling only.

Coolant Properties

The understanding of the effects of coolant properties on the heat-transfer processes in boiling remains limited, even though selection of the fluid is a most important consideration in boiling applications (Ref. 1). The physical properties of a given fluid such as liquid/vapor density ratio, latent heat of vaporization, surface tension, heat capacity, and transport properties (i.e., viscosity and thermal conductivity) may play a role in the cooling process; however, distinguishing their individual contribution is difficult, and little or no data exist to ascertain their effect. The properties are related to the pressure and/or the temperature of the fluid, and the problem of parametric distortion discussed earlier becomes evident.

The limited studies of the microscale mechanisms during boiling have produced conflicting information as to the effect of latent heat. A number of investigations (Refs. 53-56) have revealed that latent heat transport accounts for as much as 50 percent of the measured heat flux in subcooled boiling; however, Forster and Grief (Ref. 57), Brown (Ref. 40), and Plesset and Prosperetti (Ref. 58) found very little latent heat contribution.

In their work with a pool boiling apparatus, Pike, et al. (Ref. 59) found that increasing viscosity hindered the onset of boiling (decreased heat-transfer coefficient, increased wall superheat) and lowered the CHF. As will be discussed under transient operation effects, it has been proposed that transient operation is viscosity-dependent, thereby contributing to an observed difference in CHF for the transient and steady-state heating of certain fluids.

Surface tension may or may not play a beneficial role in the cooling process (Ref. 11). Fiori and Bergles (Ref. 20) identified several investigations that clearly showed that CHF decreases with decreasing surface tension. The addition of various amounts of surface-active agent has been found to increase the heat transfer quite significantly at the expense of reducing the CHF. For example, Frost and Kippenhan (Ref. 54) showed that for a given wall temperature, the heat flux increased by approximately 50 percent when a surface-active agent was added to water, thereby reducing the surface tension (Fig. 16). The reduction of surface tension (or increased wettability) had a detrimental (decreasing) effect on the CHF, which agrees with previous results, and is evident in Fig. 16. However, a recent study by Sadasivan and Lienhard (Ref. 60) showed an increased CHF with the addition of the surfactant sodium dodecyl sulfate to water. They also noted that bubble diameters were smaller, and the number of bubbles was much greater with the surfactant present.

Improvements to the CHF have been demonstrated in a limited number of investigations using binary mixture components. Papaioannou and Koumoutsos (Ref. 61) and Wei and Maa (Ref. 62) found that polymeric additives to water increased heat-transfer coefficients and broadened the peak (CHF) of the boiling curve. Tolubinskiy and Matorin (Ref. 63) found

that for ethanol-water and acetone-water mixtures, the maximum CHF (occurring at 20-percent ethanol/80-percent water and 10-percent acetone/90-percent water) exceeded the CHF for water by 30 and 40 percent, respectively (Fig. 17).

A number of coolants such as refrigerants, cryogenics, organics, binary mixtures, liquid metals, and propellants, in addition to water, have been investigated for various cooling applications. A propellant is probably not attractive for use as a coolant in a high-enthalpy facility, except in specific test article configurations. The use of organics is unlikely, except possibly as a trace additive or in a binary mixture, because of their lower performance compared to that of water (Ref. 64) and their tendency to decompose at surface temperatures experienced at nucleate boiling heat flux levels (Ref. 8). Binary mixtures, as discussed previously, may be an attractive approach to improve the CHF in a water-cooled system. Liquid metals may be considered in the future as an alternative or complement to water cooling. Because of their high thermal conductivity, liquid metals have proved useful in convective cooling applications. Boiling in liquid metals, however, is somewhat confused. Lyon, et al. (Ref. 65) showed that mercury, for instance, appears to enter film boiling at surprisingly low wall superheats. And because of the high wettability of liquid metals, high superheats are normally required to initiate boiling, in some cases having an explosive transition that can cause structural damage to hardware. A thorough understanding of boiling metals is needed before they can be applied in high heat flux/cooling situations. Refrigerants such as Freon[®] have been used in previous experiments (Refs. 66-69) to simulate water cooling at high heat flux conditions since the CHF can be achieved at much lower heat flux. Scaling methods are applied to the simulation to achieve high heat flux/water cooling predictions (see, for example, Ahmad, Ref. 70). A good example of this "fluid-to-fluid" scaling is presented by Bergles in Ref. 8. Use of refrigerants for actual cooling in high-enthalpy facilities is not recommended because of their low thermal conductivity and CHF levels. In addition, refrigerants suffer from a high wettability problem not unlike that of liquid metals. Similarly, Powell (Ref. 71) found that low heat-transfer coefficients and CHF levels existed for cryogenics such as hydrogen, nitrogen, and oxygen which would limit the use of liquified gases as a heat-transfer fluid. Refrigerants and cryogenics perform well in systems that have relatively low heat flux requirements and limited space availability.

Wall Material

Although it is considered to be a secondary effect, surface material properties appear to contribute to cooling efficiency. Early experiments in pool boiling demonstrated a difference between stainless steel and copper in nonboiling and boiling water (Ref. 72); copper, gold, and chromium in boiling ethanol (Ref. 73); nickel, tungsten, and Chromel[®] in boiling water (Ref. 74); and aluminum, copper, iron, and chrome-plated copper in water and various organic liquids (Ref. 75), among others. Later, Magrini and Nannei (Ref. 76) found that the heat-

transfer coefficient appears to be dependent on the thermal activity, $\sqrt{q''ck}$, for heaters of different metals above a limiting value of thickness (Fig. 18). Kovalev, et al. (Ref. 77) showed that copper with coatings of low thermal conductivity tended to increase the degree of wall superheat over that of clean copper boiling in Freon 113. Cheng and Ragheb (Ref. 78) found that a greater wall superheat was required for an Inconel® surface than a copper surface in flow boiling of water (Fig. 19).

Numerous pool boiling experiments have demonstrated that the CHF has a significant material dependence (Refs. 73-75 and 77) which has not been observed in flow boiling. The data of Cheng and Ragheb presented in Fig. 19 show the CHF to be equivalent for Inconel and copper. Jacket, et al. (Ref. 79) found no effect on CHF due to changing wall material from nickel to Zircaloy® or, later, stainless steel (Ref. 31) in flow boiling of water at high pressure. Van Huff and Rousar (Ref. 29) identified studies in which various metals had no effect on CHF, except where the material and coolant were incompatible (additional reactions occur). Similarly, Vandervort, et al. (Ref. 80) found no difference in CHF for subcooled forced-convection boiling of water on stainless steel 304, stainless steel 316, nickel 200, brass, and Inconel 600. However, Vandervort's team suggested that materials with low values of thermal conductivity, such as stainless steel and Inconel, may exhibit hot spots due to changes in metal crystalline structure when high wall temperature gradients are present (e.g., high heat flux in thin wall tubes). Fiori and Bergles (Ref. 20) suggest that materials with high thermal diffusivity (e.g., aluminum and molybdenum) are expected to have higher CHF.

Wall Thickness

The thickness of the heated wall has been shown to have an effect on the boiling heat flux, but only below a critical or limiting value of wall thickness. Magrini and Nannei (Ref. 76), for instance, found for saturated pool boiling of water that the limiting value was approximately 15 μm (0.0006 in.) for tin and nickel, and negligible for copper and silver. They also determined the limiting value for zinc to be approximately 70 μm (0.0028 in.), although it is not obvious from the data presented in Ref. 76. Del Valle and Kenning (Ref. 81), while studying subcooled water flow at high heat flux, found that thin heated walls (0.08- to 0.2-mm thickness) had no effect in the nonboiling region, but the rate of nucleate boiling heat transfer at a given wall superheat increased with increasing wall thickness (Fig. 20). Tippets (Ref. 28) found that CHF measured for 0.15-mm-thick heater ribbons was approximately 20 percent lower than for 0.25-mm-thick ribbons in saturated water flow. They suggest that thicker walls can maintain a higher internal heat generation rate per unit volume (q''/V) before the critical condition is reached than thin walls, since the latter will have a larger temperature rise at a given heat flux (i.e., q''/V will be greater for a thin-walled tube since the volume is smaller and the heat flux constant). Fiori and Bergles (Ref. 20), using subcooled water in a flow boiling apparatus, showed that thicker-walled tubes (2 mm versus 0.3 mm) had

a CHF up to 58 percent higher than thin-walled tubes. Aladyev, et al. (Ref. 44), however, found no effect of wall thickness (0.4 mm to 2 mm) on the CHF for water flow boiling.

Geometry

Geometric considerations that have been experimentally shown to have an effect on the cooling process include the diameter (or hydraulic diameter) of the heater (or channel), heated length (or L/D), the channel cross section and longitudinal configuration, and the flow orientation (Ref. 1). Because of various applications, past experiments associated with studying cooling problems have encompassed a wide range of configurations, and one must be cautious when comparing data from one experiment to another (Ref. 11).

The channel diameter appears to have a varied effect on boiling heat transfer. Schweppe and Foust (Ref. 82) found that for flow boiling with low-velocity water, the wall superheat increased (or heat-transfer coefficient decreased) as channel diameter increased from 11.1 mm to 26.6 mm. Collier (Ref. 7) presented subcooled, flow boiling data of Lee and Obertelli (Ref. 83) and Matzner (Ref. 84) that indicated that CHF increased as channel diameter increased from 5.6 mm to 37.5 mm at constant subcooling (Fig. 21). Bergles (Ref. 85), however, found for subcooled flow boiling that CHF increased as channel diameter decreased from 8.4 mm to 0.6 mm (see Fig. 22), although the percentage increase in CHF is somewhat less when parametric distortion is accounted for (Ref. 20). Similarly, Glushchenko (Ref. 86) found that CHF increased as the tube diameter was reduced below 2 mm. Van Huff and Rousar (Ref. 29) found no effect of channel diameter on CHF for subcooled flow boiling with diameters ranging from 2.7 to 14.9 mm.

Schweppe and Foust (Ref. 82), by varying channel diameter (as previously discussed) and holding the heated length constant, showed for flow boiling with low-velocity water that the wall superheat increased as L/D decreased below 15 to 20. Bergles (Ref. 85) found for flow boiling that CHF increased as L/D was decreased below 35 (Fig. 23). Similarly, Ornatskiy (Ref. 87), using subcooled water flowing in circular ducts, found this limiting L/D to be between 20 to 24, and Jens and Lottes (Ref. 88) showed that, for high-pressure, subcooled flow boiling, changing L/D from 110 to 21 had an increasing effect on CHF. Lee and Obertelli (Ref. 83) found a considerable effect on CHF in subcooled, low-velocity flow for L/D values less than 300 (Fig. 24). Van Huff and Rousar (Ref. 29), however, noted that data acquired by Aerojet General Corporation for high-velocity, highly subcooled water showed very little effect of L/D (ranging from 13 to 100) on CHF. As Boyd (Ref. 1) points out, since the L/D limit is related directly to the flow development, this limit is not a constant and is related to the flow parameters and fluid properties.

The geometric considerations thus far discussed have been primarily for circular tube configurations. External flow over rods (or wires) and rod bundles, jets, internal flow in

multiple tube (or tube bundle) configurations, annuli, and, to a lesser extent, rectangular channels have been studied in the past. Internal tube flow and annular flow closely simulate the cooling configurations encountered in a high-enthalpy arc facility. Becker and Hernborg (Ref. 89) found for water flowing in an annulus with inlet subcooling and an inner heated wall (similar to an arc facility nozzle) that CHF data were considerably below those for comparable flow in a circular tube, and Zenkevich, et al. (Ref. 90) also found a difference in CHF between annuli and tubes (at the same length and diameter). Barnett (Ref. 91), however, points out significant difficulties which arise when comparing tube and annulus data and the definition of an appropriate equivalent diameter. In addition, Alekseev, et al. (Ref. 92) found significant heated length effects for annuli at much greater lengths than for circular tubes. Collier (Ref. 7) discusses other characteristics of annular flow of interest. Specifically, eccentricity of the internal heated wall will tend to reduce the CHF (see also Ref. 91). In addition, Collier points out that the outer wall in a concentric annulus system has little or no effect on the CHF for the inner surface.

The channel longitudinal configuration is important to the boiling heat transfer when significant curves or twists are introduced. Such longitudinal changes have an effect on the acceleration and turbulence of the coolant flow. A discussion of these types of configurations is included in the section entitled "Acceleration and Turbulence."

Coolant flow orientation (horizontal, inclined, or vertical) has been shown to have an effect on cooling efficiency due primarily to buoyancy (gravity) causing stratification of the liquid/vapor flow (Refs. 93 and 94). The effect of flow orientation, though, diminishes with increasing subcooling and/or mass velocity, and there appears to be a threshold above which no effect of orientation has been observed (Refs. 1, 7, 94, and 95). Zeigarnik, et al. (Ref. 96), for instance, showed that the orientation of the heater plate in a rectangular flow channel had little effect on the CHF at mass velocities above 4,500 kg/m² sec (922 lbm/ft² sec) in subcooled water flow (Fig. 25). Boyd, et al. (Ref. 97) suggests that the mass velocity limit is between 3,000 and 4,500 kg/m² sec (600 to 900 lbm/ft² sec), which agrees with the velocity limit of 4,000 kg/m² sec (820 lbm/ft² sec) found by Merilo (Ref. 94).

Gas Content

A number of experiments in pool boiling (Refs. 59 and 98) and flow boiling (Refs. 21, 24, and 99) have demonstrated the effect of dissolved gases on pure convection and nucleate boiling heat transfer. McAdams, et al. (Ref. 24), for example, found little effect of dissolved air on forced-convection heating, but the presence of air tended to reduce the wall superheat necessary to initiate and sustain nucleate boiling (Fig. 26) which is typical* of data obtained

* Only Jens and Lottes (Ref. 88) found that boiling incipience is not affected by gas content.

in boiling experiments where the effect of dissolved gas was evaluated. In several experiments, the effect of dissolved gases was found to diminish in fully developed nucleate boiling (Refs. 24 and 100). This is evident in Fig. 26 at high wall superheat where the data for boiling with dissolved air match that for degassed boiling.

Data obtained to evaluate the effect of dissolved gases on CHF are contradictory; however, in experiments where an effect was noted (Refs. 24, 99-101), the presence of dissolved gases tended to reduce the CHF from that of degassed boiling at the CHF. Fisenko, et al. (Ref. 99) found this reduction to be as high as 23 percent at higher subcoolings. A number of investigators (e.g., Refs. 21, 31, and 102) identified no appreciable effect of dissolved gases on CHF. Kalayda, et al. (Ref. 103) found that for water flow boiling, the gas content had little effect on CHF at pressures below 100 bar, but at higher pressures the CHF was reduced with increased concentrations of nitrogen.

Other experimental results have been obtained with gassed and degassed coolants. Jens and Lottes (Ref. 88) and Buchberg, et al. (Ref. 100) in water flow boiling found that the presence of dissolved nitrogen had a small effect on the pressure loss along the heated wall. Baranenko, et al. (Ref. 104) found for atmospheric pool boiling of water that the bubble diameters are larger when degassed water is used rather than gassed water. The presence of dissolved oxygen can have an additional effect on the heat-transfer process due to oxidation of surfaces in contact with the coolant. A discussion of this oxidation effect is included in the following section.

Surface Aging, Deposits, and Coatings

Surface aging* has been shown in the past to increase the wall superheat in pool boiling (Refs. 11 and 13). Bonilla and Perry (Ref. 73), for instance, found this to be the case on a chrome-plated copper heater with boiling ethanol. Hughes (Ref. 21) found for subcooled flow boiling that surface aging tended to decrease the CHF, and Akhanda and James (Ref. 51) found that aging increased the wall superheat in forced-convection boiling of water.

The effect of surface deposits (or fouling) on cooling heat transfer is much more difficult to ascertain. Epstein (Ref. 105) identified several categories in which fouling (primarily in forced-flow heat exchangers) can occur. These include precipitation (dissolved substance deposits), particulates (suspended particle deposits), chemical reaction (surface is not a

* Nucleate boiling on clean surfaces will not reach a steady-state condition for a sizeable period of time (in some cases, an hour or more) due to several reasons including surface outgassing, chemical reactions, etc. (Ref. 11). This process of reaching steady-state conditions is known as aging.

reactant), and corrosion (surface reactions) among others. Collier (Ref. 7) pointed out that porous deposits on heat-transfer surfaces can influence the CHF both favorably and adversely (see also Westwater, Ref. 11). Bui and Dhir (Ref. 106), found that the presence of an oxide increased the CHF in pool boiling of water. Mel'nikov, et al. (Ref. 107), however, found that CHF decreased nearly 36 percent (at a quality of 0.06) with the presence of a 55- μm (0.002-in.)-thick ferric-oxide scale as compared to a scale-free surface in forced-convection boiling of water.

The effect of surface coatings (primarily used for heat-transfer enhancement) on cooling heat transfer is similar to that of deposits. For example, Zhukov, et al. (Ref. 108) found that the wall superheat and CHF primarily decreased for an aluminum oxide coating, but both increased for an enameled surface in Freon pool boiling. As discussed previously in the wall material effects, Kovalev, et al. (Ref. 77) found that low thermal conductive coatings increased the wall superheat. Collier (Ref. 7) discusses improvements in heat transfer demonstrated by several investigators using thin Teflon[®] films; however, Sadasivan and Lienhard (Ref. 60) showed that Teflon microcoatings on Nichrome[®] surfaces reduced the wettability and, hence, reduced CHF values.

Acceleration and Turbulence

High-enthalpy facility components invariably require coolant flow direction and area changes which, in turn, cause flow acceleration/deceleration and turbulence. Merte and Clark (Ref. 109) found for pool boiling of saturated water that increasing the acceleration (g-loading of 1 to 20) decreased the wall temperature and thereby increased the heat-transfer coefficient in both the pure convection and nucleate boiling regions, although the effect of acceleration diminished as the boiling became fully developed. Forced-convection acceleration/turbulence effects have been studied with curved channels and coiled tubes. Gu, et al. (Ref. 110), studying a fluorocarbon liquid flowing over a concave-shaped heater, found that for the same flow velocity and subcooling, both the heat-transfer coefficient and CHF are higher in a curved channel (concave section) than in a straight channel. Gu's team also found that the increase in CHF is significant (40-percent higher than straight channel CHF) at higher flow velocities. Hughes (Ref. 21) found similar results for concave heater surfaces in subcooled Freon 113 flow boiling. Hughes found that the CHF was increased up to 50 percent in concave channels over straight channels (Fig. 27). Hughes' data, however, illustrate the disadvantages of such a curved channel configuration. Should the channel be heated entirely, the convex portion could have a detrimental effect on CHF, as shown in Fig. 27. The CHF for convex surfaces was as much as 22 percent lower than that for a straight channel. Jensen and Bergles (Ref. 95) found low CHF levels in subcooled R-113 flow over inside surfaces (convex portion) of helically coiled tubes, and Bergles (Ref. 8) noted similar results found by other investigators. Winovich and Carlson (Ref. 111) made use of the advantages of a concave surface in the

design of an undulating flow channel used in various high-enthalpy facility components. They found that the undulating channel significantly increased (as much as 100 percent) the CHF over that of a straight channel (Fig. 28).

Swirl flow devices and other inserts have been used in the past to induce turbulence, thereby enhancing the cooling heat transfer in applications such as heat exchangers. Kudryavtsev, et al. (Ref. 112), used a twisted tape in tubes with saturated water flow boiling to show that the turbulence generated by density gradients and acceleration from the twisted tapes decreased the rate of nucleate boiling (increased wall superheat). However, Lopina and Bergles (Ref. 113) found little effect of swirl on the wall superheat for subcooled water flow boiling. Ornatskiy, et al. (Ref. 114) demonstrated that induced swirl at the inlet of a concentric annulus increased the CHF by 10 to 60 percent over unswirled flow for low qualities. Gambill, et al. (Ref. 115) found similar results for subcooled water flow boiling. Ornatskiy's team also showed that the effect of swirl on CHF decreases with increasing pressure (Fig. 29), but increases with increasing mass velocity (Fig. 30).

Megerlin, et al. (Ref. 116) augmented the heat transfer in subcooled water flow in tubes by using brush and mesh inserts, showing that heat-transfer coefficients up to nine times the coefficients of empty tubes can be obtained. Megerlin and his team found that the inserts produced very large pressure drops and very large wall superheats. Bergles (Ref. 8) recommends that the inserts are more suitable for use in single-phase flow heat-transfer augmentation. As mentioned previously in the discussion of surface roughness effects, macro-roughness can be used to enhance the heat transfer in forced flow, which probably involves some type of turbulence mechanism.

Heat Flux Distribution

Variations in heat flux distribution, both axial and circumferential, have been shown to have an effect on boiling heat transfer, primarily on the CHF. Stein and Begell (Ref. 117), using subcooled water flowing in internally heated annuli, found no significant effect of an axial heat flux distribution (cosine shape) on the heat-transfer coefficients. Various researchers, however, have found significant effects when CHF is approached. Styrikovich, et al. (Ref. 118), while studying subcooled and saturated water flow in pipes with uniform and linearly varying heat flux, found that the CHF for a linearly increasing heat flux (along the tube length) was nearly twice that of a tube with uniform heat flux for low-quality water at 100 atm (mass velocity of 410 lbm/ft² sec) and 40 to 50 percent higher at 180 atm. For these cases, the crisis always occurred at the exit of the heated tube. Styrikovich's team also found that the CHF for a linearly decreasing heat flux occurred near the inlet of the heated section and was larger than that with a uniform heat flux, although data errors prevented the increase from being quantified for the subcooled case. Ornatskiy, et al. (Ref. 119) found similar results

for subcooled water flow in annuli with linearly or parabolically increasing heat flux; however, they found quite different results for other nonuniform heat flux applications. Earlier (Ref. 114), Ornatskiy's team had shown that for a cosinusoidal heat flux distribution on annuli with subcooled water flow, the CHF can be as much as 80 percent lower than that of a uniformly heated annulus at similar conditions, and the difference between the nonuniform heating CHF and uniform heating CHF increased with a decrease in pressure and mass flow rate. In addition, data presented in Ref. 119 show that, for subcooled water flow in annuli, the CHF with sinusoidal, exponential, or linearly/parabolically decreasing heat flux is generally lower than the CHF with uniform heat flux. Similar results were presented by Zenkevich, et al. (Ref. 90) for subcooled and saturated water flowing in tubes with uniform and cosinusoidal heat flux distribution, although at higher pressure and subcooled conditions, the difference appears to diminish or even reverse (Fig. 31). They point out that for complex nonuniform heat flux applications, the location of the burnout point along the length of tube or annulus is difficult to predict. Swenson, et al. (Ref. 120) presented some interesting results concerning saturated water flow in tubes with nonuniform heating along their length. They showed that the effect of nonuniform heating on DNB (CHF) was similar to that of Ornatskiy's team (CHF for nonuniform heating is less than CHF for uniform heating); however, as the region over which the nonuniform heating occurred became very small (i.e., a spike heat flux), the CHF for the nonuniform heating case approached and surpassed that for a uniformly heated tube.

Aladyev, et al. (Ref. 45) demonstrated that nonuniform heating around the perimeter of a tube with subcooled or saturated water flow can affect the level of CHF. They showed that the CHF generally occurs where the heat flux is the highest and increases with increasing unevenness of the heating (characterized by the ratio of the maximum to the average heat flux). It was also shown that the effect of nonuniform heating around the perimeter decreased with increasing diameter. Leontiev, et al. (Ref. 121) found, for subcooled water flowing in horizontal tubes with nonuniform circumferential heating (the ratio of maximum heat flux to average heat flux was 1.5), that the local values of CHF were somewhat higher than those of uniformly heated tubes. However, when they averaged the heat flux at the station where the critical point occurred, the averaged CHF for the nonuniform heating case was much lower than that for the uniform heating case at subcooled conditions, and the two coincided at high-quality conditions.

Transient Operation

The effects of transient power (heat flux), flow rate, and pressure operation on heat transfer have been studied in previous experiments primarily associated with petrochemical and nuclear power plant safety (e.g., Ref. 122). A major portion of these experiments involved the study of transient heat flux effects. Ragheb, et al. (Ref. 123), showed that the wall superheat was

larger for transient boiling (found by quenching a high thermal capacity tube with subcooled, low-pressure water flow) than steady-state boiling at comparable conditions (Fig. 32). Cheng, et al. (Ref. 124) had earlier found little difference in wall superheat for transient or steady-state heating with the same apparatus, although a limitation in the steady-state heating capability prevented data comparison at heat flux levels approaching the CHF. Kataoka, et al. (Ref. 125) found an effect on wall superheat similar to the one found by Ragheb's team for an exponentially increasing heat input to a platinum wire in subcooled forced water flow.

Several interesting results have been found during studies of the effect of transient heat flux on CHF. Borishanskiy and Fokin (Ref. 64) and later Tolubinskiy, et al. (Ref. 126) found that the CHF was equal for transient and steady-state heating in pool and forced-convection boiling of water with and without subcooling. However, when organic coolants* were used, it was found that the CHF for steady-state heating was much larger than the CHF for transient heating (Tolubinskiy's team found this difference to be as large as a factor of 3). Tolubinskiy's team theorized that the transient operation is viscosity-dependent, and pointed out that the organics have higher viscosities than that of water, thereby contributing to the difference in CHF for the transient and steady-state heating of organic fluids. Roemer (Ref. 127) found no effect of transient heating (time constant of the applied power was approximately 0.1 sec) on CHF for water flow normal to cylindrical test elements as long as the test surfaces were aged. This result was found to be independent of the test element wall thickness and the speed of the power transient. The CHF for unaged specimens was as much as 25 percent lower than the CHF at comparable steady-state conditions. Other researchers have found results conflicting with those observed by Borishanskiy's team and Tolubinskiy's team for water. As seen in Fig. 32, the data of Ragheb, et al. (Ref. 123) show the CHF for transient conditions to be higher than that for steady-state conditions. Kataoka, et al. (Ref. 125) also found the CHF for transient heating to be greater than that for steady-state heating, and the difference between the two CHF varied approximately as the -0.6 power of the period of the exponentially increasing heat flux (Fig. 33).

Fewer experiments have been performed to evaluate the effects of transient flow rate or pressure operation on boiling heat transfer. Celata, et al. (Ref. 128), using subcooled Refrigerant-12 as a coolant, found that the difference between the CHF for a flow rate transient and the CHF for a steady-state flow rate became significant when the time to reach half of the initial flow became less than approximately twice the flow rate transit time. The CHF for the transient flow was typically less than the comparable steady-state CHF in these cases. Celata, et al. (Ref. 129) later evaluated the combined effect of transient flow rate and thermal power on CHF using flowing subcooled R-12. His team found that the CHF for the transient

* Borishanskiy's team used ethyl alcohol; Tolubinskiy's team used ethanol and acetone.

cases was approximately equal to that for steady-state conditions when the time to reach half flow was greater than the transit time. When the time to reach half flow dropped below the transit time, the CHF for the transient case became greater than the corresponding steady-state CHF. These trends appeared to be insensitive to the level of pressure or mass flux at which the runs were made.

Weisman, et al. (Ref. 130), using depressurization of saturated water to produce boiling in a nonflowing apparatus, found that the wall superheat for the pressure transients was significantly higher (as high as a factor of two) than a slow pressure change, although the data are probably applicable only near boiling incipience. Celata, et al. (Ref. 131) used flowing, subcooled R-12 to demonstrate that pressure transients tended to reduce the CHF (higher depressurization rates led to more marked crisis conditions) from that exhibited during comparable steady-state conditions. Finally, Celata, et al. (Ref. 122) evaluated the combined effect of transient pressure, power, and/or flow rate on CHF, although no steady-state data were obtained for comparison. Celata's team did show the inadequacy of using the available steady-state CHF correlations in predicting transient power/flow rate/pressure situations. The data acquired by Celata's team for one-, two-, and three-parameter transients were recently tabulated in Ref. 132.

Flow Instabilities

Thermal-hydraulic flow instabilities are directly related to the flow system design, and can seriously affect the value of CHF and the integrity of the flow system (Ref. 17). Podowski (Ref. 133) identified several instabilities that can appear in two-phase flow and pointed out that these instabilities can be compounded in some cases. The classes of instabilities include excursive (Ledinegg), flow regime relaxation, nucleation, density-wave oscillation, pressure drop oscillation, acoustic, and condensation-induced instabilities. Numerous authors (Refs. 17, 133-136) have provided excellent reviews of these instabilities and their effects; therefore, a rigorous treatment is excluded here. In general, flow instabilities have a detrimental effect on boiling heat transfer, primarily a reduction in the CHF (Ref. 14).

According to Podowski (Ref. 133), one of the most predominant of the instabilities is that classified under density-wave oscillation. It includes flow loop, parallel-channel, and channel-to-channel instabilities. Flow loops consisting of sections with liquid flow combined with sections having liquid/vapor flow will have areas with different speeds of propagation of perturbations. In such a system, a perturbation can induce velocity and pressure oscillations which may diverge or reach a self-sustained periodic mode. In the latter case, the oscillations can exceed the thermal limits of the system, thereby reaching a premature CHF. Premature CHF has also been demonstrated in parallel channels (see Veziroglu and Lee, Ref. 137) that share a common inlet manifold or have a bypass channel. In configurations where the channels

have similar operating conditions, the phase of oscillations may be opposite, depending on the number of channels (Ref. 133). Such oscillations are called channel-to-channel instabilities. In many cases, the manifolded cooling approach is used in high-enthalpy arc facilities and may be prone to these types of instabilities when two-phase flow is present. Concepts for future arc facility nozzle liners include thin walls with structural webbing or ribs on the cooling channel surface. Such designs may introduce channel-to-channel instabilities between the cooling passages on the nozzle liners.

Density-wave oscillations frequently combine with other phenomena such as pressure-drop oscillations to create additional instabilities. For instance, Lowdermilk, et al. (Ref. 101) and later Aladyev, et al. (Ref. 45) showed that pulsations in flowing subcooled and saturated water caused by an upstream compressible volume reduced the CHF (from that of a stable system with no pulsations) as much as 80 percent. Lowdermilk's team found that the flow instability could be removed by throttling the flow just upstream of the test section (Fig. 34). In addition, Gambill, et al. (Ref. 115) suggested that stability is improved as the test section pressure drop becomes a smaller fraction of the total system pressure drop, and restricted flow upstream of the test section for most of their tests.* It appears that the stability of a cooling apparatus which involves flow boiling can be improved by avoiding compressible volumes in the flow loop (or throttling the flow between the compressible volume and the test section) and forcing the test section pressure drop to be a small portion of the total pressure drop of the system. However, as pointed out by Boyd (Ref. 17), in cases where a compressible volume is in the test section, or in very long test sections, no amount of throttling can eliminate or reduce the instability.

Heat Application/Orientation

Although not typically associated with an actual cooling configuration, the method of heat application when resistive (Joule) heating is used in an experimental simulation can be important. Ellion (Ref. 138) was one of the first to note an effect of alternating current (a-c) heating on an experimental boiling apparatus. Ellion found that a 60-cycle/sec a-c power supply caused a 120-cycle/sec growth and collapse of the bubbles in flowing subcooled water in an annulus. The problem was rectified by switching to direct current (d-c) power with the amplitude of the voltage ripple less than 1 percent over the full operational range. Gambill, et al. (Ref. 115) suspected a similar problem when they used a-c power to electrically heat a tube with internally flowing subcooled water. Gambill's team calculated that the a-c heating reduced the CHF as much as 16 percent over that for d-c heating. Tippetts (Ref. 28), who used a-c heating of stainless steel ribbons to study subcooled and saturated water flow boiling,

* Gambill's team restricted the ratio of test section pressure drop to the total system pressure drop to values between 0.045 and 0.40.

found that the CHF for 0.006-in.-thick heater ribbons averaged 20 percent lower than those for 0.010-in.-thick ribbons, and in a few cases, the difference was substantially larger. Tippetts theorized that the reduction was due in part to the lesser thermal time constant of the thinner ribbons coupled with the a-c heating. Although Sadasivan and Lienhard (Ref. 60) showed a definite difference between a-c and d-c heating on bubble character, they found little effect on CHF.

Leung, et al. (Ref. 44) found little effect (less than 6-percent difference) of direct and indirect heating of the interior wall of an annulus with flowing water at subcooled inlet conditions. As mentioned previously, Collier (Ref. 7) points out that the outer wall in a concentric annulus system has little or no effect on the CHF for the inner surface. However, Tong (Ref. 10) suggests that the presence of an unheated wall in the proximity of a critical point can adversely affect the cooling effectiveness (termed the "unheated wall effect"). Tolubinsky, et al. (Ref. 139) found, for subcooled and saturated water flowing in annuli, that higher CHF (as much as 30 percent) existed on a heated inner wall than on a heated outer wall at comparable conditions. Yuçel and Kakac (Ref. 140) found that the heater orientation had an effect on the CHF in a rectangular channel with flowing subcooled water. Their data indicated that higher CHF is achieved with the heated surface (along one side of the rectangular channel) facing up rather than facing down. However, they attributed the difference not to the presence of an unheated wall, but to buoyancy forces moving the vapor away from the lower surface, resulting in a lower surface temperature and higher CHF (as opposed to a higher surface temperature and lower CHF on the downward facing heater).

Miscellaneous Effects

Several other parameters have been shown to have an effect on the cooling process, albeit only a small number of experiments have been performed that demonstrate their effect. Tong (Ref. 10) suggested that the local enthalpy can impair the CHF, primarily when there is significant vapor voidage near the heated wall. Such conditions could exist for subcooled* or saturated flow, even at high velocity. The local enthalpy near the wall, even at upstream locations, can be excessively high and can cause burnout when significant vapor exists in the bubble layer near the wall.

Johnson (Ref. 141) pointed out that the presence of an electric field has some effect in the pure convection region, little effect in the nucleate boiling region, and a significant effect

* Fiori and Bergles (Ref. 20) found, contrary to prior beliefs, that large vapor voidages can exist even in subcooled flow. They noted that instantaneous void fractions larger than 50 percent were possible at high heat flux (3.1×10^6 to 17.3×10^6 W/m²), high exit subcooling (28° to 56°C), and low pressure (less than 6.2 bar).

at CHF and beyond. Markels and Durfee (Ref. 142) applied a 3,000-v a-c voltage across the gap of an annulus with the inner wall heated and flowing subcooled water. They found that the CHF was augmented as much as 40 percent with the applied electric field as opposed to no field present. No effect of the applied voltage was found where flow instability burnouts occurred.

Another heat flux augmentation method which has been demonstrated involves the use of flow and ultrasonic vibration. Although the use of vibration has not resulted in an increase in CHF for forced-flow configurations (Refs. 7 and 143), an enhancement of the heat transfer (increase in the heat-transfer coefficient) in the single-phase forced-convection region and boiling onset has been demonstrated (see Bergles, Ref. 143).

Boyd (Ref. 1) identified two other heat flux enhancement techniques which should be included here for completeness. As Boyd noted, Inoue and Bankoff (Ref. 144) found that the destabilization of film boiling (initially subcooled) by the introduction of a pressure wave increased the transient heat transfer up to 20 times the steady-state values. Boyd also noted that Weede and Dhir (Ref. 145) showed that the CHF can be enhanced and its location controlled using tangential injection of a fluid into the mainstream. This technique probably takes advantage of the induced swirl and turbulence whose benefits were discussed previously.

3.2 SUMMARY OF PARAMETRIC TRENDS AND IMPLICATIONS

As suggested previously, velocity and subcooling have a primary contribution on cooling effectiveness, and it appears that a highly subcooled, forced-convection cooling system is most attractive for high-enthalpy arc facility component cooling. Figure 35 summarizes the effect of a majority of the parameters and enhancement techniques previously discussed for a subcooled, forced-convection cooling environment. Those parameters and techniques that tend to decrease heat transfer or increase wall temperature in the pure convection (nonboiling) and nucleate boiling regions, respectively, are not necessarily detrimental to the cooling process unless the wall temperature increase approaches the melt temperature of the material or contributes to plasticity to the point of structural failure. Probably the most important contributions to cooling effectiveness and, hence, component survival, are those parameters and enhancement techniques which tend to increase the CHF. A number of parameters, such as pressure, can have either a beneficial or a detrimental effect on CHF and must be optimized for the conditions of interest. However, system limitations and configuration requirements may limit the degree of optimization that can be achieved.

The implications of requiring a subcooled, forced-convection cooling configuration are numerous and are not generally conducive to experimental evaluation. As previously discussed, high velocity, high subcooling, and high pressure tend to decrease bubble diameter and lifespan,

where

μ_b/μ_w is between 0 and 40

Re_D is between 10^4 and 5×10^6

Pr is between 0.5 and 200 for 6-percent accuracy

Pr is between 200 and 2,000 for 10-percent accuracy

$n = 0.11$ for $T_w > T_b$

$n = 0.25$ for $T_w < T_b$

$n = 0$ for gases

and where

$f = 1/(1.82 \log_{10} Re_D - 1.64)^2$ for smooth pipes

or from Moody chart for smooth or rough pipes.

Sleicher and Rouse (Ref. 152) recommended a simpler expression with comparable accuracy for tube flow,

$$Nu_D = 5 + 0.015 (Re_D)^a (Pr)^b \quad (6)$$

where

$$a = 0.88 - 0.24 / (4 + Pr)$$

$$b = (1/3) + 0.5 e^{(-0.6 Pr)}$$

and

Pr is between 0.1 and 10^5

Re_D is between 10^4 and 10^6

The properties in Re_D are evaluated at the local film temperature, $T_f = (T_b + T_w)/2$, and the properties in Pr are evaluated at the local wall temperature.

Kays and Leung (Ref. 153) solved the turbulent-flow energy equation for constant heat flux in annuli over wide ranges of Reynolds number, Prandtl number, and annulus radius ratio. Table 1 in Ref. 153 or Tables 13-3 to 13-5 in Ref. 5 present the results of their computations.

For fully developed laminar flow in a circular tube with uniform heat flux, the Nusselt number and, hence, the heat-transfer coefficient is constant, independent of Reynolds number and Prandtl number,

$$\text{Nu}_D = 4.36 \quad \text{constant heat flux, } \text{Pr} > 0.6 \quad (7)$$

Treatment of heat transfer in the entry region where velocity and temperature profiles are not fully developed is discussed in Chapter 8 of Ref. 154.

Pressure drop is also of interest in a cooling process, and the pressure gradient has even been shown to have an effect on local heat transfer (see Chapter 6 of Ref. 148). Solution of the equations of motion (using semiempirical shear correlations for the turbulent case where random fluctuations are important) provides a means of determining the pressure drop in a flow cooling configuration as outlined by White (Ref. 155). Friction factors as a function of Reynolds number for flow in smooth or rough circular tubes, annuli, or noncircular ducts are provided by the Moody chart or expressions such as those presented in Chapter 6 of Ref. 155.

4.2 TRANSITION TO FLOW BOILING, FLOW BOILING, AND CHF: THEORETICAL MODELS

The theoretical determination of heat transfer, pressure drop, and other flow characteristics once a cooling process has transitioned into boiling is one of the greatest challenges facing researchers in two-phase flow. Three currently accepted two-phase flow or "mixture" models have been developed based on the more dominant flow regimes in two-phase flow. The *drift flux* model, which is based on a molecular diffusion model, allows for motion of one phase relative to the other, and the two are coupled through the use of correlations accounting for interaction effects. The correlations are difficult to obtain because they require a knowledge of the average effects of one phase moving relative to the other (see, for example, Ref. 156). Another theoretical model, the *two-fluid* model based on the application of the Navier-Stokes equations, treats the phases separately and requires matching conditions at both solid boundaries and liquid-vapor interfaces. Difficulty is encountered in obtaining local and instantaneous mass, momentum, and energy balance equations at the interfaces (see, for example, Ref. 157). The drift flux model is typically more applicable to flows where the one phase is dispersed throughout the other. The two-fluid model is generally used for flows where

the two phases are separated into layers, but has been accepted for use with dispersed flows. If the motion of the two phases can be assumed to be equivalent (i.e., no-slip condition), a simplified model, the *homogeneous* model that treats the mixture as a single-phase fluid, may be used. The transport properties required for the model are difficult to determine due to the lack of existing relationships. Although extensive progress in theoretical modeling has been achieved in recent years, its application has been limited because of the difficulties described above. A more complete treatment of these models, especially the two-fluid model, is included in Jones, Ref. 158, and Drew, Ref. 159.

4.3 TRANSITION TO FLOW BOILING: CORRELATIONAL APPROACHES

Early studies in flow boiling suggested that boiling incipience occurred at the intersection of the pure convection and fully developed nucleate boiling curves, although experimental data indicated a transition region (McAdams, et al., Ref. 24). Several investigators later derived heat-transfer expressions for the transition from pure convection to fully developed nucleate boiling (termed partial nucleate boiling). Kutateladze (Ref. 160) and, later, Forster and Greif (Ref. 57) suggested correlations based on the pure convection heat flux at the incipience of boiling and the corresponding value of heat flux in pool boiling. Bergles and Rohsenow (Ref. 161), however, later showed that the transition region between pure convection and nucleate boiling cannot be based on results from saturated pool boiling, and recommended the following relation based on an extension of the fully developed nucleate boiling curve,

$$q''/q''_{\text{conv}} = [1 + \{(q''_{\text{B}}/q''_{\text{conv}})(1 - q''_{\text{Bi}}/q''_{\text{B}})\}^2]^{1/2} \quad (8)$$

where q''_{B} is calculated from a fully developed nucleate boiling correlation at various wall temperatures, and q''_{Bi} is determined from an extension of the fully developed nucleate boiling curve to the temperature corresponding to the boiling incipient point (see Fig. 37). In addition, Bergles and Rohsenow developed a relation for heat flux at subcooled boiling incipience by solving a bubble growth equation graphically to obtain

$$q''_{\text{LB}} = 15.60 p^{1.156} (T_w - T_{\text{sat}})^{2.3/p^{0.0234}} \quad (9)$$

4.4 FLOW BOILING: CORRELATIONAL APPROACHES

The team of McAdams, et al. (Ref. 24) was one of the earliest boiling research teams to propose an empirical correlation for fully developed nucleate boiling in subcooled forced flow. They found for flow in an annulus (heated stainless steel inner wall) that the heat flux during boiling was independent of coolant velocity (1 to 36 ft/sec), degree of inlet subcooling (20° to 150°F), pressure (30 to 90 psia), and equivalent diameter (0.17 to 0.48 in.). They correlated the heat flux data with the expression,

$$q'' = C' \Delta T_{\text{sat}}^{3.86} \quad (10)$$

where the value of C' decreased from 0.19 to 0.074 as the concentration of dissolved gas decreased from 0.30 to 0.06 ml of air at standard conditions per liter of water. Jens and Lottes (Ref. 88) analyzed high-pressure, high heat flux, flow boiling data obtained by researchers at UCLA, Purdue, and MIT, and derived the following empirical correlation,

$$q'' = (0.527 e^{p/900} \Delta T_{\text{sat}})^4 \quad (11)$$

where p is in pounds per square foot. Jens and Lottes found that the wall temperature during boiling was independent of the flow velocity, gas content, and degree of subcooling and was dependent only on heat flux and water pressure. All of the data were obtained for flow inside round or square tubes made of stainless steel or nickel.

Gilmour (Ref. 162) derived a correlation based on dimensionless groups rather than temperature difference:

$$(h/c_f G) (c_f \mu_f/k_f)^{0.6} (q_f \sigma/p^2)^{0.425} = 0.001/(DG/\mu_f)^{0.3} \quad (12)$$

where

$$G = (m_v/A) (q_f/q_v)$$

and where p is in pounds per square foot. Although Gilmour substantiated the correlation with data from various experiments, including several in which water was used, it was noted that surface material had a significant effect that was not accounted for in the correlation and that data from experiments involving boiling from wires did not agree well with the correlation.

Later, Levy (Ref. 163) derived a semiempirical correlation based on the Forster and Zuber (Ref. 164) bubble growth model and applicable to nucleate boiling with flow as well as pool boiling, arguing that the fluid velocity normally used exerts a minor effect in comparison with the local turbulence produced by the bubble motions. For subcooled liquids, Levy proposed the correlation,

$$q'' = [k_f c_f q_f^2 / \sigma T_s (q_f - q_v)] [1/B_L] [\{i_{fg} + c_f (T_s - T_b)\} / i_{fg}] (\Delta T_{\text{sat}})^3 \quad (13)$$

where T_s and T_b are in $^{\circ}\text{R}$, σ in Btu/ft^2 , and B_L is an empirical constant which is a function of $q_v i_{fg}$ as shown in Fig. 38. Levy found that the above correlation agreed reasonably well with data from McAdams, et al., and the UCLA data used by Jens and Lottes discussed previously.

About the same time Levy derived his correlation, Forster and Greif (Ref. 57) theorized that the primary boiling heat-transfer mechanism is the exchange between the vapor and liquid, and that microconvection in the liquid sublayer beneath the bubbles, bubbles acting as artificial roughness, and latent heat transport by the bubbles contribute very little. Based on this argument, they used a Reynold's analogy to derive the following expression for general boiling of various liquids including water:

$$q'' = K_{sf} [\alpha c_l q_l T_s / J i_{fg} \rho_v \sigma^{1/2}] [c_l T_s \alpha^{1/2} / J (i_{fg} \rho_v)^2]^{1/4} [\rho_l / \mu_l]^{5/8} [\mu_l c_l / k_l]^{1/3} \Delta p^2 \quad (14)$$

where Δp is the pressure difference in pounds per square foot corresponding to the superheat, ΔT_{sat} . Reasonable agreement was achieved when the correlation was compared to experimental data at pressures up to 50 atm with K_{sf} equal to 0.0012. In the discussion in Ref. 57, the authors noted that the constant does change for other data.

Shah (Ref. 165) presented a correlation for the generalized prediction of heat transfer during subcooled boiling in annuli based on earlier work involving tubes (Ref. 166). His correlation is

$$q'' = h_l (T_w - T_b) + h_l (\psi_o - 1) (T_w - T_{sat}) \quad (15)$$

where

$$\psi_o = 1 + 46 B_o^{0.5} \quad \text{for } B_o < 0.3 \times 10^{-4}$$

$$\psi_o = 230 B_o^{0.5} \quad \text{for } B_o > 0.3 \times 10^{-4}$$

$$B_o = q'' / G i_{fg}$$

h_l = nonboiling heat-transfer coefficient

Shah found that the expression correlated 450 representative data points with a mean deviation of 8.9 percent. The range of test conditions was: reduced pressure from 0.009 to 0.89, inlet subcooling from 2° to 109°C (3.6° to 196°F), mass flux from 278 to 7,774 kg/m² sec (57 to 1,592 lbm/ft² sec), inner tube diameter from 4.5 to 42.2 mm (0.177 to 1.66 in.), and annular gap from 1 to 6.6 mm (0.039 to 0.26 in.). Various fluids, including water, were evaluated and heating was from the inner, outer, or both walls of the annuli.

Probably the most widely accepted and verified flow boiling correlation is based on Rohsenow's (Ref. 167) pool boiling correlation (a Nusselt number derived from the fluid Prandtl number and a bubble Reynolds number) and proposed by Rohsenow (Ref. 168) in

1952. The heat-transfer rate associated with forced-convection boiling was found to be accurately predicted by addition (or superposition) of the pool boiling effect with the pure forced-convection effect discussed above, i.e.,

$$q'' = q''_{\text{forced convection}} + q''_{\text{pool boiling}} \quad (16)$$

where $q''_{\text{forced convection}}$ is determined from the expressions presented in the previous discussion of pure forced-convection correlations and $q''_{\text{pool boiling}}$ is determined from

$$c_\ell (T_w - T_{\text{sat}}) / i_{\text{fg}} \text{Pr}^s = C_{\text{sf}} [\{q'' / \mu i_{\text{fg}}\} \{g_c \sigma / g (\rho_\ell - \rho_v)\}^{1/2}]^r \quad (17)$$

where the properties are evaluated at T_{sat} (except as noted), r equals 0.33, s equals 1 for water cooling and 1.7 for other fluids, and C_{sf} equals 0.006 for nickel and brass surfaces and 0.013 for copper and platinum surfaces.* Vachon, et al. (Ref. 169) later presented new values of r and C_{sf} which account for surface preparation technique as well as liquid-surface combination. However, their analysis applies only to the linear portion of the nucleate boiling curve, i.e., that portion which excludes partial nucleate boiling and approaching CHF. In addition, the effects of subcooling and pressure have not been fully investigated and may affect the constants presented by Vachon's team. Tong (Ref. 10) pointed out that the superposition approach may be questionable in light of the experiments of Bergles and Rohsenow (Ref. 161) which demonstrated the differences in the fluid mechanics of flow boiling and pool boiling. Bergles and Rohsenow recommended a less restrictive construction approach for predicting forced-convection boiling when the net vapor generation is relatively small, which was presented previously in Eq. (8). Bjorge, et al. (Ref. 170) and Stephan and Auracher (Ref. 171) later presented variations of the superposition approach. For additional approaches, Guglielmini, et al. (Ref. 172) provided a survey of flow boiling correlations as of 1980, including boiling incipience and partial nucleate boiling expressions.

Large vapor void fractions have been observed in low-pressure, subcooled flow, possibly greater than 20 percent on a time-averaged basis and exceeding 50 percent on a local instantaneous basis (Ref. 20). Such void fractions contribute to the accelerative and static head components of the pressure gradient along the heated channel. Flow boiling experiments where pressure drop characteristics were evaluated (e.g., Refs. 22 and 173) generally have shown that as heat flux increases, the pressure drop decreases until boiling begins, after which the pressure drop increases (Fig. 39). Boyd (Ref. 174), however, found pressure drops for high-pressure, moderately subcooled water boiling to be slightly less than single-phase pressure drops. Boyd noted that CHF occurred before substantial pressure drops occurred. Bergles

* The Rohsenow correlation is valid only for clean, relatively smooth surfaces. Rohsenow (Ref. 167) found that s varied erratically between 0.8 and 2.0 when the surface was dirty.

and Dormer (Ref. 173), who performed experiments in subcooled water flow boiling at pressure below 100 psia, noted that little success had been reported in the general correlation of pressure drop, and presented graphical correlations for the pressure drops encountered in their experiments. About the same time, Staub and Walmet (Ref. 175) identified the two regions before and after the point of significant vapor generation (SNVG) where the effects of void fraction on pressure drop are different in subcooled flow boiling. Recently, Hoffman and Kline (Ref. 176) and Lu and Jia (Ref. 177) have presented correlations for the prediction of void fraction and the subsequent gravity, acceleration, and friction pressure drop before and after SNVG.

4.5 CHF CORRELATIONAL APPROACHES

No theory of subcooled burnout has yet been created for flow boiling (Ref. 33). Complexity of the boiling mechanisms at the critical point, their unsteady nature, and the small scale of the heat-transfer processes have hindered the development of theoretical models and understanding of the phenomena from experimental studies. Moreover, the cooling flow structure and, hence, the heat-transfer processes vary depending on the heating condition, fluid properties, and flow/surface geometries as indicated in the previous discussion of parametric effects. This has led to an excessive number of correlations derived for the prediction of CHF in flow boiling. Most of the CHF correlations, not unlike those for fully developed nucleate boiling, were developed either by the analytical (mechanism-based) approach, dimensional analysis/similitude-based approach, or optimization of test data (empirical-based).

4.5.1 Mechanism-Based CHF Correlations

In an attempt to derive analytical relationships among the macroscopic heat-transfer and flow-field characteristics in a boiling environment, several models describing the mechanisms on a microscopic scale have been proposed. The mechanisms appear to vary with the degree of subcooling, and several current approaches divide the subcooled boiling regions into three areas: (1) high subcooling and mass velocity, (2) moderate subcooling, and (3) low subcooling, velocity, and pressure (Ref. 8). At high subcooling and mass velocity, it has been proposed that local wall overheat occurs when high heat flux leads to dryout and a resulting hot spot beneath a bubble; however, there is little experimental support, and no correlations have been developed based on this mechanism (Ref. 8). At moderate subcoolings, it has been proposed that the liquid flow stagnates near the heated wall when the boundary layer separates. At high heat flux, the stagnant liquid evaporates, resulting in vapor blanketing near the wall and subsequent burnout. Tong (Ref. 178) presented a correlation based on this mechanism which agreed reasonably well with data from subcooled, high-pressure water flow in tubes, annuli, and rod bundles. Purcupile and Gouse (Ref. 179) presented a similarly based correlation in nondimensional form. Other studies associated with this proposed mechanism include the

work of Kutateladze and Leont'ev (Ref. 180) and Hancox and Nicoll (Ref. 181). At low subcooling, velocity, and pressure, Fiori and Bergles (Ref. 20) suggested that dry-out of the microlayer follows when inadequate quenching of the surface by adjacent liquid occurs after the passage of a bubble. Subsequent burnout occurs when high surface temperatures prevent rewetting of the surface. Because of difficulties in defining the flow structure, no correlation could be obtained by the authors. Lee and Mudawwar (Refs. 182 and 183) proposed a similar mechanism by suggesting that CHF occurs as a result of the Helmholtz instability at the microlayer-vapor interface, leading to dry-out of the microlayer. They demonstrated that their correlation agreed with numerous subcooled (over a wide range of inlet subcoolings) water data points with a mean deviation of approximately 11 percent. Katto (Refs. 184 and 185) presented a correlation based on this same sublayer dry-out mechanism and suggested that CHF of subcooled flow boiling has strong similarities to pool boiling CHF. Earlier, Katto first presented generalized correlations for CHF in subcooled and saturated water flow in tubes (Refs. 186 and 187) and annuli (Ref. 188) based on the existence of four characteristic regimes of CHF and the following dimensionless groups:

$$q''_{CHF} / \{Gi_{fg} [1 + K (\Delta i_i / i_{fg})]\} = f (q_v / q_l, \sigma q_l / G^2 L, L/D) \quad (18)$$

where K is determined analytically to account for inlet subcooling. A reasonable correspondence between the correlations and experimental data was found; however, later studies (e.g., Ref. 189) identified problems with applying the correlations to the various regimes. In addition, difficulty was encountered in deriving an expression for CHF at very high mass velocity and pressure conditions. Nishikawa, et al. (Ref. 190) later correlated high-pressure tube data at various Freon mass flows with Katto's proposed dimensionless groups using the boiling length as the characteristic length. Their proposed expressions correlated approximately 150 data points to within ± 10 percent.

Other proposed mechanisms of general subcooled flow-boiling CHF include liquid flow blockage models and vapor removal limit/bubble crowding models (Ref. 184). The liquid flow blockage models assume that the flow of liquid normal to the heated surface is blocked by the flow of vapor along the surface. The mechanisms proposed by Bergel'son (Ref. 191) and Smogalev (Ref. 192) involve some form of liquid flow blockage. Griffith (Ref. 193) presented a dimensionless correlation based on a critical packing of bubbles on the surface. Griffith proposed that a saturated pool boiling bubble growth term be multiplied by a correction factor which included velocity and subcooling effects. Approximately 94 percent of his data were correlated by the expression to within ± 33 percent. Hughes (Ref. 21) suggested that CHF occurred when a maximum number of nucleation sites available for a surface was exceeded (i.e., bubble crowding). For Freon flow over a straight surface, he proposed the correlation:

$$q''_{CHF} = [2d_s \bar{\rho}_v (c_p \Delta T_{sub} + 2i_{fg})] / 3K \{4/9\pi\alpha (\rho_v \Delta T_{bulk} d_s / \rho_l \Delta T_{sat})^2 + \pi\alpha/3 (\rho_v i_{fg} d_s / k_l \Delta T_{sat})^2 + (1/B) \ln [(U_o + B d_s) / U_o]\} \quad (19)$$

where

$$d_s = 6.12 W D_h / Re^{7/8} \quad (W = 30 \text{ in Ref. 21})$$

$$B = (12/11) (C_D \mu_l / \rho_l d^2)$$

$$U_o = (3/4\pi\alpha) (k_l^2 \Delta T_{sat}^2 / \rho_v^2 i_{fg}^2 d)$$

and q''_{CHF} is in Btu/in.² sec, ρ is in lbm/in.³, k is in Btu/in. sec °F, μ is in lbm/in. sec, D_h and d are in in., and α is in in.²/sec. The term K was determined experimentally as

$$K = \beta_{fs} V_m^{1/2} / \Delta T_{sub} \quad (\beta_{fs} \text{ is approximately equal to } 7.94)$$

Although not given by Hughes, the drag coefficient for a bubble is approximated by

$$C_{D_{sphere}} \approx \frac{24}{Re} + \frac{6}{1 + \sqrt{Re}} + 0.4 \quad (\text{see Ref. 148, Chap. 3})$$

and, for a straight test section, the bubble diameter for the preceding equations is approximated by

$$d = d_s$$

Hughes also presented somewhat cumbersome algebraic expressions for CHF on convex and concave surfaces (see Ref. 21). Hebel, et al. (Ref. 194) similarly suggested that CHF occurs when a limiting vapor removal rate is reached. Other proposed mechanisms included in this group are those suggested by Yagov and Puzin (Ref. 195) and later, Weisman and Ileslamlou (Ref. 196). Weisman and Ileslamlou (see also Yang and Weisman, Ref. 197), by extending the earlier work reported in Ref. 198 based on limited turbulent interchange at the outer edge of a bubbly layer near a heated surface, proposed the following CHF correlation for use in highly subcooled flow:

$$q''_{CHF} = G\psi i_b [i_l (1 - x_2) + i_v (x_2) - \bar{i}] \quad (20)$$

where

$$\psi = [1/(2)^{1/2}\pi] \exp [- 1/2 (v_{11}/\sigma'_v)^2] - 1/2 (v_{11}/\sigma'_v) \operatorname{erfc} (v_{11} / (2)^{1/2} \sigma'_v)$$

$$i_b = 0.462 (K)^{0.6} (\operatorname{Re})^{-0.1} (D_b/D)^{0.6} [1 + a (\rho_\ell - \rho_v) / \rho_v]$$

\bar{i} is the average fluid enthalpy

x_2 is the average quality in the boundary layer corresponding to a void fraction of 0.82

$K = 2.4$ (experimentally determined)

$$D_b = [0.015 (\sigma D_h / \tau_w)^{1/2}] \{1 + 0.1 (g/g_c) [(\rho_\ell - \rho_v) / \tau_w] D_h\}^{-1/2}$$

~~~~~  
buoyancy correction term  $\approx 1$  for high mass velocity

$$v_{11} = q'' i_{fg} (x_2) / [\{i_\ell (1 - x_2) + i_v (x_2) - \bar{i}\} (\rho_v i_{fg})]$$

$$\sigma'_v = (G/\rho_\ell) i_b$$

$$a = 0.87 (1.36 - V_{SL}) + 0.135 \quad 0.5 < V_{SL} < 1.36 \text{ m/sec}$$

$$a = 0.135 \quad G < 9.7 \times 10^6 \text{ kg/m}^2 \text{ hr}, V_{SL} \geq 1.36 \text{ m/sec}$$

$$a = 0.135 (G/9.7 \times 10^6)^{-0.3} \quad G > 9.7 \times 10^6 \text{ kg/m}^2 \text{ hr}$$

where  $V_{SL}$  is the superficial velocity of two-phase mixture in m/sec. The correlation requires iteration on  $q''_{CHF}$  since  $v_{11}$  is dependent on  $q''$ . Andreyev, et al. (Ref. 199) suggested that CHF that occurs in the transition from bubbly to dispersed-annular flow can be based on a transition void fraction and recommended an equation for this specific void fraction that agreed reasonably well with experimental data for subcooled water flow boiling. Povarnin (Ref. 200) assumed a concept of corresponding states and derived a correlation that agreed reasonably well with subcooled CHF data for various fluids including water. No further work has been performed in recent years to substantiate Povarnin's approach. Bergles (Ref. 8) identified several other proposed mechanism-based correlations for subcooled flow boiling

CHF. Specifically, Chang (Ref. 37) developed a correlation for CHF based on the idea that large bubbles are broken up in a hydrodynamic limit, thereby reducing the heat-transfer coefficient. Thorgerson, et al., (Ref. 201) proposed a correlation which allowed a burnout condition as a result of a critical friction factor. His correlation falls somewhat in the class of expressions based on boundary-layer separation. Both of these correlations have met with little success in experimental verification or general acceptance.

Probably the most widely verified mechanism-based correlation uses the superposition approach originally proposed by Rohsenow for fully developed nucleate flow boiling and extended to CHF prediction by Gambill (Ref. 202):

$$q''_{CHF} = [q''_{CHF}]_{\text{pool boiling}} + [q''_{CHF}]_{\text{forced convection}} \quad (21)$$

where

$$[q''_{CHF}]_{\text{pool boiling}} = K i_{fg} \rho_v [\sigma g_c g (\rho_l - \rho_v) / \rho_v^2]^{1/4} [1 + (\rho_l / \rho_v)^{0.923} (c_p \Delta T_{\text{sub}} / 25 i_{fg})]$$

in which

$$K = 0.12 - 0.17, c_p \text{ is evaluated at } T = T_{\text{sat}} - (\Delta T_{\text{sub}}/2)$$

$$[q''_{CHF}]_{\text{forced convection}} = h_{\text{conv}} [(T_w)_{CHF} - T_b]$$

where  $(T_w)_{CHF}$  is evaluated with Bernath's (Ref. 203) generalized plot of wall superheat at burnout (Fig. 40). Gambill found that the correlation predicted burnout for a large number of experimental data points within a maximum deviation of 40 percent for various fluids and 17.8 percent for water. The data compared were for numerous fluids and flow configurations with a range of conditions of velocity: 0 to 174 ft/sec, pressure: 4 to 3,000 psia, subcooling (various locations): 0° to 506°F, acceleration: 1 to 57,000 g, CHF:  $0.1 \times 10^6$  to  $37.4 \times 10^6$  Btu/hr ft<sup>2</sup>. Levy (Ref. 204) presented a similar superposition correlation for CHF:

$$q''_{CHF} = q''_P + q''_C + q''_F \quad (22)$$

where

$$q''_P = 0.131 i_{fg} \rho_v [\sigma g_c^2 (\rho_l - \rho_v) / \rho_v^2]^{1/4}$$

$$q''_C = 0.696 (k_l \rho_l c_p)^{1/2} [(\rho_l - \rho_v) / \sigma]^{1/4} [\sigma g_c^2 (\rho_l - \rho_v) / \rho_v^2]^{1/8} \Delta T_{\text{sub}}$$

and

$$q''_F = h_\ell (\Delta T_{\text{sat}}) + h_\ell \Delta T_{\text{sub}}$$

where  $h_\ell$  is determined from a pure forced-convection Nusselt number,

$$h_\ell = \text{Nu } k_\ell / D$$

and  $(\Delta T_{\text{sat}})$  is determined by trial and error from a fully developed nucleate boiling relation such as Jens and Lottes [Eq. (11)] at  $q''_{\text{CHF}}$ .

The list of mechanism-based CHF correlations is by no means limited to those presented here. Those for which the equations are presented appear to be generally applicable to highly subcooled, water flow boiling which will be encountered in the cooling of high-enthalpy arc facility components. A statement made by Bergles in Ref. 8, which is applicable here, is that there are enough "adjustable" constants in any predictive equation to permit an acceptable correlation of data.

#### 4.5.2 Dimensional Analysis/Similitude-Based CHF Correlations

Although dimensional analyses have been performed by Barnett (Ref. 205), Zenkevich (Ref. 206), and Kampfenkel (Ref. 207), Glushchenko (Ref. 86) used partial modeling to obtain a correlation for highly subcooled (greater than 25°C) water flow in tubes and annuli based on the following dimensionless groups:

$$K_1 = q''_{\text{CHF}} / i_{\text{fg}} \rho_v V_{\text{avg}}$$

$$K_2 = c_p \Delta T_{\text{sub}} \rho_\ell / i_{\text{fg}} \rho_v$$

$$K_3 = k_\ell / V_{\text{avg}} D_e c_p \rho_\ell$$

$$K_4 = i_{\text{fg}} / c_p \Delta T_{\text{sat}}$$

Glushchenko proposed the correlation

$$K_1 = 18.25 K_2^{0.35} K_3^{0.5} K_4^{1.2} \quad (23)$$

which agreed reasonably well with experimental data (80 percent of nearly 200 selected data points correlated within 25 percent). The data covered the ranges: mass velocity from 500 to 40,000 kg/m<sup>2</sup> sec (100 to 8,200 lbf/ft<sup>2</sup> sec), pressure from 4.9 × 10<sup>5</sup> to 197 × 10<sup>5</sup> N/m<sup>2</sup>

(72 to 2,900 psia), subcooling (location not discussed) from 25° to 250°C (45° to 450°F), diameter from 2 to 12 mm (0.08 to 0.5 in.), and L/D from 10-20 to 60-120. Ornatskii, et al. (Ref. 208), later extended the approach to low subcooling and moderate quality water flow.

Probably the most successful approach to similitude analysis of the CHF phenomena was performed by Ahmad (Ref. 70). The primary impetus for such analyses was the need for fluid-to-fluid modeling capability. Refrigerants such as Freon have been used in previous experiments (Refs. 66-69) to simulate water cooling at high heat flux conditions, since the CHF for Freon can be achieved at much lower heat flux. Scaling methods were necessary to provide a means of relating the Freon test results to water for high heat flux/water cooling predictions. Ahmad used classical dimensional analysis to identify 12 independent groups, of which 6 were eliminated through inductive arguments. Of the remaining six terms, 3 terms (subcooling number  $\Delta i/i_{fg}$ , liquid/vapor density ratio  $\rho_l/\rho_v$ , and L/D) can be independently satisfied in a controlled experiment (controlled inlet temperature, pressure, and geometry). The remaining 3 terms (Reynolds number, Weber-Reynolds number, and liquid/vapor viscosity ratio) are distorted through the liquid and vapor viscosities when the above conditions are fixed. Ahmad solved this problem of multiple distortion by expressing the remaining 3 terms as a CHF modeling parameter  $\psi_{CHF}$ , and using a compensated distortion model to relate the terms through two empirical exponents. The final form of the modeling parameter is written as

$$\psi_{CHF} = [(GD/\mu_l) (\mu_l^2 / \sigma D \rho_l)^{2/3} (\mu_v/\mu_l)^{1/5}] \quad (24)$$

From the Buckingham Pi theorem the dependent parameter, boiling number ( $q''_{CHF}/Gi_{fg}$ ), is written as follows:

$$q''_{CHF}/Gi_{fg} = f(\psi_{CHF}, \Delta i/i_{fg}, \rho_l/\rho_v, L/D) \quad (25)$$

In addition to the independent parameters identified above, Ahmad included the ratio of the heated equivalent diameter ( $4 \times$  flow area/heated perimeter) to the hydraulic diameter ( $4 \times$  flow area/wetted perimeter),  $D_{he}/D$ , for more complex geometries. Ahmad demonstrated reasonable scaling of subcooled Freon CHF data from Coffield, et al. (Ref. 209) to water CHF using the above approach. Analysis of complex geometries by this method is limited by the modeling parameter in which the empirical exponents are highly sensitive to geometric parameters. Use of the correlation for situations other than extrapolation of refrigerant CHF data to water CHF has been very limited (see, for example, Katto, Ref. 210).



### 4.5.3 Empirical-Based CHF Correlations

Probably the most common approach to obtaining a CHF correlation is the curvefitting of experimental test data, although some confusion exists as to whether or not a correlation is considered empirical when some or all of the parameters used in the correlation are obtained from dimensional analysis or limited boiling mechanism analyses. Because most correlations rely on some form of empiricism, this is probably a moot point, and some overlap of the mechanism-based, dimensional analysis/similitude-based, and empirical-based approaches exists. A word of caution about the use of empirical-based correlations: the expressions typically have been derived for a specific range of experimental conditions, and extrapolation of a correlation outside the specific range can lead to very large errors.

The earliest empirical CHF correlations appeared in the late 1940's into the early 1950's, most notably those of McAdams, et al. (Ref. 24), Jens and Lottes (Ref. 88), Gunther (Ref. 27), Buchberg, et al. (Ref. 100), and McGill and Sibbitt (Ref. 211). The correlations proposed by McAdams' team and Gunther are limited to low pressure and only McGill and Sibbitt evaluated subcoolings greater than 250°F. All of the correlations are limited to low coolant velocity (less than 40 ft/sec or a mass velocity less than 2,500 lbm/ft sec). Only the Jens and Lottes correlation included a pressure effect, and none included geometry effects. The test configurations were typically tubes except those used by McAdams' team (annulus) and Gunther (metal strip in a rectangular channel).

Weatherhead (Ref. 43) later modified the Jens and Lottes correlation to include the effects of geometry and latent heat of vaporization. Weatherhead subdivided subcooled flow boiling into four classifications and accounted for variations in boiling characteristics at low and high pressure, low and high mass velocity, small and large geometries, and low and high inlet subcooling. The correlation at high subcooling, however, could only be validated at low L/D, and Tong (Ref. 10) later found that Weatherhead's correlation did not improve the accuracy of prediction when other data were evaluated.

A number of empirical correlations appeared in the late 1950's into the mid- 1960's, many of which are summarized in Ref. 10 (see also Refs. 212 and 213). Most notable are correlations derived by Bernath (Ref. 203), Janssen, et al. (Refs. 214 and 215), Labuntsov (Ref. 216), Van Huff and Rousar (Ref. 29), and the United Kingdom Atomic Energy Establishment at Winfrith, AEEW (Refs. 83, 91, 217, and 218). Bernath developed an empirical correlation based on the premise that at CHF the two-phase flow near the heated surface is highly turbulent and, therefore, well mixed. Assuming the convective heat transfer through this mixture, Bernath empirically formulated expressions for the wall superheat and the heat-transfer coefficient at the critical point (Ref. 219). He later (Ref. 203) refined the correlation for an extended range of geometric variables, and for water is given as

$$q''_{CHF} = h_{CHF} (T_{w,CHF} - T_b) \quad (26)$$

where

$$T_{w,CHF} = 57 \ln p - 54 [p/(p + 15)] - V/4$$

$$h_{CHF} = 19,602 [D_e/(D_e + D_i)] + (\text{slope}) V$$

$$\text{slope} = 86.4/D_e^{0.6} \quad \text{for } D_e < 0.1 \text{ ft}$$

$$\text{slope} = 162 + (18/D_e) \quad \text{for } D_e \geq 0.1 \text{ ft}$$

where  $h_{CHF}^*$  is in Btu/ft<sup>2</sup>hr°C,  $T_{w,CHF}$  and  $T_b$  are in degrees Centigrade, and  $D_i$  is the heated perimeter (inner diameter) in feet divided by pi. Bernath found that the correlation predicted the CHF for nearly 250 forced water flow experiment data points within 16 percent. The range of parameters for the correlation is: pressure from 23 to 3,000 psia, velocity from 4 to 54 ft/sec, subcooling (various locations) from 0° to 615°F, and hydraulic diameter from 0.143 to 0.66 in. Multiple configurations including tubes, annuli, ducts, and ribbons were used in the experiments.

Janssen and others (Refs. 214 and 215) developed rather cumbersome design correlations (presented in Ref. 10) for CHF in subcooled and saturated water flow in tubes and annuli (inner wall heated). Their correlations are valid over the parameter ranges: pressure from 600 to 1,450 psia, mass velocity from 0.2 to 6.2 lbm/ft<sup>2</sup> hr, and hydraulic diameters from 0.25 to 1.25 in. Labuntsov (Ref. 216) assumed (in the first approximation) that the CHF is dependent on pressure, velocity, and subcooling, and developed a CHF correlation for water flow at pressures up to 200 atm. Van Huff and Rousar (Ref. 29) compiled CHF data on 23 different fluids, including water, during the study of heat flux limits of storable propellants. They correlated the higher  $V\Delta T_{sub}$  water data as shown in Fig. 7 with the expression

$$q''_{CHF} = 5.1 + 0.000860 V\Delta T_{sub} \quad (27)$$

where  $q''_{CHF}$  is in Btu/in.<sup>2</sup>sec. Considerable scatter was noted at low  $V\Delta T_{sub}$  (less than 10,000 ft °F/sec), and a significant pressure effect was observed for data obtained in swirl

---

\* Bernath's original work computed  $h_{CHF}$  in units of P.c.u./hr ft<sup>2</sup>°C, where P.c.u. is a pound-centigrade heat unit. His equations presented here have been converted to Btu rather than P.c.u.

flow. The correlation is valid over the range of parameters: pressure from 10 to 2,000 psia, velocity from 7.5 to 205 ft/sec, and bulk fluid temperature (various locations) from 76° to 470°F.

Lee and Obertelli (Ref. 83) at AEEW in the UK satisfactorily correlated early AEEW subcooled flow boiling CHF data obtained at 1,000 psia using a modified version of an widely used correlation derived by DeBortoli, et al. (Ref. 220) for higher pressure. Lee and Obertelli also found that a more general correlation (based on a local conditions hypothesis) under consideration by AEEW colleagues at about the same period of time (see Barnett, Ref. 221) provided excellent accuracy in the prediction of over 600 CHF data points obtained at AEEW over a range of pressure from 560 to 1,600 psia. Macbeth (Ref. 217) and, later, Thompson and Macbeth (Ref. 218) correlated nearly 4,400 CHF data points (with a root-mean-square error of 7.5 percent) obtained for water flow boiling in round tubes with expressions based on Barnett's local condition hypothesis. The hypothesis assumes that the CHF is only a function of the mass quality at the point of overheating. Macbeth showed that a nearly linear relationship exists at low mass velocity; therefore, he divided the boiling map into a low-velocity regime and a high-velocity regime. Figure 41 presents the boundary limits of the two regimes as identified by Macbeth. The CHF correlations for the two regimes as given by Thompson and Macbeth are

#### High-Velocity Regime

$$q''_{CHF} = \{[A' + 0.25D (G \times 10^{-6}) \Delta i_i] / (C' + L)\} \times 10^6 \quad (28)$$

where  $A'$  and  $C'$  are given in Fig. 42,

#### Low-Velocity Regime

$$q''_{CHF} = \{[(G \times 10^{-6}) (i_{fg} + \Delta i_i)] / [158 D^{0.1} (G \times 10^{-6})^{0.49} + 4L/D]\} \times 10^6 \quad (29)$$

The terms  $L$  and  $D$  are expressed in inches. Barnett (Ref. 91) later modified the basic form of these equations to obtain a correlation more applicable to annulus data

$$q''_{CHF} = [(A + B\Delta i_i) / (C + L)] \times 10^6 \quad (30)$$

where

$$A = 67.45 D_{HE}^{0.68} (G \times 10^{-6})^{0.192} \{1 - 0.744 \exp [-6.512 D_{HY} (G \times 10^{-6})]\}$$

$$B = 0.2587 D_{HE}^{1.261} (G \times 10^{-6})^{0.817}$$

$$C = 185.0 D_{HY}^{1.415} (G \times 10^{-6})^{0.212}$$

$$D_{HE} = (D_O^2 - D_I^2)/D_I$$

$$D_{HY} = D_O - D_I$$

The terms  $L$ ,  $D_O$ , and  $D_I$  are expressed in inches. With the correlation above, Barnett correlated 724 annulus CHF data points with a root-mean-square error of 5.9 percent. Limits of the correlation are  $D_I$  from 0.375 to 3.798 in.,  $D_O$  from 0.551 to 4.006 in.,  $L$  from 24 to 108 in.,  $G \times 10^{-6}$  from 0.14 to 6.2 lbm/hr ft<sup>2</sup>, and  $\Delta i_i$  from 0 to 412 Btu/lbm.

A number of empirical CHF correlations developed for subcooled flow boiling have appeared since the 1960's. Tolubinsky, et al. (Ref. 139), at the Institute of Engineering Thermophysics, USSR, proposed a design equation for determining CHF in annular channels with the inner wall heated, noting that because the CHF is affected by the heated surface shape and dimensions, the CHF data obtained from tube flow cannot be applied to annular flow. Their expression correlated more than 90 percent of approximately 400 experimental data points to within  $\pm 25$  percent. The correlation, however, requires knowledge of the CHF during pool boiling conditions for the annular configuration of interest, which may hinder its usefulness. More recent work performed in the USSR regarding CHF in flow boiling correlations includes the studies by Levitan and others (Refs. 222 and 223) and the Scientific Council of the Academy of Sciences of the USSR (Ref. 224). Levitan and his team proposed the following correlation for subcooled and low-quality water flow in tubes:

$$q''_{CHF} = [10.3 - 7.8 (p/98) + 1.6 (p/98)^2] e^{-1.5x} (G/1,000)^{1.2\{0.25[(p/98) - 1] - x\}} \quad (31)$$

where  $q''_{CHF}$  is in MW/m<sup>2</sup>,  $p$  is in bars,  $G$  is in kg/m<sup>2</sup> sec, and  $x$  is the relative quality at CHF. The correlation is good for water flow in circular tubes with a diameter within the range of 4 to 16 mm (0.16 to 0.63 in.). Levitan and his team, along with several other researchers, later assisted the Scientific Council of the Academy of Sciences of the USSR (Ref. 224) in compiling tabular data for predicting CHF in uniformly heated, 8-mm (0.31-in.)-diam tubes. An approximation formula is provided for calculating CHF for tubes whose diameter is different than 8 mm:

$$q''_{CHF} = q''_{CHF,8} (8/D)^{0.5} \quad (32)$$

where  $q''_{CHF}$  and  $q''_{CHF,8}$  are in MW/m<sup>2</sup>,  $q''_{CHF,8}$  is the value of  $q''_{CHF}$  in the 8-mm-diam tube, and  $D$  is in millimeters. The tabular data are quoted to have a root-mean-square error of 10 percent. The tabular correlation is limited to the following range of conditions: pressure

from 29.5 to 196 bar (435 to 2,880 psia), mass velocity from 750 to 5,000 kg/m<sup>2</sup> sec (154 to 1,024 lbm/ft<sup>2</sup> sec), subcooling (location not discussed) from 0° to 75°C (0° to 135°F), diameter from 4 to 16 mm (0.16 to 0.63 in.), and length-to-diameter ratio of 20 or greater. Doroschuk, et al. (Ref. 222) modified Eq. (31) to include a variable critical pressure such that the correlation could be used for other fluids.

Bowring (Ref. 225) built upon the work of Thompson and Macbeth (Ref. 218) and developed a CHF correlation using four basic variables as functions of pressure. He showed that the correlation predicted approximately 3,800 data points with a root-mean-square error of 6.96 percent. At about the same time, Becker, et al. (Ref. 226) proposed a CHF correlation for round tubes (their data were for primarily 10-mm-diam tubes). Their correlation is given as

$$q''_{CHF} = [G(450 + \Delta i_i)/(40L/D + 156G^{0.45})] [1.02 - (p_r - 0.54)^2] \quad (33)$$

where  $q''_{CHF}$  is in W/cm<sup>2</sup>, D and L are expressed in meters,  $\Delta i_i$  in kJ/kg, G in kg/m<sup>2</sup> sec, and  $p_r$  in bars. The expression correlated over 500 data points to a root-mean-square error of 5.7 percent, and is good for the following range of conditions: pressure from 120 to 200 bar (1,765 to 2,940 psia), mass velocity from G(p), as given in Fig. 43, to 7,000 kg/m<sup>2</sup> sec (up to 1,435 lbm/ft<sup>2</sup> sec), inlet subcooling from 8° to 272°C (14° to 490°F), heated length from 2,000 to 5,000 mm (79 to 197 in.), and steam quality from -0.3 to 0.6, where negative quality represents a subcooled liquid.

Knoebel, et al. (Ref. 227) developed a CHF correlation for subcooled water flow based on previous work performed at the Savannah River Laboratory:

$$q''_{CHF} = K (1 + 0.0515V) (1 + 0.069\Delta T_{sub}) \quad (34)$$

where K equals 153,600 for stainless steel heaters. The correlation is limited to low-pressure water flow (less than 45 psia) and higher subcooling (greater than 45°F). Green and Lawther (Ref. 228) developed a CHF correlation for high-pressure water as well as Freon,

$$q''_{CHF} = Re_v^n (\rho_l/\rho_v)^m Pr_v^w \sigma_N^p f(L_{sat}/D) (1 + \delta) (1 - \delta) \quad (35)$$

where

$$n = 1 - \exp[-0.0067 (L_{sat}/D)]$$

$$m = 0.1 + \exp(-0.007 (L_{sat}/D))$$

$$p = -0.5 \{0.15 + \exp [-0.007 (L_{\text{sat}}/D)]\}$$

$$w = -\{0.21 + 0.55 \exp [-0.007 (L_{\text{sat}}/D)]\}$$

$$f (L_{\text{sat}}/D) = 9 \times 10^{-5} \exp \{-0.00055 (L_{\text{sat}}/D) + 3.83 \exp [-0.00396 (L_{\text{sat}}/D)]\}$$

$$\delta = \exp \{-[0.14 \times 10^8 \sigma_N + 0.02 (L/D) \text{Pr}_v]\}$$

$$\sigma_N = \sigma / (D \Delta i_v \rho_v)$$

$$\delta_\ell = 0.75 \exp \{-B(L/D) (V_m \sigma / \rho \mu_\ell \Delta i_v)\}$$

$$B = 130.5 \exp \{5.0 \exp (-0.02 L/D)\}$$

The expression was quoted to have correlated over 4,250 data points with a root-mean-square error of less than 10 percent, although the correlation proposed by Thompson and Macbeth (Ref. 218) predicted the higher pressure data better. The correlation is limited to reduced pressure less than 0.7, mass fluxes greater than 200 kg/m<sup>2</sup> sec (41 lbm/ft<sup>2</sup> sec), and exit quality greater than 0.1.

Shah presented graphical correlations for CHF in subcooled and saturated flows in tubes (Ref. 229) and annuli (Ref. 230). The tube correlation in functional form is

$$\begin{aligned} \text{Bo} &= f_1(x_{\text{in}}, L/D) && \text{for } Y < 10^4 \\ \text{Bo} &= f_2(x_{\text{cr}}, Y, \text{Pr}) && \text{for } Y > 10^5 \end{aligned} \quad (36)$$

where

$$Y = (\text{GD}c_p/k_\ell) (G^2/\rho_\ell^2 D)^{0.4} (\mu_\ell/\mu_v)^{0.6}$$

The graphical expressions correlated 90 percent of 1,271 tube data points within  $\pm 30$  percent. The data include various fluids including water at reduced pressure from 0.0012 to 0.94, mass flux from 6 to 24,300 kg/m<sup>2</sup> sec (1.2 to 4,980 lbm/ft<sup>2</sup> sec), and inlet quality from -3.0 to positive values. The annulus correlation in functional form is

$$\text{Bo} = f_3(x_{\text{in}}, L/D_{\text{hp}}) \quad (37)$$

where

$$D_{hp} = 4 \times \text{Flow area/Heated perimeter}$$

The graphical expression correlated 88 percent of 825 annulus data points and one noncircular geometry data point within  $\pm 30$  percent. The data include various fluids including water at reduced pressure from 0.017 to 0.9, mass flux from 100 to 15,780 kg/m<sup>2</sup> sec (20 to 3,230 lbm/ft<sup>2</sup> sec), heated perimeter diameter from 5.3 to 96.3 mm (0.2 to 3.8 in.), gap width from 0.5 to 11.1 mm (0.02 to 0.44 in.), L/D<sub>hp</sub> from 3.7 to 335, and inlet quality from -3.1 to 0.0.

Finally, Vandervort, et al. (Ref. 80), recently presented an optimized CHF correlation for subcooled forced convection in tubes based on the five parameters of mass flux, subcooling, pressure, diameter, and length-to-diameter ratio. The correlation accounts for cross-coupling of the parameters, and is given as

$$\begin{aligned} q''_{CHF} = & 17.05 [(G')^{0.0732} + 0.2390(D')] \\ & \times [(T')^{0.3060(G')} + 0.001730(T') - 0.0353 (D')] \\ & \times [(P')^{-0.1289}] \\ & \times [1 + 0.01213(D')^{-2.946} + 0.7821(G') + 0.009299(T')] \\ & \times [1.540 - 1.280 (L/D)'] \end{aligned}$$

where

$$G' = 0.005 + G/10^5$$

$$T' = 5 + \Delta T_{sub}$$

$$P' = (0.0333 + p)/3.0$$

$$D' = D/0.003$$

$$(L/D)' = (L/D)/40.0$$

and  $q''_{CHF}$  is in W/m<sup>2</sup>, G is in kg/m<sup>2</sup>-sec,  $\Delta T_{sub}$  in degrees Centigrade, p is in MPa, and D is in meters. The expression correlated 85 percent of over 800 data points within  $\pm 25$  percent.

$$q''_{CHF,max} = (GD i_{fg}/4L) [1 + c_p (\Delta T_{sub})_i / i_{fg}] \quad (41)$$

Gambill and Lienhard (Ref. 231) presented an interesting semiempirical approach to determining a practical upper limit to CHF. From kinetic theory they derived an expression for  $q_{max,max}$ , the highest heat flux that can conceivably be achieved in a phase-transition process:

$$q''_{max,max} = \rho_g i_{fg} (RT/2\pi)^{1/2} \quad (42)$$

A practical upper limit to heat transfer by phase change was shown to be  $0.1q_{max,max}$ ; however, the method is limited to pressures less than about one-tenth of the critical pressure. As a point of interest, the highest CHF achieved for any configuration and test condition was nearly  $3.4 \times 10^8 \text{ W/m}^2$  (30,000 Btu/ft<sup>2</sup> sec) measured by Ornatskii and Vinyarskii (Ref. 232) with a nonuniformly-heated (circumferential), small-bore tube.

#### 4.6 COMPARISON OF FLOW BOILING AND CHF CORRELATIONS

Guglielmini, et al. (Ref. 172) presented an interesting comparison of flow boiling correlations including boiling incipience and partial nucleate boiling. Most of the boiling incipience correlations, when compared to representative data, had an accuracy within 30 percent. A quantitative comparison of the partial nucleate boiling expressions could not be performed because of lack of data. The correlations for fully developed nucleate boiling generally predicted representative data to within  $\pm 30$  percent, although in some cases the data scatter caused error in the prediction to be as large as 70 percent.

Gambill (Ref. 233) compared ten CHF correlations for water flow in a tube (diameter of 0.1 in. and length of 20 in.) at a pressure of 600 psia and subcooling of 100°F over a range of velocity from 10 to 80 ft/sec. Prediction of CHF at the higher velocity using the correlations varied by nearly a factor of four and by a factor of two at the lower velocity. Factors of two or greater between correlation predictions at higher mass velocity have also been noted by Zeigarnik, et al. (Ref. 96) and Boyd (Ref. 17), and the disagreement tends to worsen as mass velocity increases. It should be reiterated that empirical CHF correlations typically have been derived for a specific range of experimental conditions, and extrapolation of a correlation outside the specific range can lead to very large errors. In addition, a given analytical CHF correlation typically has enough "adjustable" constants in the predictive equations to permit an acceptable correlation of a specific data set; however, general application of the correlation to various configurations or test conditions may result in significant errors.



## 5.0 APPLICABLE EXPERIMENTAL APPROACHES AND MEASUREMENT TECHNIQUES FOR BOILING HEAT TRANSFER

A representative list of flow boiling experiments that have been performed within the last 50 years is presented in Appendix B, and a few comments are in order. The heating method of choice is electrical resistance heating (Joule heating). A fewer number of experiments made use of cartridge heaters, and very few incorporated some other means of heating. The test sections were primarily tubes, although a significant number of experiments had annular test sections. Of the more than 175 listed experiments where water was used, 46 had a maximum heat flux greater than  $1 \times 10^7 \text{ W/m}^2$  (1,000 Btu/ft<sup>2</sup> sec), and only 10 had a heat flux greater than  $5.5 \times 10^7 \text{ W/m}^2$  (5,000 Btu/ft<sup>2</sup> sec), with most of these performed at a pressure less than 35 bar (500 psia), subcooling less than 170°C (300°F), or mass velocity less than 30 Mg/m<sup>2</sup> sec (6,200 lbm/ft<sup>2</sup> sec). Clearly, data obtained at high heat flux, pressure, subcooling, and velocity are severely limited.

A number of measurement techniques used in these and other experiments are worth reviewing. One of the most important measurements in a boiling experiment is surface temperature. Placement of a discrete, intrusive temperature measuring device such as a thermocouple on the surface at the fluid interface may disrupt the flow field, causing large errors in the temperature measurement. For this reason, backside wall temperature is typically measured and used to estimate surface/fluid interface temperature through the use of an analytical temperature distribution. On an electrically heated surface, the temperature measurement with a thermocouple (which provides temperature from millivolt changes) is further complicated by voltage drop in the test specimen due to current flow. Hughes (Ref. 21) incorporated a single wire junction at the surface and the two-wire thermocouple junction formed 0.8 mm (1/32 in.) from the surface, thereby preventing any extraneous voltages due to voltage drop between the thermocouple leads. Numerous researchers have used thin sheets of mica or other electrical insulating material to isolate the thermocouple from the current-carrying surface. One of the most attractive approaches as suggested by Dutton and Lee (Ref. 234) involves the use of a three-wire thermocouple. The thermocouple circuit is "balanced" by applying and subsequently reversing the current and nullifying the voltage drop with a voltage-dividing potentiometer, the net effect being the same as welding all three wires to the location of the middle wire.

Burnout detectors have been used by a number of investigators (e.g., Refs. 21, 235, and 236) to protect the test sections from destruction as the CHF is approached. However, as pointed out previously, Hughes (Ref. 21) noted that the speed and intensity of the transition to film boiling (i.e., burnout) was observed to increase with increasing velocity and subcooling, and in some cases burnout has occurred instantaneously (Ref. 147). Therefore, the effectiveness of a burnout detector to protect the test section in highly subcooled, high-velocity, high-pressure flow is questionable.

Gunther (Ref. 27) was one of the earliest to perform a detailed photographic study of subcooled flow boiling at higher heat flux, although pressure was limited to below 11.3 bar (164 psia) and velocity limited to below 12 m/sec (40 ft/sec). His photographic system was capable of 20,000 frames/sec and gave a resolution of bubbles as small as 0.1 mm (0.004 in.) diameter. Fiori and Bergles (Ref. 20) used several photographic techniques, including high-speed photographs, movies, and video. They successfully identified cyclic variations in surface temperature from variations in the flow structure by simultaneously recording surface temperature and high-speed photographs of a specific surface location. Ram, et al. (Ref. 237), although studying bubble generation in pool boiling of water, analyzed intensity fluctuations registered by a photomultiplier tube to determine bubble size and growth cycle. Lineberger (Ref. 238) used a dual-frequency sound field to determine bubble size in pool boiling of water. Brown (Ref. 40) used reflected light from bubbles detected by a light-dependent resistor to identify the presence of first vapor when boiling begins.

Several approaches have been used to determine the vapor thickness or void fraction near the heated surface in local boiling. Costello (Ref. 239) measured the number of beta particles emitted from a vial containing radioactive strontium 90 to determine the vapor thickness in a low-velocity, water flow boiling apparatus with an annular test section. Rogers, et al. (Ref. 240) used a traversing gamma-ray densitometer (cobalt-57 source) to measure void fractions in water flow boiling in an annulus. Similar densitometers have been used by Buchberg, et al. (Ref. 100) and Edelman, et al. (Ref. 241) to measure the void fraction of subcooled water flow in tubes. Jiji and Clark (Ref. 242) used a specially developed traversing thermocouple probe to measure bubble boundary-layer thickness and temperature profiles in low-velocity, subcooled water flow. Later, Stefanovic, et al. (Ref. 243) used a similar probe to measure temperature fluctuations within a superheated boundary layer adjacent to a heated annular wall in forced water flow.

The measurement of acoustic noise due to boiling has permitted various researchers to study hydrodynamic instabilities in heated channels and to diagnose the different regimes of boiling. Pressure transducers have typically been incorporated in an experimental apparatus where flow oscillations are to be studied (e.g., Refs. 244 and 245), although Romberg and Harris (Ref. 246) used piezoelectric accelerometers to measure vibrations associated with parallel channel, density wave, and acoustic oscillations in a flow boiling loop. Several investigations have been performed to show that information on the boiling mode can be ascertained from boiling noise (Refs. 247-251). Hydrophones (i.e., transducers) with piezoceramic sensing elements have typically been used to measure the acoustic emissions from boiling.

A number of important considerations can be learned from the success or failure of previous experiments and associated analyses. Westwater (Ref. 11) pointed out that one basic

method of proving the correctness of instrumentation in these types of experiments which is widely overlooked is a simple energy balance of the system. Accuracy of the all-important wall temperature can be severely affected by overlooked items such as conduction effects or temperature-dependent material properties. Flow loop layout can affect the hydrodynamic stability of the system, which can seriously degrade the heat-transfer and CHF measurements. Gas content and cooling fluid impurities have been shown to have an effect on boiling heat transfer and CHF, yet in many experiments these have been ignored or have not been adequately quantified. As shown in Appendix B, many researchers fail to present basic test condition values such that their data may be used in other analyses. In many cases, the location in which the subcooling and pressure are measured or determined is not given. Finally, the geometric scale of a heater surface has been shown to be very important. Specifically, Bakhru and Lienhard (Ref. 252) demonstrated that the hydrodynamic processes that give rise to burnout cease to occur when the Laplace number\*,  $R'$ , is reduced below a value on the order of 0.1 (see also Refs. 33 and 253). Generalized correlations based on data acquired from a configuration with a Laplace number below this value may have very large errors when applied to scaled-up or different configurations.

## 6.0 SUMMARY

An extensive review of backside water cooling processes that are applicable to high-enthalpy facility components has been conducted. The processes can be identified on the basic boiling curve which, for the configurations of interest, includes the pure convection regime, the nucleate boiling regime, and the boiling crisis point where the CHF occurs. More than 20 parameters have been shown to affect various portions of the boiling curve, and optimum cooling (and greater CHF) occurs at high subcooling and high mass velocity. The primary parameters which affect steady-state boiling heat transfer are pressure, mass velocity, subcooling, heater diameter, and heater length (Ref. 7); however, other parameters have been experimentally shown to have significant effects. Several heat-transfer enhancement techniques have also been reported.

Because of the complexity, the unsteady nature, and the small scale of the flow boiling processes, no general theory has been developed. Reasonable confidence in correlating heat-transfer data in the pure convection and nucleate boiling regimes is shown. The more recent pure forced-convection correlations of Petukhov [Eq. (5)] for turbulent flow in a tube and Kays and Leung (Ref. 153) for turbulent flow in an annulus are probably the most useful for the nonboiling regime. Bergles and Rohsenow's partial nucleate boiling expression [Eq. (8)] best correlates the transition from pure convection to fully developed nucleate boiling,

---

\* The Laplace number is defined as  $R' = r[g(\rho_l - \rho_v)/\sigma]^{1/2}$ , where  $r$  is a characteristic radius dimension of the heater (see Ref. 252).

and the widely accepted Rohsenow relation [Eqs. (16) and (17)] ranks among the best correlations for fully developed nucleate boiling in forced flow. Considerable disagreement between the large number of analytical and empirical CHF correlations currently exists. Moreover, because the CHF correlations are sensitive to the range of conditions for the data used, no single correlation can be recommended. Those CHF correlations developed with data from high mass velocity, pressure, subcooling, and heat flux experiments using water as the coolant are more appropriate for use in the design of high-enthalpy arc heater components. Recommended correlations in this group include Bernath (Ref. 203), Van Huff and Rousar (Ref. 29), Yagov and Puzin (Ref. 195), Levy (Ref. 204), Labuntsov (Ref. 216), and Vandervort, et al. (Ref. 80). Additional correlation development will be required to account for factors such as acceleration or transient effects at these extreme conditions.

Very few data exist that were obtained at high heat flux, high subcooling, high mass velocity, and high pressure, which are optimum for cooling high-enthalpy facility components. Finally, numerous shortcomings of previous experiments have been identified, and care must be taken in any experimental program where boiling heat-transfer data are acquired for future analysis and correlation.

#### REFERENCES

1. Boyd, R. D. "Subcooled Flow Boiling Critical Heat Flux (CHF) and Its Application to Fusion Energy Components. Part I. A Review of Fundamentals of CHF and Related Data Base." *Fusion Technology*, Vol. 7, January 1985, pp. 7-30.
2. Nukiyama, S. "The Maximum and Minimum Values of Heat Q Transmitted from Metal Surface to Boiling Water Under Atmospheric Pressure. *Journal of JSME* (Japan), Vol. 37, 1934, pp. 367-374 (translated in *Int. J. Heat Mass Trans.*, Vol. 9, 1966, pp. 1419-1433, and also in J. N. Addoms, "Heat Transfer at High Rates to Water Boiling Outside Cylinders." DSc Thesis, MIT, 1948).
3. Lienhard, J. H. *A Heat Transfer Textbook*. Prentice-Hall, Englewood Cliffs, NJ, 1987 (Second Edition).
4. White, F. M. *Heat and Mass Transfer*. Addison-Wesley Publishing, Reading, MA, 1988.
5. Kays, W. M. and Crawford, M. E. *Convective Heat and Mass Transfer*. McGraw-Hill, New York, 1980 (Second Edition).

6. Witte, L. C. and Lienhard, J. H. "On the Existence of Two 'Transition' Boiling Curves." *International Journal of Heat Mass Transfer.*, Vol. 25, No. 6, 1982, pp. 771-779.
7. Collier, J. C. *Convective Boiling and Condensation*. McGraw-Hill, London, 1972.
8. Bergles, A. E. "Burnout in Boiling Heat Transfer. Part II: Subcooled and Low-Quality Forced-Convection Systems." *Nuclear Safety*, Vol. 18, No. 2, March-April 1977, pp. 154-167.
9. Bergles, A. E. "Future Directions of Research in Multi-Phase Flow and Heat Transfer." *Multiphase Transport—Fundamentals, Reactor Safety, Applications*, edited by T. N. Veziroglu, Vol. 1, 1980, pp. 3-18.
10. Tong, L. S. *Boiling Heat Transfer and Two-Phase Flow*. John Wiley and Sons, New York, 1966.
11. Westwater, J. W. "Boiling of Liquids." *Advances in Chemical Engineering*, Vol. I, 1956, pp. 1-76.
12. Westwater, J. W. "Boiling of Liquids." *Advances in Chemical Engineering*, Vol. II, 1958, pp. 1-31.
13. Rohsenow, W. M. "Boiling." *Annual Review of Fluid Mechanics—Vol. 3*, 1971, pp. 211-236.
14. Rohsenow, W. M. "Heat Transfer with Boiling—Chap. 8." *Developments in Heat Transfer*. W. M. Rohsenow, Editor, MIT Press, 1964.
15. Addoms, J. N. "Heat Transfer at High Rates to Water Boiling Outside Cylinders." DSc Thesis, MIT, 1948.
16. Katto, Y. "Critical Heat Flux in Boiling." *Proceedings of the 8th International Heat Transfer Conference*, Vol. 5, 1986, pp. 171-180.
17. Boyd, R. D. "Subcooled Flow Boiling Critical Heat Flux (CHF) and Its Application to Fusion Energy Components. Part II. A Review of Microconvective, Experimental, and Correlational Aspect." *Fusion Technology*, Vol. 7, January 1985, pp. 31-52.

18. Macbeth, R. V. "The Burn-out Phenomenon in Forced-Convection Boiling." *Advances in Chemical Engineering*, Vol. 7, 1968, pp. 207-293.
19. Hewitt, G. F. "Critical Heat Flux in Flow Boiling." *Proceedings of the 6th International Heat Transfer Conference*, Vol. 6, 1978, pp. 143-171.
20. Fiori, M. P. and Bergles, A. E. "Model of Critical Heat Flux in Subcooled Flow Boiling." MIT Report No. DSR-70281-56 (AD679119), September 1968.
21. Hughes, T. G. "Critical Heat Fluxes for Curved and Straight Surfaces During Subcooled Flow Boiling." PhD Thesis, Pennsylvania State University, TM-74-194 (AD-A-003036), June 1974.
22. Kreith, F. and Summerfield, M. "Pressure Drop and Convective Heat Transfer with Surface Boiling at High Heat Flux: Data for Aniline, N-butyl Alcohol, and Water." *Heat Transfer and Fluid Mechanics Institute*, May 1949, pp. 127-138.
23. Clark, J. A. and Rohsenow, W. M. "Local Boiling Heat Transfer to Water at Low Reynolds Numbers and High Pressures." *ASME Transactions*, Vol. 76, 1954, pp. 553-562.
24. McAdams, W. H., et al. "Heat Transfer at High Rates to Water with Surface Boiling." *Industrial and Engineering Chemistry*. Vol. 41, No. 9, September 1949, pp. 1945-1953.
25. Grace, T. M. "The Mechanism of Burnout in Initially Sub-Cooled Forced Convective Systems." PhD Thesis, University of Minnesota, December 1963.
26. Abdelmessih, A. H., Hooper, F. C., and Nangia, S. "Flow Effects on Bubble Growth and Collapse in Surface Boiling." *International Journal of Heat Mass Transfer*, Vol. 15, 1972, pp. 115-125.
27. Gunther, F. C. "Photographic Study of Surface-Boiling Heat Transfer to Water with Forced Convection." *Transactions of the ASME*, Vol. 73, February 1951, pp. 115-123.
28. Tippetts, F. E. "Critical Heat Fluxes and Flow Patterns in High-Pressure Boiling Water Flows." *Journal of Heat Transfer*, Vol. 86, February 1964, pp. 12-22 (also ASME Paper 62-WA-162).
29. Van Huff, N. E. and Rousar, D. C. "Ultimate Heat Flux Limits of Storable Propellants." 8th Liquid Propulsion Symposium, CPIA Report 121, Vol. II, 1966.

30. Kreith, F. *Principles of Heat Transfer*. International Textbook, Scranton, PA, 1962.
31. Green, S. J., Le Tourneau, B. W., and Troy, M. "Forced Circulation Uniform Flux Burnout Studies for High-Pressure Water." ASME Paper 59-HT-25, 1959.
32. Katto, Y. and Yokoya, S. "CHF of Forced Convection Boiling in Uniformly Heated Vertical Tubes: Experimental Study of HP-Regime by the Use of Refrigerant 12." *International Journal of Multiphase Flow*, Vol. 8, No. 2, 1982, pp. 165-181.
33. Lienhard, J. H. "Burnout on Cylinders." *Journal of Heat Transfer*, Vol. 110, November 1988, pp. 1271-1286.
34. Dew, J. E. "Local Boiling of Water in an Annulus." M.S. Thesis in Chemical Engineering, MIT, Cambridge, 1948.
35. Ibrahim, E. A. and Judd, R. L. "An Experimental Investigation of the Effect of Subcooling on Bubble Growth and Waiting Time in Nucleate Boiling." *Journal of Heat Transfer*, Vol. 107, February 1985, pp. 168-174.
36. Cichelli, M. T. and Bonilla, C. F. "Heat Transfer to Liquids Boiling Under Pressure." *Transactions of the AIChE*, Vol. 41, 1945, pp. 755-787.
37. Chang, Y. P. "Some Possible Critical Conditions in Nucleate Boiling." *Journal of Heat Transfer*, Vol. 85, No. 2, 1963, pp. 89-100.
38. Tolubinsky, V. I. and Kostanchuk, D. M. "Vapour Bubbles Growth Rate and Heat Transfer Intensity at Subcooled Water Boiling." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B2.8, 1970.
39. Corty, C. and Foust, A. S. "Surface Variables in Nucleate Boiling." *Chemical Engineering Progress Symposium Series*, Vol. 51, No. 17, 1955, pp. 1-12.
40. Brown, W. T., Jr. "A Study of Flow Surface Boiling." PhD Thesis, MIT, 1967.
41. Berenson, P. J. "Transition Boiling Heat Transfer From a Horizontal Surface." MIT Heat Transfer Laboratory Technical Report No. 17, 1960.

42. Ramilison, J. M. and Lienhard, J. H. "Transition Boiling Heat Transfer and the Film Transition Regime." *Journal of Heat Transfer*, Vol. 109, August 1987, pp. 746-752.
43. Weatherhead, R. J. "Nucleate Boiling Characteristics and the Critical Heat Flux Occurrence in Subcooled Axial-Flow Water Systems." Argonne National Lab, ANL-6675, March 1963.
44. Leung, A., Banerjee, S., and Groeneveld, D. C. "Investigation of the Effects of Heater Characteristics on CHF Performance of a Long Vertical Annulus in High Pressure Water." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 303-308.
45. Aladyev, I. T., Miropolsky, Z. L., Doroshchuk, V. E., and Styrikovich, M. A. "Boiling Crisis in Tubes." *International Developments in Heat Transfer*, IHTC Part II, 1961, pp. 237-243.
46. Bergles, A. E. and Morton, H. L. "Survey and Evaluation of Techniques to Augment Convective Heat Transfer." MIT Technical Report No. 5382-34, February 1965.
47. Durant, W. S., Towell, R. H., and Mirshak, S. "Improvement of Heat Transfer to Water Flowing in an Annulus by Roughening the Heated Wall." *Chemical Engineering Progress Symposium Series*, Vol. 61, No. 60, 1965, pp. 106-113.
48. Kovalev, S. A., et al. "Heat Transfer Crisis in Boiling of Subcooled Water on a Finned Surface under Forced-Convection Conditions." *Heat Transfer—Soviet Research*, Vol. 8, No. 4, July-August 1976, pp. 73-78.
49. Shim, S. Y., et al. "Critical Heat Flux in Subcooled Flow Boiling on Finned and Unfinned Tube Geometries." *Heat Transfer in Turbulent Flow*, HTD-Vol. 138, ASME, 1990, pp. 91-98.
50. Ravigururajan, T. S. and Bergles, A. E. "General Correlations for Pressure Drop and Heat Transfer for Single-Phase Turbulent Flow in Internally Ribbed Tubes." *Augmentation of Heat Transfer in Energy Systems*, HTD-Vol 52, ASME, New York, 1985, pp. 9-20.
51. Akhanda, M. A. R. and James, D. D. "An Experimental Study of the Relative Effects of Transverse and Longitudinal Ribbing of the Heat Transfer Surface in Forced Convection Boiling." *Journal of Heat Transfer*, Vol. 113, February 1991, pp. 209-215.



52. Webb, R. L. "The Evolution of Enhanced Surface Geometries for Nucleate Boiling." *Heat Transfer Engineering*, Vol. 2, No. 3-4, January-June 1981.
53. Bankoff, S. G. "On the Mechanism of Subcooled Nucleate Boiling." JPL/CIT Memo No. 30-8, February 1959.
54. Frost, W. and Kippenhan, C. J. "Bubble Growth and Heat-Transfer Mechanisms in the Forced Convection Boiling of Water Containing a Surface Active Agent." *International Journal of Heat Mass Transfer*, Vol. 10, 1967, pp. 931-949.
55. Bilicki, Z. "Latent Heat Transport in Forced Boiling Flow." *International Journal of Heat Mass Transfer*, Vol. 26, No. 4, 1983, pp. 559-565.
56. Tsung-Chang, G. and Bankoff, S. G. "On the Mechanism of Forced-Convection Subcooled Nucleate Boiling." *Journal of Heat Transfer*, Vol. 112, February 1990, pp. 213-218.
57. Forster, K. and Greif, R. "Heat Transfer to a Boiling Liquid-Mechanism and Correlations." *Journal of Heat Transfer*, Ser. C, Vol. 81, No. 1, February 1959, pp. 43-53.
58. Plesset, M. S. and Prosperetti, A. "The Contribution of Latent Heat Transport in Subcooled Nucleate Boiling." *International Journal of Heat Mass Transfer*, Vol. 21, 1978, pp. 725-734.
59. Pike, F. P., Miller, P. D., Jr., and Beatty, K. O., Jr. "Effect of Gas Evolution on Surface Boiling at Wire Coils." *Chemical Engineering Progress Symposium Series*, Vol. 51, No. 17, 1955, pp. 13-19.
60. Sadasivan, P. and Lienhard, J. H. "Considerations in Predicting Burnout of Cylinders in Flow Boiling." *Journal of Heat Transfer*, Vol. 114, February 1992, pp. 185-193.
61. Papaioannou, A. T. and Koumoutsos, N. G. "The Effect of Polymer Additives on Nucleate Boiling." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 67-72.
62. Wei, H. and Maa, J. R. "Enhancement of Flow Boiling Heat Transfer with Polymer Additives." *International Journal of Heat Mass Transfer*, Vol. 25, No. 3, 1982, pp. 431-434.

63. Tolubinskiy, V. I. and Matorin, A. S. "Forced Convection Boiling Heat Transfer Crisis with Binary Mixtures." *Heat Transfer—Soviet Research*, Vol. 5, No. 2, March-April 1973, pp. 98-101.
64. Borishanskiy, V. M. and Fokin, B. S. "Onset of Heat-Transfer Crisis with Unsteady Increase in Heat Flux." *Heat Transfer—Soviet Research*, Vol. 1, No. 5, 1969, pp. 27-55.
65. Lyon, R. E., Foust, A. S., and Katz, D. L. "Boiling Heat Transfer with Liquid Metals." *Chemical Engineering Progress Symposium Series*, Vol. 51, No. 17, 1955, pp. 41-47.
66. Ahmad, S. Y. and Groeneveld, D. C. "Fluid Modeling of Critical Heat Flux in Uniformly Heated Annuli." *Progress in Heat and Mass Transfer*, Vol. 6, 1972, pp. 45-53.
67. Motley, F. E., Cadek, F. F., Cermak, J. O., and Tong, L. S. "CHF Data From Freon-11 Flow for Scaling CHF in Water." *Progress in Heat and Mass Transfer*, Vol. 6, 1972, pp. 137-153.
68. Purcupile, J. C., Tong, L. S., and Gouse, S. W., Jr. "Refrigerant-Water Scaling of Critical Heat Flux in Round Tubes—Subcooled Forced-Convection Boiling." *Journal of Heat Transfer*, Vol. 95, May 1973, pp. 279-281.
69. Purcupile, J. C., Motley, F. E., and Cadek, F. F. "Application of the Reynolds Flux Model of Critical Heat Flux for Direct Heat Flux Scaling in Nonuniform Rod Bundles." *Journal of Heat Transfer*, Vol. 97, February 1975, pp. 144-145.
70. Ahmad, S. Y. "Fluid to Fluid Modeling of Critical Heat Flux: A Compensated Distortion Model." *International Journal of Heat Mass Transfer*, Vol. 16, 1973, pp. 641-662.
71. Powell, W. B. "Heat Transfer to Fluids in the Region of the Critical Temperature." *Jet Propulsion*, July 1957, pp. 776-783.
72. Mead, B. R., Romie, F. E., and Guibert, A. G. "Liquid Superheat and Boiling Heat Transfer." *Heat Transfer and Fluid Mechanics Institute*, Preprint of Papers, 1951, pp. 209-216.
73. Bonilla, C. F. and Perry, C. W. "Heat Transmission to Boiling Liquid Mixtures." *Transactions of the AIChE*, Vol. 37, 1941, pp. 685-705.

74. Farber, E. A. and Scorah, R. L. "Heat Transfer to Water Under Pressure." *Transactions of the ASME*, Vol. 70, 1948, pp. 369-384.
75. Sauer, E. T., et al. "Heat Transfer to Boiling Liquids." *Mechanical Engineering*, September 1938, pp. 669-675.
76. Magrini, U. and Nannei, E. "On the Influence of the Thickness and Thermal Properties of Heating Walls on the Heat Transfer Coefficients in Nucleate Pool Boiling." *Journal of Heat Transfer*, Vol. 97, May 1975, pp. 173-178.
77. Kovalev, S. A., et al. "Effect of Coating with Low Thermal Conductivity Upon Boiling Heat Transfer of Liquid on Isothermal and Non-isothermal Surfaces." Paper No. B1.4, *Proceedings of the 4th International Heat Transfer Conference*, Vol. 5, 1970, pp. 1-11.
78. Cheng, S. C. and Ragheb, H. "Effect of Heated Surface Thermal Properties on Transition Boiling." *Multiphase Transport—Fundamentals, Reactor Safety, Applications*, edited by T. N. Veziroglu, Vol. 1, 1980, pp. 625-637.
79. Jacket, H. S., Roarty, J. D., and Zerbe, J. E. "Investigation of Burnout Heat Flux in Rectangular Channels at 2000 Psia." *Transactions of the ASME*, Vol. 80, February 1958, pp. 391-401.
80. Vandervort, C. L., Bergles, A. E., and Jensen, M. K. "The Ultimate Limits of Forced Convective Subcooled Boiling Heat Transfer." Rensselaer Polytechnic Institute Heat Transfer Laboratory Report HTL-9, May 1992.
81. Del Valle M., V. H. and Kenning, D. B. R. "Subcooled Flow Boiling at High Heat Flux." Oxford University Report No. PB85-139582 (OUEL-1540/84), 1982.
82. Schweppe, J. L. and Foust, A. S. "Effect of Forced Circulation Rate on Boiling-Heat Transfer and Pressure Drop in a Short Vertical Tube." *Chemical Engineering Progress Symposium Series*, Vol. 49, No. 5, 1953, pp. 77-89.
83. Lee, D. H. and Obertelli, J. D. "An Experimental Investigation of Forced Convection Burnout in High Pressure Water, Part I. Round Tubes with Uniform Flux Distribution." AEEW—R 213, 1963.
84. Matzner, B. "Basic Experimental Studies of Boiling Fluid Flow and Heat Transfer at Elevated Pressures." Columbia University Progress Report TID 18978, May 1963.

85. Bergles, A. E. "Subcooled Burnout in Tubes of Small Diameter." ASME Paper 63-WA-182, 1963.
86. Glushchenko, L. F. "Correlation of Experimental Data on Critical Heat Fluxes in Subcooled Boiling." *Heat Transfer—Soviet Research*, Vol. 2, No. 1, January 1970, pp. 139-143.
87. Ornatskiy, A. P. "The Effect of Basic Regime Parameters and Channel Geometry on Critical Heat Fluxes in Forced Convection of Subcooled Water." *Heat Transfer—Soviet Research*, Vol. 1, No. 3, May 1969, pp. 17-22.
88. Jens, W. H. and Lottes, P. A. "Analysis of Heat Transfer, Burnout, Pressure Drop and Density Data for High-Pressure Water." Argonne National Lab, ANL-4627, May 1951.
89. Becker, K. M. and Hernborg, G. "Measurements of Burnout Conditions for Flow of Boiling Water in a Vertical Annulus." *Journal of Heat Transfer*, August 1964, pp. 393-407.
90. Zenkevich, B. A., et al. "Heat Transfer Burnout in Water Flow Through Round Tubes and Annuli." *Proceedings of the 4th International Heat Transfer Conference*, Vol. VI, Paper No. B6.13, 1970.
91. Barnett, P. G. "A Correlation of Burnout Data for Uniformly Heated Annuli and Its Use for Predicting Burnout in Uniformly Heated Rod Bundles." U. K. Atomic Energy Authority Report AEEW-R-463, September 1966.
92. Alekseev, G. V., et al. "Burn-out Heat Fluxes Under Forced Water Flow," 3rd U.N. International Conference on the Peaceful Uses of Atomic Energy, A/CONF.28/P/327a, Geneva, May 1964.
93. Kreith, F. and Summerfield, M. "Heat Transfer to Water at High Flux Densities With and Without Surface Boiling." *ASME Transactions*, Vol. 71, No. 7, October 1949, pp. 805-815.
94. Merilo, M. "Critical Heat Flux Experiments in a Vertical and Horizontal Tube with Both Freon-12 and Water as Coolant." *Nuclear Engineering Design*, Vol. 44, No. 1, 1977, pp. 1-16.

95. Jensen, M. K. and Bergles, A. E. "Critical Heat Flux in Helically Coiled Tubes." *Journal of Heat Transfer*, Vol. 103, November 1981, pp. 660-666.
96. Zeigarnik, Yu. A., Privalov, N. P., and Klimov, A. I. "Critical Heat Flux with Boiling of Subcooled Water in Rectangular Channels with One-Sided Supply of Heat." *Thermal Engineering*, Vol. 28, No. 1, 1981, pp. 40-43.
97. Boyd, R. D., Powell, L. N., and Schluter, L. L. "Critical Heat Flux and Heat Transfer for High Heat Flux Applications." *International Journal of Heat Mass Transfer*, Vol. 29, No. 2, 1986, pp. 337-340.
98. Fisenko, V. V., et al. "Effect of Dissolved Gas on Nucleate Boiling and Critical Heat Flux." *Heat Transfer—Soviet Research*, Vol. 29, No. 3, May-June 1988, pp. 294-299.
99. Fisenko, V. V., et al. "Effects of Gas Dissolved in Water on Critical Heat Loadings." *Atomnaya Energiya*, Vol. 48, No. 5, May 1980, pp. 335-336.
100. Buchberg, H., et al. "Heat Transfer, Pressure Drop, and Burnout Studies With and Without Surface Boiling for De-aerated and Gassed Water at Elevated Pressures in a Forced Flow System." *Heat Transfer and Fluid Mechanics Institute*, Preprint of Papers, 1951, pp. 177-191.
101. Lowdermilk, W. H., Lanzo, C. D., and Siegel, B. L. "Investigation of Boiling Burnout and Flow Stability for Water Flowing in Tubes." NACA TN 4382, September 1958.
102. DeBortoli, R. A. and Masnovi, R. "Effect of Dissolved Hydrogen on Burnout for Water Flowing Vertically Upward in Round Tubes at 2000 psia." WAPD-TH-318, April 1957.
103. Kalayda, Y. A., Pavlenkov, I. M., and Maksimov, V. I. "Effect of Mass Velocity on the Critical Heat Fluxes in Forced Flow of High-Pressure, High-Temperature, Gas-Saturated Coolant." *Heat Transfer—Soviet Research*, Vol. 15, No. 2, March-April 1983, pp. 128-130.
104. Baranenko, V. I., et al. "Effect of Dissolved Gas on Internal Parameters of Boiling." *Heat Transfer—Soviet Research*, Vol. 19, No. 2, March-April 1987, pp. 1-6.
105. Epstein, N. "Fouling: Technical Aspects (Afterword to Fouling in Heat Exchangers)." *Fouling of Heat Transfer Equipment*. Edited by E. F. C. Somerscales and J. G. Knudsen, Hemisphere Publishing, Washington D.C., 1981.

106. Bui, T. D. and Dhir, V. K. "Transition Boiling Heat Transfer on a Vertical Surface." *Journal of Heat Transfer*, Vol. 107, November 1985, pp. 756-763.
107. Mel'nikov, V. N., et al. "Experimental Study of the Effect of Ferric-Oxide Scale on the Critical Heat Flux in Forced-Convection Boiling of Water." *Heat Transfer—Soviet Research*, Vol. 11, No. 3, May-June 1979, pp. 36-39.
108. Zhukov, V. M., et al. "Heat Transfer in Boiling of Liquids on Surfaces Coated with Low Thermal Conductivity Films." *Heat Transfer—Soviet Research*, Vol. 7, No. 3, May-June 1975, pp. 16-26.
109. Merte, H., Jr., and Clark, J. A. "A Study of Pool Boiling in an Accelerating System." University of Michigan Report 2646-21-T, Technical Report 3, November 1959.
110. Gu, C. B., Chow, L. C., and Beam, J. E. "Flow Boiling in a Curved Channel." Proceedings from the ASME Winter Meeting—San Francisco, 1989, pp. 25-32.
111. Winovich, W. and Carlson, W. C. A. "The 60-MW Shuttle Interaction Heating Facility." ISA Proceedings of the 25th International Instrumentation Symposium, Instrumentation in the Aerospace Industry—Vol. 25, Advances in Test Measurement—Vol. 16, Part 1, 1979, pp. 59-75.
112. Kudryavtsev, I. S., et al. "Nucleate Boiling of Water in Twisted-Tape Swirled Flow." *Heat Transfer—Soviet Research*, Vol. 22, No. 6, 1990, pp. 705-712.
113. Lopina, R. F. and Bergles, A. E. "Subcooled Boiling of Water in Tape-Generated Swirl Flow." *Journal of Heat Transfer*, Vol. 95, May 1973, pp. 281-283.
114. Ornatskiy, A. P., et al. "Critical Heat Fluxes in Annuli with Swirl." *Heat Transfer—Soviet Research*, Vol. 7, No. 2, March-April 1975, pp. 6-9.
115. Gambill, W. R., Bundy, R. D., and Wansbrough, R. W. "Heat Transfer, Burnout, and Pressure Drop for Water in Swirl Flow Through Tubes with Internal Twisted Tapes." *Chemical Engineering Progress Symposium Series*, Vol. 57, No. 32, 1961, pp. 127-137.
116. Megerlin, F. E., Murphy, R. W., and Bergles, A. E. "Augmentation of Heat Transfer in Tubes by Use of Mesh and Brush Inserts." *Journal of Heat Transfer*, Vol. 96, May 1974, pp. 145-151.

117. Stein, R. P. and Begell, W. "Heat Transfer to Water in Turbulent Flow in Internally Heated Annuli." *AIChE Journal*, Vol. 4, No. 2, June 1958, pp. 127-131.
118. Styrikovich, M. A., Miropol'skii, Z. L., and Chzhao-Yuan, S. "The Effect of Uneven Heating Along a Tube on the Critical Thermal Streams." *Soviet Physics—Doklady*, Vol. 6, No. 8, February 1962, pp. 691-693.
119. Ornatskiy, A. P., et al. "Burnout in Annuli with Hydrodynamically Stable Water Flows and Longitudinally Varying Heat Inputs." *Heat Transfer—Soviet Research*, Vol. 12, No. 6, November-December 1980, pp. 41-53.
120. Swenson, H. S., Carver, J. R., and Kakarala, C. R. "The Influence of Axial Heat-Flux Distribution on the Departure from Nucleate Boiling in a Water-Cooled Tube." ASME Paper 62-WA-297, 1962.
121. Leontiev, A. I., et al. "Experimental Investigation of the Critical Heat Flux in Horizontal Channels with Circumferentially Variable Heating." *International Journal of Heat Mass Transfer*, Vol. 24, No. 5, 1981, pp. 821-828.
122. Celata, G. P., et al. "CHF Behaviour During Pressure, Power and/or Flow Rate Simultaneous Variations." *International Journal of Heat Mass Transfer*, Vol. 33, No. 3, 1991, pp. 723-738.
123. Ragheb, H. S., Cheng, S. C., and Groeneveld, D. C. "Observations in Transition Boiling of Subcooled Water under Forced Convective Conditions." *International Journal of Heat Mass Transfer*, Vol. 24, No. 7, 1981, pp. 1127-1137.
124. Cheng, S. C., Ng, W. W. L., and Heng, K. T. "Measurements of Boiling Curves of Subcooled Water Under Forced Convection Conditions." *International Journal of Heat Mass Transfer*, Vol. 21, 1978, pp. 1385-1392.
125. Kataoka, I., Serizawa, A., and Sakurai, A. "Transient Boiling Heat Transfer Under Forced Convection." *International Journal of Heat Mass Transfer*, Vol. 26, No. 4, 1983, pp. 583-595.
126. Tolubinskiy, V. I., Ostrovskiy, Y. N., and Pisarev, V. Y. "Investigation of 'Unsteady' Critical Heat Fluxes." *Heat Transfer—Soviet Research*, Vol. 7, No. 6, November-December 1975, pp. 1-6.

127. Roemer, R. B. "The Effect of Power Transients on the Peak Heat Flux." *International Journal of Heat Mass Transfer*, Vol. 12, 1969, pp. 953-964.
128. Celata, G. P., et al. "Critical Heat Flux in Flow Transients." *Proceedings of the 8th International Heat Transfer Conference*, Vol. 5, 1986, pp. 2429-2435.
129. Celata, G. P., et al. "Critical Heat Flux in Transient Flow Boiling During Simultaneous Variations in Flow Rate and Thermal Power." *Experimental Thermal and Fluid Science*, 1989, pp. 134-145.
130. Weisman, J., et al. "The Initiation of Boiling During Pressure Transients." ASME Paper 73-WA/HT-25, 1973.
131. Celata, G. P., et al. "CHF in Flow Boiling During Pressure Transients." 4th Miami International Symposium on Multiphase Transport and Particulate Phenomena, December 1986.
132. Celata, G. P., Cumo, M., and D'Annibale, F. "A Data Set of Critical Heat Flux of Boiling R-12 in Uniformly Heated Vertical Tubes Under Transient Conditions." *Experimental Thermal and Fluid Science*, 1992, pp. 78-107.
133. Podowski, M. Z. "Instabilities in Two-Phase Systems." presented at Modern Developments in Boiling Heat Transfer and Two-Phase Flow Seminar, Rensselaer Polytechnic Institute, Troy, NY, July 1991, pp. 10-1 to 10-67.
134. Boure, J. A., Bergles, A. E., and Tong, L. S. "Review of Two-Phase Flow Instability." *Nuclear Engineering Design*, Vol. 25, 1973, pp. 165-192.
135. Bergles, A. E., et al. *Two-Phase Flow and Heat Transfer in the Power and Process Industries*. McGraw-Hill, New York, 1981, Chapter 13, "Instabilities in Two-Phase Systems," pp. 381-423.
136. Gouse, S. W., Jr. "Two-Phase Gas-Liquid Flow Oscillations: Preliminary Survey." Engineering Projects Laboratory, Department of Mechanical Engineering, MIT Report No. DSR 8734-5, July 1964.
137. Veziroglu, T. N. and Lee, S. S. "Boiling-Flow Instabilities in a Cross-Connected Parallel-Channel Upflow System." ASME Paper No. 71-HT-12, 1971.
138. Ellion, M. E. "A Study of the Mechanism of Boiling Heat Transfer." JPL/CIT Memorandum No. 20-88, March 1954.



139. Tolubinsky, V. I., Litoshenko, A. K., and Shevtsov, V. L. "Heat Transfer Crisis at Water Boiling in Annular Channels with External and Internal Heating." *Proceedings of the 4th International Heat Transfer Conference*, Vol. VI, Paper No. B6.11, 1970.
140. Yücel, B. and Kakas, S. "Forced Flow Boiling and Burnout in Rectangular Channels." *Proceedings of the 6th International Heat Transfer Conference—Toronto*, Vol. I, August 1978, pp. 387-392.
141. Johnson, R. L. "Effect of an Electric Field on Boiling Heat Transfer." *AIAA Journal*, Vol. 6, No. 8, August 1968, pp. 1456-1460.
142. Markels, M., Jr. and Durfee, R. L. "Boiling Heat Transfer with Electrical Fields." *Chemical Engineering Progress Symposium Series*, Vol. 82, No. 64, 1968, pp. 67-71.
143. Bergles, A. E. "The Influence of Flow Vibrations on Forced-Convection Heat Transfer." *Journal of Heat Transfer*, Vol. 86, November 1964, pp. 559-560.
144. Inoue, A. and Bankoff, S. G. "Destabilization of Film Boiling Due to Arrival of a Pressure Shock, Part I: Experimental." *Journal of Heat Transfer*, Vol. 103, August 1981, pp. 459-464.
145. Weede, J. and Dhir, V. K. "Experimental Study of the Enhancement of Critical Heat Flux Using Tangential Flow Injection." *Proceedings of the 21st National Conference on Heat Transfer*, Seattle, ASME, Vol 24, July 1983, p. 11-18.
146. Rohsenow, W. M. "Heat Transfer with Boiling." *Modern Developments in Heat Transfer*. W. E. Ibele, Editor, Academic Press, 1963, pp. 85-158.
147. Knowles, J. W. "Heat Transfer with Surface Boiling." *Canadian Journal of Research*, Vol. 26, Sec. A, 1948, pp. 268-278.
148. White, F. M. *Viscous Fluid Flow*. McGraw-Hill, New York, 1974.
149. Carpenter, F. G., et al. "Heat Transfer and Friction of Water in an Annular Space." *Transactions of the AIChE*, Vol. 42, 1947, pp. 165-187.
150. Kays, W. M. and London, A. L. *Compact Heat Exchangers*. McGraw-Hill, New York, 1964 (Second Edition).

151. Petukhov, B. S. "Heat Transfer and Friction in Turbulent Pipe Flow with Variable Physical Properties." *Advances in Heat Transfer*, Vol. 6, 1970, pp. 503-564.
152. Sleicher, C. A. and Rouse, M. W. "A Convenient Correlation for Heat Transfer to Constant and Variable Property Fluids in Turbulent Pipe Flow." *International Journal of Heat Mass Transfer*, Vol. 18, 1975, pp. 677-683.
153. Kays, W. M. and Leung, E. Y. "Heat Transfer in Annular Passages—Hydrodynamically Developed Turbulent Flow with Arbitrarily Prescribed Heat Flux." *International Journal of Heat Mass Transfer*, Vol. 6, 1963, pp. 537-557.
154. Incropera, F. P. and DeWitt, D. B. *Fundamentals of Heat and Mass Transfer*. John Wiley and Sons, New York, 1985 (Second Edition).
155. White, F. M. *Fluid Mechanics*. McGraw-Hill, New York, 1979.
156. Jain, P. K., Nourmohammadi, K., and Roy, R. P. "A Study of Forced Convection Subcooled Boiling in Heated Annular Channels." *Nuclear Engineering Design*, Vol. 60, No. 3, 1980, p. 401-411.
157. Ishii, M. and Mishima, K. "Two-Fluid Model and Hydrodynamic Constitutive Relations." *Nuclear Engineering Design*, Vol. 82, 1984, pp. 107-126.
158. Jones, O. C. "Elements of Two-Phase Flow." presented at Modern Developments in Boiling Heat Transfer and Two-Phase Flow Seminar, Rensselaer Polytechnic Institute, Troy, NY, July 1991, pp. 2-1 to 2-30.
159. Drew, D. A. "Analytical Modeling of Multiphase Flows." presented at Modern Developments in Boiling Heat Transfer and Two-Phase Flow Seminar, Rensselaer Polytechnic Institute, Troy, NY, July 1991, pp. 3-1 to 3-54.
160. Kutateladze, S. S. "Boiling Heat Transfer." *International Journal of Heat Mass Transfer*, Vol. 4, 1961, pp. 31-45.
161. Bergles, A. E. and Rohsenow, W. M. "The Determination of Forced-Convection Surface-Boiling Heat Transfer." *Journal of Heat Transfer*. Vol. 86, August 1964, pp. 365-372.
162. Gilmour, C. H. "Nucleate Boiling—A Correlation." *Chemical Engineering Progress*, Vol. 54, No. 10, October 1958, pp. 77-79.

163. Levy, S. "Generalized Correlation of Boiling Heat Transfer." *Journal of Heat Transfer*, Vol. 81, February 1959, pp. 37-42.
164. Forster, H. K. and Zuber, N. "Growth of a Vapor Bubble in a Superheated Liquid." *Journal of Applied Physics*, Vol. 25, No. 4, April 1954, pp. 474-478.
165. Shah, M. M. "Generalized Prediction of Heat Transfer during Subcooled Boiling in Annuli." *Heat Transfer Engineering*, Vol. 4, No. 1, 1983, pp. 24-31.
166. Shah, M. M. "A General Correlation for Heat Transfer during Subcooled Boiling in Pipes and Annuli." *ASHRAE Transactions*, Vol. 83, Part 1, 1977, pp. 202-217.
167. Rohsenow, W. M. "A Method of Correlating Heat-Transfer Data for Surface Boiling of Liquids." *Transactions of the ASME*, Vol. 74, 1952, pp. 969-975.
168. Rohsenow, W. M. "Heat Transfer with Evaporation." Heat Transfer... A Symposium. Summer 1952, Chapter 4, Engineering Research Institute, University of Michigan, Ann Arbor, 1953, pp. 101-149.
169. Vachon, R. I., Nix, G. H., and Tanger, G. E. "Evaluation of Constants for the Rohsenow Pool-Boiling Correlation." *Journal of Heat Transfer*, Vol. 90, May 1968, pp. 239-247.
170. Bjorge, R. W., Hall, G. R., and Rohsenow, W. M. "Correlation of Forced Convection Boiling Heat Transfer Data." *International Journal of Heat Mass Transfer*, Vol. 25, No. 6, 1982, pp. 753-757.
171. Stephan, K. and Auracher, H. "Correlations for Nucleate Boiling Heat Transfer in Forced Convection." *International Journal of Heat Mass Transfer*, Vol. 24, 1981, pp. 99-107.
172. Guglielmini, G., Nannei, E., and Pisoni, C. "Survey of Heat Transfer Correlations in Forced Convection Boiling." *Multiphase Transport—Fundamentals, Reactor Safety, Applications*. Edited by T. N. Veziroglu, Vol. 1, 1980, pp. 845-861.
173. Bergles, A. E. and Dormer, T., Jr. "Subcooled Boiling Pressure Drop with Water at Low Pressure." *International Journal of Heat Mass Transfer*, Vol. 12, 1969, pp. 459-470.

174. Boyd, R. D., "Subcooled Water Flow Boiling at 1.66 MPa under Uniform High Heat Flux Conditions." presented at the Winter Annual Meeting of ASME, San Francisco, Heat Transfer in High Energy/High Heat Flux Applications, Vol. 119, December 1989, pp. 9-15 (also in *Fusion Technology*, Vol. 16, No. 5, 1989, pp. 324-330).
175. Staub, F. W. and Walmet, G. E. "The Void Fraction and Pressure Drop in Subcooled Flow Boiling." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B4.11, 1970.
176. Hoffman, M. A. and Kline, C. T. "Evaluation of Several Empirical Models for Predicting Subcooled Flow-Boiling Pressure Drops." 23rd National Heat Transfer Conference, Denver, 1985, pp. 151-160.
177. Lu, S. and Jia, D. "A New Method for Predicting the Pressure Drop in a Subcooled Boiling Channel." *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1988*, edited by R. K. Shah, E. N. Ganic, and K. T. Yang, Elsevier Science Publishing Co., 1988, pp. 1466-1472.
178. Tong, L. S. "A Phenomenological Study of Critical Heat Flux." ASME Paper 75-HT-68, 1975.
179. Purcupile, J. C. and Gouse, S. W., Jr.. "Reynolds Flux Model of Critical Heat Flux in Subcooled Forced Convection Boiling." ASME Paper 72-HT-4, 1972.
180. Kutateladze, S. S. and Leont'ev, A. I. "Some Applications of the Asymptotic Theory of the Turbulent Boundary Layer." *Proceedings of the 3th International Heat Transfer Conference*, Vol. III, 1966, pp. 1-6.
181. Hancox, W. T. and Nicoll, W. B. "On the Dependence of the Flow-Boiling Heat Transfer Crisis on Local Near-Wall Conditions." ASME Paper 73-HT-38, 1973.
182. Lee, C. H. and Mudawwar, I. "A New Critical Heat Flux Model for Subcooled Two-Phase Flow Through a Vertical Tube." 4th Miami International Symposium on Multiphase Transport and Particulate Phenomena, December 1986.
183. Lee, C. H. and Mudawwar, I. "A Mechanistic Critical Heat Flux Model for Subcooled Flow Boiling Based on Bulk Flow Conditions." *International Journal of Multiphase Flow*, Vol. 14, No. 6, 1988, pp. 711-728.

184. Katto, Y. "A Physical Approach to Critical Heat Flux of Subcooled Flow Boiling in Round Tubes." *International Journal of Heat Mass Transfer*, Vol. 33, No. 4, 1990, pp. 611-620.
185. Katto, Y. "Prediction of Critical Heat Flux of Subcooled Flow Boiling in Round Tubes." *International Journal of Heat Mass Transfer*, Vol. 33, No. 9, 1990, pp. 1921-1928.
- Katto, Y. "A Generalized Correlation of Critical Heat Flux for the Forced Convection Boiling in Vertical Uniformly Heated Round Tubes." *International Journal of Heat Mass Transfer*, Vol. 21, 1978, pp. 1527-1542.
187. Katto, Y. "A Generalized Correlation of Critical Heat Flux for the Forced Convection Boiling in Vertical Uniformly Heated Round Tubes - A Supplementary Report." *International Journal of Heat Mass Transfer*, Vol. 22, 1979, pp. 783-794.
188. Katto, Y. "Generalized Correlations of Critical Heat Flux for the Forced Convection Boiling in Vertical Uniformly Heated Annuli." *International Journal of Heat Mass Transfer*, Vol. 22, 1979, pp. 575-584.
189. Katto, Y. and Ohno, H. "An Improved Version of the Generalized Correlation of Critical Heat Flux for the Forced Convection Boiling in Uniformly Heated Vertical Tubes." *International Journal of Heat Mass Transfer*, Vol. 27, No. 9, 1984, pp. 1641-1648.
190. Nishikawa, K., et al. "Experimental Investigation of Critical Heat Flux in Forced Convection Boiling of Freon in a Tube at High Subcritical Pressure." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 321-326.
191. Bergel'son, B. R. "Burnout under Conditions of Subcooled Boiling and Forced Convection." *Thermal Engineering*, Vol. 27, No. 1, 1980, pp. 48-50.
192. Smogalev, I. P. "Calculation of Critical Heat Fluxes with Flow of Subcooled Water at Low Velocity." *Thermal Engineering*, Vol. 28, No. 4, 1981, pp. 208-211.
193. Griffith, P. "The Correlation of Nucleate Boiling Burnout Data." MIT TR 9 (AD147714), March 1957 (also ASME Paper 57-HT-21).

194. Hebel, W., Detavernier, W., and Decreton, M. "A Contribution to the Hydrodynamics of Boiling Crisis in a Forced Flow of Water." *Nuclear Engineering Design*, Vol. 64, 1981, pp. 433-445.
195. Yagov, V. V. and Puzin, V. A. "Burnout Under Conditions of Forced Flow of Subcooled Liquid." *Thermal Engineering*, Vol. 32, No. 10, 1985, pp. 569-572.
196. Weisman, J. and Ileslamlou, S. "A Phenomenological Model for Prediction of Critical Heat Flux Under Highly Subcooled Conditions." *Fusion Technology*, Vol. 13, May 1988, pp. 654-659.
197. Yang, J. Y. and Weisman, J. "A Phenomenological Model of Subcooled Flow Boiling in the Detached Bubble Region." *International Journal of Multiphase Flow*, Vol. 17, No. 1, 1991, pp. 77-94.
198. Weisman, J. and Pei, B. S. "Prediction of Critical Heat Flux in Flow Boiling at Low Qualities." *International Journal of Heat Mass Transfer*, Vol. 26, No. 10, 1983, pp. 1463-1477.
199. Andreyev, P. A., et al. "Critical Heat Fluxes under Certain Modes of Operation of Steam-Generating Tubes of Water-Moderated Water-Cooled Power Reactors." *Heat Transfer—Soviet Research*, Vol. 12, No. 3, May-June 1980, pp. 64-66.
200. Povarnin, P. I. "Approximate Methods of Calculating the Critical Heat Load for Organic Heat-Transfer Media in Forced Convection." *Heat Transfer—Soviet Research*, Vol. 1, No. 4, July 1969, pp. 63-70.
201. Thorgerson, E. J., Knoebel, D. H. and Gibbons, J. H. "A Model to Predict Convective Subcooled Critical Heat Flux." *Journal of Heat Transfer*, Vol. 96, No. 1, 1974, pp. 79-82.
202. Gambill, W. R. "Generalized Prediction of Burnout Heat Flux for Flowing, Subcooled, Wetting Liquids." *Chemical Engineering Progress Symposium Series*, Vol. 41, No. 59, 1963, pp. 71-87.
203. Bernath, L. "A Theory of Local-Boiling Burnout and Its Application to Existing Data." *Chemical Engineering Progress Symposium Series*, Vol. 56, No. 30, 1960, pp. 95-116.

204. Levy, S. "Prediction of the Critical Heat Flux in Forced Convection Flow." General Electric Report GEAP-3961, June 1962.
205. Barnett, P. G. "An Experimental Investigation to Determine the Scaling Laws of Forced Convection Boiling Heat Transfer, Part I: The Preliminary Examination Using Burnout Data for Water and Arcton 12." AEEW-R-363, June 1964.
206. Zenkevich, B. A. "Similarity Criteria for Critical Heat Loading in Forced Liquid Flow." *Journal of Nuclear Energy, Part B: Reactor Technology*, Vol. 1, 1959, pp. 137-140.
207. Kampfenkel, O. "Model Laws for the Transition from Nucleate to Film Boiling with Forced Convection." NUREG/TR-0030, (Translation Series), U.S. Nuclear Regulatory Commission, 1978; original report no. BMFT-FB-K77-05 (July 1971), translated by Techtron Corp. in 1971; also FASTC-ID (RS) T-0129-92 translated by Foreign Technology Div., Wright-Patterson AFB, 1992.
208. Ornatskii, A. P., Glushchenko, L. F., and Maevskii, E. M. "Critical Heat Flux in Steam Generating Tubes in the Region of Low Subcooling and Steam Content." *Thermal Engineering*, Vol. 18, No. 8, August 1971, pp. 106-109 (translated from *Teploenergetika*, Vol. 18, No 8, 1971, pp.74-76).
209. Coffield, R. D., Jr., Rohrer, W. M., Jr., and Tong, L. S. "A Subcooled DNB Investigation of Freon-113 and Its Similarity to Subcooled Water DNB Data." *Nuclear Engineering Design*, Vol. 11, 1969, pp. 143-153.
210. Katto, Y. "An Analytical Investigation on CHF of Flow Boiling in Uniformly Heated Vertical Tubes with Special Reference to Governing Dimensionless Groups." *International Journal of Heat Mass Transfer*, Vol. 25, No. 9, 1982, pp. 1353-1361.
211. McGill, H. L. and Sibbitt, W. L. "Heat Transfer and Pressure Drop of Water Flowing in a Small Tube - Final Technical Report, Part I." Argonne National Lab ANL-4603, February 1951.
212. Sonnemann, G. "A Method of Correlating Burnout Heat Flux Data." *Nuclear Science and Engineering*, Vol. 5, No. 4, 1959, pp. 242-247.
213. Pasqua, P. F., et al. "Analytical Studies on Nozzle Throat Cooling." AEDC-TDR-63-58, April 1963.

214. Janssen, E. and Levy, S. "Burnout Limit Curves for Boiling Water Reactors." GE Report APED-3892, April 1962.
215. Janssen, E., Levy, S. and Kervinen, J. A. "Investigations of Burnout in an Internally Heated Annulus Cooled by Water at 600 to 1450 psia." ASME Paper 63-WA-149, 1963.
216. Labuntsov, D. A. "Critical Thermal Loads in Forced Motion of Water Which is Heated to a Temperature Below the Saturation Temperature." *Soviet Atomic Energy*, Vol. 10, No. 5, March 1962, pp. 516-518.
217. Macbeth, R. V. "Burn-out Analysis, Part 4: Application of a Local Conditions Hypothesis to World Data for Uniformly Heated Round Tubes and Rectangular Channels." AEEW-R 267, August 1963.
218. Thompson, B. and Macbeth, R. V. "Boiling Water Heat Transfer - Burnout in Uniformly Heated Round Tubes: A Compilation of World Data with Accurate Correlations." AEEW-R356, July 1964.
219. Bernath, L. "Prediction of Heat Transfer Burnout." *Heat Transfer - Louisville Chemical Engineering Progress Symposium Series*, Vol. 52, No. 18, 1956.
220. DeBortoli, R. A., et al. "Forced-Convection Heat Transfer Burnout Studies for Water in Rectangular Channels and Round Tubes at Pressures above 500 psia." U.S. Atomic Energy Commission Report WAPD-188, October 1958.
221. Barnett, P. G. "An Investigation into the Validity of Certain Hypotheses Implied by Various Burnout Correlations." AEEW-R 214, 1963.
222. Doroschuk, V. E., Levitan, L. L., and Lantsman, F. P. "Investigations into Burnout in Uniformly Heated Tubes." ASME Paper 75-WA/HT-22, 1975.
223. Levitan, L. L. and Lantsman, F. P. "Investigating Burnout with Flow of a Steam-Water Mixture in a Round Tube." *Teploenergetika*, Vol. 22, No. 1, 1975, pp. 80-83.
224. Scientific Council of the Academy of Sciences of the USSR. "Tabular Data for Calculating Burnout When Boiling Water in Uniformly Heated Round Tubes." *Teploenergetika*, Vol. 23, No. 9, 1976, pp. 90-92.



225. Bowring, R. W. "A Simple But Accurate Round Tube, Uniform Heat Flux, Dryout Correlation over the Pressure Range 0.7 to 17 MN/m<sup>2</sup> (100-2500 psia)." AEEW-R-789, March 1972.
226. Becker, K. M., et al. "Burnout Conditions for Round Tubes at Elevated Pressures." *Progress in Heat and Mass Transfer*, Vol. 6, 1972, pp. 55-73.
227. Knoebel, D. H., et al. "Forced-Convection Subcooled Critical Heat Flux, D<sub>2</sub>O and H<sub>2</sub>O Coolant with Aluminum and Stainless Steel Heaters." U.S. Atomic Energy Commission Report No. DP-1306, E. I. DuPont de Nemours and Co., February 1973.
228. Green, W. J. and Lawther, K. R. "Application of a General Critical Heat Flux Correlation for Coolant Flows in Uniformly Heated Tubes to High Pressure Water and Liquid Nitrogen." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 279-284.
229. Shah, M. M. "A Generalized Graphical Method for Predicting CHF in Uniformly Heated Vertical Tubes." *International Journal of Heat Mass Transfer*, Vol. 22, 1979, pp. 557-568.
230. Shah, M. M. "A General Correlation for Critical Heat Flux in Annuli." *International Journal of Heat Mass Transfer*, Vol. 23, 1980, pp. 225-234.
231. Gambill, W. R. and Lienhard, J. H. "An Upper Bound for the Critical Boiling Heat Flux." *Journal of Heat Transfer*, Vol. 111, August 1989, pp. 815-818.
232. Ornatskii, A. P. and Vinyarskii, L. S. "Heat Transfer Crisis in a Forced Flow of Underheated Water in Small-Bore Tubes." *High Temperature*, Vol. 3, 1965, pp. 400-406 (translated from *Teplofizika Vysokikh Temperature*, Vol. 3, No. 3, May-June 1965, pp. 444-451).
233. Gambill, W. R. "Burnout in Boiling Heat Transfer - Part II. Subcooled Forced-Convection System." *Nuclear Safety*, Vol. 9, No. 6, November-December 1968, pp. 467-480.
234. Dutton, R. and Lee, E. C. "Surface-Temperature Measurement of Current-Carrying Objects." *ISA Journal*, Vol. 6, No. 12, December 1959, pp. 49-51.
235. Tolubinskiy, V. I. and Domashev, E. D. "Discrepancies between Experimental Data on Burnout Heat Transfer in Channels." *Heat Transfer—Soviet Research*, Vol. 18, No. 4, July-August 1986, pp.1-20.

236. Shekriladze, I. G., et al. "Experimental Study of Critical Heat Fluxes in Boiling." *Journal of Engineering Physics*, Vol. 40, No. 6, 1981, pp. 613-614.
237. Ram, K. S. and McKnight, R. D. "Noise Analysis Techniques as Applied to Nucleate Pool Boiling." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B1.7, 1970.
238. Lineberger, E. R., III. "Bubble Detection Using a Dual Frequency Sound Field." MS Thesis, Naval Postgraduate School, AD-207 286, December 1988.
239. Costello, C. P. "Aspects of Local Boiling Effects on Density and Pressure Drop." ASME Paper 59-HT-18, 1959.
240. Rogers, J. T., Salcudean, M., and Tahir, A. E. "Flow Boiling Critical Heat Fluxes for Water in a Vertical Annulus at Low Pressure and Velocities." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 339-344.
241. Edelman, Z., Elias, E., and Naot, D. "Inverted Annular Boiling in a Stainless-Steel Tube with Steady Heat Sources." *International Journal of Heat Mass Transfer*, Vol. 28, No. 7, 1985, pp. 1281-1292.
242. Jiji, L. M. and Clark, J. A. "Bubble Boundary Layer and Temperature Profiles for Forced Convection Boiling in Channel Flow." *Journal of Heat Transfer*, Vol. 86, February 1964, pp. 50-58 (also ASME Paper 62-WA-141).
243. Stefanovic, M., et al. "Experimental Investigation of the Superheated Boundary Layer in Forced Convection Boiling." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B4.12, 1970.
244. Stenning, A. H. and Veziroglu, T. N. "Flow Oscillation Modes in Forced-Convection Boiling." *Proceedings of the Heat Transfer and Fluid Mechanics Institute*, 1965, pp. 301-316.
245. Jeglic, F. A. and Yang, K. T. "The Incipience of Flow Oscillations in Forced-Flow Subcooled Boiling." *Proceedings of the Heat Transfer and Fluid Mechanics Institute*, 1965, pp. 331-344.
246. Romberg, T. M. and Harris, R. W. "Application of Vibration Signals to the Identification of Hydrodynamic Instabilities in a Heated Channel." *Journal of Sound and Vibration*, Vol. 65, No. 3, 1979, pp. 329-338.

247. Schmidt, F. W., Robinson, G. E., and Skapura, R. J. "Experimental Study of Noise Generation in a Nucleate Boiling System," *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B1.8, 1970.
248. Ornatskiy, A. P. and Sharayevskiy, I. G. "Acoustic Phenomena Accompanying Boiling of Water in Annuli under Forced Convection." *Heat Transfer—Soviet Research*, Vol. 9, No. 3, May-June 1977, pp. 28-34.
249. Ornatskiy, A. P. and Sharayevskiy, I. G. "Onset and Development of Thermoacoustic Oscillations in Forced-Convection Boiling of Water." *Heat Transfer—Soviet Research*, Vol. 12, No. 1, January-February 1980, pp. 137-144.
250. Tolubinskiy, V. I., et al. "Investigation of Forced-Convection Boiling by the Acoustical Method." *Heat Transfer—Soviet Research*, Vol. 12, No. 2, March-April 1980, pp. 141-146.
251. Aljishi, S. and Tatarkiewicz, J. "Why Does Heating Water in a Kettle Produce Sound?" *American Journal of Physics*, Vol. 59, No. 7, July 1991, pp. 628-632.
252. Bakhru, N. and Lienhard, J. H. "Boiling from Small Cylinders." *International Journal of Heat Mass Transfer*, Vol. 15, 1972, pp. 2011-2025.
253. Reddy, R. P. and Lienhard, J. H. "The Peak Boiling Heat Flux in Saturated Ethanol-Water Mixtures." *Transactions of the ASME*, Vol. 111, May 1989, pp. 480-486.
254. Monrad, C.C. and Pelton, J. F. "Heat Transfer by Convection in Annular Spaces." *Transactions of the AIChE*, Vol. 38, 1942, pp. 593-611.
255. Davidson, W. F., et al. "Studies of Heat Transmission Through Boiler Tubing at Pressures from 500 to 3300 Pounds." *Transactions of the ASME*, Vol. 65, August 1943, pp. 553-591.
256. McAdams, W. H., Addoms, J. N., and Kennel, W. E. "Heat Transfer at High Rates to Water with Surface Boiling." Argonne National Laboratory, ANL-4268, December 1948.
257. Kaufman, S. J. and Isely, F. D. "Preliminary Investigation of Heat Transfer to Water Flowing in an Electrically Heated Inconel Tube." NACA RM E50G31, September 1950.

258. Rohsenow, W. M. and Clark, J. A. "Heat Transfer and Pressure Drop Data for High Heat Flux Densities to Water at High Subcritical Pressures." *Heat Transfer and Fluid Mechanics Institute*, 1951, pp. 193-207.
259. Jens, W. H. and Lottes, P. A. "Two-Phase Pressure Drop and Burnout Using Water Flowing in Round and Rectangular Channels." Argonne National Laboratory, ANL-4915, October 1952.
260. Piret, E. L. and Isbin, H. S. "Natural-Circulation Evaporation." *Chemical Engineering Progress*, Vol. 50, No. 6, June 1954, pp. 305-311.
261. Sabersky, R. H. and Mulligan, H. E. "On the Relationship Between Fluid Friction and Heat Transfer in Nucleate Boiling." *Jet Propulsion*, Vol. 25, No. 1, January 1955, pp. 9-12.
262. McEwen, L. H., et al. "Heat Transfer 'Beyond Burnout' for Forced-Convection Bulk Boiling." ASME Paper No. 57-SA-49, 1957.
263. Reynolds, J. M. "Burnout in Forced Convection Nucleate Boiling of Water." MIT TR-10 (AD235387), July 1957.
264. Zenkevich, B. A., Subbotin, V. I., and Troianov, M. F. "Critical Heat Load for Longitudinal Wetting of a Tube Bundle for Water Heated to Saturation Temperature." *Soviet Journal of Atomic Energy*, Vol. 4, 1958, pp. 485-487.
265. Griffith, P., Clark, J. A., and Rohsenow, W. M. "Void Volumes in Subcooled Boiling Systems." ASME Paper 58-HT-19, 1958.
266. Core, T. C. and Sato, K., "Determination of Burnout Limits of Polyphenyl Coolants." Aerojet General Corporation Report No. ID0-28007, February 1958.
267. Gambill, W.R. and Greene, N. D. "Boiling Burnout with Water in Vortex Flow." *Chemical Engineering Progress*, Vol. 54, No. 10, October 1958, pp. 68-76.
268. Foltz, H. L. and Murray, R. G. "Heat Transfer Rates to Boiling Freon 114 in Vertical Copper Tubes." *Chemical Engineering Progress Symposium Series*, Vol. 55, No. 29, 1959, pp. 79-86.
269. Zenkevich, B. A. and Subbotin, V. I. "Critical Heat Fluxes in Sub-cooled Water with Forced Circulation." *Journal of Nuclear Energy, Part B: Reactor Technology*, Vol. 1, 1959, pp. 134-136.

270. Schrock, V. E. and Grossman, L. M. "Local Pressure Gradients in Forced Convection Vaporization." *Nuclear Science and Engineering*, Vol. 3, 1959, pp. 245-350.
271. Zenkevich, B. A., Subbotin, V. I., and Troyanov, M. F. "Critical Heat Fluxes for a Bundle of Tubes Cooled in Pressurized Water." *Journal of Nuclear Energy, Part B: Reactor Technology*, Vol. 1, 1960, pp. 197-199.
272. Owens, W. L. and Schrock, V. E. "Local Pressure Gradients for Subcooled Boiling of Water in Vertical Tubes." ASME Paper 60-WA-249, 1960.
273. Mandler, O. J., et al. "Natural-Circulation Tests with Water at 800 to 2000 psia Under Nonboiling, Local Boiling, and Bulk Boiling Conditions." *Journal of Heat Transfer*, Vol. 83, August 1961, pp. 261-273.
274. Bankoff, S. G. and Mason, J. P. "Heat Transfer from the Surface of a Steam Bubble in Turbulent Subcooled Liquid Stream." *AIChE Journal*, Vol. 8, No. 1, March 1962, pp. 30-33.
275. Swenson, H. S., Carver, J. R., and Szoeko, G. "The Effects of Nucleate Boiling Versus Film Boiling on Heat Transfer in Power Boiler Tubes." *Journal of Engineering for Power*, Vol. 84, October 1962, pp. 365-370.
276. Schaefer, J. W. and Jack, J. R. "Investigation of Forced-Convection Nucleate Boiling of Water for Nozzle Cooling at Very High Heat Fluxes." NASA TN D-1214, May 1962.
277. Papell, S. S. "Subcooled Boiling Heat Transfer Under Forced Convection in a Heated Tube." NASA TN D-1583, 1963.
278. Judd, R. L. and Wade, J. H. T. "Forced Convection Heat Transfer in Eccentric Annular Passages." *Proceedings of the Heat Transfer and Fluid Mechanics Institute*, 1963, pp. 272-288.
279. Becker, K. M. "Burnout Conditions for Flow of Boiling Water in Vertical Rod Clusters." *AIChE Journal*, Vol. 9, No. 2, March 1963, pp. 216-222.
280. Lee, D. H. and Obertelli, J. D. "An Experimental Investigation of Forced Convection Burnout in High Pressure Water, Part II. Preliminary Results for Round Tubes with Non-Uniform Axial Heat Flux Distribution." AEEW-R 309, 1963.

281. Styrikovich, M. A., Miropol'skii, Z. L., and Eva, V. K. "The Influence of Local Raised Heat Fluxes Along the Length of a Channel on the Boiling Crisis." *Soviet Physics - Doklady*, Vol. 7, No. 7, January 1963, pp. 597-599.
282. Hosler, E. R. "Visual Study of Boiling at High Pressure." *Chemical Engineering Progress Symposium Series*, Vol. 61, No. 57, 1965, pp. 269-279.
283. Feldmanis, C. J. "Pressure and Temperature Changes in Closed Loop Forced Convection Boiling and Condensing Processes under Zero Gravity Conditions." FDL-(FDPE)-65-TM-45 (AD472881), October 1965.
284. Waters, E. D., et al. "Experimental Observations of Upstream Boiling Burnout." *Chemical Engineering Progress Symposium Series*, Vol. 61, No. 57, 1965, pp. 230-237.
285. Rousar, D. C. and Van Huff, N. E. "Heat-Transfer Characteristics of 98% H<sub>2</sub>O<sub>2</sub> at High Pressure and High Velocity." AFRPL-TR-66-263 (AGC Report 10785-SR-1), August 1966.
286. Owhadi, A. "Boiling in Self-Induced Radial Acceleration Fields." Ph.D. Thesis, Oklahoma State University, 1966.
287. Todreas, N. E. and Rohsenow, W. M. "The Effect of Axial Heat Flux Distribution on Critical Heat Flux in Annular, Two Phase Flow." *Proceedings of the 3rd International Heat Transfer Conference*, Vol. III, 1966, pp. 78-85.
288. Moeck, E. O., et al. "Critical Heat Fluxes in Internally Heated Annuli of Large Diameter Cooled by Boiling Water at 1000 psia." *Proceedings of the 3rd International Heat Transfer Conference*, Vol. III, 1966, pp. 86-97.
289. Maulbetsch, J. S. and Griffith, P. "System-Induced Instabilities in Forced-Convection Flows with Subcooled Boiling." *Proceedings of the 3rd International Heat Transfer Conference*, Vol. IV, 1966, pp. 247-257.
290. Larsen, P. S., et al. "DNB Measurements for Upwards Flow of Water in an Unheated Square Channel with a Single Uniformly Heated Rod at 1600-2300 psia." *Proceedings of the 3rd International Heat Transfer Conference*, Vol. III, 1966, pp. 143-148.
291. Bergles, A. E. and Suo, M. "Investigation of Boiling Water Flow Regimes at High Pressure." *Proceedings of the Heat Transfer and Fluid Mechanics Institute*, 1966, pp. 79-99.

292. Glickstein, M. R. and Whitesides, R. H., Jr. "Forced-Convection Nucleate and Film Boiling of Several Aliphatic Hydrocarbons." ASME Paper No. 67-HT-7, 1967.
293. Weisman, J., et al. "Experimental Determination of the Departure from Nucleate Boiling in Large Rod Bundles at High Pressures." *Chemical Engineering Progress Symposium Series*, Vol. 82, No. 64, 1968, pp. 114-125.
294. Lopina, R. F. and Bergles, A. E. "Heat Transfer and Pressure Drop in Tape-Generated Swirl Flow of Single-Phase Water." *Journal of Heat Transfer*, Vol. 91, August 1969, pp. 434-442.
295. Miropol'skiy, Z. L. and Pikus, V. Yu. "Critical Boiling Heat Fluxes in Curved Channels." *Heat Transfer—Soviet Research*, Vol. 1, No. 1, January 1969, pp. 74-79.
296. Tolubinsky, V. I., Litoshenko, A. K., and Shevtsov, V. L. "Correlation of Experimental Data on Critical Heat Fluxes in Annular Channels." *Heat Transfer—Soviet Research*, Vol. 1, No. 1, January 1969, pp. 80-87.
297. Peskov, O. L., et al. "The Critical Heat Flux for the Flow of Steam-Water Mixtures Through Pipes." *Problems of Heat Transfer and Hydraulics of Two-Phase Media - A Symposium*, Pergamon Press, New York, 1969, pp. 48-62 (First Edition).
298. Sterman, L. S. and Nekrasov, A. V. "Studies of Burnout Heat Fluxes with Water Boiling in Tubes." *Proceedings of the 4th International Heat Transfer Conference*, Vol. VI, Paper No. B6.9, 1970.
299. Osmachkin, V. S. and Borisov, V. D. "Pressure Drop and Heat Transfer for Flow of Boiling Water in Vertical Rod Bundles." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B4.9, 1970.
300. Gaddis, E. S. and Hall, W. B. "Forced Convection Boiling From Prepared Nucleation Sites." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B4.4, 1970.
301. Johnson, H. A. "Transient Boiling Heat Transfer." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B3.1, 1970.
302. Kawamura, H., Tachibana, F., and Akiyama, M. "Heat Transfer and DNB Heat Flux in Transient Boiling." *Proceedings of the 4th International Heat Transfer Conference*, Vol. V, Paper No. B3.3, 1970.

303. Mattson, R. J. "A Photographic Study of Subcooled Flow Boiling and the Boiling Crisis in Freon-113." Ph.D. Thesis, University of Michigan, 1972.
304. Plummer, D. N., et al. "A Study of Post Critical Heat Flux Heat Transfer in a Forced Convection System." MIT TR 73645-80, March 1973.
305. Katto, Y. and Monde, M. "Study of Mechanism of Burn-out in a High Heat-Flux Boiling System with an Impinging Jet." *Proceedings of the 5th International Heat Transfer Conference - Tokyo*, Vol. 4, 1974, pp. 245-249.
306. Ornatskiy, A. P., Chernobay, V. A., and Vasil'yev, A. F. "Heat Transfer Crisis in Annuli in Which the Rate of Heat Transfer Varies Longitudinally." *Heat Transfer—Soviet Research*, Vol. 7, No. 4, July-August 1975, pp. 27-30.
307. Iloeje, O. C., et al. "An Investigation of the Collapse and Surface Rewet in Film Boiling in Forced Vertical Flow." *Journal of Heat Transfer*, Vol. 97, May 1975, pp. 166-172.
308. Spencer, R. G. and Rousar, D. C. "Supercritical Oxygen Heat Transfer." NASA CR-135339, November 1977.
309. Cumo, M., et al. "Boiling Sublayers Along Heated Walls." *AIChE Symposium Series*, Vol. 73, No. 164, 1977, pp. 14-20.
310. Lung, H., Latsch, K., and Rampf, H. "Boiling Heat Transfer to Subcooled Water in Turbulent Annular Flow." *Heat Transfer in Boiling*, edited by E. Hahne and U. Grigull, Academic Press, 1977, pp. 219-235 .
311. Eddington, R. I. and Kenning, D. B. R. "The Prediction of Flow Boiling Bubble Population from Gas Bubble Nucleation Experiments." *Proceedings of the 6th International Heat Transfer Conference*, Vol. 1, 1978, pp. 275-279.
312. Eddington, R. I., Kenning, D. B. R., and Korneichev, A. I. "Comparison of Gas and Vapour Bubble Nucleation on a Brass Surface in Water." *International Journal of Heat Mass Transfer*, Vol. 21, 1978, pp. 855-862.
313. Kutateladze, S. S. and Malenkov, I. G. "Boiling and Bubbling Heat Transfer Under the Conditions of Free and Forced Convection." *Proceedings of the 6th International Heat Transfer Conference*, Toronto, Vol. 1, August 1978, pp. 281-286.



314. Monde, M. and Katto, Y. "Burnout in a High Heat-Flux Boiling System with an Impinging Jet." *International Journal of Heat Mass Transfer*, Vol. 21, 1978, pp. 295-305.
315. Drizius, M. -R. M., Skema, R. K., and Slanciauskas, A. A. "Boiling Crisis in Swirled Flow of Water in Pipes." *Heat Transfer—Soviet Research*, Vol. 10, No. 4, July-August 1978, pp. 1-7.
316. Doroschuk, V. E., et al. "Investigations into Burnout Mechanism in Steam-Generating Tubes." *Proceedings of the 6th International Heat Transfer Conference - Toronto*, Vol. 1, Paper No. FB-21, August 1978.
317. Ragheb, H. S., Cheng, S. C., and Groeneveld, D. C. "Measurement of Transition Boiling Boundaries in Forced Convection Flow." *International Journal of Heat Mass Transfer*, Vol. 21, 1978, pp. 1621-1624.
318. Chen, W. J., Lee, Y., and Groeneveld, D. C. "Measurement of Boiling Curves During Rewetting of a Hot Circular Duct." *International Journal of Heat Mass Transfer*, Vol. 22, 1979, pp. 973-976.
319. Ragheb, H. S. and Cheng, S. C. "Surface Wetted Area During Transition Boiling in Forced Convection Flow." *Journal of Heat Transfer*, Vol. 101, May 1979, pp. 381-383.
320. Bennett, D. L. and Chen, J. C. "Forced Convection Boiling in Vertical Tubes for Saturated Pure Components and Binary Mixtures." *AIChE Journal*, Vol. 26, No. 3, May 1980, pp. 454-461.
321. Mori, Y. H., Sano, H., and Komotori, K. "Cinemicrophotographic Study of Boiling of Water-in-Oil Emulsions." *International Journal of Multiphase Flow*, Vol. 6, 1980, pp. 255-266.
322. Petukhov, B. S., Zhukov, V. M., and Shil'dkret, V. M. "Investigation of Forced-Convection Boiling Heat Transfer with Helium." *Heat Transfer - Soviet Research*, Vol. 12, No. 3, May-June 1980, pp. 51-57.
323. Koba, A. L., et al. "Burnout with Boiling under Conditions of Forced Motion in Capillaries." *Thermal Engineering*, Vol. 27, No. 6, 1980, pp. 355-357.

324. Yilmaz, S. and Westwater, J. W. "Effect of Velocity on Heat Transfer to Boiling Freon-113." *Journal of Heat Transfer*, Vol. 102, February 1980, pp. 26-31.
325. Yao, S. C. "Boiling Heat Transfer in Confined Space." Carnegie-Mellon University Report N00014-79-C-0623 (ADA107363), October 1981.
326. Styrikovich, M. A., et al. "Boiling Crises in Horizontal Channels with a Screen on the Inside Surface." *High Temperature*, Vol. 18, No. 4, 1981, pp. 617-622.
327. Ramamohan, T. R., Somalingeswara Rao, A., and Srinivas, N. S. "Forced Convection Heat Transfer to Boiling Binary Mixtures." *Canadian Journal of Chemical Engineering*, Vol. 59, June 1981, pp. 400-402.
328. France, D. M., et al. "Critical Heat Flux Experiments and Correlation in a Long, Sodium-Heated Tube." *Journal of Heat Transfer*, Vol. 103, February 1981, pp. 74-80.
329. Agrawal, K. N., Varma, H. K., and Lal, S. "Pressure Drop During Forced Convection Boiling of R-12 Under Swirl Flow." *Journal of Heat Transfer*, Vol. 104, November 1982, pp. 758-762.
330. Aounallah, A., et al. "Boiling Heat Transfer in Annular Flow." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 193-199.
331. Fukuyama, Y. and Hirata, M. "Boiling Heat Transfer Characteristics with High Mass Flux and Disappearance of CHF Following to DNB." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 273-278.
332. Katto, Y. and Ashida, S. "CHF in High-Pressure Regime for Forced Convection Boiling in Uniformly Heated Vertical Tubes of Low Length-to-Diameter Ratio," *Proceedings 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 291-296.
333. Mishima, K. and Ishii, M. "Experimental Study on Natural Convection Boiling Burnout in An Annulus." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 309-314.
334. Sekoguchi, K., et al. "Heat Transfer Characteristics of Boiling Flow in Subcooled and Low Quality Regions." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 243-248.

335. Viannay, S. and Karian, J. "Study of the Accelerated Cooling of a Very Hot Wall with a Forced Flow of Subcooled Liquid in Film Boiling Regime." *Proceedings of the 7th International Heat Transfer Conference*, Vol. 4, 1982, pp. 431-435.
336. Ueda, T., Tsunenari, S., and Koyanagi, M. "An Investigation of Critical Heat Flux and Surface Rewet in Flow Boiling Systems." *International Journal of Heat Mass Transfer*, Vol. 26, No. 8, 1983, pp. 1189-1198.
337. Sharon, A., Chen, L., and Bankoff, S. G. "Convective Boiling Heat Transfer in a Concentric Annular Gap." *International Journal of Multiphase Flow*, Vol. 9, No. 5, 1983, pp. 545-560.
338. Klimenko, V. V. and Sudarchikov, A. M. "Investigation of Forced Flow Boiling of Nitrogen in a Long Vertical Tub." *Cryogenics*, Vol. 23, July 1983, pp. 379-385.
339. Baines, R. P., El Masri, M. A., and Rohsenow, W. M. "Critical Heat Flux in Flowing Liquid Films." *International Journal of Heat Mass Transfer*, Vol. 27, No. 9, 1984, pp. 1623-1629.
340. Kozhelupenko, Yu D., Smirnov, G. F., and Koba, A. L. "Boiling Crisis (Dryout) in Low-Velocity Flow of Subcooled Water in Narrow Annuli." *Heat Transfer—Soviet Research*, Vol. 17, No. 5, September-October 1985, pp. 93-96.
341. Hino, R. and Ueda, T. "Studies on Heat Transfer and Flow Characteristics in Subcooled Flow Boiling." *International Journal of Multiphase Flow*, Vol. 11, No. 3, 1985, pp. 269-297.
342. Evans, D., Webb, S. W., and Chen, J. C. "Axially Varying Vapor Superheats in Convective Film Boiling." *Journal of Heat Transfer*, Vol. 107, August 1985, pp. 663-669.
343. Fujita, Y., et al. "Nucleate Boiling Heat Transfer on Horizontal Tubes in Bundles." *Proceedings of the 8th International Heat Transfer Conference*, Vol. 5, 1986, pp. 2131-2136.
344. Fukuyama, Y., Kuriyama, T., and Hirata, M. "Boiling Transition and the Possibility of Spontaneous Nucleation under High Subcooling and High Mass Flux Density Flow in a Tube." *Proceedings of the 8th International Heat Transfer Conference*, Vol. 5, 1986, pp. 2197-2202.

345. Grigoriev, V. A., Klimenko, V. V., and Klimenko, A. V. "Pool and Channel Nucleate Boiling of Cryogenic Fluids—Similarities and Differences." *Proceedings of the 8th International Heat Transfer Conference*, Vol. 5, 1986, pp. 2161-2166.
346. Steinhagen, M. H., Watkinson, A. P., and Epstein, N. "Subcooled-Boiling and Convective Heat Transfer to Heptane Flowing Inside an Annulus and Past a Coiled Wire." *Journal of Heat Transfer*, Vol. 108, November 1986, pp. 922-933.
347. Ueda, T. and Kim, K. "Heat Transfer Characteristics During the Critical Heat Flux Condition in a Subcooled Flow Boiling System." *Proceedings of the 8th International Heat Transfer Conference*, Vol. 5, 1986, pp. 2203-2208.
348. Aounallah, A. and Kenning, D. B. R. "Nucleate Boiling and the Chen Correlation for Flow Boiling Heat Transfer." *Experimental Heat Transfer*, Vol. 1, 1987, pp. 87-92.
349. Yezhova, L. I., et al. "Effect of Dissolved Gas on Boiling Heat Transfer and on the Boiling Crisis." *Heat Transfer—Soviet Research*, Vol. 19, No. 1, January-February 1987, pp. 55-60.
350. Lee, Y. and Shen, W. -Q. "Effect of Surface Roughness on the Rewetting Process." *International Journal of Multiphase Flow*, Vol. 13, No. 6, 1987, pp. 857-861.
351. Inasaka, F. and Nariai, H. "Critical Heat Flux and Flow Characteristics of Subcooled Flow Boiling in Narrow Tubes." *JSME International Journal*, Vol. 30, No. 268, 1987, pp. 1595-1600.
352. El-Genk, M. S., Haynes, S. J., and Kim, S. "Experimental Studies of Critical Heat Flux for Low Flow of Water in Vertical Annuli at Near Atmospheric Pressure." *International Journal of Heat Mass Transfer*, Vol. 31, No. 11, 1988, pp. 2291-2304.
353. Steinhagen, M. H., Epstein, N., and Watkinson, A. P. "Effect of Dissolved Gases on Subcooled Flow Boiling Heat Transfer." *Chemical Engineering Processes*, Vol. 23, 1988, pp. 115-124.
354. Yin, S. T., et al. "Measurements of Critical Heat Flux in Forced Flow at Pressures up to the Vicinity of the Critical Point of Water." *ASME Proceedings*, 1988 National Heat Transfer Conference, Vol. 2, HTD-Vol. 96, edited by H. R. Jacobs, 1988, pp. 501-506.

355. Fleishman, R. V. and Yuen, W. W. "Mesh Enhanced Forced Convection Heat Transfer for High Heat Flux Applications." *ASME Proceedings*, 1988 National Heat Transfer Conference, Vol. 1, HTD-Vol. 96, edited by H. R. Jacobs, 1988, pp. 653-660.
356. Passos, J. C. and Gentile, D. "An Experimental Investigation of the Transition Boiling in a Subcooled Freon 113 Forced Flow." Presented at the Winter Annual Meeting of ASME, Chicago, Fundamentals of Gas-Liquid Flows, Vol. 72, November-December 1988, pp. 57-61.
357. Blumenkrantz, A., "Comparison of Rod Bundle- and Single Tube- Critical Heat Flux Data." *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1988*, edited by R. K. Shah, E. N. Ganic, and K. T. Yang, Elsevier Science Publishing Co., 1988, pp. 1496-1501.
358. Boyd, R. D. "Subcooled Water Flow Boiling Experiments under Uniform High Heat Flux Conditions." *Fusion Technology*, Vol. 13, 1988, pp. 131-142.
359. Lee, T. Y. and Simon, T. W. "Critical Heat Flux in Forced Convection Boiling from Small Regions." Presented at the Winter Annual Meeting of ASME, San Francisco, Heat Transfer in High Energy/High Heat Flux Applications, Vol. 119, December 1989, pp. 1-7.
360. Jung, D. S., et al. "Horizontal Flow Boiling Heat Transfer Experiments with a Mixture of R22/R114." *International Journal of Heat Mass Transfer*, Vol. 32, No. 1, 1989, pp. 131-145.
361. Jung, D. S., et al. "A Study of Flow Boiling Heat Transfer with Refrigerant Mixtures." *International Journal of Heat Mass Transfer*, Vol. 32, No. 9, 1989, pp. 1751-1764.
362. Polonskii, V. S., et al. "Boundary of the Onset of Surface Boiling in Straight High-Pressure Steam-Generating Channels." *High Temperature*, Vol. 27, No. 5, March 1990, pp. 745-749 (*Teplofizika Vysokikh Temperatur*, 1989).
363. Hasan, A., Roy, R. P., and Kalra, S. P. "Experiments on Subcooled Flow Boiling Heat Transfer in a Vertical Annular Channel." *International Journal of Heat Mass Transfer*, Vol. 33, No. 10, 1990, pp. 2285-2293.
364. Cornwell, K. "The Influence of Bubbly Flow on Boiling from a Tube in a Bundle." *International Journal of Heat Mass Transfer*, Vol. 33, No. 12, 1990, pp. 2579-2584.

365. Sivagnanam, P. and Varma, Y. B. G. "Subcooled Boiling of Binary Mixtures under Conditions of Forced Convection." *Experimental Thermal and Fluid Science*, Vol. 3, 1990, pp. 515-522.
366. El-Genk, M. S., Bedrose, S. D., and Rao, D. V. "Forced and Combined Convection of Water in Rod Bundles." *Heat Transfer Engineering*, Vol. 11, No. 4, 1990, pp. 32-43.
367. Dietrich, M., Blochl, R., and Muller-Steinhagen, H., "Heat Transfer for Forced Convection Past Coiled Wires." *Journal of Heat Transfer*, Vol. 112, November 1990, pp. 921-925.
368. Vandervort, C. L., Bergles, A. E., and Jensen, M. K. "Ultimate Limits of Boiling Heat Fluxes." *Proceedings of the 8th Symposium on Energy Engineering Sciences*, May 1990, pp. 95-102.
369. Yuncu, H., et al. "The Effect of Inlet Subcooling and Heat Transfer Enhancement on Two-Phase Flow Pressure-Drop Type and Thermal Instabilities." *Proceedings of the 9th International Heat Transfer Conference*, Vol. 6, 1990, pp. 107-112.
370. Brauer, H., Mayinger, F., and Stangl, G. "Onset of Nucleate Boiling, Heat Transfer, Void Fraction and Pressure Drop in Subcooled Convective Boiling with R12." *Proceedings of the 9th International Heat Transfer Conference*, Vol. 3, 1990, pp. 419-424.
371. Hosaka, S., Hirata, M., and Kasagi, N. "Forced Convection Subcooled Boiling Heat Transfer and CHF in Small-Diameter Tubes." *Proceedings of the 9th International Heat Transfer Conference*, Vol. 2, 1990, pp. 129-134.
372. Hihara, E. and Saito, T. "Forced Convection Heat Transfer of Binary Mixtures in a Horizontal Tube." *Proceedings of the 9th International Heat Transfer Conference*, Vol. 2, 1990, pp. 123-128.
373. Hahne, E., Spindler, K., and Shen, N. "Incipience of Flow Boiling in Subcooled Well Wetting Fluids." *Proceedings of the 9th International Heat Transfer Conference*, Vol. 2, 1990, pp. 69-74.
374. Dougherty, T., et al. "Flow Boiling in Vertical Down-Flow." *Proceedings of the 9th International Heat Transfer Conference*, Vol. 2, 1990, pp. 9-14.
375. Liu, H. T. and Kakac, S. "Parametric Study of Two-Phase Flow Instabilities in a Convective Boiling Up-Flow System." *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1991*, edited by J. F. Keffer, R. K. Shah, and E. N. Ganic, Elsevier Science Publishing Co., 1991, pp. 1214-1221.

376. Ravindran, S., Jagadish, B. S., and Jaganmohan, A. "Flow Boiling in Horizontal Annuli." *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1991*, edited by J. F. Keffer, R. K. Shah, and E. N. Ganic, Elsevier Science Publishing Co., 1991, pp. 1007-1013.
377. Boyd, R. D., Sr. "Heat Transfer Transition and the L/D-Effect on Subcooled Water Flow Boiling CHF for a Horizontal Uniformly Heated Tube." *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1991*, edited by J. F. Keffer, R. K. Shah, and E. N. Ganic, Elsevier Science Publishing Co., 1991, pp. 939-944.
378. Feng, Q. and Johannsen, K. "Experimental Results of Maximum Transition Boiling Temperature During Upflow in a Circular Tube at Medium Pressure." *Experimental Thermal and Fluid Science*, Vol. 4, 1991, pp. 90-102.
379. Celata, G. P., et al. "CHF Behaviour During Pressure, Power and/or Flow Rate Simultaneous Variations." *International Journal of Heat Mass Transfer*, Vol. 33, No. 3, 1991, pp. 723-738.
380. Kocamustafaogullari, G. and Wang, Z. "An Experimental Study on Local Interfacial Parameters in a Horizontal Bubbly Two-Phase Flow." *International Journal of Multiphase Flow*, Vol. 17, No. 5, 1991, pp. 553-572.
381. Hasan, A., Roy, R. P., and Kalra, S. P. "Some Measurements in Subcooled Flow Boiling of Refrigerant-113." *Journal of Heat Transfer*, Vol. 113, February 1991, pp. 216-223.
382. Balino, J. L. and Converti, J. "Critical Heat Flux in Horizontal Annular Channels with Variable Eccentricity." *International Communications on Heat Mass Transfer*, Vol. 18, No. 5, September-October 1991, pp. 659-667.
383. Boyd, R. D., Sr. "Critical Heat Flux and Heat Transfer Transition for Subcooled Flow Boiling." *Journal of Heat Transfer*, Vol. 113, February 1991, pp. 264-266.
384. Gyul'mamedov, N. B., Yusufova, V. D., and Bronshtein, A. I. "The Effect of Trilon B Water Treatment on Critical Heat Transfer in a Vapour-Generating Channel." *Thermal Engineering*, Vol. 38, No. 7, 1991, pp. 395-397.
385. Galloway, J. E. and Mudawar, I. "Critical Heat Flux Enhancement by Means of Liquid Subcooling and Centrifugal Force Induced by Flow Curvature." *International Journal of Heat Mass Transfer*, Vol. 35, No. 5, 1992, pp. 1247-1260.

386. Dykas, S. and Jensen, M. K. "Critical Heat Flux on a Tube in a Horizontal Tube Bundle." *Experimental Thermal and Fluid Science*, Vol. 5, 1991, pp. 34-39.
387. Leroux, K. M. and Jensen, M. K. "Critical Heat Flux in Horizontal Tube Bundles in Vertical Crossflow of R113." *Journal of Heat Transfer*, Vol. 114, February 1992, pp. 179-184.
388. Orozco, J. and Chen, L. "Experimental Investigation of Transition Boiling in Forced Convection." *Journal of Thermophysics*, Vol. 6, No. 1, January-March 1992, pp. 145-151.
389. Panchal, C. B., France, D. M., and Bell, K. J. "Experimental Investigation of Single-Phase, Condensation, and Flow Boiling Heat Transfer for a Spirally Fluted Tube." *Heat Transfer Engineering*, Vol. 13, No. 1, 1992, pp. 42-52.
390. Willingham, T. C. and Mudawar, I. "Channel Height Effects on Forced-Convection Boiling and Critical Heat Flux From a Linear Array of Discrete Heat Sources." *International Journal of Heat Mass Transfer*, Vol. 35, No. 8, 1992, pp. 1865-1880.
391. Vandervort, C. L., Bergles, A. E., and Jensen, M. K. "Heat Transfer Mechanisms in Very High Heat Flux Subcooled Boiling." ASME HTD Vol. 217, *Fundamentals of Subcooled Flow Boiling*, 1992, pp. 1-9.



from Ref. 3

16




Figure 1. Basic boiling curve.




Figure 2. Effect of pressure and velocity on subcooled boiling.

from Ref. 24




Figure 3. Effect of velocity and subcooling.




Figure 4. Effect of mass velocity and vapor quality.

from Ref. 26




Figure 5. Effect of liquid velocity on bubble growth and collapse.

from Ref. 31




Figure 6. Effect of subcooling with increasing mass velocity.




Figure 7. Subcritical pressure water burnout heat flux.

from Ref. 27

- $\theta$  = Bubble Lifetime
- $N$  = Population
- $R_{max}$  = Average Maximum Bubble Radius
- $F$  = Average Fraction of Surface Coverage by Bubbles




Figure 8. Effect of subcooling on bubble characteristics.



from Ref. 36




Figure 9. Optimum pressure for the boiling of n-pentane.

from Ref. 15




Figure 10. Effect of heater size on optimum pressure.

from Ref. 1




Figure 11. Effect of mass velocity on optimum pressure.

from Ref. 38




Figure 12. Effect of pressure on bubble characteristics.





Figure 13. Effect of surface roughness on heat transfer.

from Ref. 40



103

Figure 14. Roughness effect on heat transfer.

from Ref. 47




Figure 15. Burnout heat flux of knurled surfaces.

from Ref. 54






Figure 16. Effect of a surface active agent on heat transfer.

$P = 6.6 \text{ bars}$   
 $\Delta T_{\text{sat}} = 50^\circ\text{C}$   
 $\Delta C = \text{Excess Concentration of the Volatile Component in the Vapor}$



a. Ethanol-water

from Ref. 63



b. Acetone-water

Figure 17. Effect of binary mixture concentrations on critical heat flux (CHF).



from Ref. 76




Figure 18. Effect of wall material on heat transfer.

from Ref. 78




Figure 19. Effect of wall material on CHF.




Figure 20. Effect of wall thickness on heat transfer.

from Ref. 7




Figure 21. Influence of tube diameter on CHF at various subcoolings.




Figure 22. Effect of tube diameter on CHF.




Figure 23. Effect of heated length on CHF.




Figure 24. Effect of tube length on CHF at various subcoolings.

- $G = 4,500 \text{ kg/m}^2/\text{sec}$  } Heating Surface at
- △  $G = 9,000 \text{ kg/m}^2/\text{sec}$  } Bottom of Channel
- $G = 4,500 \text{ kg/m}^2/\text{sec}$  } Heating Surface at
- ▲  $G = 9,000 \text{ kg/m}^2/\text{sec}$  } Top of Channel

from Ref. 96




Figure 25. Effect of position of the heating surface on CHF.






Figure 26. Effect of gas content on heat transfer.

from Ref. 21




Figure 27. Effect of curved test section on CHF.




Figure 28. Effect of undulating flow on heat transfer.

from Ref. 114








Figure 29. Pressure effect with flow swirl.


from Ref. 114



a.  $G = 500 \text{ kg/m}^2\text{-sec}$



b.  $G = 1,000 \text{ kg/m}^2\text{-sec}$



c.  $G = 1,700 \text{ kg/m}^2\text{-sec}$

Figure 30. Mass velocity effect with flow swirl.

from Ref. 90




Figure 31. Effect of nonuniform heating on CHF.





Figure 32. Comparison of steady-state and transient heating data.





$G = 1.78 \times 10^6 \text{ lbm/ft}^2 \text{ hr}$   
 $D = 0.76 \text{ in.}$




Figure 34. Effect of flow restriction on flow stability and burnout.




Figure 35. Parametric trends for subcooled, forced-convection cooling.

- $\theta$  = Bubble Lifetime
- $N$  = Population
- $R_{max}$  = Average Maximum Bubble Radius
- $F$  = Average Fraction of Surface Covered by Bubbles

from Ref. 27




Figure 36. Effect of heat-transfer rate on bubble characteristics.

from Ref. 161




Figure 37. Construction of the partial boiling curve.

- Addoms, Water, at 14.7, 283, 770, 1,205, 1,985, 2,465 psia (Ref. 15)
- + Cichelli-Bonilla, Benzene, at 14.7, 55, 115, 265, 515 psia (Ref. 36)
- ▽ Cichelli-Bonilla, n-Heptane, at 6.6, 14.7, 50, 115, 215 psia (Ref. 36)
- Piret-Isbin, Water, Carbon Tetrachloride, Iso-propyl and n-Butyl Alcohol, at 14.7 psia (Ref. 260)
- × Cichelli-Bonilla, n-Pentane, at 22,60, 115, 215, 315 psia (Ref. 36)
- △ Cichelli-Bonilla, Ethanol, at 14.7, 55, 115, 265, 515 psia (Ref. 36)




Figure 38. Determination of the coefficient  $B_L$  in the Levy correlation.

from Ref. 173




Figure 39. Dependence of overall pressure drop on operating conditions.

from Ref. 203




Figure 40. Generalized wall superheat at burnout.

from Ref. 218





Figure 41. Approximate limits of velocity regimes for round tubes.




from Ref. 218




a.  $A'$  for  $p = 560 \text{ psia}$

Figure 42. Constant inputs for the Thompson and Macbeth correlation.


from Ref. 218



**b.  $C'$  for  $p = 560 \text{ psia}$   
Figure 42. Continued.**




c.  $A'$  for  $p = 1,000 \text{ psia}$   
 Figure 42. Continued.




d.  $C'$  for  $p = 1,000$  psia  
 Figure 42. Continued.

from Ref. 218




e.  $A'$  for  $p = 1,550 \text{ psia}$   
 Figure 42. Continued.


from Ref. 218



f. C' for p = 1,550 psia  
Figure 42. Continued.



g.  $A'$  for  $p = 2,000$  psia  
 Figure 42. Continued.



h.  $C'$  for  $p = 2,000$  psia  
 Figure 42. Concluded.






Figure 43. Mass velocity range for the Becker burnout correlation.

## APPENDIX A

Table of Conversion Factors

| Multiply                 | By          | To Obtain             | Parameter                             |
|--------------------------|-------------|-----------------------|---------------------------------------|
| ft <sup>2</sup>          | 9.290E - 02 | m <sup>2</sup>        | A                                     |
| ft/sec                   | 3.048E - 01 | m/sec                 | V                                     |
| ft                       | 3.048E - 01 | m                     | D,L                                   |
| Btu/lbm°F                | 4.187E + 00 | kJ/kg°C               | c <sub>p</sub>                        |
| Btu/ft <sup>2</sup> hr   | 3.155E + 00 | W/m <sup>2</sup>      | q", CHF, q/A                          |
| in.                      | 2.540E + 01 | mm                    | d                                     |
| lbm/ft <sup>2</sup> hr   | 1.356E - 03 | kg/m <sup>2</sup> sec | G                                     |
| ft/hr <sup>2</sup>       | 2.352E - 08 | m/sec <sup>2</sup>    | g,a                                   |
| Btu/ft <sup>2</sup> hr°F | 5.679E + 00 | W/m <sup>2</sup> °C   | h                                     |
| Btu/lbm                  | 2.326E + 00 | kJ/kg                 | i, i <sub>fg</sub>                    |
| Btu/ft hr°F              | 1.731E + 00 | W/m°C                 | k                                     |
| psia                     | 6.895E - 02 | bar                   | p                                     |
| psia                     | 6.895E + 03 | Pa                    | p                                     |
| °F (differential)        | 5.556E - 01 | °C, K                 | ΔT <sub>sub</sub> , ΔT <sub>sat</sub> |
| ft <sup>2</sup> /hr      | 2.581E - 05 | m <sup>2</sup> /sec   | α                                     |
| lbm/ft hr                | 4.134E - 04 | kg/m sec              | μ                                     |
| lbm/ft <sup>3</sup>      | 1.602E + 01 | kg/m <sup>3</sup>     | ρ                                     |
| lbf/ft                   | 1.459E + 01 | N/m                   | σ                                     |
| lbf/ft <sup>2</sup>      | 4.788E + 01 | N/m <sup>2</sup>      | τ                                     |
| °C = 5/9 (°F - 32)       |             |                       |                                       |
| K = °C + 273.15          |             |                       |                                       |







## NOMENCLATURE

|                   |                                                                                 |
|-------------------|---------------------------------------------------------------------------------|
| A                 | Surface area, ft <sup>2</sup>                                                   |
| a                 | Centrifugal acceleration, ft/hr <sup>2</sup>                                    |
| Bo                | Boiling number, = $q''/G i_{fg}$                                                |
| c, c <sub>p</sub> | Specific heat, Btu/lbm °F                                                       |
| C <sub>D</sub>    | Drag coefficient for a sphere                                                   |
| CHF               | Critical heat flux, Btu/ft <sup>2</sup> hr                                      |
| D                 | Diameter, ft                                                                    |
| d                 | Bubble departure diameter, in.                                                  |
| DNB               | Departure from nucleate boiling                                                 |
| erfc              | Complementary error function                                                    |
| f                 | Friction factor as given in Eq. (5)                                             |
| G                 | Mass velocity, = $\rho V$ except as defined in Eq. (12), lbm/ft <sup>2</sup> hr |
| g                 | Acceleration of gravity, ft/hr <sup>2</sup>                                     |
| g <sub>c</sub>    | Gravitational constant, ft/hr <sup>2</sup>                                      |
| h                 | Heat-transfer coefficient, Btu/ft <sup>2</sup> hr °F                            |
| i                 | Enthalpy, Btu/lbm                                                               |
| i <sub>fg</sub>   | Latent heat of vaporization, Btu/lbm                                            |
| J                 | Energy conversion factor, = 778 ft-lbf/Btu                                      |
| k                 | Thermal conductivity, Btu/ft hr °F                                              |

|            |                                                        |
|------------|--------------------------------------------------------|
| L          | Length, ft                                             |
| $m_v$      | Vapor rate, lbm/hr                                     |
| Nu         | Nusselt number, = $hD/k$                               |
| p          | Pressure, psia                                         |
| Pr         | Prandtl number, = $\mu c/k$                            |
| $q'', q/A$ | Heat flux, Btu/ft <sup>2</sup> hr, except as noted     |
| $q''/V$    | Internal heat generation rate per unit volume          |
| R          | Ideal gas constant                                     |
| r          | Characteristic radius, ft                              |
| R'         | Laplace number, = $r[g(\rho_l - \rho_v)/\sigma]^{1/2}$ |
| Re         | Reynolds number, = $\rho VD/\mu$                       |
| T          | Temperature, °F                                        |
| t          | Wall thickness (Fig. 35)                               |
| $t_{in/2}$ | Time to reach half of initial flow, sec                |
| $t_{tr}$   | Flow rate transit time, sec                            |
| V          | Velocity, ft/sec                                       |
| x          | Vapor quality                                          |
| Z          | Length, as defined in Figs. 21 and 24                  |

**SYMBOLS**

|            |                                                                                    |
|------------|------------------------------------------------------------------------------------|
| $\alpha$   | Thermal diffusivity, ft <sup>2</sup> /hr                                           |
| $\Delta C$ | Excess concentration of the volatile component in the vapor, percent (see Fig. 17) |

|                          |                                                                                             |
|--------------------------|---------------------------------------------------------------------------------------------|
| $\Delta i_i$             | Enthalpy difference due to inlet subcooling, = $i_{\text{local}} - i_{\text{in}}$ , Btu/lbm |
| $\Delta T_{\text{bulk}}$ | Complete temperature difference, = $T_w - T_b$ , °F                                         |
| $\Delta T_{\text{sat}}$  | Superheat, = $T_w - T_{\text{sat}}$ , °F                                                    |
| $\Delta T_{\text{sub}}$  | Subcooling, = $T_{\text{sat}} - T_b$ , °F (may be inlet, outlet, local, or average)         |
| $\mu$                    | Viscosity, lbm/ft hr                                                                        |
| $\rho$                   | Density, lbm/ft <sup>3</sup>                                                                |
| $\sigma$                 | Surface tension, lbf/ft                                                                     |
| $\tau$                   | Shear stress, lbf/ft <sup>2</sup> [except as defined in Eqs. (38) and (39)]                 |
| $\phi_m$                 | Specific mass flow rate in Eq. (39), kg/m <sup>2</sup> sec                                  |

### SUBSCRIPTS

|       |                                                                             |
|-------|-----------------------------------------------------------------------------|
| avg   | Average                                                                     |
| B     | Fully developed nucleate boiling                                            |
| Bi    | Extension of the fully developed nucleate boiling curve to incipience point |
| b     | Bulk fluid                                                                  |
| CHF   | Critical heat flux conditions                                               |
| conv  | Pure convection conditions                                                  |
| cr    | Critical heat flux conditions                                               |
| D     | Diameter                                                                    |
| $D_e$ | Equivalent or hydraulic diameter                                            |
| e     | Equivalent or hydraulic                                                     |



|      |                              |
|------|------------------------------|
| f    | Film                         |
| FC   | Forced convection            |
| h    | Hydraulic                    |
| htr  | Heater                       |
| I    | Inner                        |
| i,in | Inlet                        |
| ℓ    | Liquid                       |
| LB   | Subcooled boiling incipience |
| m    | Mean                         |
| O    | Outer                        |
| o    | Outlet                       |
| r    | Reduced                      |
| sat  | Saturation                   |
| ss   | Steady-state conditions      |
| tr   | Transient conditions         |
| ts   | Test section                 |
| v    | Vapor                        |
| w    | Wall                         |