

DR. 2222

# THE BROOKHAVEN BUILDINGS ENERGY CONSERVATION OPTIMIZATION MODEL

Steven C. Carhart, Shirish S. Mulherkar, and Yasuko Sanborn

January 1978

Prepared for the  
DIVISION OF BUILDINGS AND COMMUNITY SYSTEMS  
UNITED STATES DEPARTMENT OF ENERGY  
by the  
ECONOMIC ANALYSIS DIVISION  
DEPARTMENT OF ENERGY AND ENVIRONMENT

BROOKHAVEN NATIONAL LABORATORY  
ASSOCIATED UNIVERSITIES, INC.

UNDER CONTRACT NO. EY-76-C-02-0016 WITH THE

UNITED STATES DEPARTMENT OF ENERGY



MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

# THE BROOKHAVEN BUILDINGS ENERGY CONSERVATION OPTIMIZATION MODEL

Steven C. Carhart, Shirish S. Mulherkar, and Yasuko Sanborn

January 1978

**NOTICE**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Prepared for the  
DIVISION OF BUILDINGS AND COMMUNITY SYSTEMS  
UNITED STATES DEPARTMENT OF ENERGY  
by the  
ECONOMIC ANALYSIS DIVISION  
DEPARTMENT OF ENERGY AND ENVIRONMENT

BROOKHAVEN NATIONAL LABORATORY  
UPTON, NEW YORK 11973

## NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy (DOE), nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Printed in the United States of America  
Available from  
National Technical Information Service  
U.S. Department of Commerce  
5285 Port Royal Road  
Springfield, VA 22161  
Price: Printed Copy \$6.00; Microfiche \$3.00

October 1978

475 copies

## ABSTRACT

The Brookhaven Buildings Energy Conservation Optimization Model is a linear programming representation of energy use in buildings. Starting with engineering and economic data on cost and performance of energy technologies used in buildings, including both conversion devices (such as heat pumps) and structural improvements, the model constructs alternative flows for energy through the technologies to meet demands for space heating, air conditioning, thermal applications, and electric lighting and appliances. Alternative paths have different costs and efficiencies. Within constraints such as total demand for energy services, retirement of existing buildings, seasonal operation of certain devices, and others, the model calculates an optimal configuration of energy technologies in buildings.

The penetration of the various basic technologies within this configuration is specified in considerable detail, covering new and retrofit markets for nine building types in four regions. Each market may choose from several appropriate conversion devices and four levels each of new and retrofit structural improvement.

The principal applications for which the model was designed include the following: market penetration analysis, showing the role of individual technologies within a system context; policy analysis, to show the effect of buildings sector policies on the technologies in the building stock; analysis of RD&D programs; analysis of the preferred configuration for sensitivity to changes in price or other variables; analysis of the effect of technology implementation rates on overall energy; and the environmental and supply system effects of buildings energy conservation.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

CONTENTS

Abstract..... iii

1. Introduction..... 1

2. Structure of BECOM..... 4

    2.1. Mathematical Structure..... 4

    2.2. Economic Structure..... 15

    2.3. Structure of the Equations..... 17

3. Data Inputs..... 22

4. Model Operation and Outputs..... 23

5. Applications..... 53

Acknowledgements..... 57

References..... 58

Appendix A: Residential and Commercial  
    Inventory and Forecasts..... 59

Appendix B: Theoretical Loads for  
    Buildings..... 65

    Conservation Technology Costs  
    and Savings..... 70

    First Costs of Conventional  
    HVAC Equipment..... 79



## 1. Introduction

The Brookhaven Buildings Energy Conservation Optimization Model (BECOM) is designed to provide a tool for projecting, analyzing, and evaluating the energy implications of conventional and proposed energy-related technologies in buildings. Starting with detailed cost and performance data for individual building technologies, the model assembles alternative combinations of these technologies within a linear programming framework. For any combination of building stocks, fuel prices and availabilities, and other constraints on technological availability, BECOM calculates the preferred technological configuration of the buildings sector. Because the basic elements of the model are specified in terms of technologies, this configuration is expressed in terms of levels of market penetration of specific technologies. BECOM is designed as an extension of the Brookhaven Energy System Optimization Model (BESOM).

BESOM is a representation of the technological and economic features of the energy system. It has been used for detailed analyses of energy resource allocation and technology implementation.<sup>1</sup> BESOM is a linear programming formulation of the Reference Energy System (RES). The RES, shown in Figure 1, is a specialized format for representing the detailed technological structure of the energy system. Solution of the BESOM model yields resource consumption, energy flows through the RES network, and emissions to air and water. Efficiency, cost, and environmental data are supplied by the Energy Model Data Base.<sup>2,3</sup> Each flow through the network represents a process




Figure 1. Reference energy system, year.

or mix of processes to convert some primary resource into a fuel to meet some end use. Demand is specified by a specially defined term - the basic energy demand - which is the amount of energy required to support an energy-utilizing activity such as space heat, automotive propulsion, etc., at some nominal level (assuming no changes in equipment operation or user behavior). For a given basic energy demand, all other levels in a particular model run of energy flows are characterized as changes in technical demand efficiency. Basic energy demands are converted to fuel requirements by adjusting for demand conversion efficiencies, and fuel requirements are converted to primary resource demands by adjusting via appropriate supply conversion efficiencies. This generates the fuel mix and the primary resource mix.

Though BESOM contains a detailed representation of the supply system, it has a highly aggregated representation of the demand portion of the system. The methodology for extension of this approach for energy utilization technology has been described elsewhere<sup>4</sup> and is carried out in detail in the Buildings Energy Conservation Optimization Model (BECOM). BECOM extends BESOM to provide more end-use detail for residential and commercial buildings, explicitly modeling 25 energy conversion technologies and 8 structural technologies that can be used by 9 building types in each of 4 regions. The model covers all energy use in buildings including space heat, air conditioning, water heating, cooking, and appliance and illumination loads. As a result it is possible to measure in

detail the effects of technical changes in burners, motors, and other conversion devices\* and in structural shells as well as the effects of governmental programs such as setting standards for building insulation and appliance efficiency.

BECOM thus allows an explicit and flexible formulation of the policy variables that the decision maker wishes to analyze. For a given set of inputs, the linear programming algorithm implements the lowest-cost technology in a particular market to the maximum level set by constraints. This decision can be made on the basis of very small cost differentials between technologies. Thus, technology implementation levels should be interpreted with care. However, this difficulty inherent in linear programming is mitigated in BECOM by the use of 72 separate building markets, which may be further subdivided by market share constraints.

## 2. Structure of BECOM

### 2.1. Mathematical Structure

Mathematically the model is formulated as a modified transportation/transshipment problem. A transportation problem is concerned with distributing a commodity from any group of supply centers (sources) to any group of demand points (destinations), subject to limitations imposed by supply, demand, and other constraints. Each supply point  $i$  ( $i = 1, 2, \dots, m$ )

---

\*To simplify the exposition, the set of end-use energy conversion devices used in buildings by households, government activities, and commercial enterprises will be called conversion devices. This includes burners, heat pumps, electric motors, condensers, light bulbs and other illuminating equipment, blower fans, etc.

has a supply of  $S_i$  units to distribute to any destination  $j$  ( $j = 1, 2, \dots, n$ ), each of which has a demand for  $D_j$  units to be received from the sources. Assuming that the cost of distributing units from source  $i$  to destination  $j$  is proportional to the number of units shipped, the objective is to meet demands at all destinations at minimum cost.

The problem then becomes

$$\text{Minimize } Z = \sum_{i=1}^m \sum_{j=1}^n C_{ij} X_{ij}$$

where  $Z$  is the total distribution cost;  $C_{ij}$  is the cost of shipping each unit from source  $i$  to destination  $j$ ; and  $X_{ij}$  is the number of units shipped from  $i$  to  $j$ . Since the total number of units shipped from source  $i$  cannot be greater than the supply available, and since the demand at each destination has to be met, the constraints given below are introduced.

Supply constraint:

$$\sum_{j=1}^n a_{ij} X_{ij} \leq S_i \quad \text{for } i = 1, 2, \dots, m$$

Demand constraint:

$$\sum_{i=1}^m b_{ij} X_{ij} = D_j \quad \text{for } j = 1, 2, \dots, n$$

Also:

$$X_{ij} \geq 0 \quad \text{for all } i \text{ and } j.$$

Here,  $a_{ij}$  and  $b_{ij}$  are the supply and demand efficiencies, respectively, for the fuel  $X_{ij}$ .


Besides the supply and demand constraints, there are various equations which reflect technological realities and market

behavior. These are treated in more detail in Section 2.3.

BESOM is basically a modified transportation problem where the  $X_{ij}$ 's represent the flow of energy (in  $10^{15}$  Btu) from a resource to a demand at point of use. Each branch can be divided into two parts: a supply trajectory describing the conversion of a resource into an intermediate energy form (such as electricity or distillate oil delivered to the home) and a demand trajectory including all further processes on the branch. There are now 27 supply and 22 demand categories.

The structure of BECOM is similar to that of a transshipment problem, with the aggregate demand points from BESOM for residential/commercial space heat, air conditioning, water heating, and appliances serving as sources for the transshipment.

The destinations for this problem are the different buildings markets, each of which requires a certain amount of energy to provide an acceptable level of comfort or service. Shipments from sources to destinations are made through intermediate transfer points or transshipment points, which in this case are conversion devices and thermal shells.



Each conversion device is characterized by an efficiency coefficient representing the efficiency of conversion of the fuel in the device and a cost coefficient which is the annual-

ized capital cost for the device. Devices in existing buildings have a cost coefficient of zero since they are already in place. The thermal shell\* is similarly characterized by an efficiency coefficient which compares its heat-loss characteristics with those of a defined reference shell, and by a cost coefficient which is the annualized capital cost of upgrading a structure relative to the reference shell. Non-upgraded buildings and reference new buildings have an efficiency of 1. Upgraded shells have higher efficiencies. The energy demand in each market can be met by any combination of firing device and thermal shell (represented schematically in Figures 2 to 7).

If the model is run as a cost minimization, it selects those combinations of conversion devices and thermal integrities that will satisfy demands in the various markets subject to the limitations imposed by the other constraints.

The operation of the model may be illustrated by following one example in the diagram for residential space heat. In the "fuel" column in Figure 2 all the BESOM gas to space heat variables are gathered in a pool to serve as the gas source for heating residential and commercial buildings. The gas or other fuel goes to two demand points: the detailed flow network representing technologies in buildings in one particular region, and an aggregated demand representing demand in the other three

\*The shell is a level of energy integrity. For space heating and air conditioning, the shell corresponds to the building envelope; for water heating it can be interpreted to be the pipe and heater insulation; and for the appliance sector it is a representation of performance of improved appliance package.




Figure 2. BECOM: Structure of residential space heat.






Figure 3. BECOM: Structure of residential air conditioning.




Figure 4. Structure of residential thermal, lighting and appliances.

BESOM SPACE-HEAT VARIABLES




Figure 5. BECOM: Structure of commercial space heat.




Figure 6. BECOM: Structure of commercial air conditioning.




Figure 7. Structure of BECOM commercial thermal, lighting and appliances.

regions. The output thus represents national energy flows to the buildings sector, with technological detail presented in one region at a time. The model is run successively with each region represented in detail in turn to develop a full national projection.

The detailed regional flows go as follows. Each unit of the new variable representing the total gas to residential space heat can flow either to a gas heat pump or to a gas burner. If it flows to a burner, upon coming out of the burner it is multiplied by the energy-conversion efficiency of the burner and incurs a cost equal to the annualized capital cost of the burner if it is a new burner, or a zero cost if it is an old burner. If it flows through the heat pump it is multiplied by the seasonal performance factor of the heat pump, and incurs a cost equal to the annualized capital cost of the heat pump.

From the conversion device, energy may flow to any of 8 levels of thermal integrity for each building type. In Figure 2, from the burner there are 32 possible paths (4 building types and 8 levels of thermal integrity).

Levels of thermal integrity are represented by 8 thermal shells for each building type. Shells 1 to 4 represent existing stock: shell 1 refers to an existing building without special conservation options and shells 2 to 4 refer to existing buildings with increasing levels of conservation features. Similarly, for new buildings, shell 5 refers to a base building without any special conservation technology options (see

Appendix B for building and conservation technology data).

A flow from the burner to a single family inherited shell with no additional insulation (shell 1) would be multiplied by the efficiency of the shell (1.0) and incur a cost of zero (since no energy-conserving capital stock has been purchased). A flow from the burner to an inherited shell retrofitted with energy-conservation features would have a higher efficiency and would incur a cost equal to the annualized capital cost of the conservation technologies implemented in that shell.

The flow from each shell enters the node representing total housing stock, where it is multiplied by the inverse of the theoretical load for that building type. This coefficient converts energy flow to actual numbers of housing units, or, conversely, it converts right-hand sides for the model, which are in physical units, (housing units in the residential sector and square feet in the commercial) to energy demands for each shell.

The air conditioning, thermal applications, and appliances for both the residential and commercial sectors are modeled in a similar way. Thermal applications include water heating, cooking and drying. The appliances category includes refrigeration, power loads (elevators, escalators, etc.) and miscellaneous electrical appliances.

## 2.2. Economic Structure

Flows of energy into the buildings network incur a cost equal to the price of the relevant energy form. The flow is allowed to take any of the paths corresponding to a conversion

device and shell combination as long as the total demand and other constraints described below are met.

When the energy flows through a node of the network (a conversion or shell technology), it is multiplied by the efficiency of that technology and charged the annualized capital charge for that technology. The optimization makes a lowest-cost tradeoff to invest just the right amount in energy-conserving capital stock to improve efficiency to the point at which the lowest total cost of annualized capital plus the lowest total fuel cost is achieved.

Capital investments are charged an annual charge which is found by multiplying the initial investment by a capital recovery factor to calculate the annual payment required to retire the investment in a certain number of years.

$$\text{Capital recovery factor} = \frac{i}{1 - (1 + i)^{-n}}$$

where  $i$  is the long-term discount rate and  $n$  is the equipment lifetime in years.

Different equipment lifetimes and discount rates are used for residential and commercial markets and for new and retrofit technologies. These are input parameters in the model and can be easily varied.

The capital charges are applied to incremental investments from the 1975 base year building stock. That is, equipment existing in 1975 is not charged for capital cost, but post-1975 retrofits of existing buildings and investment in new construction are. This means that the optimized capital stock derived in this way represents a preferred investment strategy for the



period 1976 through the case year for which the model is programmed, on the assumption that decision makers act as though the case year prices are maintained from 1976 on.

### 2.3. Structure of the Equations

BESOM and BECOM are run simultaneously as a cost minimization problem. The BESOM equations will be described in detail elsewhere.<sup>5</sup> They may be classified as follows.

1. Supply equations limit the amount of a given resource that may be used in the planning year, either in total use or for a specific purpose. The constraints are given in terms of the energy content of the primary fuel (minemouth and wellhead) input to that supply category. For synthetic fuels and pumped storage, the supply constraint equations represent the energy content of the synthetic fuel after manufacturing.

2. Demand equations specify the energy requirements that must be met in order to satisfy demands from the demand sectors. They are specified as basic energy demands; each basic energy demand is defined as the amount of energy required to support an energy-utilizing activity assuming that the energy could be used at a reference technical efficiency (after conversion). Basic energy demands are specified for each of the demand categories.

3. Electrical supply and peaking constraint equations limit the electrical generating capacity of plant types as well as accounting for peak electric demands and energy balances. The peaking equations are of two types, weekly and seasonal, and describe off-peak power availability.

4. Environmental constraints limit emissions of various types, such as  $SO_x$  or particulates. However, in most model runs these constraints are not binding and serve only to sum up environmental effects.

5. Market penetration equations limit the technology penetration of markets, and relate to minimum or maximum levels of fuel use or permitted capacity of a particular type.

BECOM constraints may be grouped in the following classes.

1. Demand constraints. For each type of demand and building type, the flow from all shells to final demand must equal the theoretical building load times the building stock in the year for which consumption is projected.

$$\sum_{j=1}^8 \frac{1}{a_k} \chi_{jk} = b_k \quad \text{for all building types } k$$

where

$a_k$  = theoretical building load,

$b_k$  = total stock, and

$\chi_{jk}$  = flow from shell  $j$  to building  $k$ .

2. Minimum constraints on residual stock. The optimization is conducted for a given year subject to the constraint that the number of dwelling units of a particular type heated by any given fuel must equal the number that actually existed in the base year (1975) minus the removals in the period from the base to the year for which the analysis is performed.

$$\sum_{j=1}^4 \frac{1}{a_k} e_{j,i} \chi_{ij} = b_{ik} \quad \text{for each conversion device } i \text{ and shell } j, \text{ for each building type } k$$

where

- $c_j$  = efficiency of shell j,
- $b'_{ik}$  = total inherited stock (in physical units) of building type k with conversion device i,
- $a_k$  = theoretical load for building type k,
- $d_i$  = fuel adjustment factor for conversion device i,  
and
- $x_{ij}$  = flow from conversion device i to shell j.

3. Seasonal load balance. In order to ensure that the heating, air-conditioning, thermal, and appliance loads for each shell are balanced, an equation exists for each shell setting this balance.

$$x_{jk} - a_k y_{jk} = 0 \quad \text{for all shells } j \text{ to building types } k$$

where

- $x_{jk}$  = space-heating flow from shell j to total building type k,
- $a_k$  = ratio of space-heating to air-conditioning load for building type k, and
- $y_{jk}$  = air-conditioning flow from shell j to building type k.

4. Fuel mix in new construction. The market shares of oil, gas, electric, and solar heated units are set in these equations reflecting current construction trends or the results of housing models.

$$q_{ik} n_k \leq \sum_{i=1}^r \sum_{j=5}^8 \frac{1}{a_k} d_i e_j x_{ij} \leq p_{ik} n_k \quad \text{for all building types } k$$

where

- $a_k$  = theoretical load of building type k,
- $d_i$  = fuel adjustment factor,
- $e_j$  = efficiency of shell j,
- $x_{ij}$  = flow from conversion device i to shell j,
- $p_{ik}$  = upper limit in percent market penetration for fuel i in building type k,
- $q_{ik}$  = lower limit in percent market penetration for fuel i in building type k,
- $n_k$  = new construction of building type k, and
- $r$  = number of conversion devices using fuel i.

5. Seasonal operation constraints on heat pumps. Electric and gas heat pumps are constrained to have a ratio of heating and cooling equal to the ratio of heating/cooling loads for the relevant shell, building type, and region.

$$e_j x_{ij} - k f_j \gamma_{ij} = 0 \quad \text{for all heat pumps, for all shells in each building type}$$

where

- $x_{ij}$  = space-heating flow from heat pump i to shell j,
- $\gamma_{ij}$  = air-conditioning flow from heat pump i to shell j,
- $e_j$  = efficiency of shell j in the heating season,
- $f_j$  = efficiency of shell j in the cooling season,
- and
- $k$  = ratio of space-heating to cooling load.

6. Solar back up constraints. These equations require that the use of solar energy be accompanied by a certain fraction

of back up from conventional energy sources to provide heating or cooling when insolation is insufficient. There is an equation for all new shells in each building type for solar space heating, air conditioning, and water heating. The fraction of back up varies depending on end use.

$$x_{bj} = f_1 x_{sj} \quad \text{for all shells } j, \text{ for all building types, for each end use } l$$

where

$x_{bj}$  = flow from backup device to shell  $j$ ,

$x_{sj}$  = flow from solar unit to shell  $j$ , and

$f_1$  = fraction of load provided by backup device.

7. Solar AC constraints. These equations ensure that solar air conditioning can occur only in buildings that employ solar space heating, recognizing that solar air conditioning is never used by itself.

$$x_{sj} \geq h x_{aj} \quad \text{for all shell } j, \text{ for all building types}$$

where

$x_{sj}$  = solar space heat to shell  $j$ ,

$x_{aj}$  = solar air conditioning to shell  $j$ , and

$h$  = ratio of heating to air-conditioning loads.

8. Solar water heating. These equations ensure that buildings employing solar space-heating systems derive their hot water from the same system.

$$x_{tj} \geq k x_{sj} \quad \text{for all shells } j, \text{ for all building types}$$

where

$x_{tj}$  = solar water heating to shell  $j$ ,

$x_{sj}$  = solar space heating to shell  $j$ , and

$k$  = ratio of water-heating load to space-heating load.

### 3. Data Inputs

Within the network flow conception we have outlined, internally consistent performance and cost data are used, taken from the Arthur D. Little data base for buildings<sup>6</sup> summarized in Appendices A and B. The main categories of data are the following.

1. Building stocks. These include inventory data for 1975 for four types of residences and five types of commercial buildings, removals in the period 1976-2000, new construction by type during 1976-2000, and total building stocks.

2. Theoretical building loads. These are defined as the energy required from any conversion device for the reference shell for various types of loads. They are different for different buildings types and different climatic conditions in various regions. They are specified for each region for reference structural technologies for the following categories: space heating, air conditioning, hot water, lighting plus power, and auxiliaries in commercial buildings.

3. Shell efficiencies. These are the percentage improvements in structural integrity, over a nominal 1975 value for new and existing buildings, which can be expected from implementation of certain technologies applicable to building envelopes.

4. Conversion-device efficiencies. These are the percentages of delivered energy which can actually be applied to the theoretical building loads. For heat pumps, for example, this corresponds to the seasonal performance factor.

5. Technology costs. These include the cost for conversion devices and structural technologies, both for new

buildings and for retrofit applications.

Other efforts have been made at BNL and elsewhere<sup>7</sup> to develop improved data for this model, and these will be continued. The ADL data base is being used currently because of its completeness and internal consistency and the extensive experience it embodies.

#### 4. Model Operation and Outputs


The equations for the model are set up by using the Haverly Systems, Inc., general-purpose problem-description system (PDS/MAGEN), which contains a bidirectional interface to the Control Data Corporation APEX III linear programming system. The model is run on the APEX III out-of-core system-1 under control of the SCOPE 2.1 operating system on Brookhaven's Control Data 7600 series computer.

Using PDS/MAGEN, a single control file generates the equations, with data inputs being stored in separate files (one for each region). Though each region uses the same control program, a run for any region is independent of the runs for the other regions.

For each case to be explored, the data inputs are total building stocks, bounds for building market shares by fuel, technology cost, and performance data, building loads for each end use (space heating, air conditioning, thermal, and appliances), and the relevant fuel prices. BESOM and BECOM are then run simultaneously as a cost-minimization problem. The combined problem has almost 3800 constraints and 6000 variables and takes almost 200 CPU seconds to solve.

Because of the complexity and size of the problem, a simplified format is used to present the output. This is written by using the report-generating features of PDS/MAGEN.

The information flow is shown schematically below.



The output for each region is displayed at three different levels of aggregation. The first level, Figures 8 to 16, shows energy demand by building type. Conversion technologies with fuel are listed in the column at left. Structural technologies for both retrofitted and new buildings are listed across the top. Since each building option is in fact a combination of a conversion technology and a structural technology, each path represented by a given combination of fuel-firing device plus shell in the BECOM network is represented by a cell in this matrix. In the output, the fuel delivered ("over the fence") to each conversion device/shell technology combination is reported in the appropriate cell in the matrix. For each case year and policy scenario one of these matrices is prepared for each of nine building types. Retrofit i ( or New i) is a category for a set of conservation technologies in buildings. The eight columns correspond to the eight shell definitions outlined earlier. The two-letter designation (SH, AC, TH, AP) in the third column from the left identifies the end use that the conversion device is satisfying. All the numbers are in units of  $10^{12}$  Btu.

The second level of aggregation sums the energy flows separately in residential buildings (Figure 17) and commercial buildings.



(Figure 18). This enables one to find the energy demand by conversion device or end use for all buildings in a sector. The third level of aggregation presents net energy demand by fuel and end use for each region (Figure 19).

The regional totals in Figure 19 sum residential and commercial sectors for each region. The sum of these regional tables yields national demand totals by fuels in the two sectors.

#### Coverage of Output

Regions: Northeast, North Central, South, West

Building types:	Residential--	Commercial--
	Single family	Hospitals
	Low density	Schools
	Multi-family	Retail
	Mobile homes	Offices
		Miscellaneous

In addition, the results of each run are presented in terms of physical units which use each technology combination, expressed in  $10^9$  square feet for commercial buildings and  $10^6$  units for residential structures. A sample of this output is included in Figures 20 to 31.

Finally, to facilitate calculation of investment requirements, the investment (in 1975 constant dollars) in energy-related devices and structures during the period from 1976 through the case year is summarized. These data are presented by new and retrofit markets and building types for both devices and structures. These outputs are illustrated in Figures 32 to 35.

REGION			NORTH EAST	MARKET	FCSPITAL	YEAR 1990				-E12BTU-	
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	
			NO	1	2	3	NO	1	2	3	
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	TOTAL
*****											
GAS	BURNER	CLD	SF	14.066							14.066
GAS	BURNER	NEW	SF					3.219			3.219
GAS	HEAT	PUMP	SF					5.745			5.745
OIL	BURNER	CLD	SF	55.356							55.356
OIL	BURNER	NEW	SF					6.137			6.137
ELEC.	HEAT	PUMP	SF								
ELEC.	RESISTANCE		SF	0.066							0.066
SCLAR	COLLECTOR		SF					1.878			1.878
GAS	HEAT	PUMP	AC					6.790			6.790
ELEC.	HEAT	PUMP	AC								
ELEC.	ROOM		AC	3.423							3.423
SCLAR	COLLECTOR		AC					1.258			1.258
GAS	BURNER	CLD	TH	3.307							3.307
GAS	BURNER	NEW	TH					4.073			4.073
OIL	BURNER	CLD	TH	8.832							8.832
OIL	BURNER	NEW	TH					1.609			1.609
ELEC.	RESISTANCE		TH								
SCLAR	COLLECTOR		TH					0.782			0.782
ELEC.	LIGHTING	APP	AP	37.037				27.207			64.245

Figure 8. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST		MARKET		SCHOOL		YEAR 1990			-E12ETU-
			RETROFIT NO	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW NO	NEW 1	NEW 2	NEW 3	TOTAL	
*****												
GAS	BURNER	CLD	SF	29.600							29.600	
GAS	BURNER	NEW	SF					10.546			10.546	
GAS	HEAT	PUMP	SF					0.800			0.800	
OIL	BURNER	CLD	SF		102.055						102.055	
OIL	BURNER	NEW	SF					4.845			4.845	
ELEC.	HEAT	PUMP	SF									
ELEC.	RESISTANCE		SF	0.140							0.140	
SOLAR	COLLECTOR		SF					1.569			1.569	
GAS	HEAT	PUMP	AC					0.728			0.728	
ELEC.	HEAT	PUMP	AC									
ELEC.	RCCM		AC	0.757	2.232						2.989	
SOLAR	COLLECTOR		AC					0.809			0.809	
GAS	BURNER	CLD	TF	1.132							1.132	
GAS	BURNER	NEW	TF					0.789			0.789	
OIL	BURNER	CLD	TF	0.004	3.986						3.989	
OIL	BURNER	NEW	TF					0.312			0.312	
ELEC.	RESISTANCE		TF		0.260						0.260	
SOLAR	COLLECTOR		TF					0.151			0.151	
ELEC.	LIGHTING	APP	AP	7.039	24.268			12.624			44.530	

- 27 -

Figure 9. Buildings energy conservation optimization model. Case-base policy.

REGION	NCRTH EAST		MARKET	OFFICE	YEAR 1990			-E12BTU-	
	RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
	NO	1	2	3	NO	1	2	3	
	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****									
GAS	BURNER CLD	SF							35.484
GAS	BURNER NEW	SF				13.437			13.437
GAS	HEAT PUMP	SF				6.295			6.295
OIL	BURNER CLD	SF							75.615
OIL	BURNER NEW	SF				6.002	4.016		10.018
ELEC.	HEAT PUMP	SF							13.175
ELEC.	RESISTANCE	SF	13.175						13.175
SCLAR	COLLECTOR	SF					2.895		2.895
GAS	HEAT PUMP	AC				6.195			6.195
ELEC.	HEAT PUMP	AC							9.503
ELEC.	ROOM	AC	3.673	5.830					9.503
SOLAR	COLLECTOR	AC					1.514		1.514
GAS	BURNER CLD	TF	1.320						1.320
GAS	BURNER NEW	TF				1.460			1.460
OIL	BURNER CLD	TF	0.966	3.418					4.384
OIL	BURNER NEW	TF				0.325	0.225		0.555
ELEC.	RESISTANCE	TF		0.277					0.277
SCLAR	COLLECTOR	TF					0.255		0.255
ELEC.	LIGHTING APP	AP	17.857	32.563		17.308	6.130		73.858

- 28 -

Figure 10. Buildings energy conservation optimization model. Case-base policy.

REGION			NCRTH EAST	MARKET	RETAIL	YEAR 1990				-E12BTU-	
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
			NO	1	2	3	NO	1	2	3	
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****											
GAS	BURNER	OLD	SH		11.804						11.804
GAS	BURNER	NEW	SH					5.415			5.415
GAS	HEAT	PUMP	SH					3.425			3.425
OIL	BURNER	OLD	SH		47.105						47.105
OIL	BURNER	NEW	SH					5.040			5.040
ELEC.	HEAT	PUMP	SH								
ELEC.	RESISTANCE		SH	0.098							0.098
SCLAR	COLLECTOR		SH					1.455			1.455
GAS	HEAT	PUMP	AC					7.364			7.364
ELEC.	HEAT	PUMP	AC								
ELEC.	ROOM		AC	0.062	5.884						5.946
SCLAR	COLLECTOR		AC								
GAS	BURNER	OLD	TH	0.023	0.507						0.531
GAS	BURNER	NEW	TH					0.908			0.908
OIL	BURNER	OLD	TH		1.985						1.985
OIL	BURNER	NEW	TH					0.359			0.359
ELEC.	RESISTANCE		TH		0.129						0.129
SCLAR	COLLECTOR		TH					0.174			0.174
ELEC.	LIGHTING	APP	AP	0.589	70.168			45.901			116.658

- 29 -

Figure 11. Buildings energy conservation optimization model. Case-base policy.

		REGION	NORTH EAST	MARKET	MISC.	YEAR 1990				-E12BTU-				
						RETROFIT NO	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW NO	NEW 1	NEW 2	NEW 3	TOTAL
						CONSERV.	CCNSERV.	CCNSERV.	CCNSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****														
GAS	BURNER OLD	SF	29.974											29.974
GAS	BURNER NEW	SF								31.567				31.567
GAS	HEAT PUMP	SF												
OIL	BURNER OLD	SF	11.789											11.789
OIL	BURNER NEW	SF								10.044				10.044
ELEC.	HEAT PUMP	SF												
ELEC.	RESISTANCE	SF	18.928							0.341				19.269
SOLAR	COLLECTOR	SF												
GAS	HEAT PUMP	AC												
ELEC.	HEAT PUMP	AC												
ELEC.	ROOM	AC	14.807							5.940				20.747
SOLAR	COLLECTOR	AC												
GAS	BURNER OLD	TF	1.233											1.233
GAS	BURNER NEW	TF								2.253				2.253
OIL	BURNER OLD	TF	4.640											4.640
OIL	BURNER NEW	TF								0.699				0.699
ELEC.	RESISTANCE	TF	0.303											0.303
SOLAR	COLLECTOR	TF												
ELEC.	LIGHTING APP	AP	54.174							60.324				114.498

Figure 12. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	SINGLE FAMILY	YEAR 1990			-E12BTU-		
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
			NO	1	2	3	NO	1	2	3	
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****											
GAS	BURNER OLD	SF	453.507								453.507
GAS	BURNER NEW	SF						74.076			74.076
GAS	HEAT PUMP	SF									
OIL	BURNER OLD	SF		963.880							963.880
OIL	BURNER NEW	SF						15.465			15.465
ELEC.	HEAT PUMP	SF						25.694			25.694
ELEC.	RESISTANCE	SF	15.911								15.911
SOLAR	COLLECTOR	SF									
GAS	HEAT PUMP	AC									
ELEC.	HEAT PUMP	AC						2.345			2.345
ELEC.	ROOM	AC	2.745	3.412				0.426			6.587
SOLAR	COLLECTOR	AC									
GAS	BURNER OLD	TF		274.066							274.066
GAS	BURNER NEW	TF						55.925			55.925
OIL	BURNER OLD	TF	230.216								230.216
OIL	BURNER NEW	TF						9.321			9.321
ELEC.	RESISTANCE	TF	23.124	26.208				21.054			70.386
SOLAR	COLLECTOR	TF									
ELEC.	LIGHTING APP	AP	67.374	92.921				36.975			197.269

- 31 -

Figure 13. Buildings energy conservation optimization model. Case-base policy.

		REGION	NORTH EAST	MARKET	LOW DENSITY	YEAR 1990				-E12BTU-				
						RETROFIT AC	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW AC	NEW 1	NEW 2	NEW 3	TOTAL
						CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****														
GAS	BURNER OLD	SF	181.919											181.919
GAS	BURNER NEW	SF								22.351				22.351
GAS	HEAT PUMP	SF												
OIL	BURNER OLD	SF			377.177									377.177
OIL	BURNER NEW	SF								4.666				4.666
ELEC.	HEAT PUMP	SF								6.901				6.901
ELEC.	RESISTANCE	SF	5.973											5.973
SCLAR	COLLECTOR	SF												
GAS	HEAT PUMP	AC												
ELEC.	HEAT PUMP	AC								0.615				0.615
ELEC.	ROOM	AC	1.336		1.656					0.182				3.173
SCLAR	COLLECTOR	AC												
GAS	BURNER OLD	TF	29.116		24.656									53.772
GAS	BURNER NEW	TF								6.353				6.353
OIL	BURNER OLD	TF			45.169									45.169
OIL	BURNER NEW	TF								1.059				1.059
ELEC.	RESISTANCE	TF	9.679							2.392				12.071
SCLAR	COLLECTOR	TF												
ELEC.	LIGHTING AFF. AP		36.200		49.240					12.300				98.340

Figure 14. Buildings energy conservation optimization model. Case-base policy.



REGION		NCRH EAST		MARKET		MULTI-FAMILY		YEAR 1990		-E12BTU-
		RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
		NC	1	2	3	NC	1	2	3	
		CONSERV.	CCNSERV.	CCNSERV.	CCNSERV.	CONSERV.	CCNSERV.	CCNSERV.	CCNSERV.	
*****										
GAS	BURNER OLD	SH			133.473					133.473
GAS	BURNER NEW	SH					7.453			7.453
GAS	HEAT PUMP	SH					4.588	0.488		5.076
OIL	BURNER OLD	SH		130.605						130.605
OIL	BURNER NEW	SH					1.387	2.439		3.827
ELEC.	HEAT PUMP	SH								
ELEC.	RESISTANCE	SH	2.363				4.293			6.656
SCLAR	COLLECTOR	SH					2.080			2.080
GAS	HEAT PUMP	AC					1.241	0.130		1.371
ELEC.	HEAT PUMP	AC								
ELEC.	ROOM	AC	0.140	1.392	0.919					2.452
SCLAR	COLLECTOR	AC					0.319			0.319
GAS	BURNER OLD	TH	3.012	30.278						33.291
GAS	BURNER NEW	TH					5.690			5.690
OIL	BURNER OLD	TH		9.777	17.285					27.063
OIL	BURNER NEW	TH						1.282		1.282
ELEC.	RESISTANCE	TH			5.707		2.897			8.604
SCLAR	COLLECTOR	TH					1.403			1.403
ELEC.	LIGHTING APP	AF	2.502	33.315	21.688		15.151	1.407		74.064

- 33 -

Figure 15. Buildings energy conservation optimization model. Case-base policy.

REGION		NCRTH EAST		MARKET		MOBILE FCME		YEAR 1990				-E12ETU-
		RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW			
		NO	1	2	3	NO	1	2	3			
		CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	TOTAL		
*****												
GAS	BURNER OLD	SH		6.360						6.360		
GAS	BURNER NEW	SH					6.124			6.124		
GAS	HEAT PUMP	SH					3.951			3.951		
OIL	BURNER OLD	SH		15.556						15.556		
OIL	BURNER NEW	SH					2.431			2.431		
ELEC.	HEAT PUMP	SH										
ELEC.	RESISTANCE	SH	0.312				3.951			4.263		
SCLAR	COLLECTOR	SH										
GAS	HEAT PUMP	AC					1.360			1.360		
ELEC.	HEAT PUMP	AC										
ELEC.	ROOM	AC	0.009	0.156						0.165		
SCLAR	COLLECTOR	AC										
GAS	BURNER OLD	TH	0.217	2.001						2.218		
GAS	BURNER NEW	TH					3.406			3.406		
OIL	BURNER OLD	TH		1.860						1.860		
OIL	BURNER NEW	TH					0.809			0.809		
ELEC.	RESISTANCE	TH		0.399			1.350			1.749		
SCLAR	COLLECTOR	TH										
ELEC.	LIGHTING APP	AP	0.221	4.371			7.364			11.956		

- 34 -

Figure 16. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	COMMERCIAL	YEAR 1990				-E12BTU-		
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW		
			NO	1	2	3	NO	1	2	3		
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	TOTAL	
*****												
GAS	BURNER	OLD	SF	73.640	35.484	11.804						120.928
GAS	BURNER	NEW	SF					64.184				64.184
GAS	HEAT	PUMP	SF					16.264				16.264
OIL	BURNER	OLD	SF	67.145	177.670	47.105						291.919
OIL	BURNER	NEW	SF					32.067	4.016			36.083
ELEC.	HEAT	PUMP	SF									
ELEC.	RESISTANCE		SF	32.407				0.341				32.748
SCLAR	COLLECTOR		SF					4.902	2.895			7.798
GAS	HEAT	PUMP	AC					21.077				21.077
ELEC.	HEAT	PUMP	AC									
ELEC.	ROOM		AC	22.722	8.061	5.984		5.940				42.607
SCLAR	COLLECTOR		AC					2.067	1.514			3.581
GAS	BURNER	OLD	TF	7.015		0.507						7.522
GAS	BURNER	NEW	TF					9.483				9.483
OIL	BURNER	OLD	TF	14.441	7.404	1.985						23.830
OIL	BURNER	NEW	TF					3.304	0.229			3.534
ELEC.	RESISTANCE		TF	0.303	0.537	0.129						0.969
SCLAR	COLLECTOR		TF					1.107	0.255			1.363
ELEC.	LIGHTING	APP	AP	156.695	57.431	70.168		163.364	6.130			453.789

- 35 -

Figure 17. Buildings energy conservation optimization model. Case-base policy.

REGION		NORTH EAST		MARKET		RESIDENTIAL		YEAR 1990		-E12BTC-
		RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
		NO	1	2	3	AC	1	2	3	
		CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****										
GAS	BURNER CLD	SF	635.426	6.360	133.473					775.259
GAS	BURNER NEW	SF					110.004			110.004
GAS	HEAT PUMP	SF					8.539	0.488		9.026
OIL	BURNER CLD	SF		1487.218						1487.218
OIL	BURNER NEW	SF					23.949	2.439		26.388
ELEC.	HEAT PUMP	SF					32.595			32.595
ELEC.	RESISTANCE	SF	24.559				8.244			32.803
SOLAR	COLLECTOR	SF					2.080			2.080
GAS	HEAT PUMP	AC					2.601	0.130		2.731
ELEC.	HEAT PUMP	AC					2.960			2.960
ELEC.	ROOM	AC	4.234	6.616	0.919		0.608			12.377
SOLAR	COLLECTOR	AC					0.319			0.319
GAS	BURNER CLD	TH	32.345	331.902						363.347
GAS	BURNER NEW	TH					71.374			71.374
OIL	BURNER CLD	TH	230.216	56.806	17.285					304.307
OIL	BURNER NEW	TH					11.188	1.282		12.471
ELEC.	RESISTANCE	TH	32.803	26.606	5.707		27.693			52.810
SOLAR	COLLECTOR	TH					1.403			1.403
ELEC.	LIGHTING APP	AP	106.296	100.446	21.688		71.790	1.407		381.629

Figure 18. Buildings energy conservation optimization model. Case-base policy.

COMMERCIAL  
\*\*\*\*\*

	SPACE HEAT	AIR CONDITIONING	THERMAL	APPLIANCE
GAS	0.1419	0.0179	0.0112	
OIL	0.1676		0.0140	
ELEC.	0.0327	0.0095	0.0010	0.4538
SCLAR	0.0078	0.0036	0.0014	

RESIDENTIAL  
\*\*\*\*\*

	SPACE HEAT	AIR CONDITIONING	THERMAL	APPLIANCE
GAS	0.5557	0.0023	0.2680	
OIL	0.7594		0.1596	
ELEC.	0.0817	0.0322	0.0928	0.3816
SCLAR	0.0021	0.0003	0.0014	

Figure 19. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	HOSPITAL	YEAR 1990				E9 SQ,FT,	
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
			NC	1	2	3	NO	1	2	3	
			CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	
*****											
GAS	BURNER OLD	SH	0,087								0,087
GAS	BURNER NEW	SH						0,039			0,039
GAS	HEAT PUMP	SH						0,236			0,236
OIL	BURNER OLD	SH	0,311								0,311
OIL	BURNER NEW	SH						0,063			0,063
ELEC.	HEAT PUMP	SH									0,002
ELEC.	RESISTANCE	SH	0,002								0,002
SOLAR	COLLECTOR	SH						0,103			0,103
GAS	HEAT PUMP	AC						0,236			0,236
ELEC.	HEAT PUMP	AC									0,248
ELEC.	ROOM	AC	0,248								0,248
SOLAR	COLLECTOR	AC						0,103			0,103
GAS	BURNER OLD	TH	0,124								0,124
GAS	BURNER NEW	TH						0,187			0,187
OIL	BURNER OLD	TH	0,276								0,276
OIL	BURNER NEW	TH						0,063			0,063
ELEC.	RESISTANCE	TH									0,103
SOLAR	COLLECTOR	TH						0,103			0,103
ELEC.	LIGHTING APP	AP	0,400					0,302			0,702

Figure 20. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	SCHOOL	YEAR 1990				E9 SQ,FT,	
			RETROFIT NO	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW NO	NEW 1	NEW 2	NEW 3	TOTAL
			CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	
*****											
GAS	BURNER OLD	SH	0,222								0,222
GAS	BURNER NEW	SH						0,177			0,177
GAS	HEAT PUMP	SH						0,043			0,043
OIL	BURNER OLD	SH		0,802							0,802
OIL	BURNER NEW	SH						0,070			0,070
ELEC.	HEAT PUMP	SH									0,005
ELEC.	RESISTANCE	SH	0,005								0,005
SOLAR	COLLECTOR	SH						0,113			0,113
GAS	FEAT PUMP	AC						0,043			0,043
ELEC.	FEAT PUMP	AC									0,257
ELEC.	ROOM	AC	0,057	0,201							0,257
SOLAR	COLLECTOR	AC						0,113			0,113
GAS	BURNER OLD	TH	0,226								0,226
GAS	BURNER NEW	TH						0,206			0,206
OIL	BURNER OLD	TH	0,001	0,709							0,710
OIL	BURNER NEW	TH						0,070			0,070
ELEC.	RESISTANCE	TH		0,093							0,093
SOLAR	COLLECTOR	TH						0,113			0,113
ELEC.	LIGHTING APP	AP	0,227	0,802				0,332			1,361

Figure 21. Buildings energy conservation optimization model. Case-base policy.

REGION	NORTH EAST	MARKET	OFFICE	YEAR 1990				E9 SW,FT,				
				RETROFIT NO CONSERV.	RETROFIT 1 CONSERV.	RETROFIT 2 CONSERV.	RETROFIT 3 CONSERV.	NEW NO CONSERV.	NEW 1 CONSERV.	NEW 2 CONSERV.	NEW 3 CONSERV.	TOTAL
*****												
GAS	BURNER OLD	SH			0,263							0,263
GAS	BURNER NEW	SH						0,186				0,186
GAS	HEAT PUMP	SH						0,288				0,288
OIL	BURNER OLD	SH		0,512								0,512
OIL	BURNER NEW	SH						0,071	0,055			0,126
ELEC.	HEAT PUMP	SH										
ELEC.	RESISTANCE	SH	0,425									0,425
SOLAR	COLLECTOR	SH								0,204		0,204
GAS	HEAT PUMP	AC						0,288				0,288
ELEC.	HEAT PUMP	AC										
ELEC.	ROOM	AC	0,234	0,426								0,660
SOLAR	COLLECTOR	AC								0,204		0,204
GAS	BURNER OLD	TH	0,264									0,264
GAS	BURNER NEW	TH						0,372				0,372
OIL	BURNER OLD	TH	0,161	0,667								0,828
OIL	BURNER NEW	TH						0,071	0,055			0,126
ELEC.	RESISTANCE	TH		0,108								0,108
SOLAR	COLLECTOR	TH								0,204		0,204
ELEC.	LIGHTING APP	AP	0,425	0,775				0,443	0,157			1,800

- 40 -

Figure 22. Buildings energy conservation optimization model. Case-base policy.



REGION			NORTH EAST	MARKET	RETAIL	YEAR 1990				E9 SQ,FT.	
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
			NO	1	2	3	NO	1	2	3	
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****											
GAS	BURNER OLD	SH			0,184						0,184
GAS	BURNER NEW	SH						0,147			0,147
GAS	HEAT PUMP	SH						0,336			0,336
OIL	BURNER OLD	SH			0,651						0,651
OIL	BURNER NEW	SH						0,118			0,118
ELEC.	HEAT PUMP	SH									
ELEC.	RESISTANCE	SH	0,007								0,007
SOLAR	COLLECTOR	SH						0,190			0,190
GAS	HEAT PUMP	AC						0,336			0,336
ELEC.	HEAT PUMP	AC									
ELEC.	ROOM	AC	0,004		0,417						0,421
SOLAR	COLLECTOR	AC									
GAS	BURNER OLD	TH	0,007		0,178						0,185
GAS	BURNER NEW	TH						0,347			0,347
OIL	BURNER OLD	TH			0,581						0,581
OIL	BURNER NEW	TH						0,118			0,118
ELEC.	RESISTANCE	TH			0,076						0,076
SOLAR	COLLECTOR	TH						0,190			0,190
ELEC.	LIGHTING APP	AP	0,007		0,835			0,560			1,402

Figure 23. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	MISC,	YEAR 1990				E9 SQ,FT,	
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
			NO	1	2	3	NO	1	2	3	
			CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	
*****											
GAS	BURNER OLD	SH	0.367								0,367
GAS	BURNER NEW	SH						0,859			0,859
GAS	HEAT PUMP	SH									
OIL	BURNER OLD	SH	0.131								0,131
OIL	BURNER NEW	SH						0,234			0,234
ELEC.	HEAT PUMP	SH									
ELEC.	RESISTANCE	SH	1.183					0,022			1,205
SOLAR	COLLECTOR	SH									
GAS	HEAT PUMP	AC									
ELEC.	HEAT PUMP	AC									
ELEC.	ROOM	AC	0,840					0,670			1,510
SOLAR	COLLECTOR	AC									
GAS	BURNER OLD	TH	0.370								0,370
GAS	BURNER NEW	TH						0,882			0,882
OIL	BURNER OLD	TH	1.160								1,160
OIL	BURNER NEW	TH						0,234			0,234
ELEC.	RESISTANCE	TH	0.151								0,151
SOLAR	COLLECTOR	TH									
ELEC.	LIGHTING APP	AP	1.681					1,116.			2,797

Figure 24. Buildings energy conservation optimization model. Case-base policy.

42

REGION			NORTH EAST	MARKET	SINGLE FAMILY	YEAR 1990				E6 UNITS		
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL	
			NO	1	2	3	NO	1	2	3		
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.		
*****												
GAS	BURNER OLD	SH	2,895									2,895
GAS	BURNER NEW	SH						0,836				0,836
GAS	HEAT PUMP	SH										
OIL	BURNER OLD	SH		4,423								4,423
OIL	BURNER NEW	SH						0,150				0,150
ELEC.	HEAT PUMP	SH						0,774				0,774
ELEC.	RESISTANCE	SH	0,312									0,312
SOLAR	COLLECTOR	SH										
GAS	HEAT PUMP	AC										
ELEC.	HEAT PUMP	AC						0,774				0,774
ELEC.	ROOM	AC	0,962	1,327				0,141				2,430
SOLAR	COLLECTOR	AC										
GAS	BURNER OLD	TH		3,815								3,815
GAS	BURNER NEW	TH						1,047				1,047
OIL	BURNER OLD	TH	2,670									2,670
OIL	BURNER NEW	TH						0,150				0,150
ELEC.	RESISTANCE	TH	0,536	0,608				0,563				1,708
SOLAR	COLLECTOR	TH										
ELEC.	LIGHTING APP	AP	3,207	4,423				1,760				9,390

- 43 -

Figure 25. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST		MARKET		LOW DENSITY		YEAR 1990			E6 UNITS
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL	
			NO	1	2	3	NO	1	2	3		
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.		
*****												
GAS	BURNER OLD	SH	1.629									1,629
GAS	BURNER NEW	SH						0,292				0,292
GAS	HEAT PUMP	SH										
OIL	BURNER OLD	SH		2,492								2,492
OIL	BURNER NEW	SH						0,052				0,052
ELEC.	HEAT PUMP	SH						0,271				0,271
ELEC.	RESISTANCE	SH	0.181									0,181
SOLAR	COLLECTOR	SH										
GAS	HEAT PUMP	AC										
ELEC.	HEAT PUMP	AC						0,271				0,271
ELEC.	ROOM	AC	0,561	0,773				0,080				1,414
SOLAR	COLLECTOR	AC										
GAS	BURNER OLD	TH	1.165	0,986								2,151
GAS	BURNER NEW	TH						0,366				0,366
OIL	BURNER OLD	TH		1,506								1,506
OIL	BURNER NEW	TH						0,052				0,052
ELEC.	RESISTANCE	TH	0,645					0,197				0,842
SOLAR	COLLECTOR	TH										
ELEC.	LIGHTING APP	AP	1.810	2,492				0,615				4,917

Figure 26. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	MULTI-FAMILY	YEAR 1990			E6 UNITS		
			RETROFIT NO	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW NO	NEW 1	NEW 2	NEW 3	TOTAL
			CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	CONSERV.	
*****											
GAS	BURNER OLD	SH			1,205						1,205
GAS	BURNER NEW	SH						0,163			0,163
GAS	HEAT PUMP	SH						0,472	0,057		0,529
OIL	BURNER OLD	SH		1,851							1,851
OIL	BURNER NEW	SH						0,026	0,052		0,078
ELEC.	HEAT PUMP	SH						0,294			0,433
ELEC.	RESISTANCE	SH	0,139					0,285			0,285
SOLAR	COLLECTOR	SH									
GAS	HEAT PUMP	AC						0,472	0,057		0,529
ELEC.	HEAT PUMP	AC									
ELEC.	ROOM-	AC	0,074	0,981	0,639						1,693
SOLAR	COLLECTOR	AC						0,285			0,285
GAS	BURNER OLD	TH	0,139	1,459							1,598
GAS	BURNER NEW	TH						0,405			0,405
OIL	BURNER OLD	TH		0,392	0,726						1,118
OIL	BURNER NEW	TH							0,078		0,078
ELEC.	RESISTANCE	TH			0,479			0,294			0,774
SOLAR	COLLECTOR	TH						0,285			0,285
ELEC.	LIGHTING APP	AP	0,139	1,851	1,205			0,842	0,078		4,115

- 45 -

Figure 27. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST	MARKET	MOBILE HOME	YEAR 1990				E6 UNITS	
			RETROFIT	RETROFIT	RETROFIT	RETROFIT	NEW	NEW	NEW	NEW	TOTAL
			NO	1	2	3	NO	1	2	3	
			CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	
*****											
GAS	BURNER OLD	SH		0,102							0,102
GAS	BURNER NEW	SH						0,108			0,108
GAS	HEAT PUMP	SH						0,208			0,208
OIL	BURNER OLD	SH		0,155							0,155
OIL	BURNER NEW	SH						0,037			0,037
ELEC.	HEAT PUMP	SH									
ELEC.	RESISTANCE	SH	0,013					0,139			0,152
SOLAR	COLLECTOR	SH									
GAS	HEAT PUMP	AC						0,208			0,208
ELEC.	HEAT PUMP	AC									
ELEC.	ROOM	AC	0,003	0,064							0,068
SOLAR	COLLECTOR	AC									
GAS	BURNER OLD	TH	0,013	0,122							0,135
GAS	BURNER NEW	TH						0,245			0,245
OIL	BURNER OLD	TH		0,094							0,094
OIL	BURNER NEW	TH						0,050			0,050
ELEC.	RESISTANCE	TH		0,040				0,139			0,179
SOLAR	COLLECTOR	TH									
ELEC.	LIGHTING APP	AP	0,013	0,257				0,433			0,703

Figure 28. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST				MARKET		COMMERCIAL			YEAR 1990			E9 SQ.FT.
			RETROFIT NO	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW NO	NEW 1	NEW 2	NEW 3	TOTAL				
*****															
GAS	BURNER OLD	SH	0.676	0.263	0.184									1,123	
GAS	BURNER NEW	SH						1,408						1,408	
GAS	HEAT PUMP	SH						0,903						0,903	
OIL	BURNER OLD	SH	0.442	1,314	0,651									2,407	
OIL	BURNER NEW	SH						0,556	0,055					0,611	
ELEC.	HEAT PUMP	SH													
ELEC.	RESISTANCE	SH	1,622					0,022						1,644	
SOLAR	COLLECTOR	SH						0,406	0,204					0,610	
GAS	HEAT PUMP	AC						0,903						0,903	
ELEC.	HEAT PUMP	AC													
ELEC.	ROOM	AC	1,383	0,627	0,417			0,670						3,096	
SOLAR	COLLECTOR	AC						0,216	0,204					0,420	
GAS	BURNER OLD	TH	0,991		0,178									1,169	
GAS	BURNER NEW	TH						1,994						1,994	
OIL	BURNER OLD	TH	1,598	1,376	0,581									3,555	
OIL	BURNER NEW	TH						0,556	0,055					0,611	
ELEC.	RESISTANCE	TH	0,151	0,201	0,076									0,428	
SOLAR	COLLECTOR	TH						0,406	0,204					0,610	
ELEC.	LIGHTING APP	AP	2,740	1,577	0,835			2,753	0,157					8,062	

1  
47  
1

Figure 29. Buildings energy conservation optimization model. Case-base policy.

REGION			NORTH EAST				MARKET		RESIDENTIAL		YEAR 1990			E6 UNITS
			RETROFIT NO	RETROFIT 1	RETROFIT 2	RETROFIT 3	NEW NO	NEW 1	NEW 2	NEW 3			TOTAL	
			CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,	CONSERV,				
*****														
GAS	BURNER OLD	SH	4.524	0,102	1,205								5,831	
GAS	BURNER NEW	SH						1,400					1,400	
GAS	HEAT PUMP	SH						0,680	0,057				0,737	
OIL	BURNER OLD	SH		8,921									8,921	
OIL	BURNER NEW	SH						0,265	0,052				0,317	
ELEC.	HEAT PUMP	SH						1,045					1,045	
ELEC.	RESISTANCE	SH	0.645					0,433					1,078	
SOLAR	COLLECTOR	SH						0,285					0,285	
GAS	HEAT PUMP	AC						0,680	0,057				0,737	
ELEC.	HEAT PUMP	AC						1,045					1,045	
ELEC.	ROOM	AC	1,600	3,145	0,639			0,221					5,604	
SOLAR	COLLECTOR	AC						0,285					0,285	
GAS	BURNER OLD	TH	1.317	6,382									7,699	
GAS	BURNER NEW	TH						2,063					2,063	
OIL	BURNER OLD	TH	2.670	1,993	0,726								5,389	
OIL	BURNER NEW	TH						0,252	0,078				0,330	
ELEC.	RESISTANCE	TH	1.182	0,649	0,479			1,193					3,503	
SOLAR	COLLECTOR	TH						0,285					0,285	
ELEC.	LIGHTING APP	AP	5.169	9,023	1,205			3,650	0,078				19,125	

Figure 30. Buildings energy conservation optimization model. Case-base policy.



REGION NORTH EAST SUMMARY YEAR 1990 PHY,UNITS

COMMERCIAL  
\*\*\*\*\*

	SPACE HEAT	AIR CONDITIONING	THERMAL	APPLIANCE
GAS	3,4340	0,9027	3,1634	
OIL	3,0181		4,1660	
ELEC.	1,6443	3,0964	0,4277	8,0620
SOLAR	0,6100	0,4196	0,6100	

RESIDENTIAL  
\*\*\*\*\*

	SPACE HEAT	AIR CONDITIONING	THERMAL	APPLIANCE
GAS	7,9674	0,7368	9,7611	
OIL	9,2379		5,7188	
ELEC.	2,1229	6,6492	3,5025	19,1250
SOLAR	0,2852	0,2852	0,2852	

Figure 31. Buildings energy conservation optimization model. Case-base policy.

REGION - NORTH EAST                      RESIDENTIAL      YEAR 1990                      UNIT - \$ BILLION  
 \*\*\*\*\*

		NEW ***		OLD ***	
SINGLE FAMILY	LEVEL I	1.1483		3.3965	
	LEVEL II				
	LEVEL III		1.1483		3.3965
LOW DENSITY	LEVEL I	0.2968		1.4287	
	LEVEL II				
	LEVEL III		0.2968		1.4287
MULTI-FAMILY	LEVEL I	0.1604		0.6864	
	LEVEL II	0.0276		0.6999	
	LEVEL III		0.1880		1.3864
MOBIL HOME	LEVEL I	0.1714		0.0643	
	LEVEL II				
	LEVEL III		0.1714		0.0643
TOTAL		1.8044		6.2759	

Figure 32. Buildings energy conservation optimization model. Capital investment in structural technologies (1975 \$).

REGION - NORTH EAST                      COMMERCIAL                      YEAR 1990                      UNIT - \$ BILLION  
 \*\*\*\*\*

		NEW ***		OLD ***	
HOSPITALS	LEVEL I	0.1046			
	LEVEL II				
	LEVEL III		0.1046		
SCHOOLS	LEVEL I	0.1128		0.5419	
	LEVEL II				
	LEVEL III		0.1128		0.5419
OFFICES	LEVEL I	0.1054		0.3664	
	LEVEL II	0.0920			
	LEVEL III		0.1973		0.3664
RETAIL	LEVEL I	0.1308			
	LEVEL II			0.7108	
	LEVEL III		0.1308		0.7108
MISC	LEVEL I	0.4503			
	LEVEL II				
	LEVEL III		0.4503		
TOTAL		0.9959		1.6191	

Figure 33. Buildings energy conservation optimization model. Capital investment in structural technologies (1975 \$).

REGION NORTH EAST                      RESIDENTIAL      YEAR 1990                      UNIT - \$ BILLION  
 \*\*\*\*\*

	SPACE HEAT	AIR COND	THERMAL	APPLIANCE & LIGHT
SINGLE FAMILY	7.3888	0.2551	1.4302	4.1442
LOW DENSITY	2.1610	0.0523	0.1625	1.3786
MULTI-FAMILY	2.9811	0.0896	0.2765	1.8559
MOBIL HOME	0.7026		0.0886	0.8254
TOTAL	13.2334	0.3969	1.9577	8.2041

Figure 34. Buildings energy conservation optimization model. Capital investment in conversion devices (1975 \$).

REGION NORTH EAST COMMERCIAL YEAR 1990 UNIT - \$ BILLION  
 \*\*\*\*\*

	SPACE HEAT	AIR COND	THERMAL	APPLIANCE & LIGHT
HOSPITALS	3.4716	0.2132	0.1234	3.0762
SCHOOLS	1.6330	0.0932	0.0248	1.4273
OFFICES	4.3642	0.2012	0.0451	2.6500
RETAIL	2.7071		0.0267	5.1899
MISC	0.4517	1.8152	0.0354	6.8207
TOTAL	12.6275	2.3227	0.2553	19.1641

Figure 35. Buildings energy conservation optimization model. Capital investment in conversion devices (1975 \$).

## 5. Applications

The most important feature of the model from the point of view of the user is that BECOM consists of a multitude of individually specified building energy technologies which are selected and assembled in a systematic way to project a picture of the entire stock of energy technologies in buildings and the resulting energy consumption. The technologies currently included comprise the major classes of conventional equipment and also major types of equipment under development. Novel and conventional equipment types compete on an equal basis.

These structural characteristics of BECOM make it especially suited for certain types of analysis.

1. Market penetration analysis. Because all types of equipment compete simultaneously, meaningful analyses of the relative roles of various technologies can be developed. Furthermore, since all possible combinations of conversion devices (such as HVAC equipment and various structural improvements) are included, one can analyze the synergistic effects of combining various types of conversion devices and structural technologies. Unlike many other models of buildings energy demand, BECOM makes it impossible to double-count energy savings.

Because it includes nine building types, two building classes (new and retrofit), and four regions, BECOM can be used to calculate the market penetrations of technologies in considerable detail and also on a national aggregate basis. Thus, the model identified both those technologies that have a

large national impact and those that may be highly desirable in a limited market.

2. Policy analysis. A major question before the nation in relation to energy consumption in buildings is the role of various policy measures such as price regulation of various forms of energy, tax incentives for investment in specific building technologies, implementation of various code improvements, and setting of performance standards for appliances, air conditioning, and buildings. BECOM can analyze effects of such measures in a high degree of detail. Various pricing policies can be represented through input prices, which can be varied for different regions and consuming sectors. Tax incentives or other measures for changing the economics of building investment can and have been entered through adjustments to the capital charges for various building types. These adjustments can be different for each type of building just as they are likely to be for different classes of building owners. (Store owners will be treated differently than homeowners, for example.) Finally, regulatory action can be represented through constraints requiring or prohibiting certain technologies in the various markets.

3. Analysis of research, development, and demonstration projects. Because BECOM makes projections of buildings energy demand by assembling an overall technological configuration from many individual technologies, it is particularly well suited to examining the role of these technologies in the context of total building energy consumption.

Within BECOM, a technology is a generic type. For example, the electric heat pump is one generic technology. DOE or other RD&D projects related to electric heat-pump market share for each region or building type (if the project were so directed) indicated by BECOM. If the project were directed at achieving a particular cost or efficiency improvement, these parameters could be entered in the model to estimate the degree to which a given cost or improvement would improve market penetration, and the particular building types and regions where the increased market penetration would occur.

A key feature of BECOM for RD&D assessment is that the simultaneous competition of all technologies precludes double counting of energy savings which could occur if energy savings from technologies were estimated without considering competing technologies. Also, since buildings are defined according to both conversion devices and structural technologies, savings are attributed to the combined effect of conversion-device improvements and structural improvements, as will actually occur in the field.

4. Sensitivity analysis. This type of analysis is closely related to the other areas outlined above. Because of the advanced programming system used for this model, one can quickly perform a series of evaluations of the types outlined, varying a single parameter (an energy price, for example, or the level of a tax credit) and produce a complete analysis of the entire buildings sector for each value of the parameter of



interest. Thus the full effects of a specific decision variable can be thoroughly analyzed.

5. Conservation implementation. BECOM is expected to be used in the near future to study the relationship between implementation of energy-conservation technologies (revealed, for example, through sales figures for insulation, heat pumps, and so forth) and yearly totals for energy consumption in buildings. By reconciling yearly sales totals of building energy technologies and total energy consumption within the BECOM framework, it will be possible to assess whether federal policies are having the anticipated effects on conservation-technology implementation and ultimately on energy consumption. If not, policy adjustments can be assessed.

6. Environmental effects of conservation in buildings. Reduced environmental impacts in the energy supply system as a whole are captured in BESOM. Detailed coefficients for emissions from the individual conversion devices included in BECOM are being developed. When this task is completed, detailed assessments of the environmental effects of buildings conservation policies can be performed.

## Acknowledgements

Many persons have made essential contributions to this program. William Marcuse originally conceived this approach to modeling energy conservation technologies, and he has provided continuing guidance and support. The overall building energy conservation program at BNL has been made possible by continuing interest and support from the Division of Buildings and Community Systems, particularly its director, Dr. Maxine Savitz, and Dr. S. Melvin Chiogioji and Joan Hock. Martin Glesk, leader of the Arthur D. Little case team on buildings, provided invaluable assistance in the form of data presented in the appendices to this report and also working suggestions. Comments from the Market Oriented Program Planning Study Residential and Commercial Working Group were helpful and essential, particularly those of Ed Blum and Eric Hirst.

Invaluable assistance was provided by Doreen Schneider and Marc Raisch of the BNL staff in assembling data and completing calculations. Barbara Nichols, Carmen Zopf, Marge Gallitelli, and Nancy Jesaitis provided their customary efficient and capable services in typing and assembly. Technical drawings were done by Stan Majeski. This effort has greatly benefited from the environment of Brookhaven's National Center for Analysis of Energy Systems, and especially from contact with several members who have worked in this general area - Kenneth Hoffman, Andy Kydes, Andres Doernberg, and Alan Hermelee. Responsibility for the paper remains, of course with the authors.

### References

1. Cherniavsky, E.A., Brookhaven Energy System Optimization Model, Informal Report, BNL 19569, 1974.
2. Goldberg, M.D., An Energy Model Data Base, Informal Report, BNL 19200, undated (1973).
3. Beller, M., Editor, Sourcebook for Energy Assessment, BNL 50483, December 1975.
4. Marcuse, W., Carhart, S., and Mulherkar, S., Residential energy demand analysis - Data and methodology, Presented at Joint National Meeting Operations Res. Soc. Am. and Institute of Management Science, Miami, November 1976 (BNL 21920).
5. Cherniavsky, E.A., Kydes, A.S., et al., Brookhaven Energy Systems Optimization Model - Methodology and Documentation (Version 2.1), BNL report, in preparation.
6. Glesk, M., et al., Report to Department of Energy on Building Technologies, Arthur D. Little, Inc., in preparation.
7. Daifuku, R., Residential Space Heating and Cooling in New England 1972-2000, BNL 50614, December 1976.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

APPENDIX A

Residential and Commercial  
Inventory and Forecasts

RESIDENTIAL CONSTRUCTION INVENTORY FORECASTS

(thousand units)

	1975	NEW CONSTRUCTION			REMOVALS	2000
	<u>INVENTORY</u>	<u>1976-1980</u>	<u>1981-1985</u>	<u>1986-2000</u>	<u>1976-2000</u>	<u>INVENTORY</u>
Northeast Total	16,282	1,250	1,500	3,357	1,629	20,760
Single Family Detached	7,910	698	693	1,475	640	10,136
Low Density	4,544	156	246	648	397	5,197
Multi-Family	3,445	252	407	801	409	4,496
Mobile Homes	383	144	154	433	183	931
North Central Total	18,993	2,074	2,505	5,646	2,353	26,865
Single Family Detached	13,253	1,250	1,335	2,926	1,259	17,505
Low Density	2,840	161	235	616	321	3,531
Multi-Family	2,112	340	588	1,134	306	3,868
Mobile Homes	788	323	347	970	467	1,961
South Total	22,488	3,827	4,647	10,504	3,439	38,027
Single Family Detached	16,051	2,330	2,477	5,499	2,014	24,343
Low Density	2,315	280	442	1,106	255	3,888
Multi-Family	2,428	580	1,045	1,988	236	5,805
Mobile Homes	1,694	637	683	1,911	934	3,991
West Total	13,067	2,149	2,628	5,926	1,629	22,141
Single Family Detached	8,379	1,140	1,175	2,553	846	12,401
Low Density	1,740	285	439	1,102	128	3,438
Multi-Family	2,098	428	698	1,385	209	4,400
Mobile Homes	850	296	316	886	446	1,902
U. S. Total	70,830	9,300	11,280	25,433	9,050	107,793

COMMERCIAL CONSTRUCTION INVENTORY FORECASTS

(million square feet)

	1975	NEW CONSTRUCTION			REMOVALS	2000
	<u>INVENTORY</u>	<u>1976-1980</u>	<u>1981-1985</u>	<u>1986-2000</u>	<u>1976-2000</u>	<u>INVENTORY</u>
Northeast Total	5,688	938	980	3,272	879	9,999
Office & Bank	1,321	193	203	660	198	2,179
Retail	928	179	190	636	139	1,794
Schools	1,150	114	107	342	199	1,514
Hospitals	440	94	101	368	66	937
Other	1,849	358	379	1,266	277	3,575
North Central Total	6,674	1,169	1,217	4,089	1,135	12,014
Office & Bank	1,317	198	207	675	224	2,173
Retail	1,517	334	354	1,195	258	3,142
Schools	1,812	190	179	576	308	2,449
Hospitals	511	113	122	448	87	1,107
Other	1,517	334	355	1,195	258	3,143
South Total	7,320	1,273	1,379	4,783	1,464	13,291
Office & Bank	1,650	265	288	975	330	2,848
Retail	1,589	317	349	1,212	318	3,149
Schools	1,530	167	162	540	306	2,093
Hospitals	486	113	127	480	97	1,109
Other	2,065	411	453	1,576	413	4,092
West Total	4,781	811	891	3,106	813	8,776
Office & Bank	1,146	185	203	690	195	2,029
Retail	960	180	202	706	163	1,884
Schools	934	104	102	342	159	1,323
Hospitals	294	70	80	304	50	698
Other	1,447	272	304	1,064	246	2,842
U.S. Total	24,463	4,191	4,467	15,250	4,291	44,080

Building Units and % Air Conditioned - 1976-2000  
 New - Non Residential 1976-2000

		<u>NEW</u>		<u>RETROFIT</u>	
		<u>Built</u> <u>1976-2000</u>	<u>% A C</u>	<u>1976-2000</u>	<u>% A C</u>
Northeast	Offices	1,056	65	1,123	55
	Ret. & Other	3,008	60	2,361	50
	Schools	563	30	978	25
	Hospitals	563	95	374	62
North Central	Offices	1,080	65	1,093	50
	Ret. & Other	3,767	60	2,518	45
	Schools	945	50	1,504	32
	Hospitals	683	97	424	56
South	Offices	1,528	95	1,320	70
	Ret. & Other	4,318	90	2,923	65
	Schools	869	75	1,224	60
	Hospitals	720	100	389	75
West	Office	1,078	85	951	60
	Ret. & Other	2,728	80	1,998	55
	Schools	548	70	775	52
	Hospitals	454	100	244	67



Building Units and % Air Conditioned - 1976-2000  
New and Retrofit

		<u>New Units</u> 1976-2000	<u>% A C*</u>	<u>Retro</u> <u>Units</u>	<u>% A C*</u>
Northeast	Single Family	2,866	52	7,270	30
	Low Density	1,050	57	4,147	31
	Multi-Family	1,465	73	3,036	53
	Mobile Home	731	48	200	25
North Central	Single Family	5,511	70	11,994	43
	Low Density	1,012	73	2,519	34
	Multi-Family	2,062	87	1,806	67
	Mobile Home	1,640	45	321	30
South	Single Family	10,306	87	14,037	48
	Low Density	1,828	90	2,060	43
	Multi-Family	3,613	95	2,192	77
	Mobile Home	3,231	85	760	35
West	Single Family	4,868	70	7,533	35
	Low Density	1,826	75	1,612	31
	Multi-Family	2,511	82	1,889	39
	Mobile Home	1,498	72	404	35

\* Central and Room

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

APPENDIX B

- Theoretical Loads for Buildings
- Conservation Technology Costs and Savings
- First Costs of Conventional HVAC Equipment

THEORETICAL BUILDING ENERGY LOADS

RESIDENTIAL - NEW CONSTRUCTION 1976-1980

<u>Building Type</u>	<u>Region</u>	<u>Fossil</u>	<u>Heat</u> <u>Electric</u>	<u>Cool</u>	<u>Thermal</u>	<u>Light</u> <u>and</u> <u>Power</u>	<u>Aux.</u>
Single-Family	NE	81	65	8	19	21	
	NC	102	81	13	19	23	
	S	39	36	59	19	21	NA
	W	57	53	60	19	23	
Low Density	NE	70	50	6	13	20	
	NC	102	62	11	13	21	
	S	38	28	47	13	20	NA
	W	57	40	48	13	21	
Multi-Family	NE	46	21	3	11	18	
	NC	53	23	5	11	18	
	S	19	11	22	11	17	NA
	W	23	15	21	11	18	
Mobile Homes	NE	57	41	8	8	17	
	NC	66	47	12	8	20	
	S	31	22	38	8	20	NA
	W	38	27	37	8	17	

All figures in  $10^6$  Btu/unit

Assumes the following conversion efficiencies:

Gas 0.7  
 Oil 0.6  
 Electric 1.0  
 A C CoP 2.1

THEORETICAL BUILDING ENERGY LOADS

COMMERCIAL - NEW CONSTRUCTION 1976-1980

<u>Building Type</u>	<u>Region</u>	<u>Fossil</u>	<u>Heat</u>	<u>Electric</u>	<u>Cool</u>	<u>Thermal</u>	<u>Light and Power</u>	<u>Aux.</u>
Office and Bank	NE	68		44	23	3	24	15
	NC	68		51	23	3	30	18
	S	42		24	53	3	30	20
	W	43		25	34	3	31	20
Retail	NE	37		22	25	2	62	20
	NC	44		26	26	2	67	25
	S	18		14	61	2	69	30
	W	23		16	40	2	72	30
Schools	NE	60		40	19	3	26	12
	NC	70		46	19	3	28	15
	S	31		18	43	3	28	18
	W	38		23	25	3	31	18
Hospitals	NE	73		54	19	17	60	30
	NC	86		54	19	17	74	30
	S	37		19	43	17	73	35
	W	46		25	25	17	86	35
Other	NE	37		24	--	2	34	20
	NC	44		27	--	2	35	25
	S	17		15	61	2	37	30
	W	22		16	--	2	39	30

All figures in  $10^3$  Btu/square foot

Assumes the following conversion efficiencies:

Gas	0.7
Oil	0.6
Electric	1.0
A C CoP	2.1

THEORETICAL BUILDING ENERGY LOADS

RESIDENTIAL - RETROFIT 1975 INVENTORY

<u>Building Type</u>	<u>Region</u>	<u>Gas</u>	<u>Heat</u>		<u>Electric</u>	<u>Cool</u>	<u>Thermal</u>	<u>Light and Power</u>	<u>Aux.</u>
			<u>Oil</u>						
Single-Family	NE	94	128		51	6	22	21	
	NC	118	114		64	19	22	23	
	S	43	79		31	63	22	21	NA
	W	57	102		44	74	22	23	
Low Density	NE	67	89		33	5	15	20	
	NC	87	84		45	11	15	21	
	S	30	54		21	36	15	20	NA
	W	37	65		30	54	15	20	
Multi-Family	NE	43	58		17	4	13	18	
	NC	50	49		24	9	13	18	
	S	16	29		10	34	13	17	NA
	W	20	35		14	33	13	18	
Mobile Homes	NE	44	59		24	6	10	17	
	NC	54	53		29	10	10	20	
	S	21	53		15	40	10	20	NA
	W	27	48		20	46	10	17	

All figures in  $10^6$  Btu/unit

Assumes the following conversion efficiencies:

Gas 0.6  
 Oil 0.5  
 Electric 1.0  
 A C CoP 2.1

THEORETICAL BUILDING ENERGY LOADS\*

COMMERCIAL - RETROFIT 1975 INVENTORY

<u>Building Type</u>	<u>Region</u>	<u>Gas</u>	<u>Heat</u>		<u>Electric</u>	<u>Cool</u>	<u>Thermal</u>	<u>Light and Power</u>	<u>Aux.</u>
			<u>Oil</u>						
Office and Bank	NE	91	83		31	33	3	24	18
	NC	84	68		--	36	-	30	20
	S	64	60		19	87	3	30	22
	W	66	59		20	57	3	31	22
Retail	NE	50	47		14	37	2	62	22
	NC	46	37		--	41	-	67	27
	S	29	26		10	99	2	69	33
	W	35	32		13	68	2	72	33
Schools	NE	80	74		28	28	3	26	15
	NC	74	60		--	30	-	28	18
	S	50	44		14	70	3	28	20
	W	58	52		19	39	3	31	20
Hospitals	NE	97	89		33	42	16	60	32
	NC	90	73		--	45	--	74	32
	S	55	51		14	106	16	73	37
	W	68	61		20	76	16	86	37
Other	NE	49	45		16	37	2	34	22
	NC	46	37		--	41	-	35	27
	S	27	24		11	99	2	37	33
	W	33	30		13	68	2	39	33

All Figures in  $10^3$  Btu/square foot

Assumes the following conversion efficiencies:

Gas 0.6  
 Oil 0.5  
 Electric 1.0  
 A C CoP 2.1

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: SINGLE FAMILY 1560 SQ. FT. UNIT

		First Cost \$/unit	CONSERVATION LEVEL I % of load saved			L&P
			Heating	Cooling	Hot Water	
New Construction	NE	220	23	20	5	5
	NC	220	25	22	5	5
	S	240	23	25	5	5
	W	240	25	23	5	5
Retrofit	NE	260	15	10	0	0
	NC	260	17	10	0	0
	S	200	12	15	0	0
	W	200	14	13	0	0
CONSERVATION LEVEL II						
New Construction	NE	800	50	35	5	5
	NC	800	52	37	5	5
	S	770	44	35	5	5
	W	770	46	33	5	5
Retrofit	NE	1,130	43	20	0	0
	NC	1,130	45	20	0	0
	S	1,070	37	25	0	0
CONSERVATION LEVEL III						
New Construction	NE	2,140	58	40	10	5
	NC	2,140	60	42	10	5
	S	1,760	50	40	10	5
	W	1,760	52	38	10	5
Retrofit	NE	1,860	52	25	5	0
	NC	1,860	54	25	5	0
	S	1,770	44	30	5	0
	W	1,770	46	28	5	0



CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: LOW DENSITY 1000 SQ. FT. UNIT

		First Cost \$/unit	CONSERVATION LEVEL I % of load saved			L&P
			Heating	Cooling	Hot Water	
New Construction	NE	165	23	20	5	5
	NC	165	25	22	5	5
	S	180	23	25	5	5
	W	180	25	23	5	5
Retrofit	NE	195	15	10	0	0
	NC	195	17	10	0	0
	S	150	12	15	0	0
	W	150	14	13	0	0
CONSERVATION LEVEL II						
New Construction	NE	600	50	35	5	5
	NC	600	52	37	5	5
	S	580	44	35	5	5
	W	580	46	33	5	5
Retrofit	NE	850	43	20	0	0
	NC	850	45	20	0	0
	S	800	37	25	0	0
	W	800	39	23	0	0
CONSERVATION LEVEL III						
New Construction	NE	1,600	58	40	10	5
	NC	1,600	60	42	10	5
	S	1,320	50	40	10	5
	W	1,320	52	38	10	5
Retrofit	NE	1,400	52	25	5	0
	NC	1,400	54	25	5	0
	S	1,330	44	30	5	0
	W	1,330	46	28	5	0

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: MULTI-FAMILY 900 SQ.FT. UNIT

		First Cost \$/unit	CONSERVATION LEVEL I % of load saved				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	65	30	25	15	5	10	
	NC	65	33	25	15	5	10	
	S	65	25	30	15	5	10	
	W	65	27	28	15	5	10	
Retrofit	NE	126	18	25	8	5	0	
	NC	126	21	25	8	5	0	
	S	126	17	18	8	5	0	
	W	126	20	16	8	5	0	
CONSERVATION LEVEL II								
New Construction	NE	120	38	35	15	5	10	
	NC	120	40	35	15	5	10	
	S	120	35	42	15	5	10	
	W	120	37	40	15	5	10	
Retrofit	NE	198	24	25	15	5	0	
	NC	198	28	25	15	5	0	
	S	198	25	22	15	5	0	
	W	198	29	20	15	5	0	
CONSERVATION LEVEL III								
New Construction	NE	260	45	44	20	5	10	
	NC	260	48	44	20	5	10	
	S	260	40	50	20	5	10	
	W	260	42	47	20	5	10	
Retrofit	NE	324	24	25	23	5	0	
	NC	324	29	25	23	5	0	
	S	324	25	22	23	5	0	
	W	324	30	18	23	5	0	

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: MOBILE HOME 720 SQ. FT. UNIT

		First Cost \$/unit	CONSERVATION LEVEL I % of load saved			L&P
			Heating	Cooling	Hot Water	
New Construction	NE	1	30	30	5	0
	NC	1	30	30	5	0
	S	1	20	20	5	0
	W	1	20	20	5	0
Retrofit	NE	85	15	15	3	0
	NC	85	15	15	3	0
	S	85	15	15	3	0
	W	85	15	15	3	0
CONSERVATION LEVEL II						
New Construction	NE	330	45	45	5	0
	NC	330	45	45	5	0
	S	230	30	30	5	0
	W	230	30	30	5	0
Retrofit	NE	435	30	25	7	0
	NC	435	30	25	7	0
	S	335	25	30	7	0
	W	335	25	30	7	0
CONSERVATION LEVEL III						
New Construction	NE	790	61	61	7	0
	NC	790	61	61	7	0
	S	490	46	46	7	0
	W	490	46	46	7	0
Retrofit	NE	655	37	28	7	0
	NC	655	37	28	7	0
	S	475	30	33	7	0
	W	475	30	33	7	0

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: OFFICE

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL I % of load saved			L&P	Aux.
			Heating	Cooling	Hot Water		
New Construction	NE	80	25	20	0	15	10
	NC	80	27	20	0	15	10
	S	80	28	35	0	15	10
	W	80	30	32	0	15	10
Retrofit	NE	160	11	13	0	25	17
	NC	160	13	13	0	25	17
	S	160	6	8	0	20	14
	W	160	8	7	0	20	14

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL II % of load saved			L&P	Aux.
			Heating	Cooling	Hot Water		
New Construction	NE	200	35	35	5	25	16
	NC	200	38	35	5	25	16
	S	200	38	45	5	25	16
	W	200	41	42	5	25	16
Retrofit	NE	330	15	17	0	50	28
	NC	330	17	17	0	50	28
	S	330	13	11	0	40	23
	W	330	15	10	0	40	23

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL III % of load saved			L&P	Aux.
			Heating	Cooling	Hot Water		
New Construction	NE	465	40	47	10	25	20
	NC	465	43	47	10	25	20
	S	465	45	50	10	25	20
	W	465	48	47	10	25	20
Retrofit	NE	580	23	34	0	50	38
	NC	580	26	34	0	50	38
	S	580	19	24	0	40	32
	W	580	22	22	0	40	32

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: SCHOOL

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL I % of load saved				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	115	30	25	5	15	20	
	NC	115	33	25	5	15	20	
	S	115	35	20	5	15	20	
	W	115	38	17	5	15	20	
Retrofit	NE	230	14	16	0	12	26	
	NC	230	16	16	0	12	26	
	S	230	13	9	0	11	20	
	W	230	13	8	0	11	20	
CONSERVATION LEVEL II								
New Construction	NE	355	42	35	5	20	25	
	NC	355	45	35	5	20	25	
	S	355	48	35	5	20	25	
	W	355	51	32	5	20	25	
Retrofit	NE	590	21	26	0	30	33	
	NC	590	24	26	0	30	33	
	S	590	19	14	0	28	25	
	W	590	22	12	0	28	25	
CONSERVATION LEVEL III								
New Construction	NE	880	50	41	10	20	30	
	NC	880	53	41	10	20	30	
	S	880	55	40	10	20	30	
	W	880	58	37	10	20	30	
Retrofit	NE	1,100	29	56	30	42	53	
	NC	1,100	32	56	30	42	53	
	S	1,100	30	28	30	39	40	
	W	1,100	33	25	30	39	40	

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: HOSPITAL

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL I % of load saved				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	140	20	15	10	10	10	
	NC	140	23	15	10	10	10	
	S	140	20	20	10	10	10	
	W	140	23	17	10	10	10	
Retrofit	NE	280	7	7	12	8	19	
	NC	280	9	7	12	18	19	
	S	280	11	8	12	7	16	

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL II				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	455	32	25	15	15	15	
	NC	455	35	25	15	15	15	
	S	455	35	30	15	15	15	
	W	455	38	27	15	15	15	
Retrofit	NE	760	15	24	24	12	25	
	NC	760	18	24	24	12	25	
	S	760	23	13	24	10	22	
	W	760	26	11	24	10	22	

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL III				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	1,040	40	33	20	15	15	
	NC	1,040	43	33	20	15	15	
	S	1,040	45	35	20	15	15	
	W	1,040	48	32	20	15	15	
Retrofit	NE	1,300	16	28	31	17	30	
	NC	1,300	19	28	31	17	30	
	S	1,300	23	15	31	14	27	
	W	1,300	26	12	31	14	27	

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: RETAIL STORE

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL I % of load saved				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	80	30	25	0	15	10	
	NC	80	32	25	0	15	10	
	S	80	28	35	0	15	10	
	W	80	30	32	0	15	10	
Retrofit	NE	160	8	12	0	13	18	
	NC	160	10	12	0	13	18	
	S	160	11	7	0	12	12	
	W	160	13	6	0	12	12	

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL II % of load saved				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	175	42	37	5	24	16	
	NC	175	45	37	5	24	16	
	S	175	45	40	5	24	16	
	W	175	48	37	5	24	16	
Retrofit	NE	290	23	20	0	25	36	
	NC	290	26	20	0	25	36	
	S	290	25	11	0	23	24	
	W	290	27	10	0	23	24	

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL III % of load saved				L&P	Aux.
			Heating	Cooling	Hot Water			
New Construction	NE	420	50	46	10	30	20	
	NC	420	53	46	10	30	20	
	S	420	55	50	10	30	20	
	W	420	58	45	10	30	20	
Retrofit	NE	520	25	20	0	25	45	
	NC	520	28	20	0	25	45	
	S	520	29	13	0	23	30	
	W	520	32	11	0	23	30	

CONSERVATION TECHNOLOGY COSTS & SAVINGS

BUILDING TYPE: MISCELLANEOUS

		First Cost \$/1000 ft <sup>2</sup>	CONSERVATION LEVEL I				L&P	Aux.
			% of load saved					
			Heating	Cooling	Hot Water			
New Construction	NE	150	30	25	5	15	15	
	NC	150	33	25	5	15	15	
	S	150	35	35	5	15	15	
	W	150	38	32	5	15	15	
Retrofit	NE	300	9	5	0	9	14	
	NC	300	11	5	0	9	14	
	S	300	8	4	0	8	13	
	W	300	10	3	0	8	13	
CONSERVATION LEVEL II								
New Construction	NE	400	42	35	10	15	20	
	NC	400	45	35	10	15	20	
	S	400	42	42	10	15	20	
	W	400	45	39	10	15	20	
Retrofit	NE	660	15	12	0	15	23	
	NC	660	18	12	0	15	23	
	S	660	20	7	0	14	23	
	W	660	23	6	0	14	23	
CONSERVATION LEVEL III								
New Construction	NE	1,040	50	40	10	20	20	
	NC	1,040	53	40	10	20	20	
	S	1,040	45	45	10	20	20	
	W	1,040	48	42	10	20	20	
Retrofit	NE	1,300	26	24	0	24	32	
	NC	1,300	30	24	0	24	32	
	S	1,300	40	13	0	22	31	
	W	1,300	44	12	0	22	31	



FIRST COSTS OF CONVENTIONAL HVAC EQUIPMENT

	Single Family \$/unit	Low Density \$/unit	Multi- Family \$/unit	Mobile Homes \$/unit	Office/ Bank \$/1000 ft <sup>2</sup>	Retail \$/1000 ft <sup>2</sup>	Schools \$/1000 ft <sup>2</sup>	Hospitals, \$/1000 ft <sup>2</sup>	Other \$/1000 ft <sup>2</sup>
<b>A. Gas Heat</b>									
NE	2,980	2,650	2,322	577	5,170	3,500	4,280	5,140	3,500
NC	3,073	2,750	2,412	599	5,360	3,640	4,430	5,320	3,640
S	2,730	2,410	2,115	528	4,720	3,200	3,920	4,700	3,200
W	3,073	2,750	2,412	600	5,360	3,650	4,430	5,330	3,650
<b>B. Oil Heat</b>									
NE	3,026	2,660	2,205	817	5,130	3,490	4,250	5,130	3,490
NC	3,120	2,760	2,376	848	5,320	3,630	4,400	5,310	3,630
S	2,777	2,320	2,088	748	4,680	3,190	3,890	4,690	3,190
W	3,120	2,760	2,385	850	5,320	3,650	4,400	5,320	3,640
<b>C. Elec. Heat</b>									
NE	2,808	2,770	2,367	504	5,240	3,557	4,060	5,180	3,557
NC	2,886	2,880	2,457	522	5,430	3,700	4,490	5,360	3,700
S	2,538	2,530	2,160	461	4,780	3,250	3,970	4,740	3,250
W	2,886	2,880	2,457	524	5,430	3,710	4,490	5,370	3,710
<b>D. Gas Heat W/AC</b>									
NE	4,705	3,239	3,780	1,978	8,940	5,940	7,720	14,667	5,940
NC	4,682	3,360	3,870	2,051	9,150	6,080	7,600	13,500	6,080
S	4,308	2,949	3,636	1,810	8,610	5,730	7,140	11,900	5,730
W	4,866	3,362	3,888	2,056	9,180	6,095	7,620	13,520	6,095
<b>E. Oil Heat W/AC</b>									
NE	4,751	3,249	3,663	2,218	8,900	5,930	7,690	14,657	5,930
NC	4,909	3,370	3,834	2,301	9,110	6,069	7,570	13,490	6,069
S	4,355	2,859	3,609	2,029	8,570	5,720	7,110	11,890	5,720
W	4,913	3,372	3,861	2,305	9,140	6,085	7,590	13,510	6,085
<b>F. Elec. Heat W/AC</b>									
NE	4,533	3,359	3,825	1,905	9,010	6,000	7,500	13,040	6,000
NC	4,675	3,490	3,915	1,976	9,220	6,140	7,660	13,540	6,140
S	4,136	3,069	3,681	1,743	8,670	5,780	7,190	11,940	5,780
W	4,679	3,492	3,933	1,980	9,250	6,170	7,680	13,560	6,170
<b>G. Elec. Heat Pump</b>									
NE	4,833	3,654	3,975	2,205	9,310	6,150	7,800	13,040	6,150
NC	5,125	3,790	4,065	2,276	9,520	6,290	7,960	13,840	6,290
S	4,436	3,219	3,831	2,143	8,970	5,930	7,490	12,390	5,930
W	5,129	3,642	4,083	2,280	9,550	6,320	7,980	13,860	6,320
<b>H. Gas Heat Pump</b>									
NE	6,725	4,965	5,255	2,735	11,810	7,850	10,345	18,680	7,850
NC	7,275	5,110	5,375	2,820	12,060	8,015	10,200	17,280	8,015
S	5,890	4,260	4,725	2,890	11,050	7,595	9,290	15,000	7,595
W	6,920	5,115	5,025	3,190	11,735	8,035	9,865	16,945	8,035