

Received April 10, 2020, accepted May 12, 2020, date of publication May 25, 2020, date of current version June 12, 2020.

Digital Object Identifier 10.1109/ACCESS.2020.2997056

Construction and Performance Investigation of Three-Phase Solar PV and Battery Energy Storage System Integrated UPQC

MUHAMMAD ALIF MANSOR^{ID}, KAMRUL HASAN^{ID},
MUHAMMAD MURTADHA OTHMAN, (Member, IEEE),
SITI ZALIHA BINTI MOHAMMAD NOOR, (Member, IEEE), AND ISMAIL MUSIRIN

Faculty of Electrical Engineering, Universiti Teknologi MARA, Shah Alam 40450, Malaysia

Corresponding author: Muhammad Murtadha Othman (mamat505my@yahoo.com)

This work was supported by the Long-Term Research Grant (LRGS), Ministry of Education Malaysia for the program titled “Decarbonization of Grid with an Optimal Controller and Energy Management for Energy Storage System in Microgrid Applications” under Grant 600-IRMI/LRGS 5/3 (001/2019).

ABSTRACT This study examines the use of Unified Power Quality Conditioner (UPQC) to mitigate the power quality problems existed in the grid and the harmonics penetrated by the non-linear loads. The UPQC is supported by the Photovoltaic (PV) and Battery Energy Storage System (BESS) in this work. Generally, the PV system supplies the active power to the load. However, if the PV is unable to supply the power then the BESS activates and provides power especially during the longer-term voltage interruption. The standalone PV-UPQC system is less reliable compared to a hybrid PV-BESS system because of its instability and high environment-dependency. Therefore, BESS will improve the voltage support capability continuously in the longer-term, reduce the complexity of the DC-link voltage regulation algorithm, and keep producing clean energy. The phase synchronization operation of the UPQC controller is directed by a self-tuning filter (STF) integrated with the unit vector generator (UVG) technique. Implementation of STF will make sure the UPQC can successfully operate under unbalanced and distorted grid voltage conditions. Thus, the requirement of a phase-locked loop (PLL) is omitted and the STF-UVG is utilized to produce the synchronization phases for the series and shunt active power filter (APF) compensator in UPQC controller. Finally, the proposed STF-UVG method is compared with the conventional synchronous references frame (SRF-PLL) method based UPQC to show the significance of the proposed technique. Several case studies are further considered to validate the study in MATLAB-Simulink software.

INDEX TERMS Battery energy storage system (BESS), power quality, self-tuning filter (STF), solar photovoltaic (PV), unified power quality conditioner (UPQC).

I. INTRODUCTION

Energy is the basic input of life. Electricity is one of the significant energy among the different forms of energy. It ensures the flexibility of life and the demand for this energy is increasing rapidly. In recent decades, the ‘Power Quality’ term has achieved remarkable responses from the researchers, most importantly in the electrical engineering sector. Energy efficiency is maintained by compensating the power quality problems which ensures a smooth generation of electrical energy and to encourage decarbonization of the grid. Under

different environmental conditions and requirements, the definition of power quality can have several interpretations and significances. For instance, the network can be affected by the harmonics created by non-linear loads which is a great concern for the utility and the disturbances existed in the supplied voltage is a great concern for the consumers. Power losses, undesirable and abnormal characteristics of equipment due to power quality problems can cause interference in neighboring communication lines, and disruption to different consumers. IEEE-1159 [1] stated the behavior of a standard waveform and categorized a different kind of disturbances. A complex power quality scenario is a specific disturbance that consists of an amalgamation of two or more individual disturbances,

The associate editor coordinating the review of this manuscript and approving it for publication was Madhav Manjrekar.

for instance, fluctuation or harmonics for a small period distortion such as, sags or surges [2].

The voltage disturbances such as voltage harmonics, swells, and sags are responsible for the tripping of equipment like sensitive loads and the consequences can be detrimental for industrial plants, for instance, termination of the industrial process. These scenarios are familiar in the industry which creates high economical losses. To overcome this situation, mitigation devices of the series APFs are installed by the industrial customers to secure their plant from the disturbances coming from the grid [3]–[8]. The use of power electronics components is growing rapidly in modern plants which results in harmonics generation and sensitive load in the system, and for this reason, shunt APFs are implemented to overcome issues [9]–[12]. Therefore, a new trend is established to fulfill dual purposes, firstly serving the utility, and secondly benefiting the customers. The significance of this trend is to protect simultaneously both the utility and customers so that the sensitive components are protected from the disturbances in the voltage and to minimize the distortion penetrated to the utility by the loads utilized by the customers [13]. Therefore, The UPQC model is formed with series and shunt APF compensator in a back to back configuration that can control both the load voltage and grid current concurrently [14]. The current trend of microgrid and distributed generation increase the interest of the researcher to work on UPQC [15]–[17]. In addition, there has been an increased concern on the utilization of renewable power sources, reduced dependence on depleting sources of fossil fuels, which also caused global warming. There is a necessity for renewable energy systems, which also enhance power quality and also have the potentiality for operation during the unavailability of the grid.

In [19], proposed a fuel cell (FC) integrated with UPQC to mitigate PQ issues effectively on the grid side by providing real power support during voltage interruption. However, in their study, did not give any emphasize on the integration of renewable energy resources with UPQC and also have not encouraged decarbonization of the grid connected system. In [20], [21], proposed a PV integrated with UPQC to produce clean energy and improve the power quality problems. However, long interruption and deep voltage sag were not considered in their study. Furthermore, the dynamic voltage restorer (DVR) connected with superconducting magnetic energy storage system (SMES) to support the load for long term and thus, addressed the issue on long interruption [22]. Nonetheless, the current related harmonics problem was not considered. In such case, energy storage system like BESS can be interfaced with the PV-UPQC and can be a great support for continuously providing real power to the load. When UPQC operating in standalone mode, BESS is most essential for renewable energy systems. The extra cost of the BESS is justified when the system is applied for critical loads such as semiconductor industries, hospitals etc. where an uninterrupted supply of best quality power is of supreme importance. Therefore, The UPQC is supported by the PV

and BESS was design in this work. The PV is attached to the DC-link through DC-DC boost converter and the BESS is connected to the DC-link through DC-DC buck-boost converter [23], [24]. Generally, the PV system supplies the active power to the load but when the PV is unable to supply the power then the BESS activates and provides power especially during the longer-term voltage interruption in order to enhance the stability of the distribution power system. In [19] and [25]–[27], researchers try to design the DC-link voltage regulation algorithm to ensure stable and constant DC-link capacitor voltage. But, the UPQC controller become more complex and computational burden. However, PV-BESS can be considered a better alternative since it can support DC-link capacitor of a UPQC externally and can reduce the burden on the DC-link capacitor.

The synchronization phase is one the most significant parts of the control of an UPQC system. Note that the accurate synchronization phase operation is required for generating reference current and voltage by the shunt and series APF compensator, respectively [28]. The UPQC should be able to perform the synchronization operation effectively by injecting the voltage and current in phase with the grid. In [15]–[21], most of the UPQC controller is developed utilizing a conventional SRF-PLL for the synchronization phase algorithm which is not capable of dealing with unbalanced and distorted voltage grid condition. Moreover, a conventional PLL controller consists of a low pass filter that introduce phase delay in the synchronization operation causing undesired ripples in the reference current and voltage. Furthermore, the PI controller of a PLL increase the control complexity and require fine tuning which is time consuming [29]. A possible solution to the phase detection synchronization is utilizing the STF that have better phase tracking and fundamental component extraction capabilities. In this work, to produce to come up with simple controller structure by its working principle involves generation of unit vectors consisting of sine and cosine function for the process of extracting harmonic current algorithm and voltage error algorithm. Furthermore, the synchronization phases in term of unit vector is apply on the reference current generation in shunt compensator that design with integrating together with strength STF with working concept of the direct-quadrature-zero (STF- $dq0$) that not depending on any components of PLL. In series compensator, the reference voltage generation also will be applying working concept of the $dq0$ with utilizing synchronization phases for in-phase compensation. Most importantly, the proposed technique that will applying on UPQC controller need to be superior and more reliable when dealing with unbalanced and distorted voltage grid condition. It is also can maintaining grid current sinusoidal with regulating the desired load voltage which minimizing the phase difference to achieve almost unity power factor.

In this paper, PV and BESS connected parallelly with UPQC is proposed to solve the complex power quality problems specifically in case of long voltage interruption. Various case study is applied to validate the dynamic performance




FIGURE 1. UPQC system configuration.

of the suggested UPQC integrated with PV and BESS. The comparison between the performance of UPQC with only DC-link capacitor and the UPQC integrated with PV and BESS is also shown. In addition, the STF integrated with the UVG technique (STF-UVG) is utilized to produce the synchronization phases for the UPQC controller to address the drawbacks of the conventional PLL. The performance comparison of the STF-UVG and a standard SRF-PLL to validate the superiority of the proposed technique. Finally, the performance of the suggested UPQC system is investigated utilizing MATLAB-Simulink software under dynamic condition.

II. SYSTEM CONSTRUCTION

The construction of PV-BESS-UPQC is displayed in Fig. 1. The three-phase system is designed for the PV-BESS-UPQC model. The PV-BESS-UPQC comprises of series and shunt APF compensator linked with DC-link split capacitor. The battery and the PV array are linked parallelly to the DC-link. The PV is linked through a boost converter to the DC-link. Moreover, the BESS is linked through a buck-boost converter to the DC-link. The series compensator works like a controlled voltage source manner and mitigates for the supply voltage sags, swells, interruption, voltage harmonic. On the other hand, the shunt compensator mitigates the current harmonics for the load. Both the series and shunt APF compensator are attached through interfacing inductors.

Due to the converter switching action harmonics are generated and therefore, ripple filter is utilized to filter out harmonics. The series compensator uses a series injection

transformer to insert voltage to the grid. In this work, a three-phase non-linear load is utilized. The PV-BESS-UPQC design procedure starts with the accurate measurement of PV array, split capacitor, reference voltage of DC-link etc. The design of the shunt compensator follows the way that apart from mitigating current harmonics it controls the peak output power from PV array. Since the PV array is connected to the UPQC DC-link directly, the PV array is constructed in a way such that the maximum power point (MPP) voltage is equivalent to the reference DC-link voltage. During nominal conditions, the rating of PV array ensures that the load active power is delivered by the PV array and power is supplied to the grid and charging BESS by the PV array as well. Besides, the BESS is designed in a way that, when the PV array generate less power than the DC-link load demand, the BESS provides the insufficient power equivalent to the decrease in DC-link voltage. Moreover, when there is no power produced by PV array, the BESS will supply the total load demand.

A. DESIGN OF UPQC

1) DC-LINK VOLTAGE MAGNITUDE

The minimum value of DC-link voltage, $V_{dc,min}$ relies on phase-voltage of the system. The voltage magnitude of the DC-link needs to be nearly twice the peak value of the phase-voltage of the supply. The equation of $V_{dc,min}$ is given as follows:

$$V_{dc,min} = \frac{2\sqrt{2} (V_{LL,rms})}{\sqrt{3}(m)} \quad (1)$$

where, m indicates the index of modulation depth that assigned as 1 and $V_{LL,rms}$ indicates the phase-voltage of the grid which is selected as $400 V_{rms}$ considered by Malaysia Energy Commission following IEC standard. Therefore, $V_{dc,min}$ is obtained as $653.2 V$ for a $V_{LL,rms}$ of $400 V_{rms}$. DC-link voltage, V_{dc} is chosen as $700 V$ after considering the value of PV-BESS as external source of DC-link.

2) DC-LINK CAPACITOR VALUE

The equation of the DC-link capacitor is presented as follows:

$$C_{dc,min} = \frac{3V_{ph}i_{sh}a_fk_e t}{1/2(V_{dc,set}^2 - V_{dc,min}^2)} \quad (2)$$

Here, V_{ph} indicates the phase-voltage, i_{sh} indicates the phase-current for shunt APF, a_f indicates the overloading factor, t indicates the time to achieve the steady-state, k_e indicates the variation of energy during dynamic condition, $V_{dc,set}$ indicates the voltage which is equivalent to the reference voltage and $V_{dc,min}$ indicates the minimum required voltage of the DC-link. The calculated minimum voltage of the DC link, $V_{dc,min} = 677.69V$, $V_{dc,set} = 700V$, $V_{ph} = 230.9 V$, $i_{sh} = 57.5 A$, $t = 30 ms$, $a_f = 1.2$, and energy variation during dynamics = 10% ($k_e = 0.1$), the measured value of $C_{dc,min}$ is $9330.28 \mu F$ and it is approximated as $9400 \mu F$. Then, two split capacitors are set on $4700 \mu F$ each.

3) INDUCTOR RIPPLE FILTER FOR SHUNT APF

The shunt APF is attached through an inductor with the network as a passive filter which relies on the switching frequency denoted as f_{SH} , $I_{cr,pp}$ denotes ripple current and $V_{dc,set}$ denotes the DC-link voltage. The interfaced inductor equation is shown as follows:

$$L_{f,min} = \frac{(\sqrt{3})(m)(V_{dc,set})}{12(a_f)(f_{SH})(I_{cr,pp})} \quad (3)$$

Here, m indicates the modulation depth, a_f indicates the maximum overload value in pu unit, $I_{cr,pp}$ indicates the ripple current for the inductor which measured as 20% of Shunt APF rms phase current. f_{SH} indicates the switching frequency. Considering $I_{cr,pp} = 20\%$, $f_s=10$ kHz, $m = 1$, $V_{DC} = 700$ V, and $a = 1.5$, the value of $L_{f,min}$ is measured as 1.79 mH. Here, the set value is considered which is 3mH in this investigation

4) SERIES INJECTION THREE-PHASE ISOLATION TRANSFORMER

The injection transformer is considered for attaching the VSC of a series APF in series with the grid. The transformer voltage rating relies on the voltage that need to be injected and the DC-link voltage. For compensating a voltage variation of $\pm 60\%$, the voltage to be injected, V_{SE} is calculated as 138.54 V. In that case the modulation index becomes low for the series compensator at 700 V DC-link voltage. The maximum value turns ratio of the injection transformer for the series APF is expressed as follows:

$$K_{SE} = \frac{V_{LL_{rms}}}{\sqrt{3}(V_{SE})} \quad (4)$$

where the K_{SE} is calculated was 1.667 approximate to 2. The VA rating of the injection transformer is expressed as follows:

$$S_{SE} = 3 (V_{SE}) (i_{SE(undersag)}) \quad (5)$$

The current across the series APF is equivalent to the grid current. During the voltage sag condition of 0.6 pu, the supply current is measured as 36 A. Therefore, the achieved injection transformer VA rating is 15 kVA.

5) INDUCTOR RIPPLE FILTER FOR SERIES APF

The series APF is attached through an inductor with the network as a passive filter which relies on the DC-link voltage, ripple current and switching frequency. The interfaced inductor equation is shown as follows:

$$L_{r,min} = \frac{(\sqrt{3})(m)(V_{dc,set})(K_{SE})}{12(a_f)(f_{SE})(I_r)} \quad (6)$$

Here, m denotes the modulation depth, a denotes the maximum overload value in per unit, I_r denotes the ripple current for the inductor which computed as 20% of Series APF rms phase current. f_{SE} denotes the switching frequency. Where, $m = 1$, $a_f = 1.5$, $f_{SE} = 10$ kHz, 20% ripple current and $V_{dc,set} = 700$ V, so the measured inductor value is 3.6 mH.

B. DESIGN OF UPQC CONNECTING WITH PV-BESS AS EXTERNAL SUPPORT OF DC-LINK

The suggested model displayed in Fig. 2 comprises the PV system, BESS, boost converter, buck-boost converters, and controller. The BESS is attached parallelly to the DC-link capacitor utilizing buck-boost converter, so the stability of the UPQC is improved for compensating power quality problem. In the model, the total power flow is expressed in the (7). Furthermore, the PV system parameters and the parameters of Li-ion battery implemented in this paper are tabulated in the Table 1.

$$P_{total} = P_{pv} + P_{BESS} - P_{Load_{DC-link}} \quad (7)$$




FIGURE 2. PV-BESS system configuration.

TABLE 1. Parameters of devices implemented in the work.

Device	Parameters	Values
	Rated Power	214.92 W
	Open circuit voltage (V_{OC})	48.3 V
PV panel	Short circuit current (I_{SH})	5.8 A
single panel	Voltage at maximum power (V_{MP})	39.8 V
(SunPower	Current at maximum power (I_{MP})	5.4 A
SPR-215-	Number of cells in parallel	11
WHT-U)	Number of cells in series	18
	Temperature	25 °C
	Rated Capacity	350 Ah
	Maximum Capacity	450 Ah
Li-ion battery	Nominal voltage	650 V
	Fully charge voltage	756 V

1) PV SYSTEM MODELLING

In this paper, the PV model is utilized from the Simulink library. The PV model consists of some strings of PV modules connected in parallel. Besides, series PV modules are included on each string as well to achieve the required current, voltage and power ratings. In a module, each PV cells can be modelled by utilizing single-diode equivalent circuit as




FIGURE 3. Single-diode PV cell equivalent circuit.

displayed in Fig. 3. The construction of the single-diode equivalent circuit consists of a current source parallelly connected with a forward diode, a series connected resistance and a resistance connected in parallel. Whenever the PV cell detect the sunlight, it starts producing current. Utilizing Kirchoff's current law, PV cell output current is derived as:

$$i_{pv} = i_{ph} - i_d - i_{sh} \quad (8)$$

Here, i_{ph} denotes the photocurrent, i_d indicates the current flowing across the forward diode and i_{sh} denotes the current flowing across the shunt resistance. Substituting relevant expressions for i_d and i_{sh} in (9) can be described as follows:

$$i_{pv,c} = i_{ph} - i_s \left[\exp \left(\frac{Q(V_{pv} + i_{pv,c}R_s)}{\eta k T_c} \right) - 1 \right] - \frac{V_{pv,c} + i_{pv,c}R_s}{R_{sh}} \quad (9)$$

where i_s denotes the leakage current or reverse saturation of the diode (A), Q denotes the electron charge (1.602×10^{-19} C), η denotes the diode ideality factor following the type of PV cell technology (Si-mono) which is 1.2 used in this work, k denotes the Boltzmann's constant (1.381×10^{-23} J/K), T_c denotes the actual temperature of the cell ($^{\circ}$ C), $V_{pv,c}$ denotes the cell output voltage (V), $i_{pv,c}$ denotes the cell output current (A), R_{sh} denotes the shunt resistance of the cell (Ω) and R_s denotes the cell series resistance (Ω). Furthermore, when the PV cells are attached in series to create a module, the output voltage and output current relationship expressed in (10) can be rewritten as:

$$i_{pv,m} = i_{ph} - i_s \left[\exp \left(\frac{Q(V_{pv} + N_s i_{pv,m} R_s)}{N_s \eta k T_c} \right) - 1 \right] - \frac{V_{pv,m} + N_s i_{pv,m} R_s}{N_s R_{sh}} \quad (10)$$

where $i_{pv,m}$ indicates the module current (A), $V_{pv,m}$ indicates the module voltage (V) and N_s indicates the series connected PV cells number for a module. Moreover, the PV modules can be attached in parallel or in series to attain the required output voltage and power. The array is formed by the series and/or parallel connected PV modules. The modification of

(10) builds the PV array as follows:

$$i_{pv,m} = i_{ph} N_p - i_s N_p \left[e^{\left(\frac{Q(V_{pv,m} + \frac{N_s}{N_p} i_{pv,m} R_s)}{N_s \eta k T_c} \right)} - 1 \right] - \frac{V_{pv,m} + \frac{N_s}{N_p} i_{pv,m} R_s}{\frac{N_s}{N_p} (R_{sh})} \quad (11)$$

where N_p denotes the number of cell strings in parallel. From (8), the photocurrent, i_{ph} relies on the solar irradiation G , the actual cell temperature, T_c and on the surface of the PV cell. Thus, the i_{ph} can be expressed as:

$$i_{ph} = (i_{ph,n} + K_1 \Delta T_c) \frac{G}{G_n} \quad (12)$$

where G denotes the solar irradiance (W/m²), G_n denotes the solar irradiance at STC (W/m²), $i_{ph,n}$ denotes the photocurrent (A) at STC, K_1 denotes the temperature coefficient of short circuit current (A/ $^{\circ}$ C), ΔT_c denotes the variation of the T_c actual cell temperature ($^{\circ}$ C) and $T_{c,n}$ denotes the cell temperature at STC ($^{\circ}$ C). From (9)-(11), the diode saturation current, i_s relies on the cell temperature and it can be stated as:

$$i_s = i_{s,n} \left(\frac{T_c}{T_{c,n}} \right)^3 \exp \left[\frac{Q(E_{go})}{\eta k} \left(\frac{1}{T_{c,n}} - \frac{1}{T_c} \right) \right] \quad (13)$$

where E_{go} denotes the energy band gap of the material (eV) and 1.12eV is selected as the value according to the category of semiconductor material utilized in this work and $i_{s,n}$ denotes the diode saturation current at STC. The $i_{s,n}$ can be expressed as follows:

$$i_{s,n} = i_{ph,n} \exp \left[\frac{Q(V_{oc,n})}{N_s \eta k T_c} \right] \quad (14)$$

The shunt resistance R_{sh} and series resistance R_s enhance the cell performance by managing the slope of voltage and current relationship. The R_{sh} and R_s can be approximated as follows in (15) and (16). Where V_{oc} denotes the open circuit voltage (V) and i_{sh} denotes the short circuit current (A).

$$R_{sh} > \frac{10V_{oc}}{i_{sh}} \quad (15)$$

$$R_s < \frac{0.1V_{oc}}{i_{sh}} \quad (16)$$

The construction of the PV system model follows the parameter of PV panel specified to acquire the desired current, voltage and power ratings that is desired by the UPQC system in MATLAB Simulink. The parameter utilized for the PV system in this work is tabulated in Table 1. The parameters of cell and array of the PV model is developed to follow SunPower SPR-215-WHT-U PV module. The PV characteristic curve with specified temperature (25 $^{\circ}$ C) for the PV module and varying irradiance is displayed in Fig. 4. The I-V characteristic illustrates in Fig. 4(A) and the P-V characteristics is shown in Fig. 4(B) for solar array.




FIGURE 4. PV cell waveforms at 25 °C and irradiance variation (A) I-V (B) P-V.




FIGURE 5. PV cell waveforms at different temperature and designated irradiance (1000 W/m²) (A) I-V (B) P-V.

The characteristic curve with specified irradiance (1000 W/m²) and varying temperature is shown in Fig. 5. I-V characteristic illustrates in Fig. 5(A) and the P-V characteristics is shown in Fig. 5(B) for solar array.

Next, the solar radiations achieved by the solar panel are varied continuously which results in low quality performance of the solar panel. Likewise, higher temperatures are also responsible for lowering the performance quality of the solar module. The Variation in insolation modifies all the parameters (P_{max} , V_{max} , i_{max} , V_{oc} , i_{sc}) of the solar module illustrated in the PV cell characteristics curves in Fig. 6. Maximum power point tracking (MPPT) can be utilized to improve the efficiency of a PV module under a specified irradiance and temperature. The DC-DC boost converter duty cycle is regulated to maintain the algorithm of the MPPT. In this work, a simple method named Perturb and observe




FIGURE 6. Solar PV module I-V and P-V feature.

(P & O) is selected and this method can track the MPP more accurately. The P & O algorithm is easy to implement and demonstrated as the flowchart in Fig. 7. PV module output voltage V_{pv} and output current i_{pv} are the input of the MPPT algorithm. To execute this method, the current and voltage of PV modules need to be measured initially to determine the power of PV modules, P_{pv} . The observation and perturbation process is continued until the operating point reaches the MPP. The algorithm compares the voltages and power of time (n) with the sample at a time ($n - 1$) and estimates the time to reach to MPP. The P & O algorithm traces by increasing or reducing the voltage at the MPPT regularly of the PV module. When the positive power alteration occurs, a slight voltage perturbation can change the power of solar panel and voltage perturbation is maintained in similar track. Whereas when negative delta power occurs, it shows that the MPP is at far distance and the perturbation is reduced to attain the MPP. The P & O algorithm is summarized in Table 2. Therefore, the complete PV curve is examined by small-scale perturbations to locate the MPP that extend the response time of the algorithm. On the other hand, if the perturbation size is expanded, it produces steady-state oscillations about the MPP. The P & O algorithm output is the approximated MPPT voltage V_{mpp} . The MPPT voltage is employed to regulate the DC-DC converter to achieve the PV open-circuit voltage continuously. The PV system output power, P_{pv} is boosted by the DC-DC boost converter that control by controller shows in Fig. 8. The controller of the DC-DC boost converter is operating by getting DC voltage error, $V_{DC,error}$. The voltage error is calculated by comparing the given reference voltage, V_{ref} which is 700V.

The reference voltage is assigned with instantaneous DC-DC Boost converter output DC voltage V_{DC} . Afterwards, $V_{DC,error}^*$ is approximated by reducing the $V_{DC,error}(t)$ using a PI controller. In mathematic terms, the approximation can be explained as found from (17) and (18):

$$V_{DC,error}^* = k_{p,1}(V_{DC,error}(t)) + k_{i,1} \int_0^t (V_{DC,error}(t))dt \tag{17}$$

$$V_{DC,error}(t) = V_{ref} + V_{DC}(t) \tag{18}$$

where $k_{p,1}$ and $k_{i,1}$ indicates the two fixed values that denotes as proportional gain and integral gains of the controller PI₁.




FIGURE 7. Flow chart of Perturb & Observe algorithm.




FIGURE 8. PV DC-DC boost converter control scheme.

TABLE 2. Scheme of Perturb & Observe algorithm.

Perturbation	ΔP	Perturbation Output
+ve	+ve	+ve
+ve	-ve	-ve
-ve	+ve	-ve
-ve	-ve	+ve

The values are allocated as 0.1 and 0.1, consecutively. However, the controller of the DC-DC Boost converter will break off the PV system output power, P_{pv} during battery's state of charge SOC_{BESS} is over or equal to 98% of battery capacity. The reason is to keep away the battery from being overcharged and unstable. Moreover, the lifetime of the battery can be reduced due to overcharging.

2) BATTERY ENERGY STORAGE SYSTEM MODELLING

Batteries generally consist of one or more electrochemical cells in series and/or parallel to achieve the desired nominal voltage and capacity for the BESS modelling. Generally, the classification of battery models depends on

electrochemical model and electric circuit model, and from these models the other models are normally obtained. For example, using Peukert's equation, the model of a battery is improved by integrating current. Besides, Shepherd's equation which is an electrochemical model. The mathematical model is utilized in this work because of efficient tools like SIMULINK/MATLAB. The Li-ion battery is used in this work due to its high-power density and energy, slow self-discharge and low maintenance cost, comparing to the other batteries. The parameter utilized for the BESS system in this work is tabulated in Table 1.

The equivalent electrical circuit of battery is constructed by a controlled voltage source connected with a constant internal resistance in series. The charging/discharging model of the Li-ion battery is stated in as follows:

$$V_{battery,charge} = E_{f1,2}(i_t, i_l, i) - iR \quad (19)$$

where $V_{battery,charge}$ indicates the battery voltage (V), $E_{f1,2}(i_t, i_l, i)$ indicates the no-load voltage (V), R indicates the internal resistance (Ω), and i indicates the battery current (A). Next, the controlled voltage source can be expressed for charging and discharging in charge model and discharging model. Then, the charging model of Li-ion battery is given as follows:

$$E_{f1}(i_t, i_l, i) = E_0 - K \frac{Q}{(0.1)Q + i_t} i_l - K \frac{Q}{Q - \int i_t dt} i_t + A \exp(-B \cdot \int i_t dt) \quad (20)$$

Then, the discharging model of the Li-ion battery is stated in as follows:

$$E_{f2}(i_t, i_l, i) = E_0 - K \frac{Q}{Q + i_t} i_l - K \frac{Q}{Q - \int i_t dt} i_t + A \exp(-B \cdot \int i_t dt) \quad (21)$$

From the (20) and (21), where E_0 indicates the battery constant voltage (V), K indicates the polarization voltage (Ah^{-1}), Q indicates the battery rated capacity (Ah), $\int i_t dt$ indicates the extracted battery capacity current rate (Ah), A indicates the exponential zone amplitude (V), B indicates the exponential zone time constant inverse (Ah^{-1}) and i_l indicates the low frequency current (A). Next, the term $A_{exp}(-B \cdot \int i_t dt)$ symbolizes the exponential area of the voltage when it is fully charged to the edge of exponential zone of the discharge characteristic curve. Thus, the gain of undetermined parameters of A and B can be specified from the exponential part as follows. The voltage drops during the exponential zone express in as follows.

$$A = E_{full} - E_{exp} \tag{22}$$

where E_{full} indicates the fully charged voltage and E_{exp} indicates the voltage at the boundary of exponential zone. The exponential zone time constant inverse is:

$$B = \frac{3}{Q_{exp}} \tag{23}$$

where Q_{exp} indicates the charge at the boundary of exponential zone. Here, the parameter E_0 utilized in (20) and (21) symbolizes the transition quantity between the starting of voltage when it is fully charged and the boundary of exponential zone. Thus, the value of E_0 can be calculated from the voltage in fully charged condition and it can be stated as follows:

$$E_0 = E_{full} + iR - A \tag{24}$$

The term $-K(Q/Q - \int i_t dt)i_t$ utilized in (20) and (21) indicates the nominal area from the boundary of exponential zone to the boundary of nominal zone of the discharge characteristic curve. Thus, the gain of K can be specified from the nominal part as follows:

$$K = (E_0 - E_{nom} - iR + A_{exp}(-BQ_{nom})) \frac{Q - Q_{nom}}{Q(Q_{nom} + i)} \tag{25}$$

where E_{nom} indicates the end voltage of the nominal zone and Q_{nom} indicates the end voltage of the nominal zone. The value of the completely charged voltage, charge of nominal zone, the end voltage and charge of the exponential zone can be determined from the discharge characteristic curve of that battery.

The Battery State of Charge (SOC) Regarding Charging and Discharging: The SOC presents one of the most important feature for batteries, however it represents many different concerns. Generally, the SOC of a battery is determined as the ratio of its current capacity to the nominal capacity.

The manufacturer provide the nominal capacity and it shows the charge that can be stored in maximum amount in the battery. The counting method by Coulomb estimates the charging current and discharging current of a battery is integrated over time in order to measure the SOC. Coulomb counting technique is done to measure the $SOC(t)_{charge}$ or $SOC(t)_{discharge}$ at time in (%), which is




FIGURE 9. Feature of Li-ion battery current discharge.

calculated from the charging current, $i_{BESS,charge}(t)$ or discharging current, $i_{BESS,discharge}(t)$ with battery capacity in (Ah), and prior calculated SOC values, $SOC(t-1)_{charge}$ or $SOC(t-1)_{discharge}$. SOC is measured by the following (26) and (27)

$$SOC(t)_{charge} = SOC(t-1)_{charge} + \frac{1}{C_{BESS}} \int_{t-1}^t i_{BESS,charge}(t) dt \tag{26}$$

$$SOC(t)_{discharge} = SOC(t-1)_{discharge} - \frac{1}{C_{BESS}} \int_{t-1}^t i_{BESS,discharge}(t) dt \tag{27}$$

However, there are some factors that affect the perfection of Coulomb counting method involving the battery history, temperature, discharge current, and cycle life.

The discharge featured waveform of Li-ion battery is illustrated in Fig. 9. The discharge features are separated into three section and which are nominal section, exponential section and the last is discharge curve. Voltage reduced rapidly in the exponential area, whereas the nominal battery voltage is the mid-point voltage throughout the charging and discharging and flatter curve represent minor inequality in voltage in this region. In the fully charged stage the voltage is superior over the nominal voltage. However, when end of life is appeared, the voltage is lower comparing to the mid-point voltage.

3) FREQUENCY SHARING STRATEGY OF A BESS-PV

In Fig. 10, shown the bidirectional converter Buck-Boost DC-DC controller for charging and discharging mode that contains embedded internal control loops and external control loops.

The stability of the frequency is maintained by the provided active power with proper configuration of the external control




FIGURE 10. BESS DC-DC Buck-Boost converter controller scheme.

TABLE 3. Frequency droop features under several working conditions.

Working Conditions	Frequency	Droop features	Power distribution
Solar PV generation > DC-link Load demand	Increases	Regulate the rise in frequency and voltage within the suitable limits.	BESS absorbs the extra power equivalent to the rise in frequency and bus voltage until it attains the maximum charging limit.
Solar PV generation = DC-link Load demand	Stable	Maintain the stable voltage and frequency at its nominal value.	PV system supply the load- demand. BESS function at standby state.
Solar PV generation < DC-link Load demand	Decreases	Controlling the fall in frequency and voltage within the suitable limits.	BESS delivers the insufficient power equivalent to the fall in frequency and bus voltage until it attains the lowest discharging limit.
No Solar PV generation	Decreases	Controlling the fall-in frequency and voltage at a steady state value.	BESS delivers the total load-demand.

with a frequency droop f_{droop} . The design of internal control loop is constructed with a control loop of voltage to stabilize the system voltage and for fast dynamic response the filter output current is adjusted by the current control loop. The BESS active power can be measured as:

$$P_{BESS} = P_{DC-LINK} - P_{pv} \quad (28)$$

Here, $P_{DC-LINK}$ is the DC-link active power, P_{pv} is the total active power supplied by the PV. The active power of BESS, P_{BESS} obtained from (28) present the frequency droop,

$$f_{droop} = f_{atmo-load} - m [P_{BESS(atfull-load)} - P_{BESS(atmo-load)}] \quad (29)$$

The f_{droop} can be adjusted within their suitable limits to gain system stability. The methodology is suggested based on the frequency stability approach where load is divided between low and high-frequency elements by utilizing of a filter as demonstrated below in (30) and (31).

$$V_{DC,ref}^* = \left(\frac{1}{1 + T.s} \right) (V_{DC}) \quad (30)$$

$$i_{BESS,ref} = \left(\frac{1}{1 + T.s} \right) (i_{BESS}) \quad (31)$$

The PV module DC-link voltage of a, $V_{DC,ref}^*$ is compared with the DC voltage reference, V_{ref} and is then delivered to the voltage controller outer loop using PI₂ controller to generate current reference. Mathematically, the approach can be expressed as obtained from (32) and (33).

$$V_{DC,error}(t) = V_{ref} - V_{DC,ref}^*(t) \quad (32)$$

$$i_{T,ref} = k_{p,2}(V_{DC,error}(t)) + k_{i,2} \int_0^t (V_{DC,error}(t))dt \quad (33)$$

where $k_{p,2}$ and $k_{i,2}$ are the two fixed values that denotes as proportional gain and integral gains of the controller PI₂. The values are allocated as 1.477 and 3077. Furthermore, the output reference BESS current, $i_{BESS,ref}$ is compared with the reference current from voltage control loop, $i_{T,ref}$ and is then delivered to the inner current loop controller using controller PI₃. The approach can be seen in mathematical term in (34) and (35).

$$i_{BESS,error}^* = k_{p,3}(i_{BESS,error}(t)) + k_{i,3} \int_0^t (i_{BESS,error}(t))dt \quad (34)$$

$$i_{BESS,error}(t) = i_{T,ref} - i_{BESS,ref}(t) \quad (35)$$

where $k_{p,3}$ and $k_{i,3}$ are the two fixed values that denotes as proportional gain and integral gains of the controller PI₃. The values are allocated as 0.043 and 0.65. When the active power of a PV module increases than the load demand of DC-link for UPQC, then the voltage frequency components is high. But, When the active power of a PV module decreases than the load demand of DC-link for UPQC, then the voltage frequency components is low. The lower frequency components delivered, and the gate signals are generated for the DC-DC converter of a BESS for discharging mode. In Table 3 explains the interpretation of the frequency droop features for power distributing under several working conditions of the PV-BESS-UPQC system.

III. WORKING PRINCIPLE OF THE PROPOSED CONTROL OF PV-BESS-UPQC USING SELF-TUNING FILTER TECHNIQUE

A. STF-UVG SYNCHRONIZATION TECHNIQUE

The proposed STF-UVG technique extract the synchronization phases in a simple method from the supply voltage and the method is non-iterative. In Fig.11 shown the STF technique in UPQC controller scheme. In (36) the matrix form of

the three-phase supply voltage is demonstrated, and Clarke transformation matrix is used to convert the source voltage from abc -domain to $\alpha\beta 0$ -domain.

$$\begin{bmatrix} V_{S\alpha} \\ V_{S\beta} \\ V_{S0} \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & -\frac{1}{2} & -\frac{1}{2} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ \frac{1}{2} & \frac{1}{2} & \frac{1}{2} \end{bmatrix} \begin{bmatrix} V_a \\ V_b \\ V_c \end{bmatrix} \quad (36)$$

The distorted supply voltage is separated into fundamental component and harmonic component by considering only two phases in $\alpha\beta$ -domain. The relationship is shown in (37).

$$\begin{bmatrix} V_{S\alpha} \\ V_{S\beta} \end{bmatrix} = \begin{bmatrix} V_{S\alpha(fund)} + V_{S\alpha(har)} \\ V_{S\beta(fund)} + V_{S\beta(har)} \end{bmatrix} \quad (37)$$

Here, $V_{s,\alpha(fund)}$ indicates the fundamental (fund) component and $V_{s,\alpha(har)}$ indicates the harmonic (har) component in $\alpha\beta$ -domain. Both the fundamental component in $\alpha\beta$ -domain is required to produce synchronization phases. The fundamental components are extracted by self-tuning filtering (STF) method. The STF method is applied to suppress the existed harmonic components in the distorted supply voltage. Therefore, the synchronization phases are extracted more perfectly, and the quality of the extraction is improved. The Laplace transformation is performed and a typical STF transfer function is expressed in (38).

$$\begin{bmatrix} V_{S\alpha(fund)}(s) \\ V_{S\beta(fund)}(s) \end{bmatrix} = \frac{K_1}{s} \begin{bmatrix} V_{S\alpha}(s) - V_{S\alpha(fund)}(s) \\ V_{S\beta}(s) - V_{S\beta(fund)}(s) \end{bmatrix} + \frac{2\pi f_{c1}}{s} \begin{bmatrix} -V_{S\beta(fund)}(s) \\ V_{S\alpha(fund)}(s) \end{bmatrix} \quad (38)$$

Here, K_1 denotes constant gain parameter and f_{c1} denotes the cut-off frequency. The rating of K_1 can be estimated in between 20 to 80 and the rating of f_{c1} follows the system frequency. In this project, the rating is estimated 20 for K_1 and 50 Hz for f_{c1} . Synchronization phases of $\sin(\omega t)$ and $\cos(\omega t)$ can be attained with the availability of $V_{s,\alpha(fund)}$ and $V_{s,\beta(fund)}$ and demonstrated in the (39).

$$\begin{bmatrix} \sin(\omega t) \\ \cos(\omega t) \end{bmatrix} = \frac{1}{\sqrt{(V_{S\alpha(fund)})^2 + (V_{S\beta(fund)})^2}} \begin{bmatrix} V_{S\alpha(fund)} \\ -V_{S\beta(fund)} \end{bmatrix} \quad (39)$$

The action of conventional PLL element can be omitted by utilizing (39) as UVG technique and the generation of synchronization phases can be effectively done in the presence of supply voltage distortion in UPQC.

B. CONTROL OF SERIES APF COMPENSATION

The three-phase reference voltage signal, $V_{ref,abc}^*$ in abc -domain is calculated as follows in (40) by utilizing the information of phase and frequency of STF-UVG. Here, the value of maximum peak voltage magnitude, $V_{m,max-peak}$ is obtained from peak amplitude of the fundamental load voltage. The reference voltage signal should be in phase with

supply voltage at PCC, peak amplitude load reference voltage is the d -frames components while the q -frames components should be zero.

$$\begin{bmatrix} V_{ref_a}^* \\ V_{ref_b}^* \\ V_{ref_c}^* \end{bmatrix} = V_{m,max-peak} \begin{bmatrix} \sin(\omega t) \\ \sin(\omega t - \frac{2\pi}{3}) \\ \sin(\omega t + \frac{2\pi}{3}) \end{bmatrix} \quad (40)$$

$$\begin{bmatrix} V_{ref_\alpha}^* \\ V_{ref_\beta}^* \\ V_{ref_0}^* \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & -\frac{1}{2} & -\frac{1}{2} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ \frac{1}{2} & \frac{1}{2} & \frac{1}{2} \end{bmatrix} \begin{bmatrix} V_{ref_a}^* \\ V_{ref_b}^* \\ V_{ref_c}^* \end{bmatrix} \quad (41)$$

$$\begin{bmatrix} V_{ref_d}^* \\ V_{ref_q}^* \end{bmatrix} = \begin{bmatrix} \cos(\omega t) & \sin(\omega t) \\ -\sin(\omega t) & \cos(\omega t) \end{bmatrix} \begin{bmatrix} V_{ref_\alpha}^* \\ V_{ref_\beta}^* \end{bmatrix} \quad (42)$$

Then, three-phase reference voltage signal demonstrated in matrix form in (41) and Clarke transformation matrix is used to convert the reference voltage signal from abc domain to $\alpha\beta 0$ -domain. Next, the fundamental component of the distorted supply voltage at PCC is extracted by using the proposed STF-UVG to generate synchronization phases and frequency that obtained in (39) is used for producing the reference axis in the dq -frames. Considering only two phases, the reference voltage signal is acquired in the dq -frames by using (42) where Park transformation matrix is utilized. Moreover, the Equation (43) is utilized to transform the three-phase load voltage, $V_{L,abc}$ from abc -domain to $\alpha\beta 0$ -domain utilizing Clarke-matrix. Then, load voltage signal in $\alpha\beta 0$ -domain is converted by considering only two phases in dq -frames by using Park-matrix with the consideration of synchronization phases and frequency from STF-UVG for producing the reference axis in the dq -frames and demonstrated in (44).

$$\begin{bmatrix} V_{L\alpha} \\ V_{L\beta} \\ V_{L0} \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & -\frac{1}{2} & -\frac{1}{2} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ \frac{1}{2} & \frac{1}{2} & \frac{1}{2} \end{bmatrix} \begin{bmatrix} V_{La} \\ V_{Lb} \\ V_{Lc} \end{bmatrix} \quad (43)$$

$$\begin{bmatrix} V_{Ld} \\ V_{Lq} \end{bmatrix} = \begin{bmatrix} \cos(\omega t) & \sin(\omega t) \\ -\sin(\omega t) & \cos(\omega t) \end{bmatrix} \begin{bmatrix} V_{L\alpha} \\ V_{L\beta} \end{bmatrix} \quad (44)$$

Next, the Equation (45) is utilized to transform the three-phase supply voltage, $V_{s,abc}$ from abc -domain to $\alpha\beta 0$ -domain utilizing Clarke-matrix. Then, supply voltage signal in $\alpha\beta 0$ -domain is converted by considering only two phases in dq -frames by using Park-matrix with the consideration of synchronization phases and frequency from STF-UVG for producing the reference axis in the dq -frames and

demonstrated in (46).

$$\begin{bmatrix} V_{S_\alpha} \\ V_{S_\beta} \\ V_{S_0} \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & -\frac{1}{2} & -\frac{1}{2} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ \frac{1}{2} & \frac{1}{2} & \frac{1}{2} \end{bmatrix} \begin{bmatrix} V_{S_a} \\ V_{S_b} \\ V_{S_c} \end{bmatrix} \quad (45)$$

$$\begin{bmatrix} V_{S_d} \\ V_{S_q} \end{bmatrix} = \begin{bmatrix} \cos(\omega t) & \sin(\omega t) \\ -\sin(\omega t) & \cos(\omega t) \end{bmatrix} \begin{bmatrix} V_{S_\alpha} \\ V_{S_\beta} \end{bmatrix} \quad (46)$$

In the series active power filter controller compensator, the compensation strategies are using the comparison technique between the load voltage, $V_{L,dq}$ and supply voltage, $V_{s,dq}$ at PCC both in the dq frames to give actual voltage error of series compensator. Next, the reference voltage signal, $V_{ref,dq}^*$ that already in phase with supply voltage at PCC is compared with the supply voltage, $V_{s,dq}$ at PCC both in the dq frames to obtain actual reference voltage of series compensator. Moreover, the comparison between actual reference voltage and actual voltage error of series compensator will attain the injection reference voltage, $V_{SE,dq}^*$. Both the equation is demonstrated in (47) and (48).

$$V_{SE,d}^* = (V_{ref,d}^* - V_{S_d}) - (V_{L_d} - V_{S_d}) \quad (47)$$

$$V_{SE,q}^* = (V_{ref,q}^* - V_{S_q}) - (V_{L_q} - V_{S_q}) \quad (48)$$

Then, the $V_{SE,d}^*$ and $V_{SE,q}^*$ is converted from dq -frames to abc -domain and demonstrated in Equations (49) and (50). The injection reference voltage series compensator, $V_{SE,abc}^*$ are passed through in a hysteresis voltage controller to generate appropriate gating pulses for the series converter

$$\begin{bmatrix} V_{SE,\alpha}^* \\ V_{SE,\beta}^* \end{bmatrix} = \begin{bmatrix} \sin(\omega t) & \cos(\omega t) \\ -\cos(\omega t) & \sin(\omega t) \end{bmatrix} \begin{bmatrix} V_{SE,d}^* \\ V_{SE,q}^* \end{bmatrix} \quad (49)$$

$$\begin{bmatrix} V_{SE,a}^* \\ V_{SE,b}^* \\ V_{SE,c}^* \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & 0 \\ -\frac{1}{2} & \frac{\sqrt{3}}{2} \\ -\frac{1}{2} & -\frac{\sqrt{3}}{2} \end{bmatrix} \begin{bmatrix} V_{SE,\alpha}^* \\ V_{SE,\beta}^* \end{bmatrix} \quad (50)$$

C. CONTROL OF SHUNT APF COMPENSATION

The extraction of the load current harmonic component is done by the suggested STF on $\alpha\beta$ -domain. The (51) is utilized to transform the three-phase load current $i_{L,abc}$ from abc domain to $\alpha\beta 0$ -domain utilizing Clarke-matrix. Emphasizing on $\alpha\beta$ -domain, the signal of load current $i_{L,\alpha\beta}$ can be divided into fundamental component and harmonic component. Therefore, the relationship can be stated in (52).

$$\begin{bmatrix} i_{L_\alpha} \\ i_{L_\beta} \\ i_{L_0} \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & -\frac{1}{2} & -\frac{1}{2} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \\ \frac{1}{2} & \frac{1}{2} & \frac{1}{2} \end{bmatrix} \begin{bmatrix} i_{L_a} \\ i_{L_b} \\ i_{L_c} \end{bmatrix} \quad (51)$$

$$\begin{bmatrix} i_{L_\alpha} \\ i_{L_\beta} \end{bmatrix} = \begin{bmatrix} i_{L_{\alpha(fund)}} + i_{L_{\alpha(har)}} \\ i_{L_{\beta(fund)}} + i_{L_{\beta(har)}} \end{bmatrix} \quad (52)$$

Here, $i_{L,\alpha(fund)}$ indicate the fundamental (fund) components and $i_{L,\alpha(har)}$ indicate the harmonic (har) components of load current on α -domain. The representation of load current component in β -domain is same as α -domain. The Laplace transformation is performed and the STF technique is implemented for the extraction of load current fundamental components ($i_{L,\alpha(fund)}$ and $i_{L,\beta(fund)}$) on $\alpha\beta$ -domain. The formula is shown in (53).

$$\begin{bmatrix} i_{L_{\alpha(fund)}}(s) \\ i_{L_{\beta(fund)}}(s) \end{bmatrix} = \frac{K_2}{s} \begin{bmatrix} i_{L_\alpha}(s) - i_{L_{\alpha(fund)}}(s) \\ i_{L_\beta}(s) - i_{L_{\beta(fund)}}(s) \end{bmatrix} + \frac{2\pi f_{c2}}{s} \begin{bmatrix} -i_{L_{\beta(fund)}}(s) \\ i_{L_{\alpha(fund)}}(s) \end{bmatrix} \quad (53)$$

Here, K_2 denotes constant gain parameter and f_{c2} denotes the cut-off frequency. The rating of K_2 can be estimated in between 20 to 80 and the rating of f_{c2} follows the system frequency. In this project, the rating is estimated 20 for K_1 and 50 Hz for f_{c1} . The harmonic components ($i_{L,\alpha(har)}$ and $i_{L,\beta(har)}$) can be achieved by utilizing the fundamental components ($i_{L,\alpha(fund)}$ and $i_{L,\beta(fund)}$). The calculation is expressed in (54):

$$\begin{bmatrix} i_{L_{\alpha(har)}} \\ i_{L_{\beta(har)}} \end{bmatrix} = \begin{bmatrix} i_{L_\alpha} - i_{L_{\alpha(fund)}} \\ i_{L_\beta} - i_{L_{\beta(fund)}} \end{bmatrix} \quad (54)$$

Equation (54) shows the process of extraction of harmonic components. The process follows by the subtraction between the fundamental components (the extraction is done using STF filter) and the load current component $i_{L,\alpha\beta}$ in $\alpha\beta$ -domain. Therefore, the harmonic components are extracted in an indirect manner. Next, the harmonic components attained from (54) and synchronization phases attained from (39) are used to achieve the harmonic components in d -frame following the (55).

$$i_{L_d(har)} = i_{L_{\alpha(har)}} \sin(\omega t) - i_{L_{\beta(har)}} \cos(\omega t) \quad (55)$$

The wave of the original load current in $\alpha\beta$ -domain, $i_{L,\alpha\beta}$ and the identical synchronized phases are implemented to operate the transformation of $\alpha\beta$ -domain into frame- q by utilizing the following approach in (56):

$$i_{L_q} = i_{L_\alpha} \cos(\omega t) + i_{L_\beta} \sin(\omega t) \quad (56)$$

In the $\alpha\beta 0$ -domain, 0-domain does not require to be transformed. However, the DC component of the d -frame denotes the fundamental load current magnitude and the oscillating AC component denotes the harmonic current magnitude. Besides, q -frame carries the phase data of the load current. Noteworthy fact is frame-0 of reference frame $dq0$ which is straightly acquired from the domain- $\alpha\beta 0$ is required to stabilize the dc-link voltage. Likewise, the harmonic component of d -frame loads current $i_{L,d(har)}$, load current $i_{L,q}$ in q -frame and load current $i_{L,0}$, in 0-frame are three different undesirable component of load currents that denote unbalanced, harmonic and reactive currents.

Next, $i_{error,dc}$ is measured by reducing the error $e_1(t)$ obtained between total instantaneous dc-link voltage and




FIGURE 11. Control block diagram of the self-tuning filter (STF) technique in UPQC controller scheme (A) STF-UVG (B) Shunt APF control scheme (C) Series APF control scheme.

reference dc-link voltage $V_{dc,ref}$ with a PI controller. The mathematic calculation is given in (57) and (58):

$$i_{error_{dc}} = k_{p,4}e_1(t) + k_{i,4} \int_0^t e_1(t) dt \quad (57)$$

$$e_1(t) = V_{dc,ref} - (V_{cap1}(t) + V_{cap2}(t)) \quad (58)$$

where $k_{p,4}$ and $k_{i,4}$ are two fixed values that denotes as proportional gain and integral gains of the controller PI_4 . The values are allocated as 0.3 and 2 in this study. Therefore, the grid reference current in the d -frame is given as in (59):

$$i_{L_d}^* = i_{L_d(har)} - i_{error_{dc}} \quad (59)$$

Then, the signal $i_{L_d}^*$ and i_{L_q} is converted into abc -domain injection reference grid currents. From (60) and (61) are applied to produce the reference current $i_{SH,abc}$. The injection reference supply currents and the measured supply current are compared in a hysteresis current controller to produce the shunt converter gating pulses.

$$\begin{bmatrix} i_{L_\alpha}^* \\ i_{L_\beta}^* \end{bmatrix} = \begin{bmatrix} \sin(\omega t) & \cos(\omega t) \\ -\cos(\omega t) & \sin(\omega t) \end{bmatrix} \begin{bmatrix} i_{L_d}^* \\ i_{L_q} \end{bmatrix} \quad (60)$$

$$\begin{bmatrix} i_{SH_\alpha}^* \\ i_{SH_\beta}^* \\ i_{SH_c}^* \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} 1 & 0 \\ -\frac{1}{2} & \frac{\sqrt{3}}{2} \\ -\frac{1}{2} & -\frac{\sqrt{3}}{2} \end{bmatrix} \begin{bmatrix} i_{L_\alpha}^* \\ i_{L_\beta}^* \end{bmatrix} \quad (61)$$

IV. SIMULATION RESULTS

The operation of proposed PV-BESS-UPQC using STF-UVG combine with STF- $dq0$ filter technique (knowns as STF technique) is presented and the operation is analysed using MATLAB-Simulink platform (R2018a). The simulation studies include connection of the proposed PV-BESS-UPQC circuits, design of the PV-BESS-UPQC control system and performance assessment. A standard two-level inverter for the shunt APF compensator and series APF compensator sharing common DC-link which is a combination of the DC link capacitor, PV and BESS. At the shunt APF, standard split DC-link capacitors of 4700 μF are utilized and each of them stores the reactive power from the unbalance non-linear load. Then, the output of shunt compensator is attached to a 3 mH L -typed filter while by attaching a 3.6 mH L -typed filter to the series APF, switching ripples is minimized. In this study, the DC-link reference capacitor voltage is assigned as 700 V. Meanwhile, unbalance nonlinear loads are considered, and they are comprising of nonlinear loads allocated as three single-phase in unbalanced manner. The unbalance non-linear load parameter is summarized in Table 4. The performance of the proposed model is analysed in a comparative manner, performance simulated by UPQC that connected with PV and BESS (with PV-BESS) as external support of DC-link capacitor is compared with standard conventional UPQC (without PV-BESS) to validate the significance of UPQC after connecting the




FIGURE 12. Simulation waveform acquired under Case Study 1 for UPQC connecting with PV-BESS, with include (A) three-phase source voltage (B) Injection voltage of Series APF (C) Load Voltage (D) Load Current (E) Injection Current of Shunt APF (F) Source Current.

TABLE 4. Configuration of nonlinear load for simulation studies.

Nonlinear load	Load description
Unbalance Single phase load	Phase-a Single-phase uncontrolled rectifier supplying a series attached 1500 mH inductor and 70 Ω resistor
	Phase-b Single-phase uncontrolled rectifier supplying a series attached 1300 mH inductor and 60 Ω resistor
	Phase-c Single-phase uncontrolled rectifier supplying a series attached 1100 mH inductor and 55 Ω resistor

external support of DC-link. Furthermore, the PV-BESS-UPQC is tested while applying the proposed STF technique for the compensator controller and compared with the performance of the standard conventional SRF-PLL combine with a reference current generation applying moving average

filter (MAF) filter technique (knowns as SRF-MAF technique). Several case studies are conducted in the steady-state condition where different power quality problems are considered.

A. CASE STUDY 1: UPQC USING STF TECHNIQUE CONNECTING EXTERNAL SOURCE OF PV-BESS

1) SCENARIO A: BALANCE HARMONIC SOURCE VOLTAGE WITH NON-LINEAR LOAD AT CONSTANT IRRADIANCE 800 W/M² AT 45° (CONNECTING WITH PV-BESS AS EXTERNAL SOURCE OF DC-LINK)

The performance of PV-BESS-UPQC under context of source voltage harmonics at PCC and the combination of harmonic and sag are displayed in Fig. 12. The irradiation is maintained constant at 800 W/m² and the temperature 45 degree Celsius that follow the Malaysia tropical climate. The different observed signals are grid voltages, series compensated voltages, load voltages, load currents, shunt compensated currents, source currents. From Fig. 12(A), it can be noticed




FIGURE 13. Simulation result acquired under Case Study 1 for UPQC connecting with PV-BESS, with include (A) DC-Link Voltage (B) Current of PV (C) Power of PV (D) Output power of DC-Link (E) Power of BESS (F) SOC of BESS.

that during 0.3s to 0.45s, there is voltage harmonics and during 0.6s to 0.65s, there is a combination of voltage harmonic and voltage sag of 0.7 pu and during 0.65s to 0.7s, there is a combination of voltage harmonic and voltage sag of 0.4 pu. An appropriate voltage V_{SE} is injected by the series compensator to mitigate the source voltage, V_S under these contexts during the condition of voltage sag which can be seen in Fig. 12(B) to keep the load voltage, V_L equivalent to the rated voltage. It can be noticed from Fig. 12(C) that the load voltage is sinusoidal and equal to the rated voltage. Fig. 12(D) shows the distorted load current, i_L created by the unbalanced non-linear load. Three-phase unbalance load is considered in this work. Since the non-linear load is utilized, the shunt compensator mitigates for the source current, i_S by injecting a current i_{SH} shown in Fig. 12(E) to keep the grid current sinusoidal. The sinusoidal grid current can be seen from Fig. 12(F). From Fig. 13(A), it can be noticed that the DC link voltage is stable at 700 V during the voltage harmonic and the combination of voltage harmonic and voltage sag. The

PV current is around 46.2 A observed in Fig. 13(B) and the power of the PV can be seen in Fig. 13(C) which is 32 KW. The DC link power can be observed in Fig. 13(D) and it is increased during 0.3s to 0.45s so that the voltage harmonics can be compensated. Moreover, during 0.6s to 0.75s the power of the DC is increased so that the harmonics can be mitigated, and the load can be supported during insufficient voltage supplied from the source as well. The power of the BESS is seen in Fig. 13(E) and it can be observed that during 0.3s to 0.45s the power of the BESS is slightly increased and during 0.6s to 0.75s when the combination of harmonics and sag happened the power of the BESS is increased little high since the current of the BESS is increased. The state of charge (SOC) shows in Fig. 13(F) and can be noticed the charging operation of the BESS throughout the process.

The THD for current under voltage harmonic condition is shown in Fig. 14(A). It can be observed that the THD is very low which is 2.05%. Moreover, Fig. 14(B) shows the THD for current under voltage harmonic with sag condition and can be




FIGURE 14. Simulation findings acquired under Case Study 1 for UPQC connecting with PV-BESS, (A) THD for current under voltage harmonic condition (B) THD for current under voltage harmonic with sag condition (C) THD for voltage.




FIGURE 15. Simulation findings obtained under Case Study 1 for UPQC connecting with PV-BESS (A) Total capacitor voltage (B) Total capacitor current.

noticed that the THD is only 2.09%. Furthermore, Fig. 14(C) shows the THD for voltage and can be seen that the THD is only 0.28%. All these THD results fulfil the IEEE standard 519. From Fig. 15, it can be noticed that the rise time of the capacitor voltage is very fast. At 0.01s the capacitor voltage achieved the desired voltage. When the capacitor voltage reaches to the desired voltage faster, rapid compensation by the series compensator and the shunt compensator can be executed. Moreover, the capacitor voltage is stable during 0.3s to 0.45s when the voltage harmonic happened and during 0.6s to 0.75s when the combination of voltage harmonic and sag happened. These results verified that the shunt compensator is working properly since the shunt compensator is responsible for capacitor voltage balancing. The capacitor current is also shown in the Fig. 15. It can be observed from the Fig. 15 that transient response exists until 0.01s in the capacitor current and then it becomes stable throughout the operation. However, the UPQC without PV and BESS does not show quality result like the PV-BESS-UPQC. In the scenario B, UPQC without PV and BESS will be discussed and comparison with PV-BESS-UPQC will be shown in Table 5 and Table 6 in terms of THD.

2) SCENARIO B: BALANCE HARMONIC SOURCE VOLTAGE WITH NON-LINEAR LOAD AT CONSTANT IRRADIANCE 800 W/m² AT 45° (WITHOUT CONNECTING EXTERNAL SOURCE OF PV-BESS)

The performance of UPQC under context of PCC voltage harmonics and the combination of harmonic and sag are displayed in Fig 16. The case study is done without connecting PV and BESS. The irradiation is maintained constant at 800 W/m² and the temperature 45 degree Celsius. The different observed signals are grid voltages, series compensated voltages, load voltages, load currents, shunt compensated currents, source currents. From Fig. 16(A), it can be noticed that during 0.3s to 0.45s, there is voltage harmonics and during 0.6s to 0.65s, there is a combination of voltage harmonic and voltage sag of 0.7 pu and during 0.65s to 0.7s, there is a combination of voltage harmonic and voltage sag of 0.4 pu. The series compensator mitigates for the source voltage under these contexts by injecting an appropriate voltage V_{SE} during voltage sag which can be seen in Fig. 16(B) to keep the load voltage, V_L equivalent to the rated voltage. It can be observed from Fig. 16(C) that the load voltage is sinusoidal and equal to the rated voltage. Fig. 16(D) shows the distorted load current, i_L created by the unbalanced non-linear load. Three phase unbalance loads are considered in this work. Since the non-linear load is utilized in this work, the shunt compensator is supposed to mitigate for the source current under non-linear load context by injecting an appropriate current i_{SH} shown in Fig. 16(E) to keep the source current, i_S sinusoidal. However, the capacitor voltage takes long time to attain the determined voltage and most of the capacitor voltage is utilized by the series compensator and for that reason the shunt compensator does not have enough support from the capacitor to inject appropriate compensation current to mitigate for the source current. From Fig. 16(F) it can be




FIGURE 16. Simulation waveform acquired under Case Study 1 for UPQC connecting without PV-BESS, with include (A) three-phase source voltage (B) Injection voltage of Series APF (C) Load Voltage (D) Load Current (E) Injection Current of Shunt APF (F) Source Current.

noticed that the source current is high at the beginning and not pure sinusoidal like the PV-BESS-UPQC case study.

The THD for current under voltage harmonic condition is shown in Fig. 17(A). It can be observed that the THD is 4.66% which is higher than the PV-BESS-UPQC case study. Moreover, Fig. 17(B) shows the THD for current under voltage harmonic with sag condition and can be noticed that the THD is 5.49% which is also higher than the PV-BESS-UPQC case study. Furthermore, Fig. 17(C) shows the THD for voltage and can be seen that the THD is only 0.29% which is slightly higher than the PV-BESS-UPQC case study. From Fig. 18, it can be noticed that the capacitor voltage is rising very slow and the stability is not achieved accurately. Since the capacitor voltage reach to the desired voltage very slow, rapid compensation by the series compensator and the shunt compensator is not possible. Moreover, the capacitor voltage is not stable during 0.35s to 0.45s when the voltage harmonic happened and during 0.6s to 0.75s when the combination of

voltage harmonic and sag happened. These results verified that the shunt compensator is not working properly since the shunt compensator is responsible for capacitor voltage balancing. The capacitor current is also shown in the Fig. 18. However, the UPQC without PV and BESS does not show quality result like the PV-BESS-UPQC.

The summary of the findings of source current and load voltage is tabulated in Table 5 and Table 6. The comparative analysis between the UPQC with PV-BESS and UPQC without PV-BESS can be realized from the Table 5 and Table 6. From Table 5, it can be noticed that before connecting the UPQC during voltage harmonic condition the THD values for the source currents are 53.28%, 52.92% and 53.28% for a, b and c phases. Afterwards, UPQC is integrated in the system with PV and ESS and the THD values are significantly reduced and the values for a, b and c phases are 2.05%, 2.54% and 3.05% respectively. To verify the significance of PV-BESS-UPQC system, the PV and the BESS is removed




FIGURE 17. Simulation findings acquired under Case Study 1 for UPQC connecting without PV-BESS, (A) THD for current under voltage harmonic condition (B) THD for current under voltage harmonic with sag condition (C) THD for voltage.




FIGURE 18. Simulation findings obtained under Case Study 1 for UPQC without PV-BESS (A) Total capacitor voltage (B) Total capacitor current.

and observed the performance of the UPQC with DC link capacitor only and it can be observed that the THDs are increased which are 4.66%, 5.63% and 5.69% for a, b and c phases respectively. Besides, during the condition of voltage harmonic with sag without attaching the UPQC the THD values for the source currents are 49.49%, 49.57% and 49.43% for a, b and c phases respectively. After attaching the UPQC in the system with PV and BESS and the THD is observed for phase a, b and c and which are 2.09%, 2.83% and 3.07% respectively. To verify the significance of PV-BESS-UOQC system, the PV and the BESS is removed and observed the performance of the UPQC with DC link capacitor only and it can be observed that the THD is increased which is 5.49%, 6.35% and 6.43% for phase a, b and c respectively.

From Table 6, it can be noticed that before connecting the UPQC during voltage harmonic condition the THD values for the load voltages are 18.81%, 18.82% and 18.82% for phase a, b and c respectively. Next, UPQC is connected in the system with PV-ESS and the THD values are reduced remarkably and the values for phase a, b and c are 0.28%, 0.28% and 0.28% respectively. To validate the significance of PV-BESS-UOQC system, the PV and the BESS is detached and consider the performance of the UPQC with DC link capacitor only and it can be noticed that the THD is increased slightly which is 0.29%, 0.29% and 0.29% for phase a, b

TABLE 5. Comparative source current analysis of the proposed UPQC with PV-BESS and without PV-BESS under Case Study 1.

Analysis Parameter	Voltage Harmonic			Voltage Harmonic with sag (at 0.7 & 0.4 pu)		
	Phase a	Phase b	Phase c	Phase a	Phase b	Phase c
Before attaching UPQC						
THD value (%)	53.28	52.92	53.28	49.49	49.57	49.43
Phase Difference (°)	7.0	6.5	4.2	5.0	4.2	4.0
Power Factor	0.808	0.812	0.905	0.903	0.810	0.910
After attaching UPQC with PV-ESS						
THD value (%)	2.05	2.54	3.05	2.09	2.83	3.07
Phase Difference (°)	0.5	0.3	0.4	0.6	0.4	0.5
Power Factor	0.999	0.999	0.999	0.999	0.999	0.999
After attaching UPQC without PV-ESS						
THD value (%)	4.66	5.63	5.69	5.49	6.35	6.43
Phase Difference (°)	0.5	0.3	0.4	0.6	0.4	0.5
Power Factor	0.999	0.999	0.999	0.999	0.999	0.999

and c respectively. Besides, during the condition of voltage harmonic with sag without attaching the UPQC the THD values for the load voltages are 32.62%, 34.11% and 34.11% for a, b and c phases respectively. Next, attaching the UPQC in the system with PV and ESS and the THD is noticed for a, b and c phases which are 0.28%, 0.28% and 0.28% respectively. To validate the significance of PV-BESS-UOQC system, the PV and the BESS is disconnected and noticed the performance of the UPQC with DC link capacitor only and the THD is increased slightly which is 0.29%, 0.29% and 0.29% for a, b and c phases respectively.

TABLE 6. Comparative load voltage analysis of the proposed UPQC with PV-BESS and without PV-BESS under Case Study 1.

Analysis Parameter	Voltage Harmonic			Voltage Harmonic with sag (0.3 & 0.6 pu)		
	Phase a	Phase b	Phase c	Phase a	Phase b	Phase c
Before attaching UPQC						
THD value (%)	18.81	18.82	18.82	32.62	34.11	34.11
Phase Angle (°)	0	-120	120	0	-120	120
After attaching UPQC with PV-ESS						
THD value (%)	0.28	0.28	0.28	0.28	0.28	0.28
Compensation Magnitude (%)	100	100.1	99.78	99.939	99.66	99.54
Phase Angle (°)	0	-120	120	0	-120	120
After attaching UPQC without PV-ESS						
THD value (%)	0.29	0.29	0.29	0.29	0.29	0.29
Compensation Magnitude (%)	99.969	99.48	100.2	99.969	99.33	99.3
Phase Angle (°)	0	-120.2	199.9	0	-120.2	120.2

B. CASE STUDY 2: CONSTANT PV IRRADIANCE AT 800 W/m² AT 45°C

1) SCENARIO A: SINUSOIDAL-BALANCE SAG AND SWELL SOURCE VOLTAGE CONDITION WITH HARMONIC NON-LINEAR LOAD AT CONSTANT IRRADIANCE 800 W/M² AT 45°C

In the case study 2, the operation of PV-BESS-UPQC is operated utilizing the constant PV irradiation, which is maintained at 800 W/m² and the temperature is maintained at 45 degree Celsius that follow the Malaysia tropical climate. For the scenario A under case study 2, the PV-BESS-UPQC is considered under context of sinusoidal-balanced source voltage sag and swell condition at PCC. The performance simulation of PV-BESS-UPQC under context of sinusoidal-balanced source voltage sags and swells at PCC are displayed in term of simulation waveform are shown in The different observed waveforms are supply voltages, series compensated voltages, load voltages, load currents, shunt compensated currents, source currents. From Fig. 19(A), it can be noticed that source voltage, V_S at PCC during 0.3s to 0.35s and 0.4s to 0.45s, there is 0.7 pu voltage sag and 0.35s to 0.4s, there is 0.4 pu voltage sag. Moreover, from 0.6s to 0.65s and 0.7s to 0.75s, there is 1.3 pu voltage swell and from 0.65s to 0.7s, there is 1.6 pu voltage swell. An appropriate voltage V_{SE} is injected by the series APF compensator to mitigate for the source voltage at PCC under these contexts. The injected voltage is in phase with the grid voltage during the condition of voltage sag and opposite phase with source voltage during the condition of voltage swell which can be seen in Fig. 19(B) to keep the load voltage, V_L is equivalent to the rated voltage. It can be noticed from Fig. 19(C) that the load voltage is

sinusoidal and equal to the rated voltage. Fig. 19(D) shows the distorted load current, i_L created by the unbalanced non-linear load. Three phase unbalance loads is considered in this work. Since the non-linear load is utilized in this work, the shunt APF compensator mitigates for the source current, i_S under non-linear load context by injecting an appropriate current i_{SH} shown in Fig. 19(E) to keep the source current sinusoidal. Therefore, the source current is maintained sinusoidal and can be seen from Fig. 19(F).

From Fig. 20, it can be seen that the compensation magnitude of load voltage, V_L is achieved appropriately which is equal to the rated voltage. It shows the compensation by the series APF compensator during the condition of voltage sag and voltage swell. It can be observed that 0.3s to 0.35s and 0.35s to 0.4s, there is voltage sag of 0.7 pu and 0.4 pu respectively. The series APF compensator injected appropriate to compensate for the source voltage on both conditions. Therefore, the load voltage achieves the rated voltage during the voltage sag. Moreover, there is 1.3 pu voltage swell and 1.6 pu during the period of 0.6s to 0.65s and 0.65s to 0.7s respectively. An appropriate voltage in opposite phase with the source voltage is injected by the series compensator to compensate the grid voltage.

The THD for current under balanced voltage sag condition is displayed in Fig. 21(A). It can be observed that the THD is 2.09%. Moreover, Fig. 21(B) shows the THD for current under balanced voltage swell condition and can be noticed

that the THD is 2.02%. Furthermore, Fig. 21 (C) shows the THD for voltage and can be seen that the THD is only 0.28%.

From Fig. 22(A), it can be noticed that the measured DC link voltage is stable at 700 V during the condition of voltage sag and voltage swell. The PV current is around 46.2 A observed in Fig. 22 (B) and the power of the PV can be seen in Fig. 22(C) which is 32 KW. The DC link power can be observed in Fig. 22(D) and it is increased during 0.3s to 0.45s so that the load can be supported during insufficient voltage supply. On the other hand, the DC link power is reduced during 0.6s to 0.75s because of over voltage supply from the grid. The power of the BESS is seen in Fig. 22(E) and it is increased during the voltage sag from 0.3s to 0.45s since the current of the BESS is increased whereas the power of the BESS is reduced during voltage swell from 0.6s to 0.75s since the current of the BESS is decreased. The state of charge (SOC) shows in Fig. 22(F) and can be noticed the charging operation of the BESS throughout the process.

In Fig. 23, it can be noticed clearly that the suggested STF-UVG in Fig. 23(A) and standard conventional SRF-PLL technique in Fig. 23(B) are capable of detecting the synchronization phase value accurately in $\sin(\omega t)$ and $\cos(\omega t)$ from the grid voltage which sinusoidal-balanced under sag and swell condition at PCC. Besides, Table 7 summarizes the comparative analysis for source current when simulating the PV-BESS-UPQC with proposed STF-UVG extraction method and the conventional SRF-PLL extraction method. Besides. the comparative analysis for load voltage is tabulated in Table 8 considering the PV-BESS-UPQC with proposed




FIGURE 19. Simulation waveform acquired under Case Study 2: Scenario A for balance voltage swell and sag condition, with include (A) three-phase source voltage (B) Injection voltage of Series APF (C) Load Voltage (D) Load Current (E) Injection Current of Shunt APF (F) Source Current.

STF-UVG extraction method and the conventional SRF-PLL extraction method. The comparative analysis is done under the sinusoidal-balanced source voltage sags and swells condition at PCC. The both techniques are mitigating harmonic currents produced by non-linear load and the grid currents are maintained as sinusoidal shape with THD values suggested by IEEE standard 519 which is beneath the 5% harmonic limit. The results show that the THD is slightly lower in the proposed STF-UVG and STF- $dq0$ filter technique than using the SRF-PLL and MAF filter technique. Furthermore, the resulted phase differences between the source voltage and current is large and reduced by the STF-UVG and STF- $dq0$ filter techniques of UPQC. In other words, it proves that the STF-UVG and STF- $dq0$ filter both techniques can synchronize UPQC with the grid effectively. This is because the phase values are detected accurately in $\sin(\omega t)$ and $\cos(\omega t)$ by both techniques. Therefore, the grid current operates in phase with the grid voltage and so unity power factor is nearly achieved which is 0.999. Overall, the STF-UVG extraction method and the conventional SRF-PLL extraction method




FIGURE 20. Simulation finding showing the detected voltage magnitude under Case study 2: Scenario A for balance voltage sag and swell condition.

both methods perform identically during the source voltage operating condition of sinusoidal-balanced sag and swell for case study 2: scenario A.

2) SCENARIO B: SINUSOIDAL-UNBALANCE SAG AND SWELL SOURCE VOLTAGE CONDITION WITH HARMONIC NON-LINEAR LOAD AT CONSTANT IRRADIANCE 800 W/M^2 AT 45°

In Scenario B for case study 2, an unbalanced source voltage of swell and sag condition at PCC is considered to test the




FIGURE 21. Simulation findings acquired under Case Study 2: Scenario A for balance voltage sag and swell condition, (A) THD for current under balance voltage sag condition (B) THD for current under balance voltage swell condition (C) THD for voltage under both conditions.




FIGURE 22. Simulation result acquired under Case Study 2: Scenario A for balance voltage sag and swell condition, with include (A) DC-Link Voltage (B) Current of PV (C) Power of PV (D) Output power of DC-Link (E) Power of BESS (F) SOC of BESS.

performance of PV-BESS-UPQC. The performance of UPQC under context of PCC unbalance voltage sags and swells are displayed in figure. The irradiation is maintained constant at

800 W/m². From Fig. 24(A), it can be noticed that during 0.25s to 0.5s, there is voltage swell of 1.2 pu in phase a, 1.4 pu in phase b and 1.6 pu in phase c and from 0.65s to 0.85s, there




FIGURE 23. Simulation findings showing the detected synchronization reference phase value in $\sin(\omega t)$ and $\cos(\omega t)$ under Case study 2: Scenario A for balance voltage swell and sag condition, with include (A) Detection of synchronization phase by the STF-UVG (B) Detection of synchronization phase by the conventional SRF-PLL.

TABLE 7. Comparative source current analysis of the suggested UPQC using STF technique and standard SRF-MAF technique under Case Study 2: Scenario A.

Analysis Parameter	Balance Voltage Sag (at 0.7 & 0.4 pu)			Balance Voltage Swell (at 1.3 & 1.6 pu)		
	Phase a	Phase b	Phase c	Phase a	Phase b	Phase c
Before Connecting PV-ESS-UPQC						
THD value (%)	53.28	52.92	53.28	49.49	49.57	49.43
Phase Difference (°)	7.0	6.5	4.2	5.0	4.2	4.0
Power Factor	0.808	0.812	0.905	0.903	0.810	0.910
After Connecting PV-BESS-UPQC with the suggested STF						
THD value (%)	2.09	2.67	3.15	2.02	2.79	2.92
Phase Difference (°)	0.4	0.3	0.5	0.4	0.2	0.6
Power Factor	0.999	0.999	0.999	0.999	0.999	0.999
After Connecting PV-BESS-UPQC with the standard SRF-MAF						
THD value (%)	2.12	2.75	3.14	1.99	2.80	3.11
Phase Difference (°)	0.5	0.4	0.7	0.6	0.4	0.8
Power Factor	0.999	0.999	0.999	0.999	0.999	0.999

is voltage sag of 0.8 pu in phase a, 0.6 pu in phase b and 0.4 pu in phase c. An appropriate voltage V_{SE} is injected by the series compensator to mitigate for the source voltage under the context of unbalance sag and swell source voltage which can be seen in Fig. 24(B) to keep the load voltage equivalent

TABLE 8. Comparative load voltage analysis of the proposed UPQC using STF technique and standard SRF-MAF technique under Case Study 2: Scenario A.

Analysis Parameter	Balance Voltage Sag (at 0.3 & 0.6 pu)			Balance Voltage Swell (at 1.3 & 1.6 pu)		
	Phase a	Phase b	Phase c	Phase a	Phase b	Phase c
Before Connecting PV-BESS-UPQC						
THD value (%)	19.73	22.54	22.54	12.14	12.14	12.14
Phase Angle (°)	0	-120	120	0	-120	120
After Connecting PV-BESS-UPQC with the suggested STF technique						
THD value (%)	0.28	0.28	0.28	0.28	0.28	0.28
Compensation Magnitude (%)	100	99.41	99.53	100	100.6	100.5
Phase Angle (°)	0	-120	120	0	-120	120
After Connecting PV-BESS-UPQC with the standard SRF-MAF technique						
THD value (%)	0.28	2.14	2.45	0.28	2.45	2.22
Compensation Magnitude (%)	100	98.9	99.27	100	100.7	100.6
Phase Angle (°)	0	-120.3	119.8	0	-120.2	119.9

to the rated voltage. The sinusoidal load voltage can be noticed from Fig. 24(C) and it is equal to the rated voltage. Fig. 24(D) shows non-linear load distorted current. To keep the source current sinusoidal the shunt compensator, inject the compensation current which is displayed in Fig. 24(E).




FIGURE 24. Simulation waveform acquired under Case Study 2: Scenario B for unbalance voltage swell and sag condition, with include (A) three-phase source voltage (B) Injection voltage of Series APF (C) Load Voltage (D) Load Current (E) Injection Current of Shunt APF (F) Source Current.




FIGURE 25. Simulation findings acquired the detected voltage magnitude under case study 2: Scenario B for unbalance voltage sag and swell condition.

Since the non-linear load is utilized in this work, the shunt compensator mitigates for the source current under non-linear load context by injecting an appropriate current i_{SH} to keep the source current sinusoidal. Therefore, the source current is maintained sinusoidal and can be seen from Fig. 24(F). From Fig. 25, it can be seen that the compensation is achieved appropriately during the unbalanced voltage sag and swell. The figure shows the compensation by the series compensator

during the voltage swell from 0.25s to 0.5s and voltage sag from 0.65s to 0.85s. The series compensator injects different voltage magnitude according to the demand. The result proves that the compensation is successfully achieved. Therefore, the load voltage achieved the rated voltage during the condition of unbalanced voltage sag and swell. The DC link voltage can be seen from Fig. 26(A) and it is stable at 700 V during the voltage distortion in the supply, and Fig. 26(B) shows that the PV current is around 46.2 A and the power of the PV is shown in Fig. 26(C) and the DC link power is 32 KW. The DC link power is reduced during voltage swell from 0.25s to 0.5s so that the load can be protected in the overvoltage condition. On the other hand, the DC link power is increased during voltage swell from 0.65s to 0.85s to support the load in the insufficient voltage condition and shown in Fig. 26(D). The power of the BESS is observed in Fig. 26(E) and it is increased during the voltage sag from 0.65s to 0.85s since the current of the BESS is increased




FIGURE 26. Simulation result acquired under Case Study 2: Scenario B for unbalance voltage sag and swell condition, with include (A) DC-Link Voltage (B) Current of PV (C) Power of PV (D) Output power of DC-Link (E) Power of BESS (F) SOC of BESS.




FIGURE 27. Simulation findings acquired under Case Study 2: Scenario B for unbalance voltage swell and sag condition, (A) THD for current under unbalance voltage swell condition (B) THD for current under unbalance voltage sag condition (C) THD for voltage under both condition.

whereas the power of the BESS is reduced during voltage swell from 0.25s to 0.5s since the current of the BESS is decreased. The state of charge (SOC) shows in Fig. 26(F) that the BESS is charged throughout the process.

Fig. 27 shows the THD values under unbalance voltage swell and sag for source current and load voltage. In Table 9, the comparative analysis for source current of the proposed UPQC-STF and UPQC-SRF techniques are tabulated. From

TABLE 9. Comparative source current analysis of the proposed UPQC using STF technique and standard SRF-MAF technique under Case Study 2: Scenario B.

Analysis Parameter	Voltage Unbalance Swell (at 1.2, 1.4 & 1.6 pu)			Voltage Unbalance Sag (at 0.8, 0.6 & 0.4 pu)		
	Phase a	Phase b	Phase c	Phase a	Phase b	Phase c
	Before attaching PV-ESS-UPQC					
THD value (%)	53.28	52.92	53.28	49.49	49.57	49.43
Phase Difference (°)	7.0	6.5	4.2	5.0	4.2	4.0
Power Factor	0.808	0.812	0.905	0.903	0.810	0.910
After attaching PV-ESS-UPQC with the suggested STF technique						
THD value (%)	2.62	2.89	3.00	2.62	2.93	3.25
Phase Difference (°)	0.30	0.40	0.60	0.30	0.70	0.50
Power Factor	0.999	0.999	0.999	0.999	0.998	0.999
After attaching PV-ESS-UPQC with the standard SRF-MAF technique						
THD value (%)	4.51	4.92	5.13	4.55	4.69	5.09
Phase Difference (°)	0.40	0.40	0.70	0.30	0.70	0.60
Power Factor	0.998	0.998	0.998	0.998	0.998	0.998

the Table 9, it can be noticed that both UPQC-STF and UPQC-SRF reduced the THD value significantly. Before connecting the UPQC system in the PCC, the THD values were 53.28%, 52.92% and 53.28% for a, b and c phases respectively for unbalance voltage swell and 49.49%, 49.57% and 49.43% for phase a, b and c respectively for unbalance voltage sag. On the other hand, both PV-ESS-UPQC with STF technique and SRF technique reduced the THD. For STF technique, the THD values are 2.62%, 2.89% and 3.00% for a, b and c respectively for unbalance voltage swell and 2.62%, 2.93% and 3.25% for a, b and c respectively for unbalance voltage sag and the almost unity power factor is achieved. For SRF technique, the THD values are 4.51%, 4.92% and 5.13% for a, b and c respectively for unbalance voltage swell and 4.55%, 4.69% and 5.09% for a, b and c respectively for unbalance voltage sag and the almost unity power factor is achieved.

In the Table 10, the comparative analysis for load voltage is summarized considering the PV-BESS-UPQC with proposed STF-UVG extraction method and the conventional SRF-PLL extraction method. The comparative analysis result is obtained considering the unbalanced voltage sags and swells condition at PCC. The results show that before connecting the UPQC system the THDs for load voltages are 12.67%, 13.79% and 14.92% for unbalanced voltage swell condition

TABLE 10. Comparative load voltage analysis of the proposed UPQC using STF technique and standard SRF-MAF technique under Case Study 2: Scenario B.

Analysis Parameter	Unbalance Voltage Swell (at 1.2, 1.4 & 1.6 pu)			Unbalance Voltage Sag (at 0.8, 0.6 & 0.4 pu)		
	Phase a	Phase b	Phase c	Phase a	Phase b	Phase c
	Before Connecting PV-BESS-UPQC					
THD value (%)	12.67	13.79	14.92	18.20	22.79	34.28
Phase Angle (°)	0	-120	120	0	-120	120
After Connecting PV-BESS-UPQC with the suggested STF technique						
THD value (%)	0.28	0.37	0.38	0.28	0.33	0.35
Compensation Magnitude (%)	100	100.7	101.2	100	99.65	99.29
Phase Angle (°)	0	-120	120	0	-120	120
After Connecting PV-BESS-UPQC with the standard SRF-MAF technique						
THD value (%)	0.28	1.37	2.31	0.28	1.94	2.72
Compensation Magnitude (%)	100	100.5	101.6	100	99.45	99.54
Phase Angle (°)	0	-119.9	119.4	0	-120.2	120.1

for a, b and c respectively. Besides, for unbalanced voltage sag condition the THDs for load voltages are 18.20%, 22.79% and 34.28% for a, b and c respectively. Next, the PV-BESS-UPQC system is connected using the STF technique and can be noticed that the THDs for load voltages are 0.28%, 0.37% and 0.38% for unbalanced voltage swell condition for phase a, b and c respectively and for unbalanced voltage sag condition the THDs for load voltages are 0.28%, 0.33% and 0.35% for a, b and c respectively. On the other hand, utilizing PV-BESS-UPQC with SRF-MAF technique the THDs for load voltages are 0.28%, 1.37% and 2.31% for unbalanced voltage swell condition for a, b and c respectively and for unbalanced voltage sag condition the THDs for load voltages are 0.28%, 1.94% and 2.72% for a, b and c respectively. It can be observed that the THDs are slightly lower in the proposed STF-UVG technique than the SRF-PLL technique.

Based on Fig. 28(A), it can be observed that the synchronization phase value in $\sin(\omega t)$ and $\cos(\omega t)$ are detected accurately by the suggested STF-UVG method which is equivalent to the expected phase value. On the other hand, minor displacement can be noticed between desired phase value and the detected phase value in the Fig. 28(B) where the standard conventional SRF-PLL technique is implemented. Therefore, it indicates that the standard conventional SRF-PLL technique is not able to extract the phase value accurately




FIGURE 28. Simulation findings of the detected phase value of synchronization reference in $\sin(\omega t)$ and $\cos(\omega t)$ under Case study 2: Scenario A for unbalance voltage swell and sag condition, with include (A) Synchronization phase detected by the STF-UVG (B) Synchronization phase detected by the conventional SRF-PLL.




FIGURE 29. Simulation waveform acquired under Case Study 3: Scenario A for voltage interruption condition, with include (A) three-phase source voltage (B) Injection voltage of Series APF (C) Load Voltage.

as desired during an unbalance three-phase source voltage swell and sag condition across the PCC.

C. CASE STUDY 3: VARYING PV IRRADIANCE AND TEMPERATURE PV PANEL

1) SCENARIO A: NON-SINUSOIDAL-UNBALANCE PERMANENT INTERRUPTION SOURCE VOLTAGE WITH HARMONIC NON-LINEAR LOAD AT LOW UNBALANCE PV IRRADIANCE

The operation of UPQC under context of PCC voltage sags and interruption are displayed in Fig. 28. The irradiance is reduced to 0 W/m² from 800 W/m² during 0.35s to 0.9s. The different observed waveforms are supply voltages, series compensated voltages, load voltages, load currents, shunt compensated currents, source currents. From Fig. 29(A) it can be observed that during 0.25s to 0.35s, there is 0.6 pu




FIGURE 30. Simulation findings acquired the detected voltage magnitude under Case study 3: Scenario A for voltage interruption condition.

voltage sag and 0.35s to 0.45s, there is 0.3 pu voltage sag. Moreover, from 0.45s to the end of the simulation the voltage supply is interrupted. An appropriate voltage V_{SE} is injected by the series compensator to mitigate for the source voltage under these contexts and support the load completely during




FIGURE 31. Simulation result acquired under Case Study 2: Scenario A for voltage interruption condition, with include (A) DC-Link Voltage (B) Current of PV (C) Power of PV (D) PV Irradiance (E) PV temperature panel (F) Output power of DC-Link (G) Power of BESS (H) SOC of BESS.

voltage interruption occurred in the grid voltage. The voltage injection is displayed in Fig. 29(B). The load voltage is shown in Fig. 29(C) and it can be noticed that the load voltage is equivalent to the rated voltage. Fig. 30 shows the source voltage magnitude and the load voltage magnitude. The dotted lines indicate the source voltages and the straight lines show the load voltages. It can be seen from the Fig. 30 that the compensation is achieved appropriately. The Fig. 30 shows the compensation by the series compensator during the voltage sag from 0.25s to 0.45s and from 0.45s the source voltage is zero and the total load voltage is supplied by the series compensator using the PV and BESS.

An appropriate voltage is injected by the series compensator in phase with the grid voltage to mitigate for the source voltage on both conditions. Therefore, the load voltage achieved the rated voltage during the voltage sag and also during the voltage interruption. From Fig. 31(A), it can be noticed that the DC link voltage is stable at 700 V during the voltage sag and voltage interruption. From Fig. 31(B) it can be noticed that the PV current is around 46.2A until 0.35s and after that it becomes zero because the irradiation is reduced to 0 W/m² and the temperature also reduced

to 0°C which can be seen in Fig. 31(D) and Fig. 31(E) respectively.

From 0.9s the PV current start increasing again since the PV is connected and the irradiation is back to 800 W/m². The power of the PV can be seen in Fig. 31(C) which is 32 KW at the beginning and from 0.35s to 0.9s it becomes zero because the irradiation is reduced to 0 W/m² and then it rises again since the irradiation is now returned to 800 W/m². From the Fig. 31(F), the increase of DC link power is noticed during 0.3s to 0.45s and become maximum at 0.45s so that the load can be supported during insufficient voltage supply and also when there is no voltage supplied from the grid. The power of the BESS can be seen in Fig. 31(G) and it can be noticed that the power is decreased in the beginning and then become stable. When the PV is disconnected then the BESS supplied the power to the load through the DC link. At the beginning the BESS is started charging since the PV is still connected but when the PV is disconnected then the BESS started supplying power and start discharging. Afterwards, the PV is connected again at 0.9s and started sending power to the load. At this moment the BESS stopped supplying power and move to charging mode. The state of

charge (SOC) in Fig. 31(H) shows that the BESS is charged at the beginning and then start discharging from 0.35s to 1.1s.

V. CONCLUSION

The construction of three-phase UPQC has been investigated considering the condition of complex power quality problems which are an amalgamation of harmonics, voltage swell, and sags, and voltage interruption under unbalanced and distorted voltage grid condition. Integrating the BESS and PV with the UPQC provides active power capability to the network. The main benefit of BESS integrated with UPQC is that it makes the system capable of supplying and absorbing active power from the PV. Since renewable energy is not completely reliable because of its environment-dependent feature, integrating a BESS will solve the lack of renewable energy resources. Finally, it can be figured that the BESS and PV attached with UPQC can be a good alternative in the distributed generation to upgrade the power quality of the contemporary distribution system. The DC-link voltage is stable because of the continuous supply from the PV-BESS system. Therefore, it can reduce the complexity of the DC-link voltage regulation algorithm. The STF-UVG technique for synchronization phases is applied successfully in the shunt and series APF compensator to generate reference current and voltage. Thus, the UPQC is designed without relying on the PLL components, and mitigation of current and voltage are achieved successfully following the grid condition to ensure the system stability and to achieve almost unity power factor. The implementation of the proposed technique has confirmed that the grid current harmonics follow the IEEE-519 standard. Finally, it is worth mentioning that the proposed system can enhance the overall efficiency of the grid power system.

REFERENCES

- [1] *IEEE Recommended Practice for Monitoring Electric Power Quality*, IEEE Standards 1159-1995, IEEE Standards Coordinating Committee 22 on Power Quality, Jun. 1995, vol. 2009.
- [2] D. De Yong, S. Bhowmik, and F. Magnago, "Optimized complex power quality classifier using one vs. rest support vector machines," *Energy Power Eng.*, vol. 9, no. 10, pp. 568–587, 2017.
- [3] A. Javadi, A. Hamadi, L. Woodward, and K. Al-Haddad, "Experimental investigation on a hybrid series active power compensator to improve power quality of typical households," *IEEE Trans. Ind. Electron.*, vol. 63, no. 8, pp. 4849–4859, Aug. 2016.
- [4] A. Javadi, L. Woodward, and K. Al-Haddad, "Real-time implementation of a three-phase THSeAF based on a VSC and a P+R controller to improve the power quality of weak distribution systems," *IEEE Trans. Power Electron.*, vol. 33, no. 3, pp. 2073–2082, Mar. 2018.
- [5] M. A. Mansor, M. M. Othman, I. Musirin, and S. Z. M. Noor, "Dynamic voltage restorer (DVR) in a complex voltage disturbance compensation," *Int. J. Power Electron. Drive Syst.*, vol. 10, no. 4, pp. 2222–2230, 2019.
- [6] A. Ghosh and G. Ledwich, "Compensation of distribution system voltage using DVR," *IEEE Trans. Power Del.*, vol. 17, no. 4, pp. 1030–1036, Oct. 2002.
- [7] S. Jothibasu and M. K. Mishra, "A control scheme for storageless DVR based on characterization of voltage sags," *IEEE Trans. Power Del.*, vol. 29, no. 5, pp. 2261–2269, Oct. 2014.
- [8] A. Farooqi, M. M. Othman, A. F. Abidin, S. I. Sulaiman, and M. A. M. Radzi, "Mitigation of power quality problems using series active filter in a microgrid system," *Int. J. Power Electron. Drive Syst.*, vol. 10, no. 4, pp. 2245–2253, 2019.
- [9] C. Kumar and M. K. Mishra, "Operation and control of an improved performance interactive DSTATCOM," *IEEE Trans. Ind. Electron.*, vol. 62, no. 10, pp. 6024–6034, Oct. 2015.
- [10] Y. Hoon, M. M. Radzi, M. Hassan, and N. Mailah, "Control algorithms for shunt active power filter for harmonics mitigation: A review," *Energies*, vol. 10, no. 12, p. 2038, Dec. 2017.
- [11] L. B. G. Campanhol, S. A. O. da Silva, and A. Goedel, "Application of shunt active power filter for harmonic reduction and reactive power compensation in three-phase four-wire systems," *IET Power Electron.*, vol. 7, no. 11, pp. 2825–2836, Nov. 2014.
- [12] Y. Hoon, M. A. M. Radzi, M. K. Hassan, and N. F. Mailah, "Operation of three-level inverter-based shunt active power filter under nonideal grid voltage conditions with dual fundamental component extraction," *IEEE Trans. Power Electron.*, vol. 33, no. 9, pp. 7558–7570, Sep. 2018.
- [13] E. Hossain, M. R. Tur, S. Padmanaban, S. Ay, and I. Khan, "Analysis and mitigation of power quality issues in distributed generation systems using custom power devices," *IEEE Access*, vol. 6, pp. 16816–16833, 2018.
- [14] H. Fujita and H. Akagi, "The unified power quality conditioner: The integration of series- and shunt-active filters," *IEEE Trans. Power Electron.*, vol. 13, no. 2, pp. 315–322, Mar. 1998.
- [15] S. K. Khadem, M. Basu, and M. F. Conlon, "Intelligent islanding and seamless reconnection technique for microgrid with UPQC," *IEEE J. Emerg. Sel. Topics Power Electron.*, vol. 3, no. 2, pp. 483–492, Jun. 2015.
- [16] J. M. Guerrero, P. C. Loh, T.-L. Lee, and M. Chandorkar, "Advanced control architectures for intelligent microgrids—Part II: Power quality, energy storage, and AC/DC microgrids," *IEEE Trans. Ind. Electron.*, vol. 60, no. 4, pp. 1263–1270, Apr. 2013.
- [17] B. Han, B. Bae, H. Kim, and S. Baek, "Combined operation of unified power-quality conditioner with distributed generation," *IEEE Trans. Power Del.*, vol. 21, no. 1, pp. 330–338, Jan. 2006.
- [18] K. Hasan, M. M. Othman, N. F. A. Rahman, M. A. Hannan, and I. Musirin, "Significant implication of unified power quality conditioner in power quality problems mitigation," *Int. J. Power Electron. Drive Syst.*, vol. 10, no. 4, p. 2231, Dec. 2019.
- [19] C. K. Sundarabalan, Y. Puttagunta, and V. Vignesh, "Fuel cell integrated unified power quality conditioner for voltage and current regulation in four-wire distribution grid," *IET Smart Grid*, vol. 2, no. 1, pp. 60–68, Mar. 2019.
- [20] S. Devassy and B. Singh, "Design and performance analysis of three-phase solar PV integrated UPQC," *IEEE Trans. Ind. Appl.*, vol. 54, no. 1, pp. 73–81, Jan. 2018.
- [21] L. B. G. Campanhol, S. A. O. da Silva, A. A. de Oliveira, and V. D. Bacon, "Power flow and stability analyses of a multifunctional distributed generation system integrating a photovoltaic system with unified power quality conditioner," *IEEE Trans. Power Electron.*, vol. 34, no. 7, pp. 6241–6256, Jul. 2019.
- [22] A. M. Gee, F. Robinson, and W. Yuan, "A superconducting magnetic energy storage-emulator/battery supported dynamic voltage restorer," *IEEE Trans. Energy Convers.*, vol. 32, no. 1, pp. 55–64, Mar. 2017.
- [23] W. U. Tareen and S. Mekhilef, "Transformer-less 3P3W SAPF (three-phase three-wire shunt active power filter) with line-interactive UPS (uninterruptible power supply) and battery energy storage stage," *Energy*, vol. 109, pp. 525–536, Aug. 2016.
- [24] S. K. Kollimala, M. K. Mishra, and N. L. Narasamma, "Design and analysis of novel control strategy for battery and supercapacitor storage system," *IEEE Trans. Sustain. Energy*, vol. 5, no. 4, pp. 1137–1144, Oct. 2014.
- [25] S. B. Karanki, N. Geddada, M. K. Mishra, and B. K. Kumar, "A modified three-phase four-wire UPQC topology with reduced DC-link voltage rating," *IEEE Trans. Ind. Electron.*, vol. 60, no. 9, pp. 3555–3566, Sep. 2013.
- [26] A. Teke, L. Saribulut, and M. Tumay, "A novel reference signal generation method for power-quality improvement of unified power-quality conditioner," *IEEE Trans. Power Del.*, vol. 26, no. 4, pp. 2205–2214, Oct. 2011.
- [27] V. G. Kinhal, P. Agarwal, and H. O. Gupta, "Performance investigation of neural-network-based unified power-quality conditioner," *IEEE Trans. Power Del.*, vol. 26, no. 1, pp. 431–437, Jan. 2011.
- [28] M. Kesler and E. Ozdemir, "Synchronous-reference-frame-based control method for UPQC under unbalanced and distorted load conditions," *IEEE Trans. Ind. Electron.*, vol. 58, no. 9, pp. 3967–3975, Sep. 2011.
- [29] S. Golestan, J. M. Guerrero, and J. C. Vasquez, "Three-phase PLLs: A review of recent advances," *IEEE Trans. Power Electron.*, vol. 32, no. 3, pp. 1897–1907, Mar. 2017.



MUHAMMAD ALIF MANSOR received the Diploma degree in electrical engineering (power) and the bachelor's degree (Hons.) in electrical engineering from Universiti Teknologi MARA (UiTM), Malaysia, in 2015 and 2018, respectively. He is currently pursuing the M.Sc. degree in electrical engineering with the Faculty of Electrical Engineering, UiTM, on the research project of "Classification and Mitigation of Complex Power Quality Problems in Energy Storage System (ESS)". He has been working in power and energy with the Artificial Intelligence Research Laboratory (PEAiRL) Group, UiTM, since February 2019. His research interests include power electronics, power quality, renewable energy, and energy storage.



KAMRUL HASAN received the B.Sc. degree in electrical and electronics engineering from the Ahsanullah University of Science & Technology, Dhaka, Bangladesh, in 2015, and the M.Sc. degree in electrical engineering from Curtin University, Miri, Malaysia, in 2018. He is currently pursuing the Ph.D. degree with the Faculty of Electrical Engineering, UiTM, Shah Alam, Malaysia. He has been working in the Power and Energy with Artificial Intelligence Research Laboratory (PEAiRL) Group, UiTM, since March 2019. His research interests include power electronics, power quality, custom power devices, and renewable energy resources.



MUHAMMAD MURTADHA OTHMAN (Member, IEEE) received the B.Eng. degree (Hons.) from Staffordshire University, U.K., in 1998, the M.Sc. degree from Universiti Putra Malaysia, in 2000, and the Ph.D. degree from Universiti Kebangsaan Malaysia, in 2006. He served as the Head of the Department of the Centre for Electrical Power Engineering Studies (CEPES), from February 2009 to December 2010. Since 2012, he has been serving two times as the Deputy Director for the collaborative research project under the auspices of Ministry of Energy, Green Technology and Water (KeTTHA), Malaysia, and also the Public Works Department (JKR), Malaysia. He also served as the Deputy Director for service commercialization on energy efficiency technology under the collaboration with Centre of Excellence for Engineering and Technology JKR (CREaTE), Malaysia. He was previously appointed as the Chairman of the Energy Efficiency Committee in FEE, UiTM and also the Committee Member in the Master of Electrical Power Engineering Programme, Faculty of Engineering, Universiti Putra Malaysia (UPM). He has served as the Panel Assessor for research grant proposals at the Ministry of Higher Education (MOHE), Malaysia and Latvian Science Council, Europe. He is currently the Director of the UiTM-Solar Energy Research (U-SER) Centre, under the project of 50MW LSSPV, Gambang, Pahang. He is also an Associate Professor with the Faculty of Electrical Engineering (FEE), Universiti Teknologi MARA (UiTM), Malaysia. His area of research interests are artificial intelligence, energy efficiency, transfer capability assessment, integrated resource planning, demand side management, hybrid renewable energy, power system stability, reliability studies in a deregulated power systems, power quality, and active power filters.



SITI ZALIHA BINTI MOHAMMAD NOOR (Member, IEEE) received the bachelor's degree (Hons.) in electrical engineering, the M.Sc. degree in power electronics, and the Ph.D. degree in electrical engineering from Universiti Teknologi MARA (UiTM), Malaysia, in 2005, 2008, and 2018, respectively. She is currently a Senior Lecturer with the Faculty of Electrical Engineering, UiTM. She has authored or coauthored more than 35 technical articles in indexed international journal and conferences. Currently, she has more than 500 students joined the course worldwide. Her research interests are renewable energy, power electronics, modeling and simulation, signal processing, and embedded controller applications. She is a Certified Energy Manager, Certified Professional in Measurement and Verification (CPMV), and Qualified Person (QP) SEDA Malaysia Grid-Connected Solar Photovoltaic Systems Design. She is also attached to industry collaborations as the Subject Matter Expert (SME) for the Photovoltaic (PV) system and energy audit. She also received a gold award on the e-Content Development Competition (e-ConDev2018) for Course Renewable Energy-Friends of The World as an educator and developer of the course.



ISMAIL MUSIRIN received the bachelor's degree (Hons.) in electrical engineering from Universiti Teknologi Malaysia, in 1990, the M.Sc. degree in pulsed power technology from the University of Strathclyde, U.K., in 1992, the Ph.D. degree in electrical engineering from Universiti Teknologi MARA (UiTM), Malaysia, in 2005, and the Diploma degree in electrical power engineering from Universiti Teknologi Malaysia (UTM), in 1987. He started his higher education at UTM. He has been the Head of Programme for the Diploma of Electrical Engineering, UiTM for 3 years from 2004 to 2007, the Head of the Department Electrical Power Engineering in 2007, the Deputy Dean Research and Industrial Networking for 2 years from 2008 to 2010, and the Director for Community of Research UiTM for 4 years from 2014 to 2017. He is currently a Professor of power system with the Faculty of Electrical Engineering. He has authored and coauthored two books, more than 300 articles in international journal and indexed conferences. His research interests include artificial intelligence, optimization techniques, power system analysis, renewable energy, distributed generation, and power system stability. He is a Senior Member of the International Association of Computer Science and Information Technology (IACSIT), and a member of the Artificial Immune System Society (ARTIST) and of the International Association of Engineers (IAENG). He is also an International Journal Reviewer of the IEEE *TRANSACTIONS*, *Science* (Elsevier), *WSEAS*, John Wiley, IET, and some other publishers.

...