

**DEVELOPMENT OF AN ANALYTICAL  
COMPUTER TOOL FOR BUILDING  
INTEGRATED RENEWABLE ENERGY  
AND CHP**

**Esther Rischmüller-Magadley, MEng.**

**Thesis submitted to the University of Nottingham  
for the degree of Doctor of Philosophy**

**May 2009**

## **Abstract**

This thesis describes a computer tool that was developed to compare different combinations of photovoltaic (PV) panels, solar thermal collectors and combined heat and power (CHP) technologies for building applications in order to find the option with the lowest cost of emissions reduction.

The novelty of this computer tool is that it addresses the uncertainty of building energy load profiles in the sizing of renewable energy and CHP technologies by applying the Monte Carlo Method. A database of historical building energy load profiles was collated for this purpose. However, little domestic hot water load profiles were found in the literature. Therefore, as part of this study, a survey was also carried out to collect some domestic hot water load profile data.

The domestic hot water demand survey consisted of a questionnaire and monitoring study. The questionnaire consisted of two parts: a general questionnaire about the dwelling and a diary study. The questionnaire collected general information about the dwelling, enabling the load profiles collected to be classified into different building type categories. In the diary study the hot water consumption patterns were recorded. The hot water energy consumption data was also obtained from direct monitoring using temperature sensors attached to the hot water pipes of the different appliances to record when and from which appliance hot water was used throughout the day in the dwellings. Load profiles were formed using this data and the data from the diary study in the questionnaire, together with typical hot water usage of different appliances. These were calculated from hot water usage times and typical flow rates of the different appliances that were recorded by a clamp-on flow meter. The load

profile data collected from the survey and the literature was loaded into the computer tool database.

The tool was developed in two Excel files each combining a different renewable energy technology (Photovoltaics and Solar Thermal) with CHP and the tool was programmed using Visual Basic for Applications (VBA) in Excel. The computer tool codes are executed in the following order:

- 1) Process building loads and load profiles
- 2) Size renewable and CHP technologies
- 3) Carry out economic and environmental analysis
- 4) Apply Monte Carlo method to determine the most probable outputs of each technology combination (only carried out if building energy load profiles are not known by the user)
- 5) Compare and analyse technologies or combination of technologies to facilitate the selection of the appropriate option.

The outputs consist of a technical analysis, economic analysis and environmental analysis and a price tag on the emissions savings (£/kgCO<sub>2</sub> saved). The computer tool can therefore be used to compare several combinations of renewable energy/CHP technologies and provide project energy managers with required technical, economical and environmental data to facilitate making vital long term investment decisions.

To test the computer tool and its accuracy, a case study was used to run the tool and was compared to sample manual calculations of the tools calculation procedures. The example building with a total floor area of 1750m<sup>2</sup> consisted of three clusters of 5

two-bedroom flats of 100m<sup>2</sup> each, 15 one-bedroom flats of 50m<sup>2</sup> each, and 500m<sup>2</sup> of office space with occupancy capacity of 50 people. Three main technologies were considered in different combinations: combined heat and power, solar thermal collectors for hot water and photovoltaic panels for electricity generation.

Depending on the overriding objectives of a project, usually two scenarios are presented: a) maximising return on investment (i.e., short payback period) or b) reducing CO<sub>2</sub> emission at the expense of higher capital cost and longer payback period. Hence, it was concluded that if the project is driven by the cost of energy generation, then using Combined Heat and Power in combination with a back up boiler and grid electricity would make the best investment returns. If the reduction of CO<sub>2</sub> emissions is more important, then the option of incorporating renewables with or without CHP would be a more attractive proposition. However, the option of incorporating renewables and CHP would offer the better solutions if both cost of energy generation and CO<sub>2</sub> emissions are important.

## Acknowledgements

I dedicate this thesis to my daughter Yasmeen.

I would like to express my gratitude to a number of people whom without their support this thesis would not have made it to the finishing line. First, I would like to thank my supervisor Dr. Rabah Boukhanouf for his help, support and guidance. I would also like to thank Dr. Prince Doherty for his supervision in the first part of my PhD. Many thanks also go to Dr. Andrew Cripps and Brian Doran from Buro Happold for their supervision throughout the PhD.

I would like to thank the EPSRC, the INREB Faraday Partnership and Buro Happold for their financial support. Thank you also to Buro Happold Manchester office the School of the Built Environment their support throughout this PhD.

Many thanks go to my family for being there for me when I needed them most and for their understanding and encouragement. Thank you especially to my husband and my parents for their patience, help and support throughout my studies.

# Table of Contents

<b>Abstract</b> .....	<b>i</b>
<b>Acknowledgement</b> .....	<b>iv</b>
<b>Table of Contents</b> .....	<b>v</b>
<b>List of Figures</b> .....	<b>vii</b>
<b>List of Tables</b> .....	<b>xiii</b>
<b>Nomenclature</b> .....	<b>xiv</b>
<b>Chapter 1 Introduction</b> .....	<b>1</b>
<b>Chapter 2: Literature Review</b> .....	<b>3</b>
2.1 BACKGROUND .....	3
2.2 UK AND EU POLICIES .....	13
2.2.1 Policies on Renewables.....	13
2.2.2 Policies on CHP .....	18
2.3 COMBINED HEAT AND POWER (CHP).....	19
2.3.1 CHP technologies.....	21
2.3.2 CHP fuels .....	22
2.3.3 CHP Sizing.....	24
2.3.4 Current status of CHP in the UK.....	29
2.4 RENEWABLE ENERGY .....	32
2.4.1 Solar thermal energy .....	37
2.4.2 Photovoltaics .....	49
2.4.3 Integration of PV and ST with CHP .....	57
2.5 ANALYSIS TOOLS AND THE DECISION MAKING PROCESS .....	58
2.5.1 Decision making process .....	58
2.5.2 Analysis tools .....	62
2.6 CONCLUSION .....	69
<b>Chapter 3: Energy Demand in Buildings</b> .....	<b>70</b>
3.1 BUILDING ENERGY LOAD PROFILES.....	74
3.1.1 Monte Carlo Method .....	76
3.1.2 Space heating load profiles .....	78
3.1.3 Electricity load profiles .....	78
3.1.4 Hot water load profiles.....	80
3.1.5 Conclusion .....	82
3.2 DHW DEMAND SURVEY IN RESIDENTIAL BUILDINGS.....	83
3.2.1 Survey Questionnaire .....	83
3.1.2 Monitoring Study .....	84
3.1.3 Load profile formation .....	87
3.3 CONCLUSION .....	89

<b>Chapter 4: Computer Simulation Tool Development.....</b>	<b>90</b>
4.1 INTRODUCTION .....	90
4.2 DESCRIPTION OF THE COMPUTER TOOL .....	90
4.2.1 BLOCK A: Determining the building loads and load profiles .....	91
4.2.2 BLOCK B: Technology combinations: sizing and financial and environmental appraisals.....	100
4.2.3 BLOCK C: Most Probable Options and their Comparison.....	134
4.3 CONCLUSION .....	137
<b>Chapter 5: Computer tool evaluation and results.....</b>	<b>138</b>
5.1 INTRODUCTION .....	138
5.2 SAMPLE CALCULATION .....	139
5.2.1 The Building loads .....	139
5.2.2 Supply of heat and electricity from a boiler and grid.....	145
5.2.3 Supply of heat and electricity from a CHP, boiler and grid.....	150
5.2.4 Supply of heat and electricity from ST, boiler and grid.....	161
5.2.5 Supply of heat and electricity from ST, CHP, boiler and grid.....	171
5.2.6 Supply of heat and electricity from PV, boiler and grid .....	179
5.2.7 Supply of heat and electricity from a CHP, PV, boiler and grid.....	189
5.2.8 Summary of outputs .....	197
5.3 TOOL EVALUATION PROCEDURE .....	198
5.3.1 The Building loads .....	198
5.3.2 Evaluation of a combination of Grid, boiler, CHP and solar thermal collector systems using ST tool .....	202
5.3.3 Evaluation of a combination of Grid, Boiler, CHP and Photovoltaic panels using the PV tool.....	212
5.4 LIMITATIONS OF THE COMPUTER TOOL.....	219
5.5 DISCUSSION AND CONCLUSION.....	220
<b>Chapter 6: Conclusion and Suggestions for Future Work.....</b>	<b>223</b>
6.1 GENERAL CONCLUSIONS .....	223
6.1.1 Complexity of building load profiles/patterns .....	224
6.1.2 Hot water demand profiles .....	225
6.1.3 The computer Tool.....	226
6.1.4 The case study .....	227
6.2 CONTRIBUTION TO KNOWLEDGE AND ORIGINALITY .....	228
6.3 RECOMMENDATIONS FOR FUTURE WORK .....	229
<b>References .....</b>	<b>231</b>
<b>Appendix: Domestic hot water demand survey.....</b>	<b>245</b>

## List of Figures

Figure 2.1 UK Final Energy Consumption, by Fuel, 1970 to 2005 (BERR 2007) ....	4
Figure 2.2 UK energy prices (Eurostat 2007) .....	4
Figure 2.3 Energy Sources [adapted from Chapman 1989] .....	5
Figure 2.4 Typical costs for electricity generation (Gross et. al. 2003) .....	6
Figure 2.5 UK Use of Fuels in 2006 (BERR 2007) .....	6
Figure 2.6 European primary energy production in 2005 (Eurostat 2007) .....	7
Figure 2.7 European energy production and consumption in 2005 (Eurostat 2007) .....	8
Figure 2.8 European renewable energy production and consumption in 2005 (Eurostat 2007) .....	9
Figure 2.9 Cost of carbon reduction of mitigation technologies in the power generation sector compared to gas-fired power stations (Sims et. al. 2003) .....	10
Figure 2.10 Integrating Energy Technologies with Buildings .....	11
Figure 2.11 UK electricity mix in 2006 (DTI 2007) .....	16
Figure 2.12 Energy flow diagram – CHP vs conventional system (Carbon Trust 2004) .....	20
Figure 2.13 CHP range.....	21
Figure 2.14 CHP use of Fuels in the UK (BERR 2007) .....	23
Figure 2.15 CHP capacity in the UK (BERR 2007) .....	30
Figure 2.16 Number of CHP installations in the UK (BERR 2007) .....	30
Figure 2.17 UK heat demand vs total UK CHP output (BERR 2007) .....	31
Figure 2.18 Renewable sources used to generate electricity and heat in the UK (BERR 2007) .....	33
Figure 2.19 Use of renewable sources in 2006 in the UK (BERR 2007) .....	34
Figure 2.20 Use of renewables to generate electricity and heat in 2006 in the UK (BERR 2007) .....	34
Figure 2.21 Prediction of renewable energy contribution to the World energy supply (EREC 2004) .....	35
Figure 2.22 Mean solar irradiation on a horizontal surface – London area (CIBSE 2006) .....	38
Figure 2.23 Indirect water heating system (Kalogirou 2004) .....	42
Figure 2.24 Shares of the European solar thermal market (ESTIF 2007).....	46
Figure 2.25 Total solar thermal collectors in operation in 2006 (ESTIF 2007).....	46
Figure 2.26 Solar thermal system market growth 2005/2006 (ESTIF 2007).....	47



Figure 2.27 Installed PV power in the IEA PVPS reporting countries (IEA 2007)	.54
Figure 2.28 UK installed PV power (IEA 2007)	.....54
Figure 2.29 European installed PV power by country in 2006 (IEA 2007)	.....55
Figure 2.30 Interest groups in decision-making (Alanne 2003)	.....59
Figure 2.31 Choosing appropriate technologies.....	59
Figure 2.32 Initial ideas about selecting renewables and CHP for buildings	.....60
Figure 2.33 Schematic of the decision analysis process (Huang et. al. 1995)	.....60
Figure 3.1 UK domestic energy consumption by end use (Utley et. al. 2006)	.....71
Figure 3.2 UK energy use per household (Utley et. al. 2006)	.....71
Figure 3.3 Annual delivered energy consumption for different office types (kWh/m <sup>2</sup> ) (BRECSU 2000)	.....72
Figure 3.4 Actual national grid summer and winter demand for 2002 (National Grid Group 2004)	.....79
Figure 3.5 Typical weekly electricity consumption for an office building (Nottingham City Council 2004)	.....79
Figure 3.6 UK residential hot water profiles (CIBSE 2004, Everett et. al. 1985)	...81
Figure 3.7 US residential hot water demand profiles (ASHRAE 1999, Wiehagen et. al. 2003, USDE 2000, Goldner 1994, Lutz et. al. 1996)	.....82
Figure 3.8 Temperature sensor.....	86
Figure 3.9 Example temperature sensors reading	.....86
Figure 3.10 Example Hot Water Load Profile for 3 different weekdays for a semi-detached house	.....88
Figure 3.11 Screenshot of the tool's hot water load profile database	.....88
Figure 4.1 Block A - Building loads and load profiles	.....92
Figure 4.2 User interface start window	.....93
Figure 4.3 Rules of Thumb user interface.....	94
Figure 4.4 Load profile selection interface window	.....96
Figure 4.5 Load Profile input interface window	.....97
Figure 4.6 Loads output interface window	.....99
Figure 4.7 Block B –Technology combinations flow chart	.....102
Figure 4.8 Block B1: Boiler + EGrid	.....103
Figure 4.9 Outputs parameters of block B1: Boiler and Grid (Boiler + EGrid)	....104
Figure 4.10 Boiler installed capital costs (EST 2006, University of Strathclyde 2006)	.....105
Figure 4.11 Boiler and Grid Costs and Emissions	.....106
Figure 4.12 Block B2: CHP	.....111
Figure 4.13: CHP, Boiler and Grid Sizing Outputs interface	.....115

Figure 4.14 Installed CHP capital costs (EST 2006, University of Strathclyde 2006) .....	115
Figure 4.15: CHP and boiler costs interface .....	116
Figure 4.16: Block B3a – PV .....	117
Figure 4.17: Block B3b – ST .....	117
Figure 4.18 Variation of PV panel area with cost of CO <sub>2</sub> saved.....	120
Figure 4.19 PV sizing options.....	121
Figure 4.20 Entering maximum array area available .....	121
Figure 4.21 Optimum size of PV with CHP+Boiler+Grid.....	122
Figure 4.22 PV + Boiler + Grid Outputs.....	123
Figure 4.23 PV lifetime and costs .....	124
Figure 4.24 Installed PV costs (Faber Maunsell 2003, EST 2006, DTI 2006, IEA 2003, IEA 2006) .....	124
Figure 4.25 PV+CHP+Boiler+Grid Outputs.....	125
Figure 4.26 PV costs and lifetime .....	125
Figure 4.27 Optimum ST collector size .....	129
Figure 4.28 ST sizing options .....	129
Figure 4.29 Yearly energy demand distribution for example building.....	130
Figure 4.30 ST+Boiler+Grid Outputs .....	131
Figure 4.31: ST+Boiler lifetime & costs.....	131
Figure 4.32: ST+CHP Outputs.....	133
Figure 4.33: ST+CHP+Boiler lifetime & costs.....	133
Figure 4.34 Block C – Most probable options and their comparison .....	134
Figure 4.35: PV Tool Option Comparison.....	135
Figure 4.36: ST Tool Option Comparison .....	135
Figure 4.37: Option outputs spreadsheet.....	137
Figure 5.1 RoT building energy loads summary.....	140
Figure 5.2 Hourly hot water demands for a typical January weekday and weekend day .....	141
Figure 5.3 Hourly space heating demands for a typical January weekday and weekend day .....	142
Figure 5.4 Hourly hot water demands for a typical January weekday and weekend day.....	143
Figure 5.5 Daily building energy load profiles summary .....	144
Figure 5.6 Monthly building energy loads and monthly load factors .....	144
Figure 5.7 Boiler sizing spreadsheet .....	145
Figure 5.8 Boiler costs spreadsheet.....	146

Figure 5.9 Hourly CHP simulations for a typical day in January .....	152
Figure 5.10 CHP annual outputs and Boiler + Grid sizing .....	154
Figure 5.11 CHP, boiler and Grid costs and emissions .....	156
Figure 5.12 ST simulation for a typical July day .....	162
Figure 5.13 ST sizing .....	162
Figure 5.14 Boiler sizing and grid demand for ST+Boiler+grid option .....	165
Figure 5.15 Costs and emissions for ST+Boiler+Grid option .....	167
Figure 5.16 July day simulation of ST system.....	172
Figure 5.17 July day hourly CHP simulation for ST+CHP+boiler+grid option.....	173
Figure 5.18 Boiler and grid sizing for ST+CHP+boiler+grid option.....	173
Figure 5.19 Costs and emissions for ST+CHP+boiler+grid option .....	174
Figure 5.20 Hourly PV simulation for a typical January day .....	181
Figure 5.21 PV sizing.....	182
Figure 5.22 Boiler sizing for PV+boiler+grid option .....	183
Figure 5.23 Costs and emissions for PV+boiler+grid option.....	185
Figure 5.24 Hourly PV simulation for a typical January day .....	189
Figure 5.25 PV sizing for CHP+PV+boiler+grid option .....	190
Figure 5.26 Boiler and grid sizes for CHP+PV+boiler+grid option.....	191
Figure 5.27 Cost and emissions for CHP+PV+boiler+grid option .....	193
Figure 5.28 Start interface.....	198
Figure 5.29a Entering details for 2 bedroom flats residential building.....	199
Figure 5.29b Entering details for 1 bedroom flats residential building .....	199
Figure 5.29c Entering details for office type building .....	200
Figure 5.30 User interface window for load profile selection .....	201
Figure 5.31 Calculation of building Loads .....	201
Figure 5.32 Boiler+EGrid sizes .....	202
Figure 5.33 Costs for Boiler+Grid option.....	202
Figure 5.34 CHP+Boiler+EGrid case .....	203
Figure 5.35 Costs for CHP+Boiler+Grid case .....	204
Figure 5.36 selecting a limiting factor in the sizing of solar thermal collectors.....	205
Figure 5.37 Costs for ST+Boiler+Grid option .....	205
Figure 5.38 Technology sizes for ST+Boiler+Grid option.....	206
Figure 5.39 Costs for ST+CHP+Boiler+Grid option.....	207
Figure 5.40 Sizes of technologies for ST+CHP+Boiler+Grid .....	207
Figure 5.41 System energy costs for each technology combination.....	209

Figure 5.42 Emissions for each technology combination .....	209
Figure 5.43 Emissions reduction for each technology combination .....	209
Figure 5.44 Cost of emission savings for each technology combination.....	210
Figure 5.45 Summary of outputs and option comparison with MCM .....	210
Figure 5.46 Summary of outputs and option comparison without MCM.....	211
Figure 5.47 Selecting a limiting factor for sizing PV .....	212
Figure 5.48 Operating Costs for PV+Boiler+EGrid option .....	213
Figure 5.49 Sizes of technologies for PV+Boiler+EGrid option .....	213
Figure 5.50 Costs for PV+CHP+Boiler+EGrid option .....	214
Figure 5.51 Sizes of technologies for PV+CHP+Boiler+EGrid option .....	214
Figure 5.52 System energy costs for each technology combination.....	216
Figure 5.53 Emissions for each technology combination .....	216
Figure 5.54 Emissions reduction for each technology combination .....	216
Figure 5.55 Cost of emission savings for each technology combination.....	217
Figure 5.56 Summary of outputs and option comparison with MCM .....	217
Figure 5.57 Summary of outputs and option comparison without MCM.....	218

## List of Tables

Table 2.1 CHP case studies (Carbon Trust 2004, Van der Horst 2005) .....	32
Table 2.2 Global renewable energy resources and output of installed renewables (Gross et. al. 2003) .....	35
Table 2.3 Environmental impact of renewable energy technologies (Ackermann et. al. 2002) .....	36
Table 2.4 Solar thermal collector case studies [(1) ESD 2005, (2) TV Energy 2008, (3) Faber Maunsell 2003, (4) European Commission 2008, (5) EST 2003] .....	48
Table 2.5 PV technology (Boyle 2004, EPIA et. al. 2001) .....	50
Table 2.6 UK Building Integrated PV case studies [(1) European Commission 2008, (2) IEA 2008, (3) EST 2003] .....	56
Table 3.1 Rules of Thumb Hot Water Demand (CIBSE 2004, BSRIA 2003, Institute of Plumbing 2002) .....	73
Table 3.2 Rules of Thumb Electricity Demand (Action Energy 2000, BSRIA 2003, Institute of Plumbing 2002) .....	73
Table 3.3 Rules of Thumb Space Heating Demand (BSRIA 2003) .....	73
Table 3.4 Occupancy and number of bedroom ranges.....	84
Table 3.5 Number of questionnaires completed for each building type .....	84
Table 3.6 Appliance hot water flow rates and usage [* data from Grant 2002] .....	87
Table 4.1 Building Energy Load Profile Data Sources.....	97
Table 4.2 Building energy load profile units .....	98
Table 4.3 Space heating and electricity load factors (Elexon 2006) .....	100
Table 4.4 Comparison of Options .....	112
Table 4.5 January demand vs supply for CHP .....	113
Table 4.6 Hourly PV simulations for a typical July day .....	119
Table 4.7 Example Costs of emissions savings for CHP and PV .....	122
Table 4.8 Hourly solar thermal system simulation for a typical July day.....	126
Table 4.9 Pump power estimates (Viessmann 2007) .....	128
Table 4.10 Installed solar thermal costs (Faber Mausell 2003, EST 2006) .....	132
Table 5.1 CHP sizing simulation output list .....	151
Table 5.2 Extract of optimisation table of ST with CHP .....	171

Table 5.3 Extract of PV size optimisation table .....	180
Table 5.4 Summary of outputs .....	197

## Nomenclature

$A_{sc}$	Collector area (m <sup>2</sup> )
$A_f$	Floor area (m <sup>2</sup> )
$CC_{current}$	Current capital cost (£)
CCHP	Combined cooling heat and power
CCL	Climate Change Levy
$CC_{NPV}$	NPV capital cost (£)
$CC_{NPVreplacement}$	NPV replacement cost (£)
CHP	Combined heat and power
$C_{NPVtotal}$	Total NPV cost (£)
CO <sub>2</sub>	Carbon dioxide
$c_p$	specific heat capacity (J/gK)
$DC_{current}$	Current disposal cost (£)
DCF	Discounted cash flow
$DC_{NPV}$	NPV Disposal cost (£)
$D_e$	Electricity demand (kWh)
$D_{ep}$	Pump electricity consumption (kWh)
$D_g$	Gas demand (kWh)
$D_h$	Heat demand (kWh),
$D_{H,p}$	Peak heat demand (kW)
DR	Discount rate (%)
$EC_{boiler}$	Boiler system energy cost (p/kWh)
$EC_{EGrid}$	Electricity grid energy cost (p/kWh)
$E_{CO_2}$	CO <sub>2</sub> Emissions (kg CO <sub>2</sub> )
$EC_{system}$	System energy cost (p/kWh)
EETS	European Emissions Trading Scheme
$EF_e$	Electricity emission factor (kg CO <sub>2</sub> /kWh)
$EF_g$	Gas emission factor (kg CO <sub>2</sub> /kWh)
EGrid	National electricity grid
EPBD	European Energy Performance of Buildings Directive
ESC	System cost per emissions saved (£/kg CO <sub>2</sub> saved)

$F$	Factor related to the effectiveness of the heat transfer from the collector plate to the heat removal fluid
$f$	monthly factor to take into account the varying demand throughout the year
$f_E$	CO <sub>2</sub> emissions factor (kgCO <sub>2</sub> /kWh)
$FC_{current}$	Current annual fuel cost (£)
$FC_{NPV}$	NPV Fuel cost (£)
$FI$	Annual fuel input (kWh)
$H$	Number of operating hours (hours)
$I_s$	Incident solar radiation normal to the collector (kWh/m <sup>2</sup> )
kW	Kilowatt
kWh	Kilowatt hour
kW <sub>th</sub>	Kilowatt thermal
l	litres
$(I - L)$	efficiency of the power conditioner, transformer, interconnection (%)
m <sup>2</sup>	square meters
$MC_{current}$	Current annual maintenance cost (£)
$MC_{NPV}$	NPV Maintenance cost (£)
$n$	Project lifetime (years)
NPV	Net present value
$O$	Output (kWh)
$O_A$	Annual output (kWh)
$O_L$	Lifetime output (kWh)
$O_{NPV}$	NPV output (kWh)
$P_p$	Pump power rating (kW)
PV	Photovoltaics
$Q$	Useful heat collected per unit area (W/m <sup>2</sup> )
$Q_E$	Energy (J)
$Q_{sc}$	Collector output rating (kWh)
RET	Renewable energy technologies
ROC	Renewables Obligation Certificate
RoT	Rules of thumb
$S_b$	Boiler size (kW)
$S_{PV}$	PV size (m <sub>2</sub> )



ST	Solar thermal system
$T_a$	Ambient temperature ( $^{\circ}\text{C}$ )
$T_m$	Average collector temperature ( $^{\circ}\text{C}$ )
U	Heat loss coefficient ( $\text{W}/\text{m}^2\text{K}$ )
VBA	Visual Basic for Application
WD	Weekday
WE	Weekend day
$\Delta T$	Temperature difference (K)
$\eta_b$	Gross boiler efficiency (%)
$\eta_{PV}$	Efficiency of the PV cells (%)
$\eta_{sc}$	Collector efficiency (%)
$(\tau\alpha)$	Transmittance-absorptance product

## **Chapter 1:**

### **Introduction**

The use of renewable energy technologies and CHP in the built environment is becoming increasingly more important. However the initial design of renewable energy (RE) and CHP systems tends to be more complicated and time consuming than the design of traditional energy systems. As opposed to “conventional” fossil fuelled energy systems, the sizing of renewable energy and CHP systems energy requires building energy load profiles, which however are not easily predicted.

The main objectives of this study are:

- To develop a computer tool to enable suitable combinations of renewable energy technologies and combined heat and power (CHP) systems to be selected for a building. The tool optimises the integration of the combined technologies for the supply of electricity, space heating and hot water to different building types and helps in the selection of the more appropriate technologies. The Monte Carlo Method (MCM) is used to take into account the uncertainty of load profiles in the computer tool to give most probable sizes and costs of different technology combinations.
- To conduct a survey to collect domestic hot water demand profiles for residential buildings.

Chapter 2 describes the background and literature review to this PhD study. CHP and solar thermal and PV technologies are discussed, along with their sizing procedures and the relevant policies for CHP and RETs. Analysis tools and the decision making process in selecting appropriate technologies are also reviewed in this chapter. The review shows that there is not a tool currently available that selects suitable combinations of CHP and RETs for a project, taking into account the uncertainty of building energy load profiles using the MCM.

Chapters 3 discusses the importance of building energy load profiles for the sizing of RETs and CHP technologies; and the Monte Carlo Method is presented as a method to take into account the uncertainties of load profiles. Load profile data was collected to form a database to be used in the computer tool and a hot water demand survey was carried out to collect profile data for residential buildings.

Chapter 4 describes the methodology and the outline of the tool developed in this PhD study. The tool is being programmed using Visual Basic for Applications in Excel. Excel was selected, because it is widely available for designers and used with most Windows based applications.

Chapter 5: The developed computer tool is tested by carrying out a sample calculation and using the tool to simulate a number of possible scenarios of CHP/RET integration for an example mixed office and residential use building. The results from this example are analysed and the tool's advantages and limitations are discussed.

Chapter 6 presents the conclusions of the study and recommendations for further work.

## **Chapter 2:**

### **Literature Review**

#### **2.1 BACKGROUND**

*“The nature and pattern of our built environment both shapes and is shaped by energy issues”* (RICS Foundation 2004)

Buildings have energy demands in the form of electrical power, heat, and cooling. Traditionally, these are provided separately by the national electricity grid, boilers and air-conditioning systems respectively which are predominantly fuelled by fossil fuels. Fossil fuels constitute the main part of the UK primary energy supply and their overall consumption has increased over the years as shown in Figure 2.1. It can also be seen that there is a marked decrease in the use of coal and an increase of energy produced by natural gas and oil over this same period as a result of the UK government’s policy on climate change and pollution control.

The increasing demand for fossil fuels worldwide not only has the effect of releasing CO<sub>2</sub> and other emissions in large quantities, which result in environmental pollution and global warming, but also accelerates the depletion rate of these resources (IPCC 2001). There is a strong consensus among energy producers and researchers that fossil fuel supplies could be peaking, with the likelihood of a shortage of supplies in the near future (Salameh 2003). This has been demonstrated recently by a substantial

increase in the prices of oil and gas with negative effect on the world economy (see Figure 2.2).




Figure 2.1 UK Final Energy Consumption, by Fuel, 1970 to 2005 (BERR 2007)





Figure 2.2 UK energy prices (Eurostat 2007)

Alternative energy sources will therefore need to be developed to satisfy future energy demand. Renewable energy sources could be exploited directly by converting solar radiation or water power into electrical power or indirectly through the use of hydrogen as fuel. Figure 2.3 summarises some of the different energy sources available.




**Figure 2.3 Energy Sources** [adapted from Chapman (1989)]


Although the cost of generating power from renewables is currently higher than generating power from fossil fuels (see Figure 2.4), the increase in fossil fuels cost could play a major incentive in the push to developing more sustainable processes and technologies. However, government policies and mechanisms encouraged by agreements such as the Kyoto Protocol (UNFCCC 1997) are the key to achieving this transition.

Figure 2.5 shows that domestic buildings are the second biggest energy users in the UK after the transport sector, with 29% and 37% respectively. The need to reduce

CO<sub>2</sub> emissions from buildings is therefore essential if the UK is to meet its target outlined in its Energy White Paper to reduce CO<sub>2</sub> emissions by 60% below the 1990 level of 584 million tonnes by the year 2050 (DTI 2003, Office for National Statistics 2007).




**Figure 2.4 Typical costs for electricity generation** (Gross et. al. 2003)



**Figure 2.5 UK Use of Fuels in 2006** (BERR 2007)

The reduction of CO<sub>2</sub> emissions of buildings can be achieved by using energy efficient appliances, management of energy demand side, and introducing higher building regulation standards such as air tightness, level of thermal insulation, on-site renewable energy generation, etc...(Chwieduk 2003).

The efficient use of fossil fuels and renewable energy systems should be a prime concern in the supply of energy to buildings. The UK produced the largest amount of energy in Europe after Norway in 2005 which is a result of oil exploration from the North Sea (Figure 2.6). It can also be seen from Figure 2.6 that the share of renewables remains relatively small in most countries of the European Union (EU).




**Figure 2.6 European primary energy production in 2005** (Eurostat 2007)

Figure 2.7 shows that not all the energy consumed was also produced in the same country. With the exception of Norway all other EU countries are net importers of energy, mainly oil and gas.

Figure 2.8 shows that there is a substantial effort being made to generate power from renewables in all EU countries. Although the UK is one of the largest energy producers and consumers in the EU, its share of energy production from renewable




sources was one of the lowest. Germany, France and Sweden have the highest proportion of energy produced from renewable sources. Figure 2.8 also suggests that most of the renewable energy produced in each country tends to be used nationally.



**Figure 2.7 European energy production and consumption in 2005** (Eurostat 2007)


Sims et. al. (2003) compared the carbon emissions and mitigation costs from electricity generation and showed that there were alternative ways of generating electricity cost-effectively combined with carbon emission reduction. The comparison was made between standard gas or coal fired power stations and more efficient power generation from fossil fuels, the use of renewable energy or nuclear power and the capture and disposal of CO<sub>2</sub>. Figure 2.9 shows the average cost of carbon reduction (\$/t Carbon avoided) of some of these technologies. However the choice of technologies in terms of cost savings and carbon emission reductions is site

and application specific. Sims et. al. (2003) stated that through the application of some of these technologies the global energy sector has the potential to reduce carbon emissions by 8.7-18.7% by 2020 compared to 27 136 Mt of CO<sub>2</sub> emissions in 2003 (IEA 2007).



**Figure 2.8 European renewable energy production and consumption in 2005** (Eurostat 2007)


Sims (2004) considers how placing a value on carbon emissions could help the adoption of renewable energy technologies to reduce the effect of climate change. External costs (the associated cost to the environment and health) are not usually taken into account when comparing the costs of energy systems. However if taxes are enforced to take into account external costs, renewable energy technologies are likely to become economically more viable.



**Figure 2.9 Cost of carbon reduction of mitigation technologies in the power generation sector compared to gas-fired power stations (Sims et. al. 2003)**

Given that a large proportion of energy consumption is in buildings, Figure 2.10 shows methods of integration of energy technologies in buildings, either direct as stand alone systems, through community grids or via the national grid.

Integrated into buildings, renewable energy and combined heat and power (CHP) technologies could be used to reduce the CO<sub>2</sub> emissions of buildings. Watson (2004) discusses that payback periods for micro-generation are usually too long for most energy companies. However, payback periods could be more acceptable to consumers having to replace their existing energy technology, such as replacing a faulty boiler with a micro-CHP system for example. This research work focuses on the direct integration of renewables and CHP with buildings with any surplus electricity production being exported to the national electricity grid. However large scale electricity export to the national electricity grid results in a variety of issues that require careful consideration.



**Figure 2.10 Integrating Energy Technologies with Buildings**

Renewables and CHP can make a contribution to the security of electricity supply by diversifying the electricity mix (DTI 2007). Wu et. al. (2004) investigated the impact of CHP and renewables on the UK transmission network, distribution network, central generating system and regulatory policy. The conclusion was that the UK national electricity grid could accommodate the Government’s targets of 10% renewables and 10GWe CHP by 2010. However in order to achieve this, modifications to the distribution grid and to the regulatory framework would be required.

Currently, large “central power stations” feed directly into the national high voltage grid. In the case of smaller systems, electricity system operators need to consider intermittency, decentralisation of generation, and remoteness of some generation options associated with renewables. Most renewable generation is intermittent and relatively unpredictable. As more renewable energy is utilised intermittency becomes more of an issue. Additional storage and upgrading of transmission lines would be

required as renewables generation increases. However, others have undertaken studies to investigate various options that could be applied to enable the smooth integration and increased uptake of renewables and CHP into the national energy supply system (Wu et. al. 2004).

Decentralised energy systems are usually in close proximity to the demand, supplying power directly to local distribution networks and therefore requiring careful management of local networks. Decentralised energy systems require a strong local grid and centralised energy systems require a strong national (transmission) grid. Since national transmission grids are of higher voltages than local grids, the use of decentralised energy systems could therefore avoid large losses associated with transmission grids (Lund et. al. 2000) as well as avoiding reinforcements of the existing national transmission grid.

Abu-Sharkh et. al. (2005) investigated the viability of microgrids consisting of Micro-CHP and PV in the UK. They concluded such microgrids could avoid the need to replace coal and nuclear power stations and reduce the demand on the transmission and distribution network by being independent of the national electricity grid. This conclusion was also reported by Voorspools et al (2002) who investigated small CHP for residential applications. They concluded that careful planning of such systems can reduce the need to expand the national electricity grid.

This PhD study considers the application of building integrated CHP and renewable energy systems. The immediate proximity of the energy source to the energy demand avoids transmission losses and the on site use of energy avoids major reinforcements of the national grid. However, decentralised micro energy systems such as micro-CHP and renewables could result in increased variations of the national grid load

profile which might as previously discussed, result in a need to upgrade existing transmission lines. This could compromise overall carbon savings if not integrated in national energy policies (Peacock et. al. 2006).

## **2.2 UK AND EU POLICIES**

### **2.2.1 Policies on Renewables**

Christiansen (2002) showed the important link between public policies and the development of new and renewable energy systems. EREC (2004) considered how different policies can lead to the consideration of different renewable energy scenarios. Both studies showed that a minimal employment of renewable energy was mainly the result of weak demand-side policies, changes in public priorities and low electricity prices.

Goldemberg et. al. (2004) examined how adequate policies can be used to encourage the introduction of renewables, taking Brazil as a case study. Cosmi et. al. (2003) advised the use of suitable price mechanisms, regulatory instruments and informative campaigns to promote technology innovation and a larger use of renewable energy. Meyer (2003) argued that in European countries at present, free trade is emphasised and this hinders the long term planning of sustainable energy development. Morthorst (2003) investigated national environmental targets and international emission reduction instruments for the introduction of renewable energy. He concluded that a closely coordinated combination of an international tradable permit market and a green certificate market could achieve national greenhouse gas reduction targets. Options to support the development of renewable energy include:

public funding for R&D and dissemination programmes, public procurement, direct state subsidy, fiscal incentives, and statutory obligations on electricity suppliers (Gross et. al. 2003).

Kwant (2003) investigated the policies and instruments in The Netherlands, and concluded that renewable energy trading in a European market requires European harmonisation of energy policies. The European Directive on the promotion of electricity produced from renewable energy sources in the internal electricity market (EC 2001) was developed as a basis for creating such a Community framework. The Commission's overall target is 22% of electricity from renewables by 2010. Under this directive each country is required to commit to an individual target for renewable energy. The UK's target is 10% of electricity from renewables by 2010. In conjunction with the target, guarantees of origin are issued to ensure the electricity is generated from eligible renewable energy sources. In the UK the 2003 Electricity Regulations have implemented the renewable energy guarantees of origin (REGOs) that are issued by Ofgem (electricity and gas markets regulators in the UK).

The UK government Energy White Paper (DTI (2007) outlines a long term energy strategy for the UK. Four objectives are outlined:


- i) A target of 60% CO<sub>2</sub> reduction by 2050 from 1990 figures, with real progress by 2020
- ii) Maintaining energy supplies reliability
- iii) Promoting competitive markets and improving productivity
- iv) Ensuring every home is adequately and affordably heated.

Programmes and mechanisms introduced in the UK, in conjunction with EU programmes for funding the development of low carbon energy technologies, include: direct government expenditure (such as R&D grants), legislative requirements for energy supply companies, allowances against mainstream taxation (such as enhanced capital allowances), and measures associated with the UK climate change levy (including the Emissions Trading Scheme). DTI (2004) reports the current UK renewables policy as consisting of the following four elements:

- i) The Renewables Obligation binds all electricity suppliers in the UK to supply a specific proportion of electricity produced by renewable sources. The aim is to increase this proportion to 10% by 2010 and to 15% by 2015.
- ii) Exemption from the Climate Change Levy (CCL) for electricity produced from renewables.
- iii) Expansion of the support programmes for new and renewable energy including capital grants and an expanded R&D programme.
- iv) Initiation of a regional strategic approach to planning and targets for renewables development.

Under the EU Climate Change Agreements the European Council agreed binding targets of 20% renewable energies in overall EU consumption and 20% reduction of greenhouse gas emissions by 2020 (DTI 2007). There has been an increase in the use of renewables in the UK (see Section 2.4), however the 10% target outlined in the Renewables Obligation has yet to be achieved (Figure 2.11). The Renewables Obligation can be met by suppliers by acquiring Renewable Obligation Certificates (ROCs), paying a buy out price of £34.30 per MWh (DTI 2007), or a combination of both.





**Figure 2.11 UK electricity mix in 2006 (DTI 2007)**

The CCL is a tax on the use of non-renewable energy in industry, commerce and the public sector. Renewable energy is therefore exempt from this tax.

The UK government launched its Microgeneration Strategy in 2006 to encourage microgeneration and make it a realistic option for households, communities and small businesses. The Strategy includes planning procedures adapted to encourage microgeneration, an accreditation scheme for installers and products and the Low Carbon Buildings Programme which provides grants for microgeneration technologies (IEA 2007). Total funding for new and renewable energy from 2002 to 2008 is £500 million. Grants for research and development are given under the Technology Programme and BERR's Grant for Research and Development to help businesses and individuals develop technologically innovative products and processes. This includes funding for new and renewable energy. Capital grants are available to fund demonstration projects to help reduce their costs and risks. The Capital Grants Scheme includes the Low Carbon Buildings Programme which provides grants for micro-generation technologies (BERR 2007).

Regional renewable energy targets are being set according to the regions' renewable energy potential and are to be reflected in the regional planning policies. The 'Merton Rule' sets a target of the use of onsite renewable energy to reduce annual CO<sub>2</sub> emissions for all new major developments by 10% and was first implemented in the London Borough of Merton (Merton Rule 2008). Other local authorities have followed and/or are expected to follow Merton's lead.

Anderson et. al. (2003), however, points out a lack of clarification of targets and mechanisms for implementing the UK government's strategies and a lack of sufficient detail on which policies would achieve the targets set in the 2003 Government White Paper. Other points noted were that the time-frame for change was limited, the impact of economic growth on energy consumption was not examined, and improvements in energy-efficiency and renewables uptake would not necessarily lead to reductions in energy demands and use of fossil fuels. Also, the national statistics of energy consumption, on which the Energy White Paper is based, did not account for emissions associated with imported goods, and there is a need for regulations to be set that require all sectors to achieve absolute emissions reductions. Anderson et. al. (2003) also suggested that other issues in the White Paper were open for discussion and therefore inhibit the momentum of change. For example, although the White Paper announced a tightening of building regulations, this does not include energy efficiency improvements on existing building stock, which account for a large amount of emissions.

Wordsworth et. al. (2003) carried out an analysis on the UK government energy-efficiency programmes and concluded that although most programmes were cost effective, supply side measures were reliant on future cost reduction of technologies.

However, the study also reported that as most programmes had not been in place for long it was therefore too early to fully assess their effectiveness.

Shackley (2007) outlined other policies that could encourage the use of renewable and CHP in the UK. As well as the government policies outlined above they included the EU Emissions Trading Scheme, a target for installation of 10GWe CHP capacity by 2010, the Energy Efficiency Commitment, the Carbon Abatement Technologies Strategy, and increased RD&D into low- and zero-carbon technologies.

### **2.2.2 Policies on CHP**

The European Directive 2004/8/EC (EC 2004) and the UK governments Carbon Emission Reduction Target 2008-11 aim to promote and develop Good Quality CHP in the European internal energy market, taking into account national climatic and economic circumstances. Member states are advised to support and encourage CHP along with other energy saving measures. Cogeneration units should be developed to match economically justifiable demands for useful heat output and barriers to the increase of cogeneration should be reduced. The EU Cogeneration Directive that came into force in 2004 aims to ensure grid access to small generators, and the removal of barriers to co-generation. The UK government developed their strategy for CHP (DEFRA 2004) and in 2000, a target of 10,000MWe of CHP capacity by 2010 was announced which was reaffirmed in the UK government Energy White Paper. The government's support for CHP includes fiscal incentives, grant support, and regulatory framework (DEFRA 2004). However, no clear policy instrument or mechanism was put in place to achieve the target (Shackley 2007) and in 2006 total CHP capacity was still at 5,549 MWe (BERR 2007).


Current UK Government incentives for Good Quality CHP are: Climate Change Levy Exemption, Enhanced Capital Allowances, reduction or exemption from Business Rating charges, and VAT reductions for domestic CHP. Langdon (2004) points out that regulatory policies that could increase the use of CHP include: CHP evaluation studies to be submitted with building planning applications, enforcement of the European Energy Performance of Buildings Directive (EPBD), and enforcing the European Emissions Trading Scheme (EETS). Evaluation studies are already required to be submitted along with planning applications by some local authority planning departments. Building regulations encourage low carbon technologies such as CHP. Under the EPBD, CHP systems and decentralised energy supply systems need to be considered for new buildings and refurbishments with floor areas in excess of 1000m<sup>2</sup>. The EETS is intended to reduce carbon emissions from EU industry. This should encourage the use of CHP in industry and benefits could be passed down to customers, as decentralised systems become more viable.

### **2.3 COMBINED HEAT AND POWER (CHP)**

*“Combined Heat and Power (CHP), also known as cogeneration, is the name applied to processes which from a single stream of fuel simultaneously generate heat and power.” (CIBSE 1999)*

Haworth et. al. (2004) described the history of CHP and stated that the technology has been proven for some time. However, continual low electricity prices have hindered its widespread adoption. As electricity prices increase, CHP will become more financially viable.

CHP can offer environmental improvements, power supply security, and higher efficiencies of 70-90% compared to conventional energy systems that usually have delivered energy efficiencies of 30-45% when producing electricity (Figure 2.12). Higher efficiencies result in reduced overall primary energy consumption and carbon emissions (Hargreaves 2004).



**Figure 2.12 Energy flow diagram – CHP vs conventional system** (Carbon Trust 2004)


Jacket water cooling and engine cooling systems can recover approximately 50% of the energy content of the fuel in CHP systems. This results in an overall system efficiency of 70-80%. Using a condensing heat exchanger, a further 10% can be recovered from the exhaust gases and therefore increase efficiencies to around 90% (Langdon 2004).

Martens (1998) discusses that CHP efficiencies, especially thermal efficiencies are influenced by the application of the system and in some applications separate heat and power production can have a higher overall efficiency than a CHP system. For example, electricity production by combined cycle plants (efficiency > 50%) and

heat production by high efficiency boilers (efficiency > 90%) could lead to higher overall efficiencies than some CHP installations.

### 2.3.1 CHP technologies

The range of CHP that is available is shown in Figure 2.13. Hargreaves (2004) describes the different CHP technologies.

CHP types    Application areas	<ul style="list-style-type: none"> <li>•Fuel Cells (Solid Oxide)</li> <li>•Fuel Cells (Proton Exchange Membrane)</li> <li>•Internal Combustion Engines</li> </ul>	<ul style="list-style-type: none"> <li>•Spark Ignition Engines</li> <li>•Micro-Turbines</li> <li>•Small Scale Gas Turbines</li> </ul>	<ul style="list-style-type: none"> <li>•Large Reciprocating Engines</li> <li>•Large Gas Turbines</li> </ul>
	<b>Micro CHP</b> (up to 5 kWe)	<b>Small scale CHP</b> (below 2 MWe)	<b>Large scale CHP</b> (above 2 MWe)
	<ul style="list-style-type: none"> <li>•small groups of dwellings</li> <li>•small commercial buildings</li> <li>•individual domestic buildings</li> </ul>	<ul style="list-style-type: none"> <li>•hospitals</li> <li>•hotels</li> <li>•leisure centres</li> <li>•universities</li> <li>•residential buildings.</li> </ul>	<ul style="list-style-type: none"> <li>•community heating schemes</li> <li>•large sites comprising of several buildings</li> </ul>

**Figure 2.13 CHP range**

Traditional prime movers of CHP units are reciprocating engines or gas turbines. Small-scale CHP usually are packaged units with a spark ignition reciprocating engine driving a synchronous electric generator.

Large scale CHP are usually gas turbines that run on either gas or light oil. The rotation of the turbine drives the generator. High exhaust temperatures make this type of CHP especially applicable for high grade heat supply.

Packaged Stirling engine micro-CHP units, such as the Microgen unit now commercially available in the UK, are an alternative to reciprocating engine CHP and are more suited to domestic applications. EST (2001) claim that micro-CHP can achieve energy savings of 30% in a domestic application and that installed micro-CHP capacity could be of 15-20 GW in the UK.


In the UK, fuel cells for CHP are currently at the demonstration stage. However these systems are showing considerable potential, since they have higher electrical efficiencies, reduced CO<sub>2</sub> emissions and they operate without combustion (Langdon 2004). An example of research in this area is a co-generation system with direct internal reforming-molten carbonate fuel cell for residential use developed by Sugiura et. al. (2002).

### **2.3.2 CHP fuels**

Natural gas is the most common fuel used for CHP in the UK (Figure 2.14). However, renewable energy sources and other fuel sources, such as biomass and hydrogen, are much “cleaner” forms of energy to power CHP systems.

“Biofuels” such as wood burned for heating were the first fuels used by mankind. They are still the most commonly used form of renewable energy in the world (Figure 2.18) and can also be used to power CHP systems.

Biomass powered CHP is a well established technology in countries such as Finland, Denmark and Sweden (OPET 2004). In the UK, a tree cuttings fuelled biomass CHP plant is installed at ‘BedZED’, a zero emissions mixed-housing development in Beddington (Van der Horst 2005).



**Figure 2.14 CHP use of Fuels in the UK (BERR 2007)**

Arbon (2002) discussed that the replacement of fossil fuels with biomass is to be encouraged and the UK is focussing on biomass as one of the areas for intensive R&D studies in the near future. Van der Horst (2005) however argues that the biomass energy sector has not been supported to its fullest potential in the UK.

Hydrogen is considered an ‘energy carrier’ and could be used to store renewable energy (Boyle 2004). Hydrogen can also be used in fuel cell CHP systems that convert chemical energy into electrical energy with no emissions associated with it (Sugiura 2002).

Elam et. al. (2003) described the International Energy Agency’s efforts to advance hydrogen energy technologies, with a vision of hydrogen playing a key role in all sectors of the economy. Winter (2003) discussed this build-up of the hydrogen-based energy market in the industrial North Rhine-Wesfalen region of Germany, where in



2003, 13 stationary fuel cells were in place. These were supported by their 3-year fuel cell programme 2001-03, which aimed at developing hydrogen production, storage, transport, and utilisation technologies.

Wallmark et al (2003) investigated the application of a stand-alone PEFC for buildings in Sweden. However, they concluded that the fuel cell system is not currently economically viable. Mc Ilveen-Wright et al (2003) came to a similar conclusion in their investigation of wood-fired fuel cell applications in a hospital, a leisure centre, a multi-residential community and a university hall of residence. They concluded that expectant capital costs would not make the systems viable for general use. However they could be more cost effective in rural applications where transport cost for other fuels are high and there is no electricity grid.

### **2.3.3 CHP Sizing**

CHP is not applicable to all situations and its suitability to a project needs to be checked. For example, Boait et. al. (2006) concluded that micro-CHP in residential applications is generally best suited to dwellings with higher heating loads such as a large detached house. Hawkes et al (2005) investigated the application of a solid oxide fuel cell CHP system for different UK dwelling sizes and also concluded that the system would be viable for large dwellings only. The applicability of CHP systems however is dependant on occupancy patterns and behaviours and can therefore vary from building to building.

A CHP system should operate for at least 5000 hours per year to be economically viable (Carbon Trust 2004) and is therefore not appropriate for every application. If this condition is met, the CHP system can be sized to match the electricity and/or

heat demands. For building applications, CHP usually replaces a boiler system and would therefore be sized on the base heat demand of the building, as this is generally the limiting factor (BRECSU 1996), with the electricity grid supplying any additional electricity to the building.

BRECSU (1997) outlined a simple financial appraisal tool, in the form of a spreadsheet, for potential CHP applications. It determines the suitability of a CHP system by calculating the payback period of the system using readily available information on energy use, fuel costs and operating conditions. A better method would be the discounted cash flow (DCF) method of financial appraisal to determine the net present value (NPV) of the project (Northcott 2002).

Optimum sizing and operation strategies are important to achieve maximum economic and environmental merits of the CHP system (Beihong et. al. 2006). Different methods are used to size CHP, some of which are described below.

Voorspools (2006) compared different CHP sizing strategies. The usual sizing method, maximising the output of a cogeneration unit for a given heat demand profile is compared to the options of 1- reduced-scale sizing: using a smaller CHP unit with higher usage and 2- partial-heat-usage sizing: using the same size CHP unit with increased usage (i.e. not using part of the heat). They found that both the reduced-scale sizing and the partial-heat-usage sizing methods could result in higher fuel and emission savings.

Hawkes (2007) investigates “heat-led”, “electricity-led” and “least-cost” operating strategies for Stirling engine, gas engine and solid oxide fuel cell micro-CHP technologies. It was shown that the commonly used heat-led strategy may not always

provide the minimum cost to meet the energy demand. The fuel cell system achieved minimum operating cost and minimum CO<sub>2</sub> emissions when following the least-cost operating strategy. For the Stirling and the gas engines, minimum CO<sub>2</sub> emissions did not coincide with least-cost, but were achieved with the heat-led operating strategy. The least-cost operating strategy is dependant on electricity buy-back prices. As buy-back prices increase, electricity-led operating strategies will become less important, as surplus electricity can be viably exported to the grid.

Utilisation time can be increased by using some of the heat from the CHP to power an absorption refrigeration system providing cooling for example for the refrigeration cabinets in a supermarket (Maidment et. al. 2002).

Seasonal storage can also increase the utilisation efficiency of a CHP system, by storing heat or coolth during periods of low utilisation for use during peak-demand periods. Tanaka et. al. (2000) simulated a district heating and cooling system with seasonal water thermal storage and found that when heating and cooling demands were well balanced the energy performance of the overall system was improved. Maidment et. al. (2000) described the viability of CHP in a typical cold storage application and presented a number of CHP configurations. They concluded that by using the heat produced from the CHP for absorption chillers to provide cooling to the chill store, the utilisation period was maximised. This made CHP economically attractive with a potential payback of around 4.5 years.

Cardona et. al. (2003) described a methodology for sizing trigeneration plants in hotels. Two management philosophies were compared in the paper: the thermal demand management and the primary energy saving management. The latter being the preferred method in the paper. This method achieves maximum energy savings

during the life cycle of the plant using a criterion based on previously obtained consumption data. The optimum size of the plant was found for the highest energetic and environmental benefits. However, this analysis did not include an economic assessment, which is often the main deciding factor for projects.

Silveira et. al. (2003) presented a thermo-economic analysis of cogeneration plants. This methodology analyses and improves the design of CHP, aiming for a minimum exergetic production cost.

Dentice d'Accadia et. al. (2003) carried out an analysis of a micro CHP system when used with household appliances and determined the optimum operation mode to match the user's electricity and thermal demands. The heat output is used fully in order to optimise the micro-CHP system and maximise the efficiency of the CHP system. Therefore the CHP was not only linked to the appliances, but also supplied heat to warm the ambient air or heat the domestic hot water.

One of the main deciding factors when sizing CHP is the economic viability of the system. Langdon (2004) summarises the variables determining the capital and operating costs of a CHP system:

- i) CHP should operate for at least 5000 hours per year to be economic (Carbon Trust 2004).
- ii) Energy demand profiles determine the size of the CHP unit and therefore the expected energy savings and associated cost savings can be determined.
- iii) Using the CHP for part or all of the standby capacity can reduce capital costs.
- iv) Government incentives and regulations can also affect the cost of the CHP system.

- v) The fuel import/export and maintenance costs will affect the operating costs of the system.
- vi) Potential costs of the requirement for a new or larger gas or electricity infrastructure should not be underestimated and could make a CHP system uneconomical.
- vii) Additional potential costs associated with additional plant space and exhaust flue for the system and the cost of integrating the system with any existing heating and electrical systems should also be taken into account.

The Net Present Value (see section 4.3) is often used for the economic aspect of CHP optimisation (Kalina et. al. 2004) and takes into account the time value of money.

CHP is not only selected for projects for financial reasons. But the increased efficiency of CHP compared to “conventional” energy systems can also mean that CHP is selected for environmental reasons. CHP can therefore also be sized to have the lowest emissions associated with it.

In the computer tool developed in this study, CHP is sized in terms of both costs and emissions to achieve the lowest cost of emission savings in £/kg CO<sub>2</sub> saved. When sizing CHP, as is the case with other renewables, it is important to know when the energy will be required ie. building energy load profiles are considered. However, as discussed in chapter 3, these are sometimes difficult to predict. The tool developed in this study takes into account the uncertainty of load profiles in the sizing procedure of technologies.

Other tools that are available to size CHP systems are summarised in section 2.5.

CHP rarely covers the total heat and electricity demand in which case other technologies are required to cover the peak loads. Traditionally, back-up boilers would be used to meet the difference in heat demand and the national electricity grid would supply the additional electrical power required. However, the use of renewable energy technologies would be a better option for reducing emissions and fossil fuel demand. The tool developed in this research investigates this option.

### **2.3.4 Current status of CHP in the UK**

In the UK, CHP capacity has increased over the years (Figure 2.15) with the majority of installations being small/medium scale (Figure 2.16). However Figure 2.17 shows that there is a large potential for the increased use of micro-CHP systems especially in domestic buildings in the UK. Burer et. al. (2003) argued that advanced integrated energy solutions such as CHP could be economically and environmentally viable in the near future, especially with high electricity prices. Their adoption however would depend on the technology, the way the technology is used and the tariffs for exporting electricity (Newborough 2004). As well as having the potential to achieve energy, emissions and cost savings for domestic users, micro-CHP can reduce the load placed on the national electricity grid and Newborough (2004) states the importance of micro-CHP application in the UK being integrated with national energy policy.

Section 2.2 discussed the aspects of the policies and regulations that aim to encourage the adoption of CHP in the UK. Policies and regulations making CHP attractive for industrial businesses have led to an increase in the output of large scale CHP (Figure 2.15). King (2004), however, argued the need for increasing current

efforts in adopting CHP and for the UK to catch up with other leading European countries such as Denmark.




Figure 2.15 CHP capacity in the UK (BERR 2007)





Figure 2.16 Number of CHP installations in the UK (BERR 2007)



**Figure 2.17 UK heat demand vs total UK CHP output (BERR 2007)**

### 2.3.6 Application examples of CHP

Some CHP case studies installed in the UK are listed in table 2.1.

“Conventional” CHP is not often combined with renewables. However fuel cells are and can use hydrogen produced by renewables to produce energy when needed.

Hedstroem et. al. (2004) and Sigma Elektroteknik (2001) described a solar-hydrogen-biogas-fuel cell system installed in GlashusEtt in Stockholm, Sweden. The system consisted of a fuel cell system, PV array, electrolyser, hydrogen storage, and a separate control system. The proton exchange membrane fuel cell system had a maximum rated electrical output of 4 kWe and a maximum thermal output of 6.5 kWth. The evaluation showed that the system can work on both biogas and hydrogen (produced by electrolysis of water) and efficiencies were reported to be close to the rated efficiencies of the components.



**Table 2.1 CHP case studies** (Carbon Trust 2004, Van der Horst 2005)

<b>Case Study</b>	<b>Year of installation</b>	<b>CHP size (kWe)</b>	<b>CHP type</b>
'BedZed', Beddington	2002	130	Biomass CHP, spark ignition
York University, York	1995	1030	Reciprocating engine
Queens Medical Centre, Nottingham	1998	4900	Gas turbine
Southbury Leisure centre, Enfield	2002	80	Micro turbine
Woking Park, Woking	2001	200	Fuel cell
Coventry University, Coventry	1994	2 x 300	Reciprocating engines
Freeman Hospital, Newcastle upon Tyne	1997	2 x 1350	Spark ignition engines
Southampton City Council	1998	5700	
Northampton General Hospital, Northampton	1995, 1997, 2001	220 + 450 85	Reciprocating engines Micro-turbine
Elizabeth House, Rochester	2002	2 x 5	Reciprocating engines
Arnold Leisure Centre, Gelding	1992	75	Reciprocating engine

## **2.4 RENEWABLE ENERGY**


Renewable energy can be defined as follows:

*“Energy flows derived from natural forces that are continuously at work in the earth’s environment, and which are not depleted by being used. “* (Energy Efficiency Best Practice in Housing 2004)


Figure 2.18 shows the trend in use of different renewable energy sources since 1996.

Apart from biofuels, the contribution from renewable energy has not changed


appreciably. This is due to large scale hydro schemes not being very popular with the public, as they have an impact on its environment (Boyle 2004), wave energy use has not been explored fully yet, and wind energy technology, although being well established, has not been widely used in the UK as public opposition makes its application difficult. The use of biofuels however has dramatically increased since 1996 and Figure 2.19 shows that biofuel is currently the most widely used source of renewable energy in the UK both for the production of electricity and heat as seen in Figure 2.20. This large increase of biofuel use in electricity production is due to the increased use of landfill gas and municipal solid waste, which are classified as biofuels. Geothermal and solar energy have a high potential to be used on building applications to provide heat and electricity to buildings.



**Figure 2.18 Renewable sources used to generate electricity and heat in the UK** (BERR 2007)



**Figure 2.19 Use of renewable sources in 2006 in the UK (BERR 2007)**




**Figure 2.20 Use of renewables to generate electricity and heat in 2006 in the UK (BERR 2007)**

There is a high potential for the production of energy from renewables across the World. According to EREC (2004) renewables could supply almost 50% of the total energy demand in the World by 2040 (Figure 2.21), however Table 2.2 shows that current use of renewable energy compared to its potential is slim (Table 2.2).

The barriers to the development of renewable energy technologies need to be addressed for their widespread adoption. Duffin (2000) states that supportive policies are essential for the success of renewable energy technologies. Cost is also a barrier

to most renewable energy technologies (see Figure 2.4). However, this barrier can also be overcome by the implementation of adequate policies. Policies related to renewable energy in the UK are described in section 2.2.1.



**Figure 2.21 Prediction of renewable energy contribution to the World energy supply (EREC 2004)**

**Table 2.2: Global renewable energy resources and output of installed renewables (Gross et. al. 2003)**

Resource	Scale of technical potential (useful energy output) (TWh/year)	Output of installed renewables (TWh/year)
Direct solar	12,000 - 40,000	1.2
Wind	20,000 - 40,000	50
Tidal	>3500	-
Geothermal	4,000 - 40,000	44
Biomass	8,000 - 25,000	185

The Energy Efficiency Best Practice in Housing (2004) advises on renewable energy technologies when designing or refurbishing urban housing, and highlights the importance of the consideration of energy efficiency before considering the

installation of energy systems. It is also important to consider the indirect emissions associated with the production and transportation of the renewable technologies as shown in Table 2.3.

**Table 2.3: Environmental impact of renewable energy technologies** (Ackermann et. al. 2002)

<b>Technology</b>	<b>Energy pay back time in months</b>	<b>SO<sub>2</sub> (kg/GWh)</b>	<b>NO<sub>x</sub> (kg/GWh)</b>	<b>CO<sub>2</sub> (t/GWh)</b>	<b>CO<sub>2</sub> and CO<sub>2</sub> equiv. for methane (t/GWh)</b>
<b>Coal fired (pit)</b>	1.0- 1.1	630 – 1370	630 – 1560	830 – 920	1240
<b>Nuclear</b>	N.A.	N.A.	N.A.	N.A.	28 – 54
<b>Gas</b>	0.4	45 – 140	650 – 810	370 – 420	450
<b>Hydro:</b>					
Large hydro	5 – 6	18 – 21	34 – 40	7 – 8	5
Microhydro	9 – 11	38 – 46	71 – 86	16 – 20	N.A.
Smallhydro	8 – 9	24 – 29	46 – 56	10 – 12	2
<b>Wind turbines:</b>					
4.5m/s	6 – 20	18 – 32	26 – 43	19 – 34	N.A.
5.5m/s	4 – 13	13 – 20	18 – 27	13 – 22	N.A.
6.5m/s	2 – 8	10 – 16	14 – 22	10 – 17	11
<b>PV:</b>					
Monocrystalline	72 – 93	230 – 295	270 – 340	200 – 260	N.A.
Multicrystalline	58 – 74	260 – 330	250 – 310	190 – 250	228
Amorphous	51 – 66	135 – 175	160 – 200	170 – 220	N.A.
<b>Geothermal</b>	N.A.	N.A.	N.A.	N.A.	50 – 70
<b>Tidal</b>	N.A.	N.A.	N.A.	N.A.	2

This study concentrates on solar thermal and PV, combined with CHP technologies as solar thermal and PV technologies are commonly integrated into buildings. Ground source heat pump (GSHP) and wind technologies, although they are also well suited to building integration, are not currently included in the computer

modelling tool however could be included in further research. The tool will not incorporate hydro, wave, river, or tidal energy technologies as these are not commonly integrated into buildings and the integration of these resources with buildings are highly dependant on the location.

### **2.4.1 Solar thermal energy**

Boyle (2004) describes different ways in which solar radiation in the form of heat can be collected and used in buildings:

- **Building orientation:** designing a building with a large south facing façade could allow for passive solar heating and natural lighting.
- **Active solar thermal collectors:** a solar collector is used to harvest incident solar radiation. The low temperature heat collected is usually used for hot water heating. This is the method considered in this section.
- **Centralised power stations using concentrating solar technologies:** these are large scale power generation schemes in the order of MW power ratings and usually function according to the Rankine cycle whereby a steam turbine is used to convert high pressure working fluid vapour into shaft power. This option is not integrated with buildings and is therefore not considered in this research.


#### **a) Building design**

The use of passive solar heating in buildings can be optimised by insulating the building to reduce heat losses, installing an efficient heating system, orientating the building south facing, avoiding over shading and having “thermally massive” walls.

## b) Solar radiation

The sun radiates energy from its high temperature surface (approximately 6000°C). Radiation reaching the earth surface consists of direct and diffuse radiation (Boyle 2004). Figure 2.23 shows the mean direct and diffuse irradiation on a horizontal surface in the London area. In the UK, the total irradiation consists of about 50% direct and 50% diffuse irradiation (Boyle 2004) and the total radiation varies throughout the year, being the highest in June and lowest in December (Figure 2.22).

A south-facing surface receives the most radiation in the northern hemisphere (CIBSE 2006). The optimum tilt of the surface depends on the time of year most energy is required. Best performance of a collector in spring and autumn is achieved with a tilt equal to the latitude of the location. Optimum tilt in the summer requires a more horizontal tilt and in winter a more vertical tilt is better. The optimum tilt for year round radiation in London is 30° (Boyle 2004). However, a collector orientation between south-east and south-west is acceptable for most solar heating applications, which makes solar hot water applications suitable to most buildings (Boyle 2004).



**Figure 2.22 Mean solar irradiation on a horizontal surface – London area**  
(CIBSE 2006)

Using a solar system for space heating in the UK is not usually viable as most of the solar radiation is available during the summer, when space heating is not required, and during the winter when the space heating demand is greatest, the solar radiation available is lowest (Figure 2.22). A solar collector system could however be used for cooling in building applications. Florides et al (2002) reviews different solar and low energy cooling techniques for buildings. Thermal energy storage such as underground heat stores and aquifer stores can also be used to increase solar energy utilisation throughout the year (IEA 2002).

Theoretical efficiencies of solar thermal systems do not always correspond to their actual efficiencies and it is therefore important to gain more insight into installed systems. Solar water heating installations have been analysed and monitored to gain information on their performance and problems encountered (ETSU 2001, Lloyd 2001). ETSU (2001) monitored four systems in different sites to gain information on hot water usage, delivery temperature, useful energy delivered and the proportion of the demand satisfied by the system, which could be useful for future studies.

### **c) Rooftop solar water heater**

The rooftop solar water heater is the most common form of solar collector. This system can be a pumped system or a thermosyphon system.

In northern Europe, where freezing usually occurs in winter, pumped systems are usually used. A pumped system consists of a collector panel (which consists of three layers: glazing, absorber plate and insulation), a storage tank, and a pumped circulation system (containing anti-freeze in cold climates). In the UK this type of



system for a typical dwelling with 3-5m<sup>2</sup> of collectors would typically supply 40-50% of hot water requirements (Boyle 2004).

A thermosyphon system is a simpler installation not requiring a pump. Natural convection of the hot water rising from the collector carries heat to the storage tank situated above the collector. This system is not suited for climates where frost occurs as the hot water tank is usually situated outdoors.

Different types of solar thermal collectors available on the market are: collectors without glass cover (usually used for swimming pool applications), flat plate collectors with glass cover, and vacuum tube absorber tubes (Boyle 2004). Concentrating collectors are another form of collectors (Kalogirou 2004). Collectors can be stationary or sun-tracking. In this study collectors for building applications are considered. These are usually stationary flat plate and vacuum tube collectors as described below. Kalogirou (2004) and SEA (2004) describe these two collector types:

*i) Flat plate collectors*

Flat plate solar collectors consist of an absorber, a transparent cover and insulation in a frame. The absorber plate absorbs the solar heat and transfers it to the transport medium in tubes. Flat plate collectors are the most used collector type and are mainly used for hot water production. They are less expensive (£2000 - £3000 for a typical domestic installation (EST 2005)) however also less efficient compared to evacuated tube collectors.

## *ii) Evacuated tube collectors*

There are two main types of evacuated tubes:

The full flow evacuated tubes work in a similar way to flat plate collectors. They have an absorbing plate with tubes where a fluid absorbs the heat. However with evacuated tube collectors, all this is encased in a vacuum tube and several tubes connected to a manifold form a collector.


The heat pipe evacuated tube collectors consist of a heat pipe inside an evacuated tube. The vacuum reduces convection and conduction losses making evacuated tubes able to operate at higher temperatures than flat plate collectors. The heat pipe is a sealed copper pipe containing a fluid that undergoes an evaporating-condensing cycle: Solar heat evaporates the liquid and the vapour travels to the heat pipe condenser situated in the manifold where the fluid condenses transferring heat to the fluid in the manifold, the fluid returns back to the heat pipe and the process is repeated. Several tubes are connected to the manifold to make up a solar collector.

Evacuated tube collectors work efficiently with low radiation and with high absorber temperatures and higher temperatures may also be obtained. The heat pipe in evacuated tube collectors also protects the collector from overheating or freezing. Costs for a typical evacuated tube domestic installation are £3500 - £5000 (EST 2005).

Solar thermal systems can be direct or indirect systems. In direct systems the water is directly heated by the collectors i.e. the water to be heated passes through the collector panels. In indirect systems a heat exchanger is used to transfer the heat from the collector circuit to the water in the storage tank. This type of system is especially

used in climates where freezing occurs as anti-freeze can be used in the collector circuit to avoid the water from freezing. Figure 2.23 shows a diagram of an indirect system. The hot water storage tank in a solar thermal system has two heating coils one for the solar system and one for the auxiliary system (usually a boiler or an electric heater). In order for the solar system to be used primarily, the coil for the solar system is usually situated at the bottom of the tank (the colder part). The pump is controlled by the controller which is linked to sensors on the collectors and storage tank. (SEA 2004)

A solar thermal system can either be a pressurised circuit or a drain-back circuit. A pressurised system is a closed loop circuit with anti-freeze and requires an expansion vessel for temperature variations. A drain-back system is drained when the pump isn't working (for example when the temperature is below freezing) and therefore requires a tank inside the building for the water to drain into.



**Figure 2.23 Indirect water heating system (Kalogirou 2004)**

#### d) Solar thermal collector sizing

Design and sizing of solar thermal collectors are often achieved using Hottel-Whillier-Bliss equation. The equation expresses the useful heat collected,  $Q$ , per unit area, in terms of two operating variables, the incident solar radiation normal to the collector plate,  $I_s$ , and the temperature difference between the mean temperature of the heat removal fluid in the collector,  $T_m$ , and the surrounding air temperature,  $T_a$ .“ (McVeigh 1977). This is given as:

$$Q = F\{(\tau\alpha)I_s - U(T_m - T_a)\} \quad \text{Equation 2.1}$$

where,  $F$  is a factor related to the effectiveness of the heat transfer from the collector plate to the heat removal fluid,  $(\tau\alpha)$  is the transmittance-absorptance product and  $U$  is the heat loss coefficient ( $W/m^2K$ ).

The useful energy output of a solar collector can be expressed as follows (Duffie 1991):

$$Q_{sc} = A_{sc} \times I_s \times \eta_{sc} \quad \text{Equation 2.2}$$

where,  $A_{sc}$  is the total Collector area,  $I_s$  is the incident solar radiation normal to the collector and  $\eta_{sc}$  is the collector efficiency.

Therefore, using equation 2.1 and 2.2 a solar thermal collector instantaneous efficiency can be given by (Duffie 1991):

$$\eta_{sc} = F(\tau\alpha) - FU(T_m - T_a) / I_s \quad \text{Equation 2.3}$$

Atmaca (2003) quotes typical values of  $F(\tau\alpha) = 0.75$  and  $FU = 6.5$  for double-glazed flat plate collectors, and  $F(\tau\alpha) = 0.7$  and  $FU = 3.3$  for evacuated tube collectors. A

more detailed calculation of solar collector sizing is given in Chapter 4 as part of the computer modelling tool developed for this research.

Sizing of the components of solar thermal systems is complex and includes predictable components such as collector performance characteristics, and unpredictable components such as weather data. Simulation and modelling software packages are used for a detailed investigation and sizing of solar thermal systems (Kalogirou 2004). Many simulation methods have been developed over the years. The  $f$ -chart correlation method is one of the simple methods. It is a method to estimate the fraction of energy that will be supplied by solar energy for a given solar heating system (Beckman et al 1977). Other simulation packages such as SOLCOST (Win 1980), TRYNSYS (University of Wisconsin 1990), WATSUN (University of Waterloo 1994), Polysun (Polysun 2000), EUROSOL (Lund 1995) and RETscreen (RETscreen International 2004) are more detailed simulation methods. See Section 2.5 for more computer tools.

Although simulations can be valuable methods of investigating solar thermal systems, not all aspects affecting the performance of the systems can be considered and modelled. Mistakes can also easily be made in the process as a high skill level is required to make the correct judgements and produce accurate results. The tool developed in this study uses a basic sizing procedure not requiring many input parameters. It might not deliver a detailed simulation, however the sizing does not require “expert” knowledge of solar thermal systems in order to operate the tool.

### **e) Hot water storage tank sizing**


Matrawy et al (1996) developed a graphical method for the optimisation of solar thermal water heating systems. The optimum collector and storage sizes were found for a given solar fraction. Bojić et al (2002) concluded from their solar thermal system simulation that systems with larger storage volumes yielded higher solar fractions. However an economical analysis should be carried out in addition to find the optimum storage volume for a system. In the tool developed in this study, the hot water storage volume is assumed to be 1/3 of the daily hot water demand, as for a hot water storage for a typical boiler system (Institute of Plumbing and Heating Engineering 2002).

Lund (2005) investigated the sizing of solar thermal combi-systems (supplying both hot water and space heating) with short-term heat storage. Over-sizing a solar thermal system to provide some space heating proved to be advantageous for less efficient buildings, where there was a space heating demand in some of the summer months. However for newer, more efficient buildings, this sizing strategy leads to a negative economic outcome. Sizing the solar thermal system to supply some space heating is therefore not economically advantageous in all cases. In the tool the solar thermal system is sized only to supply hot water and does not consider the heating demand in the sizing procedure.zx


### **f) Current status of solar thermal energy**

As part of the EU target of 20% renewable energy by 2020, solar thermal technologies are encouraged (ESTIF 2007). The country with the largest share of the solar thermal market in the EU is Germany with 50% (Figure 2.24). However,


although solar energy is currently not used extensively in the UK (Figure 2.20), and the UK has one of the smallest amounts of collectors in operation (Figure 2.25), the UK has had the highest market growth in 2005/2006 with 93% (Figure 2.26) and is now in 8<sup>th</sup> place in the EU solar thermal market (ESTIF 2007).



**Figure 2.24 Shares of the European solar thermal market (ESTIF 2007)**



**Figure 2.25 Total solar thermal collectors in operation in 2006 (ESTIF 2007)**



**Figure 2.26 Solar thermal system market growth 2005/2006 (ESTIF 2007)**

Per capita statistics are a good indicator of the strength of the solar thermal market in a country. Austria for example had the largest advance in the solar thermal market with 25.2 kW<sub>th</sub> per capita: twice that of Germany and about 6 times the European average in 2006. Cyprus had the largest amount of solar thermal capacity per capita in operation in 2006 with 530 kW<sub>th</sub> per capita, Austria and Greece came second and third with 225 and 208 kW<sub>th</sub> per capita respectively in 2006 (the European average was 27 kW<sub>th</sub> per capita) (ESTIF 2007).

### **g) Application examples of solar thermal systems**

The Energy Saving Trust publishes some case studies of solar hot water systems for buildings (EST 2008). Many solar thermal collectors are integrated in residential buildings and in certain countries are installed in most residential buildings as the primary technology supplying the hot water to the building. Other application



examples are communal buildings and swimming pool applications. Some UK case studies are listed in Table 2.4.

**Table 2.4: Solar thermal collector case studies** [(1) ESD 2005, (2) TV Energy 2008, (3) Faber Maunsell 2003, (4) European Commission 2008, (5) EST 2003]

<b>Case Study</b>	<b>Year</b>	<b>ST application</b>	<b>ST type</b>	<b>Other technologies</b>
Westlea Housing Association, Calne, Wiltshire, and Swindon (1)		Domestic hot water	Flat plate	
Brill School, Buckinghamshire (2)	2003	Swimming pool	Evacuated tube	Wind turbine, PV system
SOHA Housing, Oxfordshire (2)	2004	Domestic hot water	Flat plate	PV system, GSHP
Family home, Buckinghamshire (2)	2003	Domestic hot water	Flat plate	PV system
Warden INTEGER Home, Berkshire (2)	2001	Domestic hot water	Flat plate	-
Birch Court, Sheltered elderly housing, Oxfordshire (2)	2003	Community hot water & heating	Flat plate	-
Integer Greenfields, Maidenhead (3)	1998	Domestic hot water	Flat plate	PV system
Hyde Housing Association, Greenwich (3)	1998	Domestic hot water	Flat plate	-
Phoenix House, Leicester City Council (3)	1997	Commercial building hot water	Evacuated tube	-
Josiah Wedgwood & Sons visitor centre (3)		Hot water for washrooms and café	Flat plate	-
William J. Clinton Peace Centre, Northern Ireland (4)		Hot water to Conference centre, Youth hostel, Art gallery, Café	Evacuated tube	PV system
The Fishing Village, Chatham Maritime, Kent (5)	2003	Domestic hot water	Evacuated tube	

## **2.4.2 Photovoltaics**

A definition of Photovoltaics is: “the conversion of solar energy directly into electricity in a solid-state device” (Boyle 2004). Photovoltaic cells (PV) consist of semi-conducting material, usually silicon, adapted to release electrons, which form the basis of electricity. Boyle (2004) describes the process in more detail.




Table 2.5 lists the main PV technologies available. Other innovative PV technologies include Multi-junction PV cells, Concentrating PV systems, Silicon spheres, Photoelectrochemical cells, and “Third generation” PV cells. Green (2000) describes the different photovoltaic technologies.

PV systems have no moving parts therefore lengthening their lifespan, have lower maintenance requirements, and do not generate noise pollution or polluting emissions. However PV production is an energy intensive process and PV technology remains expensive compared to other renewable energy technologies (Table 2.3). The cost of PV is around \$6 per peak Watt, which is 6-10 times the cost of grid electricity (Gross et. al. 2003).

PV systems can be grid connected, grid support, off-grid, or hybrid systems (EPIA 2001). Grid connected systems can export excess power and import additional power. A system with grid support is connected to the grid and has battery electricity storage, which is ideal in areas with unreliable grid supply. An off-grid PV system is only connected to a battery and is ideal for remote power supply. A hybrid system is a system that can be combined with another power source to ensure constant power supply. This system can be grid connected, grid support, or off-grid. Other more

efficient methods for electricity storage are being researched, such as storing energy in the form of hydrogen to be used by fuel cells (Dell 2001).

**Table 2.5: PV technology** (Boyle 2004, EPIA et. al. 2001)

Material	Diagram	Typical efficiencies (%)	Advantages	Disadvantages
<b>CRYSTALLINE PV</b>				
Monocrystalline silicon		12-15	High efficiency	Labour intensive Expensive
Polycrystalline silicon		11-14	Easier to produce	Less efficient
<b>THIN FILM PV</b>				
Amorphous silicon		5-7	Cheaper to produce than crystalline cells Less energy intensive to produce Thinner and can be deposited on a variety of materials	Less efficient than crystalline cells
Other materials suitable for thin film PV are Copper indium diselenide (CIS), Copper indium gallium diselenide (CIGS), and Cadmium telluride (CdTe).				

Building integrated PV (BIPV), such as PV roof tiles and façade cladding, can significantly reduce the cost of PV, as the cost can be offset from the alternative cladding cost. Mott Green Wall (2002) investigated the economic potential of BIPV and concluded that BIPV could make a considerable contribution towards UK renewables targets.

### **a) Sizing PV systems**

DTI (1999) published a design guide for PV in buildings which outlines some points to consider when sizing a PV system:

- i) The more energy that can be used on site the better, as exporting electricity to the grid currently is not economically interesting in the UK.
- ii) The PV system is usually sized to contribute towards the total electricity load, but usually doesn't supply the total annual load.
- iii) Available area for the collectors
- iv) Budget

CIBSE (2000) gives some rough rules of thumb outputs of different PV systems for the UK:

- Monocrystalline or polycrystalline array: 90-110 kWh/m<sup>2</sup> per year
- Amorphous thin film array: 30-70 kWh/m<sup>2</sup> per year
- Roof-mounted, grid connected system: 700 kWh/kW<sub>p</sub> installed per year

As for the solar thermal system sizing, the PV output can also be estimated using solar irradiation data, which is available from many sources. The solar radiation data used in the tool is from the European Commission Directorate General Joint Research Centre, PVGIS irradiance database (European Commission Directorate General Joint Research Centre 2007). Losses are assumed to be 25% (CIBSE 2000). Polycrystalline PV with a collector efficiency of 14% (CIBSE 2000) is being used in the tool as it is currently the most commonly used type of PV (IEA 2003). Roberts (1992) however outlines the limitations with many sizing procedures being the difficulty of accurately predicting the weather data and electricity loads.

Sizing procedures for PV systems with battery investigate the relationship between the sizes of the array and the battery to achieve a certain reliability of supply and usually make use of sizing curves (Markvart 2006). Roberts (1992) outlines a sizing procedure for small systems with battery storage. In this tool however it is assumed that the PV system is grid-connected and any surplus electricity generated at any one time is exported to the grid and any deficit is imported from the grid.

Equation 2.4 is the equation used to size the PV array in the computer tool.

$$S_{PV} = \frac{D_e}{I_s(1-L)\eta_{PV}} \quad \text{Equation 2.4 (CIBSE 2000)}$$

where,  $S_{PV}$  is the PV required area ( $m^2$ ),  $D_e$  is the electricity demand (kW),  $I_s$  is the incident solar radiation ( $kW/m^2$ ),  $\eta_{PV}$  is the efficiency of the PV cells, and  $(1-L)$  is the efficiency of the power conditioner (inverter, controller), transformer and interconnection.

In many cases the worst month in terms of solar radiation is used when sizing PV systems, this however does not result in the optimum in terms of techno-economics (Celik 2003). Celik (2003) suggests a method where another energy form is introduced instead of increasing the sizes of the renewable energy technologies and considers yearly radiation data. This method results in techno-economically more optimum systems. As in the method, Celik (2003) uses, in the tool developed in this study, yearly solar radiation data is used and an auxiliary energy source, in this case CHP and/or the national electricity grid, is included in the system design. The technologies are then sized to find the optimum system in terms of cost and emissions (see Chapter 4 for the tool description).

As for the ST sizing, there are tools available for sizing PV optimally that simulate the system in more detail. RETScreen (RETScreen International 2004) is one of such tools and can analyse both grid connected and battery systems.


Ulleberg et. al. (1997) simulated the performance of a stand-alone solar-hydrogen power system in Trondheim, Norway. The transient simulation program TRNSYS was used for the simulation study. The conclusion was that such a system in Trondheim would need to be quite large compared to similar systems, such as the SSSH in Freiburg, because of low insolation in Trondheim and large loads assumed. This illustrates the importance of reducing loads before designing the system.

#### **b) Current status of PV in the UK**


Although the manufacture of PV has remained small and costs high compared to other renewable energy technologies, the use of PV has steadily increased in the World since 1993 (Figure 2.27). This trend of increased use of PV has also been reflected in the UK (Figure 2.28). There is a large resource of solar energy (Table 2.2) and innovations, improvements in efficiency, and increased production, should reduce costs of the modules (Gross et. al. 2003). There therefore is a large potential for PV in the UK and the World. However, the UK is still lagging behind other European countries, such as Germany (Figure 2.29). Germany's domination in the European PV market is mainly due to the Feed-in Law introduced in 1999, making PV systems economically more viable (Jaeger-Waldau 2007).

In the UK, investment grants, subsidies for demonstration projects and 5% reduction in VAT for professional installations of PV systems are available (Hacker 2005). A 10 year Major PV Demonstration Programme was launched in 2002, providing


capital grants for the installation of domestic and non-domestic PV systems in the public and private sectors (Jaeger-Waldau 2003). This however was replaced by the Low Carbon Buildings Programme which provides grants for microgeneration technologies, including PV (IEA 2007).



**Figure 2.27 Installed PV power in the IEA PVPS reporting countries (IEA 2007)**



**Figure 2.28 UK installed PV power (IEA 2007)**



**Figure 2.29 European installed PV power by country in 2006 (IEA 2007)**

Export tariffs for domestic customers vary between suppliers and usually range between 6p/kWh and 8p/kWh. However a tariff of 3.5-4.5 p/kWh for total generation is also offered by suppliers (IEA 2007). There however is no Feed-in Law in the UK which has proven successful in Germany. Adequate policies encouraging the use of PV in the UK would increase the market and therefore further reduce the cost of the modules (Gross et.al. 2003).

### **c) Application examples of PV**

PV systems can be used for homes, non-domestic buildings, large scale power plants, and satellites. Currently the most common application is in urban residential rooftop systems (Green 2000). Some application examples of PV in the UK are listed in Table 2.5. Other case studies of PV projects are listed on the British Photovoltaic Association website (British Photovoltaic Association 2004).



**Table 2.6 UK Building Integrated PV case studies** [(1) European Commission 2008, (2) IEA 2008, (3) EST 2003]

<b>Case Study</b>	<b>Application</b>	<b>Rated Power (kWp)</b>	<b>Year installed</b>	<b>Other technologies</b>
Shortenills Environmental Education Centre, Buckinghamshire (1)	Shelter	4.6	2001	-
Skegness Grammar School (1)	School demonstration project	2.5	1999	Wind turbine
Reading International Solidarity Centre (1)	Demonstration project	0.43	2002	-
Greenfields Development, Maidenhead (1)	15 social housing properties	20	2002	-
Haily Village Hall, Oxfordshire (1)	Village Hall	0.9	2002	-
Dyfi Valley Community Renewable Energy Project (1)	5 individual schemes (incl. Eco Park, Schools)	3 x 1.4 kW at Eco Park, 2 x 0.69 kW at schools	2002	Hydro, wind, solar thermal, wood heat and GSHP
Bronllys Hospital, Powys, Wales (1)	Hospital	60.62	2005	-
William J. Clinton Peace Centre, Northern Ireland (1)	Conference centre, Youth hostel, Art gallery, Café	2.4		ST hot water
BedZed, London (1)	Charging electric cars	108	2002	ST, CHP
Solar Office Doxford International (2)	Offices	73	1998	-
Jubilee Campus, Nottingham University (2)	University	53.3	1999	-
Llety Llanelli Foyer, Llanelli (3)	Social housing	28.6	2003	-
Eco House, Penrhos, Gwent (3)	House	2.1	2003	Wind turbine

Brogren et. al. (2003) presented a case study of integrated PV in buildings in Hammarby Sjöstad, an ecological Olympic village. Interviews with representatives from all involved, such as designers, contractors, and future residents were conducted and the systems were analysed and simulated. Obstacles to the integration of PV in buildings were identified as cost and lack of knowledge. It was also noted that the choice of PV technology was often based on aesthetics and a wish to appear environmentally friendly, rather than on optimal system performance.

### **2.4.3 Integration of PV and ST with CHP**

The literature shows that in practice there is a distinct lack of combined “conventional” CHP and renewable energy technologies. Fuel cells, a form of CHP, however, are often combined with other renewable energy technologies used for the production of hydrogen.

The reasons for this trend could be:

- i) “Conventional” CHP is an established technology and is not usually considered as a renewable energy technology.
- ii) Although CHP is more energy efficient than other energy technologies, as discussed in section 3.4, CHP is mostly powered by natural gas, a fossil fuel, and therefore not a renewable source of energy.
- iii) Fuel cell is a more recent technology, which has received a large amount of funding for its development and has consequently become quite popular for potential use as a renewable energy technology. Policies encourage the use of hydrogen, which is seen as having a large potential for future use.


- iv) “Conventional” CHP is usually selected for economic reasons, rather than environmental. For projects where environmentally “friendly” solutions are specified, and where the expense is less important, other renewable energy technologies would rather be selected.
- v) Using biomass to power the CHP system is another renewable solution and can be adopted easily, since biomass fuel is well established. However most biomass boilers currently are not CHP.

## **2.5 ANALYSIS TOOLS AND THE DECISION MAKING PROCESS**


The tool developed in this research study is aimed to aid designers in the decision-making process when selecting appropriate CHP and renewable energy technologies to supply energy to a building or group of buildings. A wide range of factors affect the choice of technology combinations.

### **2.5.1 Decision making process**

There are many different parties that should be considered in the decision-making process. Figure 2.30 shows the different parties involved, with the first party to consider being the inhabitants (in the middle of the diagram). The building inhabitants are probably the most affected by any decisions made and their views should ideally not be ignored. However the building project participants are usually the ones making the decisions, consulting other parties such as the public administration.




**Figure 2.30 Interest groups in decision-making** (Alanne 2003)



**Figure 2.31 Factors to consider when choosing appropriate technologies**


The choice of technologies will depend on several factors (Figure 2.31), amongst these are site dependant factors such as the climate and the resources available, the building type and associated loads, achieving a balance between energy demand, supply, and costs. These are included in the tool developed in this study. However other factors which are currently not included, such as social acceptance of renewables for example, can be a hindrance to the use of renewables. Faiers et. al.

(2006) and Iniyar et. al. (2001) investigated social acceptance of renewables. These and other factors need to be considered when selecting renewable energy and CHP technologies for buildings. Initial ideas about the selection process are summarised in Figure 2.32.



**Figure 2.32 Initial ideas about selecting renewables and CHP for buildings**

Huang et. al. (1995) describes the decision analysis process outlined in Figure 2.33 and summarises different decision analysis techniques. These include decision making under uncertainty, multiple criteria decision making, and decision support systems.



**Figure 2.33 Schematic of the decision analysis process (Huang et. al. 1995)**

Kaul et. al. (2004) outlined decision parameters for shifting towards alternative fuels from renewable resources. Assets and liabilities of renewable energy technologies and fossil fuels were compared in terms of cost, environmental impact, and social effects, all of which looked favourable for renewable energy. However the main barrier to the uptake of renewable energy technologies was identified to be political and industrial interests in continuing to use fossil-fuels.

Reneke et. al. (2002) mention that decision-makers often make decisions based on their experience and intuition. It is therefore difficult in some cases to model the whole decision-making process in decision-making tools. However certain factors in the decision-making process can be modelled to aid decision-makers in the form of analysis tools.

Rogers (2001) reviews decision-making techniques for engineering projects. The computer tool uses the economics-based project appraisal techniques which include net present value (NPV) and internal rate of return (IRR) evaluations described by Northcott (2002), combined with other appraisal factors such as emissions and environmental impact. Other factors can be taken into account by the user of the tool, who makes the final decision in the process.

Certain factors affecting the selection of energy systems for buildings can be predicted more or less accurately. However others such as building energy load profiles are difficult to predict as they are dependant on climate and occupancy behaviour. This uncertainty is usually not taken into account when selecting energy systems for buildings. With “conventional” energy systems (i.e. boilers and national electricity grid) hourly building energy load profiles are not usually required to size the energy systems. They are however important for the sizing of CHP and

renewable energy systems for buildings. See Chapter 3 for building energy load profiles.

### **2.5.2 Analysis tools**

Different analysis programs have varying levels of accuracy and are intended to be used at different stages in the design process. However, even the most sophisticated building analysis tools cannot always predict precisely. A building's construction quality and occupancy schedules are some of the factors that could vary dramatically from building to building.

The tool developed in this project determines building energy loads and load profiles and then finds the optimum sizes for the technologies for different technology combinations. (See chapter 4 for a more detailed description of the tool.) Different tools are available that carry out several of these stages.

Jebaraj et. al. (2004) review different energy models available. These include energy planning models, energy supply-demand models, forecasting models, optimisation models, and emission reduction models. Paradis (2004) gave a basic description of some energy analysis tools available and their applications for different stages in the design process.

#### **a) Load prediction**

The selection of appropriate technologies for a building is highly dependant on the loads of the building. Accurate load predictions are therefore important. Many load prediction/calculation tools are available, such as Hevacomp or Cymap. Load

profiles however are more difficult to predict, as discussed in Chapter 3, and not many tools are capable of doing this.

Energy-10 PV simulates the hourly electrical load of the building to obtain realistic load profiles (Balcomb 2001). However, although the load profiles simulated are relatively realistic, a predicted load profile will always have some degree of uncertainty about it.

The tool developed in this study uses a compiled database of building energy load profiles and uses the Monte Carlo Method to take into account the uncertainties of building energy load profiles.

#### **b) Economic analysis**

Economics is another decision parameter. Economic assessment tools include the Building Life-Cycle Cost software (Paradis 2004).

Northcott (2002) compared different analysis methods for capital investment appraisal and concluded that NPV, a discounted cashflow method, takes into account the time value of money and avoids computational problems of other discounted cashflow methods. The tool developed in this study therefore uses NPV to compare economics of the different options.

#### **c) Specific Technology Tools –CHP, solar thermal, PV**

There are many tools that are designed for specific types of renewable energy system, for the design analysis of the technologies, some of which are: PVSYST, PV\*SOL, PV-DesignPro, PVcad, and RETscreen (RETscreen International 2004) are used to design PV systems; SOLCHIPS (Lund et. al. 1992), Solar Benefits Model,



SolarPro 2.0, SolDesigner, T\*SOL, SOLCOST (Win 1980), TRYNSYS (University of Wisconsin 1990), WATSUN (University of Waterloo 1994), Polysun (Polysun 2000), EUROSOL (Lund 1995) and RETscreen (RETscreen International 2004) are used to design solar thermal systems; CHP Sizer (CIBSE 2004), Building Energy Analyzer and D-Gen PRO are used to design CHP systems (United States Department of Energy Office of Energy Efficiency and Renewable Energy 2008).

Renew is a renewable energy design tool for architects that investigates PV, wind power and solar water heating (Woolf 2003). Combinations of technologies can be considered in this design tool. The technologies are not optimally sized by the tool, but the user can change the inputs and quickly see the effect of these changes on the performance of the system. It is intended for designers with little experience of renewables and is meant to encourage architects to integrate renewables into their buildings. This “trial and error” approach in the sizing of technologies also makes this design tool a good medium for the designer to learn about the energy systems investigated and the effects the various parameters have on the system.

CHP Sizer (Carbon Trust 2004) is a software that carries out preliminary evaluations for CHP suitability in new or existing hospitals, hotels, halls of residence and leisure centres. A more detailed feasibility study should however be carried out before further considering CHP for a project.

EnergyPRO is a modelling and simulation software that carries out techno-economic analysis and optimisation of cogeneration and trigeneration energy projects for residential and non-residential buildings (Maeng et. al. 2002). Most small CHP systems in Denmark have been designed using the EnergyPRO tool (Lund et. al. 2005). This software however does not find the optimal sizes of technologies.

#### **d) Geographic Parameters**

Geographical parameters influence the selection of technologies and are especially important to consider when designing renewable energy systems. Jebaraj et. al. (2004) review solar energy models to predict solar irradiation. The tool developed in this study, however, uses average hourly irradiation values.

#### **e) Simulation software**

Simulation software is widely used to understand the operation and performance of renewable energy systems. TRNSYS, Simulink, MATLAB and ECLIPSE are some examples of simulation software.

TRNSYS probably is the most commonly used simulation software. The TRNSYS software (Beckman et al 1994) is a transient systems simulation program with a modular structure, which gives the program flexibility, and facilitates the addition of mathematical models to the program. TRNSYS can be used for the detailed analysis of systems whose behaviour is dependent on the passage of time. Applications include the study a solar combi-DHW system (Jordan et. al. 2000), modelling a hybrid PV- solar thermal system (Kalogirou 2001), carrying out building analysis studies for renewable energy systems (Mihalakakou 2002), and simulating a solar-hydrogen system (Ulleberg et. al. 1997).

Simulink, a product of MathWorks, is an interactive tool for simulating and analysing dynamic systems. It has been used to simulate hybrid energy systems (Iqbal 2003, El-Shatter 2002).

MATLAB is a simulation software which has been used to simulate process and performance information of a biomass gasifier-based power station (Jurado et. al. 2003), and to evaluate control strategies for a solar-hydrogen-biogas-fuel cell system (Hedstroem et. al. 2004).

ECLIPSE simulation package (Williams et. al. 2003) has been used to simulate wood-fired fuel cells in selected buildings (McIlveen-Wright et. al. 2003).

Simulation software is useful to understand the performance of energy systems, and can be used as part of the optimisation of technologies. However, not all aspects affecting the performance of the systems can be considered and modelled in simulations. A high skill level is required to make the correct judgements and produce accurate results. The tool developed in this study uses basic sizing procedures making use of simple simulation of the systems. The tool does not require many input parameters and does not require “expert” knowledge of the technologies investigated in order to operate the tool.

#### **f) Optimisation Tools**

Optimisation of the sizing and selection of energy systems is a main part of the computer tool developed in this PhD study. The optimisation process used is described in Chapter 4. Other optimisation tools are described below.

Models dealing with the optimisation of energy systems include MODEST (Model for Optimisation of Dynamic Energy Systems with Time dependent components and boundary conditions) (Henning 1998) and MARKAL (Fishbone et. al. 1981). They are used for municipal, regional, and national energy systems and to support national planning and policy decisions. Cosmi et. al. (2003) present an application of the R-

MARKAL model, investigating the feasibility of renewable energy on a local case study, taking into account legal issues and physical limits, and presenting the minimum cost solutions.

Deeco (Dynamic Energy, Emissions, and Cost Optimisation) is an energy optimization model, that analyses the effects of counteraction between energy technologies in local energy systems with respect to energy saving, emissions reductions, and cost. It determines best practice operation and is used to compute sustainability gains against financial costs. Lindenberger et. al. (2004) reported an extension to Deeco, taking into account passive technologies.

EnergyPro is a software package that calculates both energy and economics for heat, cooling and power plants, making combined technical and economic decisions more easily. It carries out a detailed analysis and can look at a number of combinations of technologies, including renewable energy and CHP technologies, calculating their energy conversion and outputting a report for each option separately. This tool is not, however, a decision-support software and cannot compare the various options.

RETScreen is a renewable energy technologies assessment tool for preliminary feasibility studies. The tool has three stages: Energy Model, Cost Analysis and Financial Summary and can be used for most building types. This tool however can only simulate one technology at a time.

Ameli et. al. (2007) presented the initial development of IDEAS, an integrated software package to design, optimize and monitor energy systems based on micro-turbines, fuel cells and internal combustion engines using fossil fuels and renewables. This software aimed to combine several existing commercial software

packages. Links between the different software packages were developed to form a comprehensive selection tool to help in the decision-making process. A prototype has been developed with the aim of developing the actual software in the future.

The University of Strathclyde developed a tool to select energy efficiency measures and renewable energy and CHP technologies specifically for large estates (complex of different buildings). A University accommodation application was used as the basis for the model. Load profile prediction of other projects are then determined on this basis, scaling the profile as required. The results are categorized in different lists according to cost and emissions.

HOMER is a micro-power optimization model and is used to design systems for remote and distributed power. This software finds the least cost (life-cycle cost) combination of systems to satisfy the thermal and electrical loads. However the least cost combination of technologies for an application might not always be the best option. Other factors such as environmental performance need to be considered. It uses sensitivity analysis on most inputs to account for uncertainties. Values for uncertainty can be entered and the model shows the variation in the outputs due to these uncertainties. It however is difficult to model load profile uncertainty in HOMER as this uncertainty is difficult to quantify in values. This approach of taking uncertainty into account for the load profiles was therefore not adopted in the tool developed in this study.

Williams et. al. (2000) developed a tool meant for services engineers and which selects and sizes CHP systems for new buildings. Few inputs are required and the tool provides an indication of whether a more detailed investigation would be required. It estimates the building energy load profiles by using an average profile

developed from a number of existing buildings. This, however, does not take into account the uncertainty of the load profiles in the sizing procedure.

## **2.6 CONCLUSIONS**

Currently there is no computer tool available that selects suitable combinations of energy efficient technology such as CHP and renewable energy technologies for a project which takes into account the uncertainties of building energy load profiles using the Monte Carlo method. The aim of this research work was to develop a computer simulation tool to help in the decision making of choosing appropriate renewable energy and CHP systems for buildings. The tool uses the Monte Carlo method to take into account the uncertainty of building energy load profiles, using an existing large database of electricity, hot water and space heating load profiles. Details on energy load profiles of buildings and analysis of the developed computer tool is given in details in Chapter 3 and Chapter 4 respectively.


## **Chapter 3:**

### **Energy Demand in Buildings**


As discussed in Chapter 2, the energy consumption associated with buildings constitutes a large proportion of the total UK energy consumption.

When a new building is designed, it is important to consider energy at the very early stages of design. Considering the resources of the site, determining the best orientation of the building and making use of passive technologies can significantly reduce building energy requirements (Chwieduk 2003, Herbert 1998), before selecting energy technologies to cover the demand. Insulation and air tightness will reduce heating demand. However, too much insulation can cause overheating and therefore can create a need for cooling and air tightness can cause a need for mechanical ventilation. It is therefore essential that the various parameters of a building are carefully planned and balanced to ensure minimal energy wastage.

Figure 3.1 shows that domestic energy consumption has increased since 1970. This is due to there being more households since 1970 (Utley et. al. 2006). However, overall energy consumption per household has not increased since 1970 (Figure 3.2). This is due to increased energy efficiency balancing the increase in energy consumption which keeps it at a low level (Utley et. al. 2006).



**Figure 3.1 UK domestic energy consumption by end use (Utley et. al. 2006)**




**Figure 3.2 UK energy use per household (Utley et. al. 2006)**

A building's energy consumption will be largely affected by climate, orientation, its function, building shape and form. Figure 3.2 shows a variation in domestic energy consumption over the years. This variation is due to temperature variations resulting in different heating requirements from year to year (Utley et. al. 2006). The use of the building and the behaviour of the users will also influence its electricity, hot water, space heating and cooling demand.



Typical energy loads for office buildings are shown in Figure 3.3. There is large variation in energy consumption between the different types of office buildings. The use of air-conditioning is the main use that adds considerably to the energy consumption in air-conditioned offices.



**Figure 3.3 Annual delivered energy consumption for different office types (kWh/m<sup>2</sup>) (BRECSU 2000)**

Rules of thumb building energy loads used in the tool are summarised in Tables 3.1 - 3.3.

Macmillan et. al. (2004) identified available data sources of energy use in the global building stock. The main sources identified for European data were: EUROSTAT, European Environment Agency and Enerdata. This data however is mostly annual data and does not include daily consumption patterns.

**Table 3.1 Rules of Thumb Hot Water Demand** (CIBSE 2004, BSRIA 2003, Institute of Plumbing 2002)

Source	Residential						Offices	
	terraced	Semi-detached	detached	1 bed flat	2 bed flat	3 bed flat	With canteen	Without canteen
	l/person/day			l/bed/day			l/person/day	
CIBSE	68 136	68 136	68 136				14 15	
BSRIA				115	75	55	15	10
IOPG				210	130	100	45	40
High	136	136	136	210	130	100	45	40
Medium	102	102	102	162.5	102.5	77.5	22.25	25
Low	68	68	68	115	75	55	14	10

**Table 3.2 Rules of Thumb Electricity Demand** (Action Energy 2000, BSRIA 2003, Institute of Plumbing 2002)

Source	Residential (kWh/m <sup>2</sup> /year)						Offices (kWh/m <sup>2</sup> /year)	
	terraced	Semi-detached	detached	1 bed flat	2 bed flat	3 bed flat	With canteen	Without canteen
ECON19							33 54	33 51
BSRIA							54 85	51 85
IOPG	77 80	77 40	39 79	48	41	39		
High	80	77	79	48	41	39	85	85
Medium	79	59	59	48	41	39	54	53
Low	77	40	39	48	41	39	33	33

**Table 3.3 Rules of Thumb Space Heating Demand** (BSRIA 2003)

Source	Residential (W/m <sup>2</sup> )						Offices (W/m <sup>2</sup> )	
	terraced	Semi-detached	detached	1 bed flat	2 bed flat	3 bed flat	With canteen	Without canteen
BSRIA	60	60	60	60	60	60	70	70
High	60	60	60	60	60	60	70	70
Medium	60	60	60	60	60	60	70	70
Low	60	60	60	60	60	60	70	70

Daily and hourly building energy load profiles are a good medium to help understand the energy consumption patterns of a building and they are especially useful for the

design of renewable energy technologies and CHP systems, and are vital data used in the tool developed in this study.

### **3.1 BUILDING ENERGY LOAD PROFILES**

Energy load profiles for buildings depend on many factors, such as the type of building, occupancy, climate and occupancy behaviour. Occupancy behaviour in residential buildings and their effect on energy demand is investigated by Pett et. al. (2004) and Michalik et. al. (1997), recognising the uncertainty associated with their behaviour.

Monitoring of past energy use of a building will give the most accurate predictions for future energy requirements (Parker 2003). However for a new-build or some refurbishments this will not be possible. In these cases typical load profiles are estimated, by taking the monitored load profile of a similar building, an average of several, or by simulating a typical profile.

Metering existing buildings to obtain “real” load profile data for similar buildings is more accurate. However, extensive metering projects of existing buildings to obtain real load profile data would be expensive and not feasible in all cases (Akbari 1995). An alternative is to simulate load profiles. However such techniques would nevertheless also require “real” data for them to be validated (Akbari 1995).

In their model, Hawkes et al (2005) used measured residential electricity demand profiles from the BRE and heating load profiles were generated assuming heating times in the mornings and evenings of winter days. “Typical” profiles were obtained

for small, medium and large dwellings. The model in their study used 5 minute demand profiles for 6 days of the year (2 winter, 2 summer and 2 shoulder days).

Yao et. al. (2005) introduced a method to predict daily load profiles using the thermal resistant network method. The tool they developed can be used on both the macro and micro levels. They developed “typical” appliance, DHW and space heating load profiles for different dwelling types and different occupancy patterns.

Paatero et. al. (2006) used a bottom-up load model, constructing the load profiles from elementary load components.

Aydinalp et. al. (2003) described a neural network method for modelling residential energy consumption. The most commonly used methods are the engineering method and the conditional demand analysis method (Aydinalp et. al. 2003).

Diversity of demand needs to be taken into account when loads are combined for a multi-unit building, as the probability of the peaks in energy demand occurring at the same time is quite small. This can be done by applying diversity factors. Stallcup (2004) defines diversity factor as: *“the ratio of the sum of the individual maximum demands of the various subdivisions of a system, or part of a system, to the maximum demand of the whole system, or part of the system, under consideration.”* In the computer tool developed in this study, diversity is taken into account by using different load profiles and the Monte Carlo method to take into account the uncertainty of building energy load profiles.

Taking an average or “typical” load profile and scaling it to suit the project is one way of generating a typical load profile. This method was used by Cockroft et. al. (2006) to generate load profiles to compare different heat and power sources for the

UK domestic sector. Load profiles however vary depending on many factors such as occupants behaviour and climate, which are difficult to predict and a “typical” load profile therefore can’t represent all buildings of a kind. Appropriate simulation of demand patterns could possibly provide more realistic predictions. In the tool developed in this study, real load profiles are collected in a database and the Monte Carlo Method is used to take into account the uncertainty of the load profiles (see Chapter 4 for a description of the tool).

### **3.1.1 Monte Carlo Method**

Kalos et. al. (1986) and Higham (2004) give a description of the Monte Carlo Method (MCM). *“In a Monte Carlo Method successive simulations are run with the randomly generated inputs until a statistically significant distribution of outputs is obtained”* (Isukapalli 1999). The MCM can be used to take uncertainties into account. Dolan et. al. (1996) used the MCM to model residential electric water heater loads and Takoudis et. al. (2004) assessed offshore wind farm cable reliability using the Monte Carlo Method. Nishio et. al. (2006) developed a Monte Carlo simulation-based tool to generate household demand data for Japan. The application of Monte Carlo sampling can be used to find the distribution of outputs given random input variables. Coates et. al (2003) used this method to solve engineering economy problems using commonly available simulation tools. Pons et. al. (2003) compared the design for system integrity (DSI), a probabilistic methodology using the discrete combinatorial method, with the MCM and fuzzy theory, both using random variables and are both commonly used in engineering applications. Both the DSI and the MCM yielded similar output accuracies, depending on the number of iterations in the

MCM. The fuzzy theory however was not as accurate. DSI however requires probabilities associated with each input.

Gamou et al (2002) treat building energy load profiles as random variables in the sizing of CHP systems. They use a sensitivity analysis and an enumeration method to take into account their uncertainty. A similar method is used in the tool developed in this study. The Monte Carlo Method is used to take into account the uncertainty of load profiles and can also be used to take diversity into account (McQueen et. al. 2004). In the tool developed in this study, the tool does not use the same load profile for a building consisting of several units. For example, for a residential building consisting of 10 flats, the tool uses 10 load profiles, each randomly selected to create a total load profile for the building. By adopting this approach, diversity is taken into account.

The Monte Carlo method is applied as follows in the tool:

- 1) Load profiles are randomly selected from the appropriate category of the tool's load profile database. E.g. For a building consisting of 5 flats and some office space, 5 load profiles are randomly selected from the flat category of the database and one load profile is selected from the office category of the database. The 6 load profiles are then combined to create one total load profile for the building. This process is carried out for electricity, space heating and hot water load profiles.
- 2) The technologies are sized for each technology combination in the tool, giving outputs for this option, which are then stored in a spreadsheet.
- 3) Steps 1 and 2 are repeated 100 times to obtain 100 sets of outputs.

- 4) From these outputs, the most probable technology sizes and their emissions and costs are found for each technology combination (i.e. the most frequently occurring option).

Chapter 4 gives a more detailed explanation about the application of the MCM in the tool.


### **3.1.2 Space heating load profiles**

Space heating load profiles vary with climatic and weather conditions. In the UK space heating requirements will be highest in the winter months. “Typical” space heating load profiles peak in the morning and in the evening for domestic buildings (Yao et. al. 2005). Office space heating is required during office hours with a base heating only required during the night and weekends.

Little “real” space heating load profiles were found in the literature. The domestic space heating load profiles generated by Yao et. al. (2005) were therefore used in the tool and the space heating load profiles for offices were generated using rules of thumb (see Chapter 4). The load profiles could however be replaced with real data when it becomes available.


### **3.1.3 Electricity load profiles**

Figure 3.4 shows the typical electricity demand profiles on the national grid based on their recorded data. This data however represents the total demand on the grid and does not reflect the demands of individual buildings.



**Figure 3.4 Actual national grid summer and winter demand for 2002** (National Grid Group 2004)

Stokes et. al. (2004) present a model of domestic lighting demand, based on half-hourly data measured for a sample of 100 homes in the UK and Yao et. al. (2005) developed “typical” electricity load profiles for different dwelling types.



**Figure 3.5 Typical weekly electricity consumption for an office building** (Nottingham City Council 2004)



The different components of office building electricity demand profiles are investigated by Akbari (1995). The load profiles peak during office hours, with most equipment and lighting on during these times and a minimum base load during the weekend and non-occupied hours (Figure 3.5).

Nottingham City Council has kindly provided electricity load profile data from their buildings. Figure 3.5 shows an example week for one of their office buildings. This data has been incorporated into the computer tool developed in this study.

### **3.1.4 Hot water load profiles**


Domestic hot water consumption affects many aspects of the design of a hot water system, such as the sizing of hot water stores (Jordan 2000) and CHP and renewable energy system design. A total domestic hot water demand per day can be calculated from rule of thumb data. However in order to determine the potential for CHP and renewables for a building, the distribution profile of this demand during the day is also of interest. Graphically presented ‘instantaneous’ heat and power demand load data (half-hourly or hourly data) are normally used for this purpose (CIBSE 1999).

Jordan et. al. (2001) and Lutz et. al. (1996) presented simulation modelling of hot water usage patterns. Load profiles vary depending on the building type, mix of building types and number of units (e.g. flats). With existing buildings, the DHW demand and profile could be recorded over a period of time. However with new build or refurbishments where occupancy may change, then the domestic hot water demand is estimated by simulation or by using real data from similar buildings.

Hot water demand in offices is minimal, compared to residential hot water demand and occurs mostly during office hours. Hot water demand can therefore be predicted


relatively accurately by knowing office occupancy hours throughout the day. Domestic hot water demand however, is more difficult to predict.

Jordan et. al. (2000) generate realistic hot water load profiles using probabilities of hot water draw-offs of different appliances throughout the day for domestic buildings. The Energy Saving Trust is currently undertaking a monitoring study for domestic hot water energy throughout the UK (Scotland, North England, Midlands, South England) (EST 2005). This data however is not available at present.



**Figure 3.6 UK residential hot water profiles** (CIBSE 2004, Everett et. al. 1985)

A literature search for typical residential hourly domestic hot water demand profiles identified a lack of reliable data for the UK. On the other hand, a vast amount of US data is available. Figure 3.6 shows that the UK data from different sources does not follow the same pattern, whereas the US data does (Figure 3.7), which indicates that the “typical” load profile data found by the different sources is relatively accurate. Therefore, as part of this research a survey was carried out to collect domestic hot water demand profiles for the UK.



**Figure 3.7 US residential hot water demand profiles** (ASHRAE 1999, Wiehagen et. al. 2003, USDE 2000, Goldner 1994, Lutz et. al. 1996)

### 3.1.5 Conclusions

The accuracy of energy predictions is vital for a good energy system design, especially for CHP and renewable energy technologies. This data forms the basis of the design process and therefore is a major part of the tool developed in this study.

However, from the literature, not much UK load profile data has been published. The Nottingham City Council electricity load profile data for office buildings and the hot water demand survey carried out in this study are the major sources of data used in developing this tool. (See Chapter 4 for the data used in the tool.) Other load profiles could be added to the tool database as they become available.

## **3.2 DHW DEMAND SURVEY IN RESIDENTIAL BUILDINGS**

As previously mentioned, data for actual UK residential hot water demand are limited in the literature. Although space heating demand is usually larger in the UK, space heating demand is related to climate and weather and therefore more easily predicted than hot water demand. Hot water load profiles are difficult to predict, especially for residential buildings, as they depend highly on occupancy and behaviour patterns. Load profiles can differ for different households and for different days in the same household. Thus, as part of this research, a survey of DHW demand in residential buildings was carried out to obtain real DHW load profile data that was used in the tool database, and is vital to the tools MCM simulation. The survey consists of two parts: a survey questionnaire and a monitoring study.

### **3.2.1 Survey Questionnaire**

The questionnaire developed for this survey is outlined in Appendix 1. The survey consists of two parts: a general questionnaire about the dwelling and a diary study. The questionnaire enables the load profiles collected to be classified into different categories, such as building type or occupancy. In the diary study the hot water consumption patterns are recorded. The survey sample consists of 35 participants, each completing from 1 week to 18 weeks of the diary study.

The type of buildings, number of bedrooms and occupants considered in the survey is given Table 3.4.

Occupancy figures for each dwelling are usually not easily predicted when designing a new building and the number of bedrooms is usually related to the building type. The load profiles obtained were therefore classified according to building type in the

tool database. Table 3.5 summarises the number of questionnaires completed for each building type.

**Table 3.4 Occupancy and number of bedroom ranges**

<b>Building type</b>	<b>Range of occupancy</b>	<b>Range of number of bedrooms</b>
Flat	2-3	1-2
Terraced house	1-5	1-4+
Semi-detached house	2-8	2-4+
Detached house	2-6	3-4+

**Table 3.5 Number of questionnaires completed for each building type**

<b>Building type</b>	<b>Completed questionnaires</b>
Flat	3
Terraced house	8
Semi-detached house	15
Detached house	9

### **3.1.2 Monitoring Study**

The monitoring study was carried out in conjunction with the survey questionnaire. Six houses were monitored to record their hot water use. However, the reliability of measured data from two dwellings was not good and hence disregarded. The building types included in the study were: 1 flat, 2 terraced houses and 1 semi-detached house. Different options were compared to monitor the hot water consumption of the dwellings:

- a) Use of one flow meter at boiler/hot water tank outlet: This option requires one flow meter. However, this does not allow separate monitoring of hot water used for say washing up, bath, etc.


- b) Use of flow meters at boiler/hot water tank and at points of use: This option enables the monitoring of both the total flow and the flow at each point of use (kitchen, bathroom, etc...), giving a better understanding of the use of DHW in the dwelling. However the cost of flow meters is quite high as a non-intrusive ultra sonic flow meter which can be clamped to the water pipe costs around £2,000. This makes this option less cost effective and not viable for this study.
- c) Use of temperature sensors to detect hot water usage at each appliance: Temperature sensors can give a good indication when hot water is used. The Market Transformation Programme (2007) used temperature sensors attached to the hot water pipes leading to each appliance to detect when and from which appliance hot water was used. A rise in Temperature within the pipe indicates that hot water is used, and a slow decrease in water temperature thereafter indicates hot water use has ceased. The use of temperature sensors is a less expensive and more viable option.
- d) Use of a combination of flow meter and temperature sensors: Adding a flow meter at the outlet from the boiler/hot water tank to option c, would give a better understanding of the flow rates of the hot water used. A clamp-on flow meter was chosen for this purpose. Although an in-line flow meter provides more accurate readings, a clamp-on flow meter is less intrusive to the home owner and was therefore chosen for this study.

The monitoring in this study was carried out using temperature sensors attached to the hot water pipes of the different appliances within the dwellings (see Figure 3.8). When hot water was used, the temperature recorded by the sensor increased. This enabled the identification of when and from which appliance hot water was used throughout the day in the dwellings. Figure 3.9 shows an example of the temperature

change throughout the day of the hot water pipes leading to the hand basin, bath and kitchen sink in one of the houses monitored. Market Transformation Programme (2007) used this method in their pilot study for domestic hot water consumption monitoring.



**Figure 3.8 Temperature sensor**



**Figure 3.9 Example temperature sensors reading**

It is worth noting that the location of temperature sensors is important. A larger pipe for example has a longer cooling period between draw-offs and would therefore make some draw-off difficult to identify. This issue was identified by the Market Transformation Programme (2007). In some instances, when very little water is used,

hot water might leave the tank/boiler, but not reach the point of use. In this case, the temperature sensor at the boiler/tank outlet would indicate hot water use. However this hot water would not be able to be allocated to any point of use (Market Transformation Programme 2007).

Although the monitoring method of collecting data is more precise as it doesn't rely on participants remembering to record their hot water consumption, the questionnaire enabled more data to be collected. The data collected by both methods was used to form hourly hot water load profiles to be loaded into the tool.

### 3.1.3 Load profile formation

The temperature sensor and survey questionnaire data provides information on when hot water was used throughout the day. However, the amount of hot water (litres) that was used in each instance was not established. To determine this, typical hot water usage of different appliances were required.


**Table 3.6 Appliance hot water flow rates and usage** [\* data from Grant 2002]

<b>Appliance</b>	<b>Average flow rate (l/min)</b>	<b>Usage period (minutes)</b>	<b>Usage (litres)</b>
Hand basin	1.15	3	3
Shower	3.39	5	17
Kitchen sink	1.01	5	5
Bath			70*

As mentioned in Section 3.1.2 a clamp-on flow meter was used to record flow rates of different appliances to determine typical flow rates. Usage time periods of different appliances were estimated and used to calculate the typical hot water usage



of each appliance (see Table 3.6). For bath hot water usage 70 litres was assumed (Grant 2002).



**Figure 3.10 Example hot water load profiles for 3 different weekdays for a semi-detached house**

Daily hot water consumption (litres per hour)																										
Residential flat (weekday)																										
hour	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	00:00		
78	0	0	0	0	0	0	0	40	20	0	0	0	0	0	0	0	0	3	0	8	0	5	17	3		
0	0	0	0	0	0	0	0	37	0	20	0	0	0	0	0	0	0	3	0	5	3	10	0	0		
0	3	0	0	0	0	0	0	20	20	0	17	0	0	0	0	0	0	0	0	0	0	3	5	0		
0	0	0	0	0	0	17	0	20	20	3	0	0	0	0	0	0	0	0	0	0	0	5	3	0		
0	0	0	0	0	0	0	0	20	0	0	17	17	0	0	0	0	0	0	0	0	0	0	78	17		
0	0	0	0	0	0	0	0	0	40	17	0	0	0	0	0	0	0	0	5	0	0	0	22	0	0	
0	0	0	0	0	0	0	0	17	37	0	0	0	0	0	0	0	0	0	0	17	0	0	0	0	0	
0	0	0	0	0	0	17	0	0	37	0	0	0	0	0	0	0	0	0	0	0	0	5	17	0	0	
0	0	0	0	0	0	0	0	0	20	17	17	0	0	0	0	0	0	0	0	0	0	0	0	5	0	0
0	0	0	0	0	0	17	0	0	20	0	20	0	0	0	0	0	0	0	5	0	0	0	20	17	3	
0	0	0	0	0	0	17	0	0	20	0	0	0	17	0	0	0	0	0	0	0	0	0	0	0	20	
0	0	0	0	0	0	0	0	0	37	0	17	0	0	0	0	0	0	0	0	0	17	0	5	0	0	
0	0	0	0	0	0	17	0	0	20	17	0	0	0	0	0	0	0	0	0	0	17	0	5	0	0	
0	0	0	0	0	0	17	0	0	20	0	20	0	0	0	0	0	0	0	17	5	0	0	0	0	0	
0	0	0	0	0	0	17	0	0	20	17	0	0	0	0	0	0	0	0	0	0	17	0	17	0	0	
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
0	0	0	0	0	3	0	0	0	0	0	0	39	0	0	0	0	0	3	0	0	17	0	0	0	0	
0	3	0	0	0	0	0	0	0	0	0	20	20	0	5	3	3	9	0	20	0	6	0	20	3		
0	0	0	0	0	0	0	0	0	0	0	40	0	0	3	0	20	0	0	3	0	25	20	0	3		
0	0	5	17	0	0	0	0	0	0	0	17	0	0	0	0	0	20	0	3	0	5	0	0	3		
0	0	0	0	0	0	0	0	0	0	0	42	0	0	0	8	0	0	23	0	0	0	5	0	3		
0	0	0	0	0	17	0	0	0	0	0	3	20	17	0	0	0	0	0	0	0	0	0	0	0	0	
0	0	0	0	0	0	0	0	0	0	0	23	0	0	0	0	0	0	0	0	3	0	0	3	0	0	
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	
0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	17	0	5	5	0	
0	0	0	0	0	0	0	0	17	20	3	0	0	0	0	8	8	0	0	8	0	3	3	0	3	0	
0	0	0	0	0	0	0	0	3	20	17	0	3	5	5	3	0	0	0	0	0	0	3	3	0	0	

**Figure 3.11 Screenshot of the tool's hot water load profile database**

The typical hot water usages for the appliances were then combined with the survey questionnaire data and the data collected from the temperature sensors to form hot water load profiles (Figure 3.10). This data was loaded into the computer tool load profile database to be used in the tool. Figure 3.11 shows a sample screenshot of the database in the tool.

### **3.3 CONCLUSIONS**

Building energy load profiles were collected as part of this work. However, not much domestic hot water demand data was available from the literature and a survey was therefore conducted to collect domestic hot water load profiles for different residential building types. The building energy load profiles from the literature and the survey were collated to form a database for the computer tool developed in this tool.

## **Chapter 4:**

# **Computer Simulation Tool Development**

### **4.1 INTRODUCTION**

The development of the computer tool is described in this chapter. This computer tool allows suitable combinations of renewable energy technologies and combined heat and power (CHP) systems to be selected for a building. It enables the selection of more appropriate technologies for the supply of electricity, hot water and space heating by optimising the integration of the combined technologies for different building types. The tool also aims to facilitate the decision-making process of the designers, by identifying workable solutions for a project, as well as streamlining the number of options from which a reliable decision could be made.

### **4.2 DESCRIPTION OF THE COMPUTER TOOL**

The computer tool was developed using Visual Basic for Application (VBA) in Excel to size and compare different combinations of CHP and renewable energy technologies for different building types. VBA in Excel was chosen as it is widely available to designers. The Monte Carlo Method is used to take into account the uncertainties of building energy load profiles in order to provide a most probable output from the tool. One of the specific outputs of the tool is the techno-economic

analysis and carbon savings from which selected renewable energy/CHP combinations can be compared and provide the decision-makers with the required information.

The main technologies that can be analysed by the computer tool include one or a mixture of the following technologies: gas-fired CHP systems, solar thermal systems, PV panels, fossil fuel boilers and national grid electricity.


The tool is developed in two Excel files each combining a different renewable energy technology (Photovoltaics and Solar Thermal) with CHP. Each tool consists of 3 main blocks designated as block A to C where:

- A. The building loads and load profiles are processed in Block A.
- B. Sizing and selection of technical parameters of technologies followed by a financial and environmental analysis is carried out in Block B.
- C. A comparison and evaluation analysis of technologies or combination of technologies is finally given in Block C that would facilitate the selection of the appropriate option.

A detail of each block is given as follows:

#### **4.2.1 BLOCK A: Determining the building loads and load profiles**


The first step in selecting a cost effective technology for a building using the computer tool is to determine the building's energy loads and load profiles. The procedure for analysing energy loads of a building is given in the flow chart of Figure 4.1.



**Figure 4.1 Block A - Building loads and load profiles**

Prior to starting the analysis, in Block A a user interface window appears, as shown in Figure 4.2, that prompts the user to choose between two options: an already

existing project or to start a new one. If an already existing project is selected, the tool skips the following steps of Block A and goes directly to the interface, summarizing the building loads (Figure 4.6). If a new project is selected further user interface windows, which form part of block A, will be displayed to perform the building energy loads calculations. These steps are described below.



**Figure 4.2 User interface start window**

#### **a) Building Energy Loads**

If a new project is selected in Figure 4.2 information about the project building types is entered on the user interface shown in Figure 4.3. The tool first gives an estimate of energy consumption including building space heating, hot water and electrical power using rules of thumb data determined by the tool user. Cooling is currently not included in the tool; however it could be incorporated at a later stage. Rules of thumb energy consumption data for building is classified as high, medium or low. Rule of thumb load data for different types of buildings have been formulated from the values reported in various reference sources (see Tables 3.1, 3.2 and 3.3). Depending on the characteristics of the building, high, medium or low building loads can be selected or other rules of thumb can be entered. For a mixed-use project (i.e. a complex with

different building types) the information is entered for each building type. This is done by selecting “Next Building Type”, after having entered the information for the first building type. This is repeated until the information for each building type has been entered.

**Rules of Thumb Building Loads**

Please enter the details below for building type 2 or press FINISH.

**Building Type** Residential 1 bedroom flat

**Floor Area** 50 m<sup>2</sup>

**Number of dwellings** 15 (max 100)

Rules of Thumb		Loads	
Low	Medium	Hot Water	1725 litres
		Heating	45 kW
		Electricity	30000 kWh

Back Next Building type Finish

**Figure 4.3 Rules of Thumb user interface**

The rule of thumb (RoT) building energy load calculation is carried out by the tool as follows:

- RoT hot water demand ( $D_{HW}$ ): Hot water rule of thumb loads are given in litres per person per day for houses and office and in litres per bedroom per day for flats.

For houses and offices:

$$D_{\text{HW}} (\text{l/day}) = \text{RoT} (\text{l/person}) \times \text{Occupancy} \quad \text{Equation 4.1}$$

For flats, hot water demand:

$$D_{\text{HW}} (\text{l/day}) = \text{RoT} (\text{l/bedroom}) \times \text{Number of bedrooms} \quad \text{Equation 4.2}$$

- RoT space heating demand ( $D_{\text{SH}}$ ):

$$D_{\text{SH}} (\text{W}) = \text{RoT} (\text{W/m}^2) \times A_f (\text{m}^2) \quad \text{Equation 4.3}$$

Where  $A_f$  is floor area ( $\text{m}^2$ )

- RoT electricity demand ( $D_e$ ):

$$D_e (\text{kWh/year}) = \text{RoT} (\text{kWh/m}^2/\text{year}) \times A_f (\text{m}^2) \quad \text{Equation 4.4}$$

This calculation is carried out for each building type entered by the tool user and the results are added to provide total RoT hot water, space heating and electricity demands for the building or group of buildings considered in a project.

## **b) Building Energy Load Profiles**

Hourly building energy load profiles for electricity, hot water and space heating consumption for a typical day are required for the tool to carry out the necessary calculations. This information can either be entered by the user or can be selected by the tool from its load profile database. The user interface window appears as shown in Figure 4.4. If load profiles are known with certainty, for example in the case of an existing building, then the hourly consumption for hot water, space heating and electricity can be entered in the user interface window as shown in Figure 4.5. A week-day load profile and a weekend load profile are entered for hot water



(litres/hour), for space heating (kWh/hour), and for electricity (kWh/hour) for a day in January.



**Figure 4.4 Load profile selection interface window**

If the load profiles are known and entered by the user, a single process sizing calculation is carried out by the tool resulting in a single final output. However, if the load profiles are not known and it is required that this information is selected from the tool database, then a multiple process calculation is carried out using the Monte Carlo method, resulting in multiple results to reflect the uncertainty in the load profile data.

The database holds information on a number of daily load profiles for the building types RESIDENTIAL and OFFICES. The building energy load profiles data base was compiled from sources shown in Table 4.1. The data was collected from the domestic hot water demand survey as explained in Chapter 3, from the literature, and where no data was available, load profiles were derived using the rules of thumb given in Tables 3.1, 3.2 and 3.3. Then the derived load profiles would progressively be replaced with actual load profiles, as and when these become available.

Input Hot Water Load Profile

Please input the building's Hot Water Load Profile for a typical day below.

	WEEKDAY	WEEKEND	
01:00	7	9	litres
02:00	2	12	litres
03:00	33	3	litres
04:00	41	22	litres
05:00	41	11	litres
06:00	41	6	litres
07:00	41	13	litres
08:00	41	17	litres
09:00	41	9	litres
10:00	41	42	litres
11:00	41	29	litres
12:00	41	159	litres
13:00	41	230	litres
14:00	41	123	litres
15:00	41	24	litres
16:00	41	21	litres
17:00	41	30	litres
18:00	41	115	litres
19:00	41	60	litres
20:00	41	199	litres
21:00	41	138	litres
22:00	41	64	litres
23:00	41	56	litres
24:00	41	83	litres

Back Next

Figure 4.5 Load Profile input interface window

Table 4.1 Building Energy Load Profile Data Sources

Building type	Space heating	Hot water	Electricity
Residential	Literature (Yao 2005)	Survey (section 3.2)	Literature (Yao 2005)
Office	Derived from rules of thumb	Derived from rules of thumb	Nottingham City Council for council office buildings


Data used for residential load profiles are classified under building types, i.e. flats, terraced houses, semi-detached houses and detached houses. This classification was chosen as residential building types have certain size, occupancy, and occupancy behaviour pattern associated with them, which have an effect on their energy load profiles. Office load profiles are presented in energy units per square meter of floor area, as offices can be of many different sizes and the loads and load profiles are mainly dependant on the size of the office. Building energy load profiles for both residential and office buildings are further classified under weekday or weekend, as energy consumption behaviour is generally different for these days. The units of the load profiles are shown in Table 4.2.

**Table 4.2 Building energy load profile units**

<b>Building type</b>	<b>Space heating</b>	<b>Hot water</b>	<b>Electricity</b>
Residential	kWh/ dwelling	Litres/ dwelling	kWh/ dwelling
Office	kWh/ m <sup>2</sup>	Litres/ m <sup>2</sup>	kWh/ m <sup>2</sup>

If the building energy load profiles are not known, the tool selects load profiles from its database in the following manner: Each load profile has a number associated with it. From these, the tool generates a random number, and then selects the load profile associated with this number. For example, there are 43 hot water load profiles for flats. So if a building consisting of 5 flats is investigated, a number from 1 to 43 is randomly generated, assume it is 4 then the load profile number 4 is selected. This is then repeated 4 times in this case to generate 5 load profiles for flats. These are then combined to give one load profile for the building of 5 flats. This process is repeated for space heating and electricity demand profiles and for a weekday and a weekend day respectively.

The loads of every hour in a day for a typical January day are summed up to give daily building loads. These are summarised in a user interface window as shown in Figure 4.6.



**Figure 4.6 Loads output interface window**

The hot water demand profile is converted from litres to kWh. The energy required to heat a specific amount of water is:

$$Q_E = mc_p\Delta T \quad \text{Equation 4.5}$$

Where, Q is energy (J), m is mass (g),  $c_p$  is specific heat capacity (J/gK) = 4.2 J/gK for water and  $\Delta T$  is the temperature difference between the temperature of the cold water supply to the building and the hot water temperature required (K).

Assuming 1 litre = 1 kg and  $\Delta T = 60-5 = 55\text{K}$ , equation 4.6 is used to calculate the hot water demand in kWh:

$$D_{\text{HW}} (\text{kWh}) = D_{\text{HW}} (\text{litres}) \times 4.2 \times 55 / 3600. \quad \text{Equation 4.6}$$

Given the difficulty in obtaining hot water load profiles and for the purpose of the computer tool, these are assumed to be the same throughout the year. In addition,

seasonal variation in space heating and power consumption is taken into account by applying a load factor to the space heating and electricity loads in order to calculate the total monthly loads, as shown in Table 4.3.

To calculate monthly loads, it is assumed that there are  $365 \times 5 / 7 / 12 = 21.726$  weekdays per months and  $365 \times 2 / 7 / 12 = 8.69$  weekend days per month. Monthly loads for space heating, hot water and electricity are therefore calculated as:

$$D_M = [(21.726 \times D_{M,WD}) + (8.69 \times D_{M,WE})] \times f \quad \text{Equation 4.7}$$

Where,  $D_M$  is total monthly load (kWh),  $D_{M,WD}$  is monthly weekday demand (kWh),  $D_{M,WE}$  is monthly weekend demand (kWh), and  $f$  is monthly load factor.

**Table 4.3 Space heating and electricity load factors for the UK (Elexon 2006)**

Month	Space heating load factors	Electricity load factors
January	1.00	1.00
February	0.89	0.92
March	0.73	0.83
April	0.51	0.74
May	0.21	0.68
June	0.00	0.64
July	0.00	0.62
August	0.00	0.63
September	0.00	0.67
October	0.27	0.77
November	0.63	0.90
December	0.89	0.98

The annual demands of space hot water, space heating and electricity are calculated by adding the demands for each month.

#### **4.2.2 BLOCK B: Technology combinations: sizing and financial and environmental appraisals**

In this section, different combinations of technologies are evaluated to provide energy in a building in a cost effective and environmentally friendly way.


The following technologies and combination of technologies have been considered for the supply of heat and power in buildings:

- i) Option 1: A combination of Boiler and electricity grid (Boiler + EGrid)
- ii) Option 2: A combination of CHP system for base heat and power load, Boiler and Electricity Grid (CHP + Boiler + EGrid)
- iii) Option 3: Combination of Renewable energy systems (PV or Solar Thermal), Boiler and Electrical Grid (PV/Solar Thermal + Boiler + EGrid)
- iv) Option 4: Combination of Combined Heat and Power, renewables (PV or Solar Thermal), Boiler and Electrical grid (CHP + PV/Solar Thermal + Boiler + EGrid)

Two models have been developed: combinations of the above with either Solar Thermal (ST) or Photovoltaics (PV) as the renewable energy. Each of these combination options have been developed as a separate Excel spreadsheet subroutine model. The sizing orders of the technologies for each option developed as part of Block B is given in the flow chart diagram of Figure 4.7.

Option 1 represents the conventional way of supplying heat and power in buildings, using the electricity grid for power and a boiler for hot water and space heating,. This option forms the base case in the computer tool.

Option 2 takes into account the use of a CHP system to meet part of the heat and power demand of the building. The CHP system in such a scheme is usually sized to provide base load heat in order to maximise the number of running hours per year. The boiler and grid are used to supply peak heat and power loads respectively.



**Figure 4.7 Block B –Technology combinations flow chart**


In option 3, renewable solar energy systems with PV and/or Solar Thermal (ST) collectors are combined with boiler and grid. Again, the renewable energy systems provide the base load and the boiler and electricity grid supply the remaining heat and electricity demand.

In option 4, all the technologies are considered. In the PV subroutine tool, CHP provides the base load, then PV providing the intermediate load and finally a boiler and grid demand supply peak loads. For the ST subroutine tool, there is an optimum

combination of CHP and ST with the boiler and grid supplying the remaining heat and electricity demands.

**a) Block B1: Boiler and electricity grid (Boiler+EGrid) combination**

The boiler and grid option is the conventional means of supplying heat and electricity and is, therefore, the base case against which all other combinations are compared in terms of costs and emissions. The Boiler + EGrid option is incorporated into all other technology combinations. The flow chart for Block B1 is given in Figure 4.8.



**Figure 4.8 Block B1: Boiler + EGrid**

The sizing procedures carried out by the tool for the boiler, hot water storage, and electricity grid demand are outlined as follows:




The boiler should be sized to meet the heat demand of the building at a design temperature consistent with prevailing weather conditions. The boiler energy rate could be given as follows:

$$S_b = \frac{D_{H,p}}{\eta_b} \quad \text{Equation 4.8}$$


Where,  $S_b$  = boiler size (kW),  $D_{H,p}$  = peak heat demand (kW) and  $\eta_b$  = gross boiler efficiency (%).

The peak space heating load (in kW) is obtained from the daily space heating load profile for severe weather conditions which often coincide with the month of January. The peak domestic hot water demand is obtained from the daily hot water demand profile defined in Block A. In this work it was assumed that a boiler has a minimum efficiency of 80% gross (Harvey 2006). The hot water storage is sized to provide 1/3 of the daily hot water demand (The Institute of Plumbing 2002) and is given in litres. The electricity demand is met by the national electricity grid. The electricity from the grid is given as annual demand expressed in kWh/year and which is calculated from the electricity load profile. The output parameters of Block B1 subroutine is shown in the user interface window of Figure 4.9.



**Figure 4.9** Outputs parameters of block B1: Boiler and Grid (Boiler + EGrid)

Next an economic and environmental evaluation is carried out by determining cost and emissions for the boiler and grid option. The tariffs for gas to run the boiler and electricity from the grid are assumed to be 2.28p/kWh and 8.2p/kWh respectively (DTI 2006). Like CHP systems, a boiler capital cost is assumed to vary according to its size in kW as shown Figure 4.10. However the capital cost of boilers are about 150£/kW lower than that of CHP systems (EST 2006).



**Figure 4.10 Boiler installed capital costs** (EST 2006, University of Strathclyde 2006)

The annual cost of boiler maintenance is assumed to be 2% of the boiler capital cost (EST 2006, University of Strathclyde 2006). In addition the cost of the boiler disposal needs to be taken into account and this is estimated to be equivalent to twice the annual boiler maintenance cost.

Cost parameters of the system can be altered on the next user interface window as shown in Figure 4.11.

Costs and Emissions Boiler+Grid Option

Please review the values below and change them if necessary.

	Gas	Electricity
Fuel Costs (p/kWh)	2.28	8.2
Project lifetime (years)	30	
Discount rate (%)	5	
<b>BOILER</b>		
Lifetime (years)	15	
Capital Cost (£)	32555	
Maintenance Cost (£/year)	652	
Disposal Cost (£)	1304	

Back Next

**Figure 4.11 Boiler and Grid Costs and Emissions**

The tool calculates the gas and electricity consumption for each combination of technologies (in kWh/year), taking into account the efficiencies of the technologies for electricity and gas. If renewable energy technologies are used, then the total fuel consumption of the technology combination can be reduced.

To calculate emissions associated with each option, emission factors are assumed to be 0.43 kg CO<sub>2</sub> /kWh for grid electricity, 0.19 kg CO<sub>2</sub> /kWh for natural gas and 0 kg CO<sub>2</sub> /kWh for Renewables (DEFRA 2005). For the ST system, emissions associated with the electricity consumption of the pump are taken into account.

The tool calculates the total CO<sub>2</sub> emission in kg CO<sub>2</sub> for each technology combination using the following equation:

$$E_{CO_2} = (D_e \times EF_e) + (D_g \times EF_g) \quad \text{Equation 4.9}$$

where,  $E_{CO_2}$  is CO<sub>2</sub> Emissions (kg CO<sub>2</sub>),  $D_e$  is electricity consumption (kWh),  $EF_e$  is electricity emission factor (kg CO<sub>2</sub>/kWh),  $D_g$  is gas consumption (kWh), and  $EF_g$  is gas emission factor (kg CO<sub>2</sub>/kWh).

To enable comparison of the different options, the unit cost of energy production (in p/kWh) is calculated. The net present value (NPV) methodology is adopted in the tool (Northcott 2002).

The life cycle energy cost is calculated for each combination option modelled in the tool. For example, considering the Boiler + EGrid option, the overall system life cycle cost is calculated as follows;

- The lifetime energy output is calculated for the boiler using the following expression:

$$O_L = O_A \times n \quad \text{Equation 4.10}$$

where,  $O_L$  is the lifetime output (kWh),  $O_A$  is the annual output (kWh), and  $n$  is the project lifetime (years).

- NPV capital cost:

$$CC_{NPV} = CC_{current} + CC_{NPVreplacement} \quad \text{Equation 4.11}$$

where,  $CC_{NPV}$  is Capital cost (£),  $CC_{current}$  is Current capital cost (£),  $CC_{NPVreplacement}$  is NPV replacement cost (£).

The replacement of the boiler is taken into account in the capital cost if the boiler lifetime is shorter than the project lifetime.

- NPV boiler replacement cost:

$$CC_{NPVreplacement} = CC_{current} \times (1 + DR)^n \quad \text{Equation 4.12}$$

Where,  $DR$  is the discount rate (%).

- NPV fuel cost:

$$FC_{NPV} = FC_{current} \times [1 - (1 + DR)^{-n}] \div DR \quad \text{Equation 4.13}$$

where,  $FC_{NPV}$  = NPV Fuel cost (£) and  $FC_{current}$  = Current annual fuel cost (£)

- NPV maintenance cost:

$$MC_{NPV} = MC_{current} \times [1 - (1 + DR)^{-n}] \div DR \quad \text{Equation 4.14}$$

where,  $MC_{NPV}$  = NPV Maintenance cost (£),  $MC_{current}$  = Current annual maintenance cost (£)

- NPV disposal cost:

$$DC_{NPV} = DC_{current} \times (1 + DR)^{-n} \quad \text{Equation 4.15}$$

where,  $DC_{NPV}$  = NPV Disposal cost (£),  $DC_{current}$  = Current disposal cost (£)

- The costs are summed up to give a total net present value cost:

$$C_{NPVtotal} = CC_{NPV} + FC_{NPV} + MC_{NPV} + DC_{NPV} \quad \text{Equation 4.16}$$

where,  $C_{NPVtotal}$  = Total NPV cost (£)

- The boiler energy cost is obtained as follows:

$$EC_{boiler} = \frac{C_{NPVtotal}}{O_L} \times 100 \quad \text{Equation 4.17}$$

where,  $EC_{boiler}$  = Boiler system energy cost (p/kWh),  $C_{NPV,total}$  = Total NPV cost of boiler system (£) and  $O_L$  = lifetime boiler output (kWh)

- System energy cost:

The system energy cost is evaluated by first calculating the energy cost for the production of heat (in this case the boiler energy cost) and for the production of electricity (in this case the grid electricity cost). A system energy cost for the option Boiler + EGrid is obtained using the equation below:

$$EC_{system} = \frac{[(EC_{boiler} \times D_h) + (EC_{EGrid} \times D_e)]}{(D_h + D_e)} \quad \text{Equation 4.18}$$

where,  $EC_{system}$  is System energy cost (p/kWh),  $EC_{EGrid}$  is Electricity Grid Energy cost (p/kWh),  $D_h$  is heat demand (kWh), and  $D_e$  is electricity demand (kWh).

Energy cost calculations for the options “CHP+Boiler+EGrid”, “PV+Boiler+EGrid”, “PV+CHP+Boiler+EGrid”, “ST+Boiler+EGrid”, and “ST+CHP+Boiler+EGrid” are carried out in a similar fashion.

Annual CO<sub>2</sub> emissions and emissions per kWh are calculated next for the Boiler and Grid option. Annual emissions are calculated as follows:

$$E_{CO2} = f_E \times FI \quad \text{Equation 4.19}$$

Where,  $E_{CO2}$  is annual emissions (kg CO<sub>2</sub>),  $f_E$  is the CO<sub>2</sub> emissions factor (0.19 kg CO<sub>2</sub>/kWh for gas and 0.43 kg CO<sub>2</sub>/kWh for electricity), and  $FI$  is the annual fuel input (kWh).

The total annual emissions,  $E_{CO2,Total}$  (kg CO<sub>2</sub>) are calculated for the boiler:

$$E_{CO2,Total} = E_{CO2,boiler} + E_{CO2,grid} \quad \text{Equation 4.20}$$

Where, annual emissions (kg CO<sub>2</sub>) from the boiler:  $E_{CO_2,boiler} = 0.19 \times FI$  and annual emissions (kg CO<sub>2</sub>) from the grid:  $E_{CO_2,grid} = 0.43 \times FI$

Emissions per kWh are calculated as follows:

$$E_{CO_2/kWh} = \frac{E_{CO_2,total}}{(D_H + D_e)} \quad \text{Equation 4.21}$$

Where,  $E_{CO_2/kWh}$  is emissions (kg CO<sub>2</sub>/kWh),  $D_H$  is annual heat demand (kWh) and  $D_e$  is annual electricity demand (kWh).

### **b) Block B2: CHP**


Figure 4.12 shows the flow chart for Block B2. In this tool it is assumed that the CHP heat to power fraction is 2:1. The overall efficiency of CHP system is usually considered to be 80% or above.

The suitability of CHP schemes depends strongly on the number of running hours with 4500 hours per annum as a general guideline for implementation of CHP projects (CIBSE 1999). Therefore, the tool's subroutine of Block B2 first checks if there is a demand for at least 4500 hours from the hot water and space heating load profiles. Only when this criterion is met then the CHP sizing is carried out.

For every hour, it is assumed that the CHP is running when there is a heat demand in that hour. The hours the CHP is running are then added up by the tool to give total running hours per year.

CHP is usually sized to match base heat load (BRECSU 1996). The base load would normally be the hot water demand of a building as this is the load that is present throughout the year. However, sizing the CHP system above base load is usually

favoured as it offers better returns on investments and the reduction of CO<sub>2</sub> emissions. Table 4.4 shows a simple comparative study of two CHP schemes with one providing base load and the other above base load in 10 residential flats. It can be seen that option 1, which sizes the CHP above base load, achieves lower emissions with a smaller CHP size and a lower system cost than option 2 which provides only base heat load. The computer tool therefore sizes CHP by using the total heat load profile for the project. The optimum size of CHP in terms of costs and emissions is calculated by minimising the saved costs of emissions in £/kg CO<sub>2</sub>.



**Figure 4.12 Block B2: CHP**

If the CHP unit is sized above the base load and there is no demand for heat, then hot water could be stored or the system shut down. Any surplus heat produced could be stored for the next period of the heating cycle where a boiler would supply any deficit in heat generation. In this computer subroutine, the storage capacity is



assumed to be 50% of the surplus heat produced by the CHP in a summer day of the month July.

**Table 4.4 Comparison of CHP Sizing options**

	<b>Option 1</b> (sized on total heat load: above base load)	<b>Option 2</b> (sized on water load: base load only)
Optimum CHP size (kWth)	4	3
System cost (p/kWh)	2.6	2.9
Emissions (kg CO <sub>2</sub> /kWh)	0.24	0.26
£/kg CO <sub>2</sub> saved	2.2	5.1

The sizing procedure for the CHP is as follows: The tool records cost of emissions saved (£/kg CO<sub>2</sub> saved) for every kW thermal rating of CHP starting with 1 kW until a CHP size is reached that achieves less than 4500 running hours. From this list, the tool then selects the CHP size achieving the lowest £/kg CO<sub>2</sub> saved.

Table 4.7 shows an example table calculating the demand and supply of heat and power for the CHP system and CHP running hours for a typical January day. Hourly heat and electricity demands are listed in the table. CHP running hours are determined (CHP is running if there is a heat demand), and the CHP heat and electricity outputs are listed. The deficit and surplus heat and electricity are calculated for each hour:

$$Deficit = D - O_{CHP} \quad \text{Equation 4.22}$$

$$Surplus = O_{CHP} - D \quad \text{Equation 4.23}$$

Where,  $D$  is electricity or heat demand (kWh) and  $O_{CHP}$  CHP electricity or heat output (kWh).

The total heat deficit for a day is calculated taking into account the heat storage. The equation used in the cell in the Excel sheet is:

If Surplus (kWh/day) < Storage capacity (kWh/day),

Then *Total Deficit* = *Deficit* – *Surplus*,

Else *Total Deficit* = *Deficit* – *Storage capacity*. Equation 4.24

Where, *Total Deficit* is the heat deficit taking into account heat storage (kWh/day), *Deficit* is the heat deficit before taking into account the heat storage (kWh/day) and *Surplus* is the heat surplus (kWh/day).

In the tool’s CHP spreadsheet, there are 12 tables like Table 4.5, one for a typical day in each month.

**Table 4.5 January demand vs supply for CHP**

January											
Time	Heat demand (kWh)			CHP hours	CHP (kWh)			Electricity demand	CHP (kWh)		
	SH	HW	Total		Output	Deficit	Surplus		Output	Deficit	Surplus
1	7.4	1.0	8.3	1	10	0.0	1.7	6.0	5	1.0	0.0
2	14.7	1.3	15.9	1	10	5.9	0.0	4.9	5	0.0	0.1
3	21.8	0.0	21.8	1	10	11.8	0.0	5.1	5	0.1	0.0
4	14.2	0.0	14.2	1	10	4.2	0.0	4.8	5	0.0	0.2
5	19.9	0.0	19.9	1	10	9.9	0.0	4.7	5	0.0	0.3
6	10.0	0.4	10.3	1	10	0.3	0.0	4.9	5	0.0	0.1
7	128.1	3.3	131.3	1	10	121.3	0.0	7.3	5	2.3	0.0
8	104.4	0.0	104.4	1	10	94.4	0.0	16.1	5	11.1	0.0
9	109.4	13.7	123.1	1	10	113.1	0.0	21.2	5	16.2	0.0
10	35.4	8.3	43.7	1	10	33.7	0.0	22.0	5	17.0	0.0
11	41.2	10.2	51.4	1	10	41.4	0.0	23.0	5	18.0	0.0
12	38.6	14.9	53.5	1	10	43.5	0.0	21.7	5	16.7	0.0
13	32.6	10.8	43.4	1	10	33.4	0.0	23.2	5	18.2	0.0
14	49.1	8.0	57.1	1	10	47.1	0.0	24.3	5	19.3	0.0
15	37.8	13.3	51.2	1	10	41.2	0.0	23.2	5	18.2	0.0
16	58.4	5.8	64.2	1	10	54.2	0.0	22.6	5	17.6	0.0
17	51.2	4.5	55.7	1	10	45.7	0.0	23.6	5	18.6	0.0
18	102.8	7.6	110.4	1	10	100.4	0.0	22.6	5	17.6	0.0
19	67.4	5.6	72.9	1	10	62.9	0.0	24.6	5	19.6	0.0
20	80.4	1.0	81.3	1	10	71.3	0.0	30.0	5	25.0	0.0
21	64.6	8.1	72.7	1	10	62.7	0.0	25.9	5	20.9	0.0
22	33.9	5.9	39.8	1	10	29.8	0.0	23.4	5	18.4	0.0
23	7.4	5.1	12.4	1	10	2.4	0.0	15.8	5	10.8	0.0
24	12.1	14.7	26.7	1	10	16.7	0.0	9.8	5	4.8	0.0
			1285.7		240	1047.3	1.7	410.5903	120	291.3	0.71207
						1045.7	1.7			6335.8	

The annual heat and electricity deficits and surpluses are calculated by first calculating monthly figures (assuming each day in the same month is the same) and then adding the monthly figures to obtain yearly ones.

For heat and electricity:

$$- \text{Deficit}_{\text{monthly}} = [(\text{Deficit}_{\text{WD}} \times 21.726) + (\text{Deficit}_{\text{WE}} \times 8.69)] \quad \text{Equation 4.25}$$


Where,  $\text{Deficit}_{\text{monthly}}$  is monthly deficit (kWh),  $\text{Deficit}_{\text{WD}}$  is weekday deficit (kWh), and  $\text{Deficit}_{\text{WE}}$  is weekend day deficit (kWh).

$$- \text{Surplus}_{\text{monthly}} = [(\text{Surplus}_{\text{WD}} \times 21.726) + (\text{Surplus}_{\text{WE}} \times 8.69)] \quad \text{Equation 4.26}$$


Where,  $\text{Surplus}_{\text{monthly}}$  is monthly surplus (kWh),  $\text{Surplus}_{\text{WD}}$  is weekday surplus (kWh), and  $\text{Surplus}_{\text{WE}}$  is weekend day surplus (kWh).

Any surplus electricity generated is exported to the grid and the annual electricity demand from the grid is equal to the annual electricity deficit as calculated above. The optimum CHP size is found as explained above, and the CHP heat store is assumed to be 50% of the surplus heat produced by the CHP in a summer day of the month July. The Boiler is sized on the deficit heat demand as in block B1. Figure 4.14 shows the user interface window that summarises these outputs.

Like boilers, installed capital and maintenance costs for CHP are strongly dependent on power rating in kW of electrical output with the disposal cost to be equivalent to twice the annual maintenance cost. Figure 4.14 shows the trend for capital cost of CHP systems. Maintenance costs are assumed to be 2% of capital costs of the CHP (EST 2006, University of Strathclyde 2006) and disposal costs are double the annual maintenance costs.



**Figure 4.13: CHP, Boiler and Grid Sizing Outputs interface**



**Figure 4.14 Installed CHP capital costs (EST 2006, University of Strathclyde 2006)**

Then another user interface asks for further changes of data, such as service life, capital cost, etc as shown in Figure 4.15.

Costs and Emissions CHP+Boiler+Grid Option

Please review the values below and change them if necessary.

	CHP	BOILER
Lifetime (years)	20	15
Capital Cost (£)	8929	30715
Maintenance Cost (£/year)	179	615
Disposal Cost (£)	358	1230
Electricity export price	3	p/kWh

Back Next

**Figure 4.15: CHP and boiler costs interface**

Emissions and NPV system energy cost are calculated in a similar fashion as in Block B1. In addition, cost of emissions savings (£/kg CO<sub>2</sub> saved) and % emissions saved figures are calculated for this technology combination using the Boiler and Grid option as the base case.

Emissions saved,  $ES_{CO_2}$  (kg CO<sub>2</sub> saved) for the CHP, Boiler and Grid option is:

$$ES_{CO_2,CBG} = E_{CO_2,BG} - E_{CO_2,CBG} \quad \text{Equation 4.27}$$

Where,  $ES_{CO_2,CBG}$  is emissions saved in the CHP, Boiler and Grid option (kg CO<sub>2</sub> saved),  $E_{CO_2,BG}$  is emissions of the boiler and grid option (kg CO<sub>2</sub>), and  $E_{CO_2,CBG}$  is emissions of the CHP, boiler and grid option (kg CO<sub>2</sub>).

Cost per emissions savings, ESC (£/kg CO<sub>2</sub> saved) is calculated for the CHP, Boiler and Grid option:

$$ESC = \frac{(D_H + D_e) \times EC_{system}}{ES_{CO_2}} \quad \text{Equation 4.28}$$

Where, *ESC* is cost per emissions savings (£/kg CO<sub>2</sub> saved), *D<sub>H</sub>* is heat demand (kWh), *EC<sub>system,heat</sub>* is systems energy cost for heat (£/kWh), *D<sub>e</sub>* is heat demand (kWh), and *EC<sub>system,electricity</sub>* is systems energy cost for heat (£/kWh).

### c) Block B3: Renewable Energy Technologies

Block B3 has been developed for the two different Excel tools:

- i) A combination of Photovoltaic (PV) + CHP + Boiler + Grid
- ii) A Combination of Solar thermal (ST) + CHP + Boiler + Grid




Figure 4.16: Block B3a – PV




Figure 4.17: Block B3b – ST

Figures 4.16 and 4.17 show the flow diagrams of the two subroutine programmes for block B3. The subroutine programmes of block B3 specifically enable the determination of the required size for PV and solar thermal technology using the following procedures.

**i) PV sizing**

To maximise conversion of solar radiation into electricity a PV panel should have a tilt angle equal to approximately  $\pm 15$  degrees the angle of latitude of the site. In the UK, a south facing PV panel with a 30 degrees tilt angle from the horizontal yields the best results [DTI (1999)]. Assuming that the PV panel is not shaded, the area of the panel for a given amount of electrical energy to be harvested over a period of time is by CIBSE (2000):

$$S_{PV} = \frac{D_e}{I_s(1-L)\eta_{PV}} \quad \text{Equation 4.29}$$

where,  $S_{PV}$  is the PV required area( $m^2$ ),  $D_e$  is the electricity demand (kW),  $I_s$  is the incident solar radiation ( $kW/m^2$ ),  $\eta_{PV}$  is the efficiency of the PV cells, and  $(1-L)$  is the efficiency of the power conditioner (inverter, controller), transformer and interconnection.

Polycrystalline PV panels are currently the most commonly used type of PV cells (International Energy Agency 2003). With a maximum efficiency of 14% and losses of 25% due to the power conditioner (inverter, controller), transformer and interconnection (CIBSE 2000), polycrystalline panels have been adopted in this computer tool. However, other types of PV could be incorporated. In this way the

user could compare the different PV cells before choosing the type of PV to be installed.

Table 4.6 shows the hourly simulation of the PV system for a typical July day. The system is simulated for a typical day in each month, to get an understanding of the yearly performance of the system.

**Table 4.6 Hourly PV simulations for a typical July day**

July		0.62	0.62					
Time	weekday Electricity demand	weekend Electricity demand	Solar irradiance (W/m <sup>2</sup> )	PV output (kWh)	weekday deficit (kWh)	weekday surplus (kWh)	weekend deficit (kWh)	weekend surplus (kWh)
1	4.4	4.2		0	4.4	0	4.2	0
2	5.9	4.5		0	5.9	0	4.5	0
3	7.0	5.3		0	7.0	0	5.3	0
4	6.9	5.6	27	1.44	5.4	0	4.2	0
5	7.0	6.1	70.5	3.76	3.3	0	2.3	0
6	6.9	6.3	143.25	7.64	0.0	0.71	0.0	1.37
7	9.1	6.9	246	13.12	0.0	4.05	0.0	6.18
8	14.2	10.1	346	18.46	0.0	4.25	0.0	8.37
9	17.7	12.2	429.5	22.91	0.0	5.17	0.0	10.70
10	19.1	12.5	488.75	26.07	0.0	6.99	0.0	13.61
11	21.4	15.2	519.25	27.70	0.0	6.25	0.0	12.53
12	21.7	15.1	519.25	27.70	0.0	5.98	0.0	12.58
13	21.1	15.0	488.75	26.07	0.0	5.01	0.0	11.04
14	22.6	16.0	429.5	22.91	0.0	0.35	0.0	6.94
15	22.9	15.5	346	18.46	4.5	0	0.0	2.94
16	23.0	15.4	246	13.12	9.9	0	2.3	0
17	24.4	16.7	143.25	7.64	16.8	0	9.1	0
18	26.3	18.5	70.5	3.76	22.6	0	14.7	0
19	29.1	22.5	27	1.44	27.7	0	21.1	0
20	30.8	28.4		0	30.8	0	28.4	0
21	28.5	29.0		0	28.5	0	29.0	0
22	28.1	28.4		0	28.1	0	28.4	0
23	23.6	23.8		0	23.6	0	23.8	0
24	21.1	21.2		0	21.1	0	21.2	0
	442.9	354.5	4540.5					

Hourly PV output,  $O_{PV}$  (kW) is calculated:

$$O_{PV} = S_{PV} I_S (1 - L) \eta_{PV} \quad \text{Equation 4.30}$$

Where,  $O_{PV}$  is PV output (kW).


Assuming a constant output for the PV during each hour,  $O_{PV}$  can also have kWh units, as is shown in Table 4.6. Deficit and surplus are also calculated for each hour.

It is assumed here that any surplus is exported to the grid and any deficit is imported



from the grid. Yearly surplus and deficit figures are therefore calculated using equation 4.25.

Figure 4.18 shows that there is an optimum PV panel size ( $m^2$ ) that would yield the lowest cost of saved  $CO_2$  emission. However, in some cases, there is a trivial solution to the optimum PV area and hence the PV panel would be sized to generate required power for the month of July when solar radiation is at its highest value.




**Figure 4.18 Variation of PV panel area with cost of  $CO_2$  saved**


In the computer tool, the user can select to size the PV panel to provide the optimum annual electricity demand, providing there is no restriction on the amount of roof area and capital cost. Alternatively, the user can select to size the PV panels either restricting the maximum available area for the PV or selecting a 10% reduction in  $CO_2$  emission of the site as shown in the user interface of Figure 4.19 and Figure 4.20.

If the tool calculates a PV area larger than the restricted area specified by the user, then this restricted area is taken as the maximum area for the PV array. If the project

requirement is to reduce carbon emissions by 10%, as is more frequently becoming the case throughout the UK, the tool then calculates a PV size to achieve this target.



**Figure 4.19 PV sizing options**



**Figure 4.20 Entering maximum array area available**

The tool investigates two options that include PV:


- PV + Boiler + Grid (Option 3 – see Figure 4.7)
- CHP + PV + Boiler + Grid (Option 4 – see Figure 4.7)

For the PV + Boiler + Grid combination of technologies, the PV is sized first, as described above. The boiler supplies the total heating demand and the grid supplies the electricity demand not met by the PV.

Table 4.7 and Figure 4.21 show that CHP achieves a lower cost of emissions savings than PV. Therefore in the CHP + PV + Boiler + Grid option, the CHP is sized first as described in Block B2. The sizing of the CHP is based on the heat demand. If all the electricity demand is met by the CHP, then the tool indicates that no PV installation is required. If PV is required then the PV system is sized as described above. Figure 4.21 shows that the optimum size of PV with CHP would be 0m<sup>2</sup>. However, since the tool examines the combination of PV with CHP, the CHP is sized first and then considered with different sizes of PV in order to find an optimum size of PV. The boiler and EGrid then supplies any remaining heat demand and electricity demand.

**Table 4.7 Example Costs of emissions savings for CHP and PV**

Example	Optimum CHP size	Optimum PV size
Cost of Emissions savings (£/kgCO <sub>2</sub> saved)	6.3	10.1



**Figure 4.21 Optimum size of PV with CHP+Boiler+Grid**

Figure 4.22 shows sizes of the PV, Boiler and Grid and the percentage of emissions saved in this option. The tool calculates estimated costs of the PV system (Figure 4.23). Figure 4.24 shows the typical costs collected and the formula used to estimate the PV capital cost. PV maintenance and disposal costs are assumed to be 1% and 2% respectively of the capital costs. The costs and lifetime of the PV systems can again be changed by the user (Figure 4.23).

The screenshot shows a software window titled "Option: PV+Boiler+Grid" with a close button (X) in the top right corner. The window contains the following text and data:

**Please review the values below and go back to change the input parameters if necessary.**

PV	
<b>PV annual output (kWh)</b>	<b>776322</b>
<b>PV array size (m2)</b>	<b>550</b>

Boiler	
<b>Boiler size (kW)</b>	<b>168</b>
<b>Storage (litres)</b>	<b>747</b>

Grid	
<b>Annual Grid Demand (kWh)</b>	<b>135500</b>

**Emissions saved (%)**                      **16.4**

At the bottom of the window, there are two buttons: "Back" and "Next".

**Figure 4.22 PV + Boiler + Grid Outputs**

Costs and Emissions PV+Boiler+Grid Option

Please review the values below and change them if necessary.

	PV	BOILER
Lifetime (years)	30	15
Capital Cost (£)	201756	32555
Maintenance Cost (£/year)	2018	652
Disposal Cost (£)	4036	1304

Back Next

Figure 4.23 PV lifetime and costs




Figure 4.24 Installed PV costs (Faber Maunsell 2003, EST 2006, DTI 2006, IEA 2003, IEA 2006)

Figure 4.25 shows sizes of the PV, CHP, Boiler and Grid and the percentage of emissions saved in this option. The tool calculates cost estimates of the PV system. Figure 4.26 shows the estimated costs and lifetime of the PV system, which can again be changed by the user.




Figure 4.25 PV+CHP+Boiler+Grid Outputs




Figure 4.26 PV costs and lifetime

Finally, system energy costs, emissions, % emissions saved and the cost of emissions savings are calculated for the PV+Boiler+Grid and the CHP+PV+Boiler+Grid options, as for the other options.

## ii) Solar Thermal (ST) sizing

In this work it is assumed that the solar thermal system supplies only domestic hot water. Given that evacuated tube solar thermal collectors are most suitable for North European climate, its characteristics were included in the computer tool. However, other types of solar collectors could be included in the computer tool through separate subroutines in future work. The computer tool evaluates the solar collector output on an hourly basis for a typical day and for each month as follows (Duffie 1991). Table 4.8 shows an example of the solar thermal system simulation for a typical day in July.

**Table 4.8 Hourly solar thermal system simulation for a typical July day**

July		1.00	1.00										
Time	Weekday Hot water demand (kWh)	Weekend Hot water demand (kWh)	Abient temperature (degC)	Solar irradiance (W/m2)	Collector efficiency	ST output (kWh)	weekday deficit (kWh)	weekday deficit after storage (kWh)	weekday surplus (kWh)	weekend deficit (kWh)	weekend deficit after storage (kWh)	weekend surplus (kWh)	Pump running hours
1	0.4	0.6			0	0	0.4	0.0	0	0.6	0.5	0	0
2	0.1	0.8			0	0	0.1	0.0	0	0.8	0.8	0	0
3	2.1	0.2			0	0	2.1	1.5	0	0.2	0.2	0	0
4	2.6	1.4	12.3	27	0	0	2.6	2.6	0	1.4	1.4	0	0
5	2.6	0.7	13.8	70.5	0	0	2.6	2.6	0	0.7	0.7	0	0
6	1.4	0.4	15.1	143.25	0	0	1.4	1.4	0	0.4	0.4	0	0
7	3.7	0.8	16.4	246	0.18	5.67	0.00	0.00	2.01	0.00	0.00	4.84	1
8	0.4	1.1	17.5	346	0.34	15.03	0.00	0.00	14.58	0.00	0.00	13.94	1
9	13.9	0.6	18.5	429.5	0.42	22.86	0.00	0.00	9.00	0.00	0.00	22.29	1
10	12.6	2.7	19.3	488.75	0.46	28.49	0.00	0.00	15.91	0.00	0.00	25.79	1
11	11.6	1.9	20.0	519.25	0.48	31.49	0.00	0.00	19.94	0.00	0.00	29.63	1
12	14.6	10.2	20.6	519.25	0.48	31.72	0.00	0.00	17.09	0.00	0.00	21.52	1
13	8.7	14.8	20.9	488.75	0.47	29.16	0.00	0.00	20.43	0.00	0.00	14.40	1
14	9.8	7.9	21.1	429.5	0.44	23.95	0.00	0.00	14.14	0.00	0.00	16.06	1
15	7.7	1.5	21.0	346	0.38	16.52	0.00	0.00	8.82	0.00	0.00	14.98	1
16	4.7	1.3	20.8	246	0.24	7.52	0.00	0.00	2.83	0.00	0.00	6.17	1
17	5.7	1.9	20.3	143.25	0	0	5.7	0.0	0	1.9	0.0	0	0
18	10.8	7.4	19.6	70.5	0	0	10.8	0.0	0	7.4	0.0	0	0
19	6.8	3.9	18.7	27	0	0	6.8	0.0	0	3.9	0.0	0	0
20	2.2	12.8			0	0	2.2	0.0	0	12.8	0.0	0	0
21	3.4	8.9			0	0	3.4	0.0	0	8.9	0.0	0	0
22	9.1	4.1			0	0	9.1	0.0	0	4.1	0.0	0	0
23	5.0	3.6			0	0	5.0	0.0	0	3.6	0.0	0	0
24	3.7	5.3			0	0	3.7	0.0	0	5.3	0.0	0	0
	143.7	94.6		4540.5			8.2	8.2	124.77	3.94	3.94	169.62	310
									47.91			47.91	

The output of the solar thermal system is calculated:

$$Q_{sc} = A_{sc} I_s \eta_{sc} \quad \text{Equation 4.31}$$

where,  $Q_{sc}$  is the collector output rating (kW),  $A_{sc}$  is the collector area ( $\text{m}^2$ ),  $I_s$  is the incident solar radiation normal to the collector ( $\text{kW}/\text{m}^2$ ), and  $\eta_{sc}$  is the collector efficiency (%).

Typical evacuated solar collector efficiency can be expressed by the following empirical relationship (Atmaca 2003):

$$\eta_{sc} = 0.7 - 3.3 \frac{T_{SCav} - T_{Am}}{I_s} \quad \text{Equation 4.32}$$

where,  $T_{SCav}$  and  $T_{Am}$  are the average collector temperature ( $^{\circ}\text{C}$ ) and ambient temperature ( $^{\circ}\text{C}$ ) respectively.

Ambient temperatures and solar radiation at 30 degrees tilt south-facing at different times throughout the day and year were obtained from the European Commission Directorate General Joint Research Centre. The average collector temperature is assumed to be  $55^{\circ}\text{C}$ .

The hot water storage capacity is assumed to be 1/3 of the daily hot water demand, as is the case for the boiler system. Hourly deficit and surplus values are calculated, as well as the hourly deficit after hot water storage has been taken into account. The latter is especially important for the sizing of solar thermal with CHP.

Like in most active solar thermal collectors, the electrical power consumption of the pump to circulate the heat carrying fluid could be substantial. The pump is usually activated by a dedicated controller when there is sufficient temperature difference



(e.g., 3°C) between the solar collector and hot water storage tank. The power consumption can be calculated as:

$$D_{ep} = P_p H \quad \text{Equation 4.33}$$


where,  $D_{ep}$  is the pump electricity consumption (kWh),  $P_p$  is the pump power rating (kW) and  $H$  is the number of operating hours (hours).

Typical power consumption of a solar thermal collector pump depends essentially on the size of the solar collector. Table 4.9 shows estimates of power consumption of a solar collector pump obtained through private communication from the solar thermal department of Viessmann, a solar technology company based in Telford, Shropshire. This data is incorporated into the computer tool to calculate the power consumption of the solar collector.

**Table 4.9 Pump power estimates (Viessmann 2007)**


Solar thermal collector size (m <sup>2</sup> )	Pump power (W)
1-5	40
5-10	60
10-15	75
15-20	140
20-25	210
25-30	245

The tool optimises the solar thermal system to find the collector size to achieve an optimum cost of emission saving in £/kg CO<sub>2</sub> saved. Figure 4.27 shows that the cost of emissions saved varies with the size of ST collector and there is an optimum size for a given building load (e.g., a building consisting of 20 2-bedroom flats has an optimum surface area of about 70m<sup>2</sup> and would cost about £11 per kg of CO<sub>2</sub> saved).



**Figure 4.27 Optimum ST collector size**


As in the PV sizing tool, the user can select a limitation in the sizing procedure as shown in Figure 4.28. A maximum collector array area can be entered or the user can select the option where the tool calculates an array area that achieves the maximum reduction in carbon emissions. If no limitation is selected the ST collector is sized as described above.



**Figure 4.28 ST sizing options**

The option of achieving a 10% reduction in emissions is not available in the ST tool. This is due to the fact that the ST only supplies hot water and from Figure 4.29, this

figure could not be achieved by using ST alone, unless seasonal storage was used and this option therefore is currently not included in the tool.



**Figure 4.29 Yearly energy demand distribution for example building**

The sizing tool for ST considers two options that include:

- ST + Boiler + Grid
- ST + CHP + Boiler + Grid

For the first option (i.e., ST + Boiler + Grid combination), the solar thermal collector is sized to provide as much heat as permissible within the design limitations described above. Then the boiler is used to supply the remaining hot water and heating demand, whereas the Grid would supply the electricity demand. Figures 4.30 and 4.31 show the user interface windows of the sizing tool for the technology and the associated costs and emissions. Furthermore, lifetime and cost estimates are calculated separately as shown in Figure 4.31, for which the user can choose appropriate operational parameters.

Option: ST+Boiler+Grid

Please review the values below and go back to change the input parameters if necessary.

ST

ST annual output (kWh)	39255
ST array size (m2)	127

Boiler

Boiler size (kW)	168
Storage size (litres)	747

Grid

Annual Grid Demand (kWh)	192900
--------------------------	--------

Emissions saved (%)      4.1

Back      Next

Figure 4.30 ST+Boiler+Grid Outputs

Costs and Emissions ST+Boiler+Grid Option

Please review the values below and change them if necessary.

	ST	BOILER
Lifetime (years)	30	15
Capital Cost (£)	107950	32555
Maintenance Cost (£/year)	2159	652
Disposal Cost (£)	5397.5	1304

Back      Next

Figure 4.31 ST+Boiler lifetime & costs

The second option which integrates solar thermal with CHP in the ST + CHP + Boiler + Grid option is less straight forward than integrating PV with CHP as solar thermal and CHP technologies are both sized on heat demand. Solar thermal provides higher CO<sub>2</sub> emissions savings than CHP; however CHP is economically more viable than solar thermal. Approximate costs of solar thermal installations are summarized in Table 4.10. Solar thermal maintenance costs and disposal costs were assumed to be 2% and 5% respectively of the installed capital cost.

**Table 4.10 Installed solar thermal costs** (Faber Mausell 2003, EST 2006)

price (£) for 4 m <sup>2</sup> of ST collectors	£/m <sup>2</sup>
3500	875
3150	787.5
4000	1000
3000	750
<b>Average</b>	<b>853</b>

For the ST + CHP + Boiler + Grid option, the tool calculates the optimum CHP size for different ST collector sizes to find an optimum combination of ST and CHP in terms of £/kgCO<sub>2</sub> saved. However if an area limitation was selected by the user as described in Figure 4.28, then the ST areas considered in this calculation will be limited to the value entered by the user. If the limitation selected was to achieve a maximum CO<sub>2</sub> emissions reduction, then the tool will find the combination of CHP and ST to achieve the highest % carbon emissions saved.

As was the case for the PV tool, the user can review the outputs of the ST tool and go back to revise any of the inputs if necessary, as shown in Figure 4.32. Technology lifetime, capital cost, maintenance cost and disposal costs can also be changed by the user in a separate procedure as shown in Figure 4.33.

Option:ST+CHP+Boiler+Grid

Please review the values below and go back to change the input parameters if necessary.

ST

ST annual output (kWh)	11746
ST array size (m2)	38

CHP

CHP Size (kW) heat	17
Storage (kWh)	8.5

Boiler

Boiler size (kW)	147
Storage (litres)	383.5

Grid

Annual Grid Demand (kWh)	124100
--------------------------	--------

Emissions saved (%)      9.2

Back      Next

Figure 4.32 ST+CHP Outputs

Costs ST+CHP+Boiler+Grid

Please review the values below and change them if necessary.

	ST	CHP	BOILER
Lifetime (years)	30	20	15
Capital Cost (£)	32300	12097	29775
Maintenance Cost (£/year)	646	242	596
Disposal Cost (£)	1615	484	1192


Back      Next

Figure 4.33 ST+CHP+Boiler lifetime & costs

Finally, system energy costs, emissions, % emissions saved and the cost of emissions savings are calculated for the ST+Boiler+Grid and the ST+CHP+Boiler+Grid options, as for the other options.

#### 4.2.3 BLOCK C: Most Probable Options and their Comparison

Figure 4.34 shows the flow chart for Block C. The Monte Carlo method is applied to take into account the uncertainty of building energy load profiles.



**Figure 4.34 Block C – Most probable options and their comparison**

The most probable options from the outputs from block B are found and are summarized in terms of system energy costs and emissions (Figures 4.35 and 4.36). The user can subsequently make an informed decision as to which technology combination to choose.

Load profiles, which are an important input to the tool, are difficult to predict and are therefore largely uncertain. The Monte Carlo Method is used to account for this uncertainty by sizing each of the combination options described above for 100 different load profiles.

	BOILER + GRID	BASE CASE (Boiler + Grid)	CHP + BOILER + GRID	BASE CASE (Boiler + Grid)	PV + BOILER + GRID	BASE CASE (Boiler + Grid)	CHP + PV + BOILER + GRID
<b>TECHNOLOGY SIZES</b>							
Boiler Size (kW)	160	169	154	161	161	154	138
Grid Demand (kWh)	193000	188100	136400	193300	138200	206200	113400
CHP size (kWth)			12				13
PV array size (m2)					537		355
<b>COSTS AND EMISSIONS</b>							
System Cost (p/kWh)	3.1	3.1	2.9	3.1	4.2	3.1	3.7
Emissions (kgCO2/kWh)	0.32	0.317	0.306	0.319	0.268	0.323	0.277
Cost per emission savings (£/kgCO2saved)			2.5		0.8		0.8
Reduction in emissions (%)			3.7		16.3		14.1

Back      Print Summary

Figure 4.35 PV Tool Option Comparison

	BOILER + GRID	BASE CASE (Boiler + Grid)	CHP + BOILER + GRID	BASE CASE (Boiler + Grid)	ST + BOILER + GRID	BASE CASE (Boiler + Grid)	CHP + ST + BOILER + GRID
<b>TECHNOLOGY SIZES</b>							
Boiler Size (kW)	160	169	154	184	184	179	158
Grid Demand (kWh)	190400	188100	136400	189600	191600	241600	169500
CHP size (kWth)			12				17
ST array size (m2)					125		20
<b>COSTS AND EMISSIONS</b>							
System Cost (p/kWh)	3.1	3.1	2.9	3.1	4	3.2	3.1
Emissions (kgCO2/kWh)	0.319	0.317	0.306	0.317	0.302	0.329	0.304
Cost per emission savings (£/kgCO2saved)			2.4		3		1.1
Reduction in emissions (%)			4		4		8.6

Back      Print Summary

Figure 4.36 ST Tool Option Comparison



This is an iterative process and the number of times this simulation process is carried out depends on the determination of the number of trials required for the Monte Carlo method to give a significant confidence level. In this tool 100 iterations were performed for the simulation to achieve a high confidence level. The method is carried out as follows:

- Each load profile present in the sizing tool is assigned a number.
- Then the tool generates a random number, and selects the load profile associated to the generated random number.
- Using the selected load profile, the simulation is run for each of the technology combination options for sizing and cost analysis.
- The cost and emissions for each technology combination option are obtained and recorded in a spreadsheet. Figure 4.37 shows an extract of this spreadsheet.
- The simulation process is repeated for the estimated number of trials (i.e., 100). Therefore yielding 100 outputs.
- For each combination the most likely technology sizes, costs and emissions are obtained.

These results can then be compared by the user (as described in Figure 4.35 and Figure 4.36), to make the ultimate decision based on the economical and environmental criteria of the project. The random selection of load profiles is explained in more detail using an example in the next chapter in section 5.2.1.

Finally, feedback into the tool is important, so that the tool can be updated and improved as it is being used. For example, costs will change over time and will therefore need to be updated regularly; and, as more building energy load profiles become available, these could be added into the tool.



## **Chapter 5:**

### **Computer tool evaluation and results**

#### **5.1 INTRODUCTION**

Using the case study outlined below, a sample calculation is carried out to show the tool's calculation procedures in section 5.2. The tool is then run in section 5.3 using the same example. The outputs of the sample calculation and the tool's outputs are then compared to check the tool's outputs are correct. The case study used is a mixed-use office and residential building located in the UK. The building, with a total floor area of 1750m<sup>2</sup>, consists of three clusters of 5 two-bedroom flats of 100m<sup>2</sup> each, 15 one-bedroom flats of 50m<sup>2</sup> each, and 500m<sup>2</sup> of office space with occupancy capacity of 50 people. In this analysis, it is assumed that the building loads and load profiles are not known in advance and hence the tool uses its database of load profiles that match each cluster building. Three different technologies are evaluated in the tool: combined heat and power, solar thermal collectors for hot water and photovoltaic panels for electricity generation with an operation life time of 15, 20 and 30 years respectively. To evaluate the economic viability and compare different technologies that may be suitable for this type of building project, it was assumed that gas prices and mains electricity tariff are 2.28p/kWh and 8.2p/kWh respectively, whereas on-site generated surplus electrical power is sold back to the grid at 3p/kWh. The project lifetime is assumed to be 30 years and at a discount cash flow rate of 5%.

## 5.2 SAMPLE CALCULATION

The tool's calculation procedures are outlined below using the case just described.

### 5.2.1 Building loads

#### a) Rule of Thumb energy loads

The rule of thumb (RoT) building energy load calculation is carried out by the tool as follows using equations 4.1 - 4.4:

For this example:

- For the 5 two-bedroom flats of 100 m<sup>2</sup> each, using RoT of 75 l/bedroom/day for hot water, 60 W/m<sup>2</sup> for space heating and 41 kWh/m<sup>2</sup>/year for electricity:

$$D_{\text{HW}} = 75 \times 2 \times 5 = 750 \text{ l/day.}$$

$$D_{\text{SH}} = 60 \times 100 \times 5 = 30\,000 \text{ W} = 30 \text{ kW}$$

$$D_e = 41 \times 100 \times 5 = 20\,500 \text{ kWh/year}$$

- for the 15 one-bedroom flats of 50 m<sup>2</sup> each, using RoT of 115 l/bedroom/day for hot water, 60 W/m<sup>2</sup> for space heating and 41 kWh/m<sup>2</sup>/year for electricity:

$$D_{\text{HW}} = 115 \times 1 \times 15 = 1725 \text{ l/day.}$$

$$D_{\text{SH}} = 60 \times 50 \times 15 = 45\,000 \text{ W} = 45 \text{ kW}$$

$$D_e = 40 \times 50 \times 15 = 30\,000 \text{ kWh/year}$$

- for the 500 m<sup>2</sup> office space without canteen with an occupancy of 50, using RoT of 10 l/person/day for hot water, 70 W/m<sup>2</sup> for space heating and 33 kWh/m<sup>2</sup>/year for electricity:

$$D_{HW} = 10 \times 50 = 500 \text{ l/day.}$$

$$D_{SH} = 70 \times 500 = 35\,000 \text{ W} = 35 \text{ kW}$$

$$D_e = 33 \times 500 = 16\,500 \text{ kWh/year}$$

Total loads are then calculated in the spreadsheet (Figure 5.1):

$$D_{HW} = 750 + 1725 + 500 = 2975 \text{ l/day.}$$

$$D_{SH} = 30 + 45 + 35 = 110 \text{ kW}$$

$$D_e = 20\,500 + 30\,000 + 16\,500 = 67\,000 \text{ kWh/year}$$

<b>Rules of Thumb Building Loads:</b>				21
Occupancy				50
Floor area(m2)	500	750		500
Number of building	5	15		1
Building type	Residential	Residential	Office	
	2 bedroom flat	1 bedroom flat	without canteen	
Heating (kW)	30	45		35
Hot Water (litres)	750	1725		500
Electricity (kWh)	20500	30000		16500
Totals:		Heating (kW) =		<b>110 kWh</b>
		Hot water (litres) =		<b>2975 litres</b>
		Electricity (kWh) =		<b>67000 kWh</b>

**Figure 5.1 RoT building energy loads summary**

## b) Load profiles

In this example, it is assumed the load profiles are not known and the database of load profiles is therefore used to determine the building energy load profiles for this building. The following calculation procedures however are only for one set of load profiles and the Monte Carlo method is only applied in section 5.3 when the tool is run.

daily hot water load profiles (litres/hour)																							
weekday																							
hours																							
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	0	0	0	0	0	0	0	0	0	0	25	0	0	0	0	3	3	0	0	20	0	0	0
0	0	0	0	0	0	0	37	0	20	0	0	0	0	0	0	0	3	0	5	3	10	0	0
3	0	0	0	0	0	0	0	0	3	0	3	0	3	0	0	0	0	0	0	20	0	0	3
0	0	0	0	0	0	0	0	0	20	3	0	0	0	0	0	0	0	0	3	0	0	0	0
0	0	0	0	17	0	0	0	0	0	3	20	17	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	25	20	0	0	0	0	0	3	0	20	0	0	0	3
0	0	0	0	0	0	0	17	20	0	0	3	6	0	0	0	3	0	6	0	0	0	5	0
0	0	0	0	0	0	0	17	20	3	0	0	0	0	0	3	8	3	3	0	0	3	0	0
0	0	0	0	0	17	0	0	20	17	0	0	0	0	0	0	0	0	0	0	17	0	5	0
0	0	0	0	0	0	0	0	20	0	0	0	0	0	0	0	0	0	0	0	3	0	3	0
0	0	0	0	0	0	0	0	0	0	40	0	0	3	0	20	0	0	3	0	25	20	0	3
0	0	0	0	0	0	0	0	20	17	17	0	0	0	0	0	0	0	0	0	0	0	5	0
0	0	25	20	0	0	0	0	0	0	20	3	0	0	0	0	17	0	0	0	25	0	0	3
0	0	5	17	0	0	0	0	0	0	17	0	0	0	0	0	20	0	3	0	5	0	0	3
0	0	0	0	0	0	0	37	0	20	0	0	0	0	0	0	0	3	0	5	3	10	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0
0	0	0	0	0	17	0	0	20	0	0	0	17	0	0	0	0	0	0	0	0	0	0	20
0	0	0	0	0	17	0	0	37	0	0	0	0	0	0	0	0	0	0	0	0	5	17	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17
0	0	0	0	0	0	0	0	0	0	42	0	0	0	8	0	0	23	0	0	0	5	0	3
0	0	0	0	0	0	0	100	50	50	50	50	100	100	50	50	100	50	0	0	0	0	0	0
weekend																							
hours																							
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	0	0	0	0	0	0	0	0	6	3	0	20	20	0	0	0	0	0	0	0	5	3	3
0	0	0	0	0	0	0	0	0	0	0	0	25	0	0	0	0	20	5	20	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	25	0	0	0	0	20	5	20	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	17	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	6	34	0	0	0	0	0	17	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	3	3	0	17	0	0	0	3	0	25	0	5	0	3
0	0	0	3	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	28	8	8	25
5	0	0	0	0	0	0	0	0	20	0	34	0	0	0	3	0	0	0	0	0	0	11	0
0	5	0	6	0	0	0	0	0	0	0	0	20	0	17	0	0	5	0	0	17	5	3	0
0	0	0	0	0	0	0	0	0	0	0	6	17	6	3	0	0	0	3	20	17	0	0	0
0	0	0	0	0	0	0	0	0	0	0	6	17	6	3	0	0	0	3	20	17	0	0	0
0	0	0	0	3	0	3	3	0	0	0	20	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	17	0	0	0	0	0	0
0	5	0	6	0	0	0	0	0	0	0	20	0	17	0	0	5	0	0	17	5	3	0	0
0	0	0	0	3	0	3	3	0	0	0	20	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	6	17	6	3	0	0	0	3	20	17	0	0	0
0	0	0	3	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	28	8	8	25
0	0	0	0	0	0	0	0	0	6	3	0	20	20	0	0	0	0	0	0	0	5	3	3
0	0	0	0	0	0	0	3	0	0	3	0	17	0	0	5	0	0	0	0	0	5	0	0
0	0	0	0	0	0	0	0	0	0	0	25	0	0	0	0	20	5	20	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

**Figure 5.2 Hourly hot water demands for typical January weekday and weekend day**

For this example building, consisting of 15 one-bedroom flats, 5 two-bedroom flats and 500 m<sup>2</sup> of office space where the load profiles are not known, the tool selects 20 load profiles randomly from the “flats” section of the load profile database for hot water, space heating and hot water respectively. A load profile is then randomly selected for each hot water, space heating and electricity from the office database, which are then multiplied by 500 to give the load profiles for the office space of 500 m<sup>2</sup>. This is carried out for both weekend and weekday profiles. The data for these load profiles are shown in Figures 5.2-5.4. The load profiles for the different building

types are then summed up to give total hot water, space heating and electricity load profiles for the building for a weekday and weekend day respectively (Figure 5.5).

Heating Load Profiles																								
weekday																								
hours																								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	
weekend																								
hours																								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
0	0.3	0.2	0.05	0.3	0	3.5	4.2	3.5	1.1	1	1	0.7	1.2	0.7	1.6	1.5	3.3	3	3	2.6	1	0	0.3	
0	0.4	1	0.5	0.8	0.2	7.4	5.2	5.4	1	1.5	1.3	1	2	1.4	2.5	2	5	3	4	3	1.5	0	0.2	
10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.4	

**Figure 5.3 Hourly space heating demands for a typical January weekday and weekend day**

To calculate monthly loads, it is assumed that there are  $365 \times 5 / 7 / 12 = 21.726$  weekdays per months and  $365 \times 2 / 7 / 12 = 8.69$  weekend days per month. January hot water load, (cell B49) is therefore calculated as:

$$D_{HW,J} = (21.726 \times D_{HW,J,WD}) + (8.69 \times D_{HW,J,WE}) \quad \text{Equation 4.5}$$

Where,  $D_{HW,J}$  is total January hot water load (litres),  $D_{HW,J,WD}$  is January weekday hot water demand (litres) and  $D_{HW,J,WE}$  is January weekend hot water demand (litres).

In this case:  $D_{HW,J} = (21.726 \times B45) + (8.69 \times G45) = (21.726 \times 2240) + (8.69 \times 1475) = 61\ 485\ 1$

Electricity Load Profiles																								
weekday																								
hours																								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.2	0.2	0.2	0.2	0.4	0.75	1	0.95	1.05	0.9	0.75	0.95	0.7	0.8	0.6	0.3
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.4	0.45	0.5	0.4	0.3	0.4	0.3	0.35	0.4	0.55	0.9	1.1	1	1	0.7	0.4
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.2	0.2	0.2	0.2	0.4	0.75	1	0.95	1.05	0.9	0.75	0.95	0.7	0.8	0.6	0.3
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.4	0.45	0.5	0.4	0.3	0.4	0.3	0.35	0.4	0.55	0.9	1.1	1	1	0.7	0.4
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4
0.25	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	1.4	1.4	0.5	0.6	0.45	0.2	0.15	0.15	0.4	0.55	0.9	0.85	0.5	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.4	0.45	0.5	0.4	0.3	0.4	0.3	0.35	0.4	0.55	0.9	1.1	1	1	0.7	0.4
0.25	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	1.4	1.4	0.5	0.6	0.45	0.2	0.15	0.15	0.4	0.55	0.9	0.85	0.5	0.4	
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.25	0.5	0.6	0.7	0.5	1.05	0.85	0.5	0.45	0.55	0.6	0.65	0.85	1	0.65	0.75	0.45	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.2	0.2	0.2	0.2	0.4	0.75	1	0.95	1.05	0.9	0.75	0.95	0.7	0.8	0.6	0.3	
2.28	2.24	2.28	2.26	2.28	2.86	5.29	8.36	12.6	14	14.3	14.3	14.2	14.1	14.1	14	13.6	11.5	8.93	6	3.38	2.38	2.02	2	
weekend																								
hours																								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
0.25	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	1.4	1.4	0.5	0.6	0.45	0.2	0.15	0.15	0.4	0.55	0.9	0.85	0.5	0.4	
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.2	0.2	0.2	0.2	0.4	0.75	1	0.95	1.05	0.9	0.75	0.95	0.7	0.8	0.6	0.3
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.25	0.5	0.6	0.7	0.5	1.05	0.85	0.5	0.45	0.55	0.6	0.65	0.85	1	0.65	0.75	0.45	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.4	0.45	0.5	0.4	0.3	0.4	0.3	0.35	0.4	0.55	0.9	1.1	1	1	0.7	0.4	
0.25	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	1.4	1.4	0.5	0.6	0.45	0.2	0.15	0.15	0.4	0.55	0.9	0.85	0.5	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.4	0.45	0.5	0.4	0.3	0.4	0.3	0.35	0.4	0.55	0.9	1.1	1	1	0.7	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.25	0.5	0.6	0.7	0.5	1.05	0.85	0.5	0.45	0.55	0.6	0.65	0.85	1	0.65	0.75	0.45	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.25	0.5	0.6	0.7	0.5	1.05	0.85	0.5	0.45	0.55	0.6	0.65	0.85	1	0.65	0.75	0.45	
0.25	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	1.4	1.4	0.5	0.6	0.45	0.2	0.15	0.15	0.4	0.55	0.9	0.85	0.5	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.25	0.5	0.6	0.7	0.5	1.05	0.85	0.5	0.45	0.55	0.6	0.65	0.85	1	0.65	0.75	0.45	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.5	0.2	0.2	0.2	0.2	0.4	0.75	1	0.95	1.05	0.9	0.75	0.95	0.7	0.8	0.6	0.3	
0.15	0.75	0.9	0.65	0.5	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.4	1.2	1.65	1.2	0.85	0.85	0.6	0.4	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
0.25	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	1.4	1.4	0.5	0.6	0.45	0.2	0.15	0.15	0.4	0.55	0.9	0.85	0.5	0.4	
0.15	0.1	0.1	0.1	0.1	0.1	0.1	0.4	0.7	0.4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.7	1.9	1.8	1.7	0.75	0.4	
1.9	1.9	1.91	1.88	1.97	1.95	2.02	2.07	2.07	1.97	2	1.93	1.98	1.98	1.97	2.03	2.09	2.12	2.07	2.05	2.03	2.07	1.9	1.97	

**Figure 5.4 Hourly electricity demands for a typical January weekday and weekend day**

Space heating and electricity loads are calculated in the same way. For other months in the year, factors are applied to take into account the varying demand throughout the year.



$$D_{HW} = [(21.726 \times D_{HW,WD}) + (8.69 \times D_{HW,WE})] \times f \quad \text{Equation 4.6}$$

Where, f is the monthly factor.

For example space heating for April (cell C52) is calculated as  $[(21.726 \times C45) + (8.69 \times H45)] \times G52 = [(21.726 \times 1410) + (8.69 \times 1394)] \times 0.51 = 21669 \text{ kWh}$  (Figure 5.6).

Daily week day	Hot Water (litres)	Heating (January) (kWh)	Electricity (kWh)	Daily weekend	Hot Water (litres)	Heating (January) (kWh)	Electricity (kWh)
01:00	7	11	7.0	01:00	9	11	6.7
02:00	2	20	9.5	02:00	12	19	7.2
03:00	33	26	11.3	03:00	3	25	8.5
04:00	41	20	11.0	04:00	22	20	9.0
05:00	41	27	11.3	05:00	11	26	9.8
06:00	22	19	11.1	06:00	6	18	10.0
07:00	57	130	14.5	07:00	13	126	11.1
08:00	7	113	22.8	08:00	17	112	16.2
09:00	216	110	28.4	09:00	9	108	19.6
10:00	196	41	30.6	10:00	42	41	20.0
11:00	180	47	34.4	11:00	29	46	24.3
12:00	228	46	34.8	12:00	159	45	24.2
13:00	136	41	33.7	13:00	230	40	24.1
14:00	153	57	36.2	14:00	123	56	25.6
15:00	120	47	36.7	15:00	24	46	24.9
16:00	73	68	36.8	16:00	21	67	24.7
17:00	89	63	39.2	17:00	30	62	26.8
18:00	168	113	42.2	18:00	115	111	29.6
19:00	106	89	46.7	19:00	60	89	36.1
20:00	34	101	49.4	20:00	199	100	45.6
21:00	53	88	45.6	21:00	138	87	46.5
22:00	142	58	45.0	22:00	64	57	45.6
23:00	78	33	37.9	23:00	56	33	38.2
00:00	58	39	33.8	00:00	83	39	34.0
<b>Total</b>	<b>2240</b>	<b>1410</b>	<b>710</b>	<b>Total</b>	<b>1475</b>	<b>1394</b>	<b>569</b>

Figure 5.5 Daily building energy load profiles summary

Yearly	Hot Water (litres)	Space Heating (kWh)	Electricity (kWh)	HW factors	SH factors	E factors
January	61485	42748	20370	1	1.00	1.00
February	61485	38179	18686	1	0.89	0.92
March	61485	31103	16848	1	0.73	0.83
April	61485	21669	15010	1	0.51	0.74
May	61485	8992	13785	1	0.21	0.68
June	61485	0	13019	1	0.00	0.64
July	61485	0	12712	1	0.00	0.62
August	61485	0	12866	1	0.00	0.63
September	61485	0	13631	1	0.00	0.67
October	61485	11498	15776	1	0.27	0.77
November	61485	27123	18379	1	0.63	0.90
December	61485	38031	19911	1	0.89	0.98

Figure 5.6 Monthly building energy loads and monthly load factors

The hot water demand profile is converted from litres to kWh in columns C and F in Figure 5.7 using equation 4.6. For example, at 01:00 on a weekday hot water demand is 7 litres (Figure 5.5). The demand in kWh during that hour (Cell C14

Figure 5.7) therefore is:  $D_{HW}$  (kWh) =  $D_{HW}$  (litres)  $\times$  4.2  $\times$  55 / 3600 = 7  $\times$  4.2  $\times$  55 / 3600 = 0.4 kWh

Annual heat load  $D_H$  (kWh) (cell D40 in Figure 5.7) is calculated by adding the space heating load  $D_{SH}$  (kWh) and the hot water load  $D_{HW}$  (kWh).

$$D_h = D_{SH} + D_{HW} = 219\,294 + 47\,344 = 266\,637 \text{ kWh/year}$$

The annual electricity demand (cell J40 in Figure 5.7) is calculated by adding the demands for each month and is rounded to the nearest 100 kWh. Therefore, in this example, the electricity demand,  $D_e = 190\,900$  kWh.

### 5.2.2 Supply of heat and electricity from a Boiler and Grid

#### a) Boiler sizing

OPTION 1: Boiler + Grid										
Boiler Size							Grid Demand			
peak heat demand =	134 kW									
boiler efficiency =	0.8									
boiler size =	167	168 kW								
Hot water storage size	747	747 litres				(daily HW demand/3)				
January										
Time	Weekday Heat Demand (kWh)			Weekend Heat Demand (kWh)			Week day electricity (kWh)	Weekend electricity (kWh)		
	SH	HW	Total	SH	HW	Total				
1	11.4	0.4	11.9	11.4	0.6	12.0	7.0	6.7		
2	19.5	0.1	19.6	19.4	0.8	20.2	9.5	7.2		
3	26.2	2.1	28.3	25.4	0.2	25.6	11.3	8.5		
4	20.4	2.6	23.0	19.9	1.4	21.3	11.0	9.0		
5	26.9	2.6	29.5	26.4	0.7	27.1	11.3	9.8		
6	18.6	1.4	20.0	18.4	0.4	18.8	11.1	10.0		
7	130.3	3.7	134.0	126.4	0.8	127.3	14.5	11.1		
8	113.4	0.4	113.9	112.4	1.1	113.5	22.8	16.2		
9	110.3	13.9	124.2	108.4	0.6	109.0	28.4	19.6		
10	41.3	12.6	53.9	41.4	2.7	44.1	30.6	20.0		
11	46.9	11.6	58.5	46.4	1.9	48.3	34.4	24.3		
12	45.7	14.6	60.3	45.4	10.2	55.6	34.8	24.2		
13	40.7	8.7	49.4	40.4	14.8	55.2	33.7	24.1		
14	57.2	9.8	67.0	56.4	7.9	64.3	36.2	25.6		
15	47.1	7.7	54.8	46.4	1.5	48.0	36.7	24.9		
16	68.3	4.7	73.0	67.4	1.3	68.8	36.8	24.7		
17	62.9	5.7	68.6	62.4	1.9	64.3	39.2	26.8		
18	113.1	10.8	123.9	111.4	7.4	118.8	42.2	29.6		
19	89.4	6.8	96.2	89.4	3.9	93.3	46.7	36.1		
20	101.4	2.2	103.6	100.4	12.8	113.2	49.4	45.6		
21	87.8	3.4	91.2	87.4	8.9	96.3	45.6	46.5		
22	57.9	9.1	67.0	57.4	4.1	61.5	45.0	45.6		
23	33.4	5.0	38.4	33.4	3.6	37.0	37.9	38.2		
24	39.3	3.7	43.0	39.4	5.3	44.7	33.8	34.0		
			1553.5			1488.15	709.7	568.1		
Annual heat load =			266637 kWh/year	Annual electricity load =			190900 kWh/year			

Figure 5.7 Boiler Sizing spreadsheet

The peak heat demand (cell D5) is found from the weekday and weekend heat load profiles (rows D and G). In this example, peak heat demand,  $D_{H,p} = 134$  kW and boiler efficiency,  $\eta_b = 80\%$ . Therefore using equation 4.8, the boiler size,  $S_b$  is:

$$S_b = \frac{D_{H,p}}{\eta_b} = 134 / 0.8 = 167 \text{ kW. The boiler size is rounded up to the nearest kW.}$$

The boiler size in this case therefore is 168 kW.

The hot water storage is assumed to be 1/3 of a day's hot water demand of either weekday or weekend day, depending on which demand is largest. In this case, the storage is therefore assumed to be  $2240 / 3 = 747$  litres.

Costs			
Project Lifetime (years) =	30		
Discount rate (%) =	5		
Gas cost =	2.28	Gas emission factor =	0.19
Electricity cost =	8.2	Electricity emission factor =	0.43
System			
System = Boiler		System = Grid	
Lifetime (years) =	15		
Efficiency =	0.80	<b>PW</b>	
Annual heat output (kWh) =	266637	<b>7999115</b>	
Fuel input (kWh) =	333296	4999447	kWh
Capital costs (£) =	32,555	48215	
Annual fuel costs (£) =	7,599	116818	
Annual Maintenance (£) =	652	10023	
Disposal Cost (£) =	1304	302	
		<b>175357</b>	£
Energy cost (p/kWh) =	2.19		
			Energy cost (p/kWh) = 4.20
System costs			
Heat =	2.19	p/kWh	
Electricity =	4.20	p/kWh	5727000
TOTAL =	3.1	p/kWh	
ENERGY SUPPLY			
	Boiler	Electricity	
Energy cost (p/kWh)	2.28	8.20	
CO2 emission factor (kg/kWh)	0.19	0.43	
Annual heat/electricity load (kWh)	266637	190900	
Annual Fuel input (kWh)	333,296		
Annual fuel cost (£)	7599	15654	5.08 p/kWh
Annual CO2 emissions (kg)	63326	82087	0.32 kg CO2/kWh
Emissions			145413 kg CO2

Figure 5.8 Boiler costs spreadsheet

## b) System costs and emissions

### 1) Boiler

The annual boiler heat output  $O_{boiler}$  is the annual heat demand  $D_H$  as previously calculated. The boiler fuel input  $FI_{boiler}$  (kWh) therefore is:

$$FI_{boiler} = O_{boiler} / \eta_{boiler} = 266\,637 / 0.80 = 333\,296 \text{ kWh}$$

Assuming a gas cost,  $GC$  of 2.28 p/kWh in this case, the annual fuel cost  $FC_{boiler}$  (£/year) is:

$$FC_{boiler} = FI_{boiler} \times GC = 333\,296 \times 2.28 / 100 = \text{£ } 7\,599 \text{ /year}$$

The boiler capital cost is calculated using the equation from Figure 4.10:

$$CC_{boiler} = 1058.7 \times S_b^{-0.3314} \times S_b = 1058.7 \times 168^{-0.3314} \times 168 = \text{£ } 32\,555$$

Annual boiler maintenance cost is:

$$MC_{boiler} = CC_{boiler} \times 2\% = \text{£ } 652 \text{ /year}$$

Boiler disposal cost is:

$$DC_{boiler} = MC_{boiler} \times 2 = \text{£ } 1\,304$$

Next, the net present value (NPV) system cost is calculated.

- Assuming a project lifetime,  $n$  of 30 years, the lifetime energy output,  $O_L$  (kWh) (cell F66 Figure 5.8) is calculated for the boiler using equation 4.10:

$$O_{L,boiler} = O_{boiler} \times n = 266\,637 \times 30 = 7\,999\,115 \text{ kWh}$$

- NPV boiler replacement cost  $CC_{NPVreplacement}$  (£) is calculated using equation 4.12. In this case the boiler is only replaced once during the project lifetime as the boiler lifetime is 15 years and project lifetime is 30 years. The discount rate is assumed to be 5 % in this case.

$$CC_{NPVreplacement} = CC_{current} \times (1 + DR)^{-n} = 32\,555 \times (1 + 0.05)^{-15} = \text{£ } 15\,660$$

- NPV capital cost is calculated using equation 4.11:

$$CC_{NPV} = CC_{current} + CC_{NPVreplacement} = 32\,555 + 15\,660 = \text{£ } 48\,215$$

- Boiler NPV fuel cost using equation 4.13:

$$FC_{NPV,boiler} = FC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 7\,599 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 116\,818$$

- Boiler NPV maintenance cost using equation 4.14:

$$MC_{NPV,boiler} = MC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 652 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 10\,023$$

- Boiler NPV disposal cost using equation 4.15:

$$DC_{NPV,boiler} = DC_{boiler} \times (1 + DR)^{-n} = 1\,304 \times (1 + 0.05)^{-30} = \text{£ } 302$$

- The costs are summed up to give a total NPV cost (equation 4.16):

$$C_{NPVboiler,total} = CC_{NPV,boiler} + FC_{NPV,boiler} + MC_{NPV,boiler} + DC_{NPV,boiler}$$

$$= 48\,215 + 116\,818 + 10\,023 + 302 = \text{£ } 175\,357$$

- The boiler energy cost is obtained using equation 4.17:

$$EC_{boiler} = \frac{C_{NPVboiler,total}}{O_{Lboiler}} \times 100 = \frac{175357}{7999115} \times 100 = 2.19 \text{ p/kWh}$$

## 2) Grid

- Electricity lifetime output  $O_{Le}$  (kWh) is:

$$O_{Le} = D_e \times n = 190\,900 \times 30 = 5\,727\,000 \text{ kWh}$$

- Assuming an electricity cost,  $EC$  of 8.20 p/kWh in this case, the annual fuel cost  $FC_e$  (£/year) is:

$$FC_e = D_e \times EC = 190\,900 \times 8.2 / 100 = \text{£ } 15\,653 \text{ /year}$$

- NPV fuel cost  $FC_{NPV,e}$  is:

$$FC_{NPV,e} = FC_e \times [1 - (1 + DR)^{-n}] / DR = 15653 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 240\,637$$

637

- Electricity energy cost is:

$$EC_e = \frac{FC_{NPV,e}}{O_{Le}} \times 100 = \frac{240637}{5727000} \times 100 = 4.20 \text{ p/kWh}$$

## 3) System energy cost

System energy cost is calculated using equation 4.18:

$$EC_{system} = \frac{[(EC_{boiler} \times D_h) + (EC_{EGrid} \times D_e)]}{(D_h + D_e)} = \frac{[(2.19 \times 266637) + (4.2 \times 190900)]}{(266637 + 190900)} = 3.1 \text{ p/kWh}$$

#### 4) Emissions

Assuming an electricity emission factor,  $EF_e$  of 0.43 kg CO<sub>2</sub>/kWh, and a gas emission factor,  $EF_g$  of 0.19 kg CO<sub>2</sub>/kWh, the annual CO<sub>2</sub> emissions  $E_{CO_2,BG}$  (kg CO<sub>2</sub>) are calculated using equation 4.9:

$$E_{CO_2,BG} = (D_e \times EF_e) + (D_g \times EF_g) = (190\,900 \times 0.43) + (333\,296 \times 0.19) = 145\,413 \text{ kg CO}_2$$

System CO<sub>2</sub> Emissions per kWh for the boiler and grid option are:  $E_{CO_2,BG} / (D_e + D_h) = 145413 / (190900+266637) = 0.32 \text{ kg CO}_2/\text{kWh}$ .

### **5.2.3 Supply of heat and electricity from a CHP, Boiler and Grid**

#### **a) System sizing**

In this tool it is assumed that the CHP heat to power fraction is 2:1. The overall efficiency of CHP system is usually considered to be 80%.

The tool first checks if there is a demand for at least 4500 hours from the hot water and space heating load profiles. Only when this criterion is met then the CHP sizing is carried out.

For every hour, it is assumed that the CHP is running when there is a heat demand in that hour. The hours the CHP is running are then added up by the tool to give total running hours per year.

The computer tool sizes CHP by using the total heat load profile for the project. The optimum size of CHP in terms of costs and emissions is found by minimising the saved costs of emissions in £/kg CO<sub>2</sub>.

**Table 5.1 CHP sizing simulation output list**

CHP size (kW)	Energy cost (p/kWh)	Emissions (kg CO <sub>2</sub> /kWh)	£/kg CO <sub>2</sub> saved)	CHP hours
11	2.9	0.307	2.5	5670.9
12	2.9	0.307	2.5	5497
13	2.9	0.307	2.5	5292.8
14	2.9	0.307	2.5	5118.9
15	2.9	0.307	2.5	4888.7
16	2.9	0.307	2.5	4810.5
10	2.9	0.307	2.6	5914.2
17	2.9	0.307	2.6	4754.1
9	3	0.307	2.7	6140.4
8	3	0.308	2.8	6335.9
18	2.8	0.308	2.8	4614.9
7	3	0.308	2.9	6561.8
19	2.8	0.309	3	4506.3
6	3	0.309	3.3	6740
5	3	0.311	3.9	7026.9
4	3	0.312	4.7	7187.6
3	3	0.313	6.1	7548.4
2	3.1	0.315	8.8	7961.5
1	3.1	0.317	17	8256.5

Any surplus heat produced could be stored for the next period of the heating cycle where a boiler would supply any deficit in heat generation. In this computer subroutine, the storage capacity is assumed to be 50% of the surplus heat produced by the CHP in a summer day of the month July.

The sizing procedure for the CHP is as follows: The tool records cost of emissions saved (£/kg CO<sub>2</sub> saved) for every kW thermal rating of CHP starting with 1 kW until a CHP size is reached that achieves less than 4500 running hours. From this list, the tool then selects the CHP size achieving the lowest £/kg CO<sub>2</sub> saved. Table 5.1 shows the simulation outputs of the different CHP sizes in this example, which were sorted



to find the lowest £/kg CO<sub>2</sub> saved at the top of the table. A CHP of 11kW<sub>th</sub> was selected to achieve the lowest £/kg CO<sub>2</sub> saved in this example.

OPTION 2 CHP - Boiler - Grid																									
CHP SIZE																									
Peak heat demand		134 kW																							
CHP size		11 kW <sub>th</sub>			5.5 kW <sub>e</sub>																				
Assume storage		50% of surplus July day			65 kW <sub>h</sub>																				
		5671 CHP hours/year			21.726																				
January										January															
WEEKDAY 21.726										WEEKEND 8.690															
Time	Heat demand (kWh)			CHP (kWh)			electricity demand (kWh)			CHP (kWh)			Time	Heat demand (kWh)			CHP (kWh)			electricity demand (kWh)			CHP (kWh)		
	SH	Hw	Total	hours	Output	Deficit	Surplus	demand (kWh)	Output	Deficit	Surplus		SH	Hw	Total	hours	Output	Deficit	Surplus	demand (kWh)	Output	Deficit	Surplus		
1	11.4	0.4	11.9	1	11	0.9	0.0	7.0	5.5	1.5	0.0	1	11.4	0.6	12.0	1	11	1.0	0	6.7	5.5	1.2	0.0		
2	19.5	0.1	19.6	1	11	8.6	0.0	9.5	5.5	4.0	0.0	2	19.4	0.8	20.2	1	11	9.2	0	7.2	5.5	1.7	0.0		
3	26.2	2.1	28.3	1	11	17.3	0.0	11.3	5.5	5.8	0.0	3	26.4	0.2	25.6	1	11	14.6	0	8.5	5.5	3.0	0.0		
4	20.4	2.6	23.0	1	11	12.0	0.0	11.0	5.5	5.5	0.0	4	19.9	1.4	21.3	1	11	10.3	0	9.0	5.5	3.5	0.0		
5	26.9	2.6	29.5	1	11	18.5	0.0	11.3	5.5	5.8	0.0	5	26.4	0.7	27.1	1	11	16.1	0	9.8	5.5	4.3	0.0		
6	18.6	1.4	20.0	1	11	9.0	0.0	11.1	5.5	5.6	0.0	6	18.4	0.4	18.8	1	11	7.8	0	10.0	5.5	4.5	0.0		
7	130.3	3.7	134.0	1	11	123.0	0.0	14.5	5.5	9.0	0.0	7	126.4	0.8	127.3	1	11	116.3	0	11.1	5.5	5.6	0.0		
8	113.4	0.4	113.9	1	11	102.9	0.0	22.8	5.5	17.3	0.0	8	112.4	1.1	113.5	1	11	102.5	0	16.2	5.5	10.7	0.0		
9	110.3	13.9	124.2	1	11	113.2	0.0	28.4	5.5	22.9	0.0	9	108.4	0.6	109.0	1	11	98.0	0	19.6	5.5	14.1	0.0		
10	41.3	12.6	53.9	1	11	42.9	0.0	30.6	5.5	25.1	0.0	10	41.4	2.7	44.1	1	11	33.1	0	20.0	5.5	14.5	0.0		
11	46.9	11.6	58.5	1	11	47.5	0.0	34.4	5.5	28.9	0.0	11	46.4	1.9	48.3	1	11	37.3	0	24.3	5.5	18.8	0.0		
12	45.7	14.6	60.3	1	11	49.3	0.0	34.8	5.5	29.3	0.0	12	45.4	10.2	55.6	1	11	44.6	0	24.2	5.5	18.7	0.0		
13	40.7	8.7	49.4	1	11	38.4	0.0	33.7	5.5	28.2	0.0	13	40.4	14.8	55.2	1	11	44.2	0	24.1	5.5	18.6	0.0		
14	57.2	9.8	67.0	1	11	56.0	0.0	36.2	5.5	30.7	0.0	14	56.4	7.9	64.3	1	11	53.3	0	25.6	5.5	20.1	0.0		
15	47.1	7.7	54.8	1	11	43.8	0.0	36.7	5.5	31.2	0.0	15	46.4	1.5	48.0	1	11	37.0	0	24.9	5.5	19.4	0.0		
16	68.3	4.7	73.0	1	11	62.0	0.0	36.8	5.5	31.3	0.0	16	67.4	1.3	68.8	1	11	57.8	0	24.7	5.5	19.2	0.0		
17	62.9	5.7	68.6	1	11	57.6	0.0	39.2	5.5	33.7	0.0	17	62.4	1.9	64.3	1	11	53.3	0	26.8	5.5	21.3	0.0		
18	113.1	10.8	123.9	1	11	112.9	0.0	42.2	5.5	36.7	0.0	18	111.4	7.4	118.8	1	11	107.8	0	29.6	5.5	24.1	0.0		
19	89.4	6.8	96.2	1	11	85.2	0.0	46.7	5.5	41.2	0.0	19	89.4	3.9	93.3	1	11	82.3	0	36.1	5.5	30.6	0.0		
20	101.4	2.2	103.6	1	11	92.6	0.0	49.4	5.5	43.9	0.0	20	100.4	12.8	113.2	1	11	102.2	0	45.6	5.5	40.1	0.0		
21	87.8	3.4	91.2	1	11	80.2	0.0	45.6	5.5	40.1	0.0	21	87.4	8.9	96.3	1	11	85.3	0	46.5	5.5	41.0	0.0		
22	57.9	9.1	67.0	1	11	56.0	0.0	45.0	5.5	39.5	0.0	22	57.4	4.1	61.5	1	11	50.5	0	45.6	5.5	40.1	0.0		
23	33.4	5.0	38.4	1	11	27.4	0.0	37.9	5.5	32.4	0.0	23	33.4	3.6	37.0	1	11	28.0	0	38.2	5.5	32.7	0.0		
24	39.3	3.7	43.0	1	11	32.0	0.0	33.8	5.5	28.3	0.0	24	39.4	5.3	44.7	1	11	33.74	0	34.0	5.5	28.5	0.0		
			1563.5		264	1289.5	0.0	709.71	132	577.7	0				1488		264	1224	0	568.09	132	436.1	0		
						1289.5	0.0			12565.1	0							1224.1	0.0				3779.6		

Figure 5.9 Hourly CHP simulations for a typical day in January

Figure 5.9 shows the hourly simulation of the CHP system for a typical January day. This table is repeated for each month of the year to simulate the CHP system throughout the year. The hourly demand and supply of heat and power for the CHP system and CHP running hours for a typical January day are listed. It is assumed that the CHP is running if there is a heat demand. The deficit and surplus heat and electricity are calculated for each hour using equations 4.22 and 4.23. For example, the weekday heat deficit and surplus during 01:00 are:

$$Deficit_{heat} = D_h - O_{CHP} = 11.9 - 11 = 0.9 \text{ kWh}$$

As there is a deficit during this hour, there is no surplus. Therefore,

$$Surplus_{heat} = 0$$

The weekday electricity deficit and surplus at 01:00 are:

$$Deficit_e = D_e - O_{CHP} = 7 - 5.5 = 1.5 \text{ kWh}$$

As there is a deficit during this hour, there is no surplus. Therefore,

$$Surplus_e = 0$$

The surpluses and deficits are calculated in this manner for every hour in the day for a weekday and a weekend day as shown in Figure 5.9.

The total heat deficit for a day is calculated taking into account the heat storage. Equation 4.24 is used in cell G38 in the Excel sheet is:

If *Surplus* (kWh/day) < *Storage capacity* (kWh/day),

Then *Total Deficit* = *Deficit* – *Surplus*,

Else *Total Deficit* = *Deficit* – *Storage capacity*.

Where, *Total Deficit* is the heat deficit taking into account heat storage (kWh/day), *Deficit* is the heat deficit before taking into account the heat storage (kWh/day) and *Surplus* is the heat surplus (kWh/day).

In this case, *Surplus* = 0, therefore *Total Deficit* = *Deficit* = 1282 kWh for this day in January.

Where there is a surplus, for example on a typical day in May, where *Surplus* = 30.7 kWh, *Deficit* = 207 kWh and *Storage capacity* = 65 kWh, then, since *Surplus* < *Storage capacity*, then: *Total Deficit* = *Deficit* – *Surplus* = 207 - 30.7 = 176.3 kWh

The annual heat and electricity deficits and surpluses of the CHP (Figure 5.10) are calculated by first calculating monthly figures and then adding the monthly figures to obtain yearly ones.

Heat		Electricity	
Total deficit	186616 kWh/year	Total deficit	142894 kWh/year
CHP annual output	96360 kWh/year	Total surplus	216 kWh/year
			48180 kWh/year
<b>BOILER SIZE</b>		<b>GRID DEMAND</b>	
peak heat demand =	123 kW		
boiler efficiency =	0.8		
boiler size =	154 <b>154 kW</b>		
Hot water storage size	747 <b>747 litres</b>		
<b>Annual Boiler Load =</b>	<b>186616 kWh/year</b>	<b>Annual EGrid Load =</b>	<b>142900 kWh/year</b>

**Figure 5.10 CHP annual outputs and Boiler + Grid sizing**

Equations 4.25 and 4.26 are used to calculate monthly heat deficit and electricity deficit and surplus. For January, weekday heat deficit,  $Deficit_{WD,h} = 176.3$  kWh, and weekend day heat deficit,  $Deficit_{WE,h}$  is 1224.1 kWh, therefore monthly heat deficit,  $Deficit_{January,h}$  (kWh) is:

$$Deficit_{January,h} = [(Deficit_{WD,h} \times 21.726) + (Deficit_{WE,h} \times 8.69)] = [(1289.5 \times 21.726) + (1224.1 \times 8.69)] = 38\,653 \text{ kWh}$$

For January, weekday electricity deficit,  $Deficit_{WD,e} = 577.71$  kWh, and weekend day electricity deficit,  $Deficit_{WE,e}$  is 436.1 kWh, therefore monthly electricity deficit,  $Deficit_{January,e}$  (kWh) is:

$$Deficit_{January,e} = [(Deficit_{WD,e} \times 21.726) + (Deficit_{WE,e} \times 8.69)] = [(577.71 \times 21.726) + (436.1 \times 8.69)] = 16\,328 \text{ kWh}$$

There is no weekday or weekend day surplus in January for this example. Therefore  $Surplus_{January,e} = 0$  kWh in this case.

The annual CHP heat output  $O_{CHP,h}$  and electricity demand  $O_{CHP,e}$  are calculated in the CHP simulation spreadsheet above by calculating monthly figures and adding these up to give an annual heat output, as was the case for the surpluses and deficits.

For January, weekday and weekend day CHP heat outputs ( $O_{CHP,WD,h}$  and  $O_{CHP,WE,h}$ ) are 264 kWh and weekday and weekend day CHP electricity outputs ( $O_{CHP,WD,e}$  and  $O_{CHP,WE,e}$ ) are 132 kWh, therefore, January CHP heat and electricity outputs ( $O_{January,CHP,h}$  and  $O_{January,CHP,e}$ ) are:

$$O_{January,CHP,h} = [(O_{CHP,WD,h} \times 21.726) + (O_{CHP,WE,h} \times 8.69)] = [(264 \times 21.726) + (264 \times 8.69)] = 8\,030 \text{ kWh}$$

$$O_{January,CHP,e} = [(O_{CHP,WD,e} \times 21.726) + (O_{CHP,WE,e} \times 8.69)] = [(132 \times 21.726) + (132 \times 8.69)] = 4\,015 \text{ kWh}$$

Outputs are calculated for every month and are added up to give annual CHP heat and electricity outputs:

$$O_{CHP,h} = 96\,360 \text{ kWh/year}$$

$$O_{CHP,e} = 48\,180 \text{ kWh/year}$$

Any surplus electricity generated is exported to the grid and the annual electricity demand from the grid is equal to the annual electricity deficit as calculated above ( $Surplus_e = 261 \text{ kWh/year}$  and  $Deficit_e = 142\,894 \text{ kWh/year}$ ).

The Boiler is sized on the deficit heat demand as in block B1. In this case boiler size:

$$S_b = \frac{D_{H,p}}{\eta_b} = 123 / 0.8 = 154 \text{ kW.}$$

The hot water storage is 1/3 of a July day Deficit heat demand of either weekday or weekend day ( $Deficit_{JanuaryWD,h}$  or  $Deficit_{JanuaryWE,h}$ ) depending on which demand is largest. In this case, the storage is therefore assumed to be  $1289.5 / 3 = 430$  litres.

## b) System costs and emissions

<b>COSTS</b>			
Project Lifetime (years) =	30		
Discount rate (%) =	5		
Electricity export price (p/kWh) =	3		
Gas cost (p/kWh) =	2.28	Gas emission factor =	0.19
Electricity cost (p/kWh) =	8.2	Electricity emission factor =	0.43
<b>System</b>			
<b>System = Boiler</b>			
Lifetime (years) =	15		
Efficiency =	0.80	<b>PV</b>	
Annual heat output (kWh) =	186616	5598479	
			<b>5598479 kWh</b>
Fuel input (kWh) =	233270		
Capital costs (£) =	30,715	45489	
Annual fuel costs (£) =	5,319	81759	
Annual Maintenance (£) =	615	9454	
Disposal Cost (£) =	1230	285	
			<b>136987 £</b>
<b>Energy cost (p/kWh) =</b>	<b>2.45</b>		
<b>System = CHP</b>			
CHP Lifetime (years) =	20		
Efficiency =	0.8	<b>PV</b>	
Annual heat output (kWh) =	96360	2890800	
Annual electricity output (kWh) =	48180	1445400	
Fuel input (kWh) =	180675		<b>4336200 kWh</b>
Capital costs (£) =	8929	12294	
Annual fuel costs (£) =	4113	63226	
Annual Maintenance (£) =	179	2752	
Disposal Cost (£) =	358	83	
Electricity export (£) =	-6		
			<b>78354 £</b>
<b>Energy cost (p/kWh) =</b>	<b>1.81</b>		
<b>System = Grid</b>			
Annual electricity output (kWh) =	142900		
Life time output (kWh) =	<b>4287000</b>		
annual fuel costs (£) =	11717.8		
NPV fuel cost (£) =	<b>180131.3066</b>		
<b>Energy cost (p/kWh) =</b>	<b>4.20</b>		
<b>System costs</b>			
Heat =	2.37	p/kWh	
Electricity =	3.60	p/kWh	
<b>TOTAL =</b>	<b>2.9</b>	<b>p/kWh</b>	
<b>ENERGY SUPPLY</b>			
	Boiler	Grid	CHP
Energy cost (p/kWh)	2.28	8.20	2.28
CO2 emission factor (kg/kWh)	0.19	0.43	0.19
Annual heat/electricity load (kWh)	186616	142900	144540
Annual Fuel input (kWh)	233270		180675
Annual fuel cost (£)	5318.56	11717.80	4112.92
			<b>4.62 p/kWh</b>
Annual CO2 emission (kg)	44321	61447	34328
			<b>0.31 kg CO2/kWh</b>
<b>Emissions saved</b>			<b>5317 kg CO2 saved</b>
			<b>2.5 £/kg CO2 saved</b>
			<b>3.70 % carbon emissions saved</b>

Figure 5.11 CHP, Boiler and Grid costs and emissions

The NPV system energy costs are calculated for each technology as in the Boiler and Grid option:

### 1) boiler

$$FI_{boiler} = O_{boiler} / \eta_{CHP} = 186\,616 / 0.80 = 233\,270 \text{ kWh}$$

$$FC_{boiler} = FI_{boiler} \times GC = 233\,270 \times 2.28 / 100 = \text{£ } 5\,319 \text{ /year}$$

$$CC_{boiler} = 1058.7 \times S_b^{-0.3314} \times S_b = 1058.7 \times 154^{-0.3314} \times 154 = \text{£ } 30\,715$$

$$MC_{boiler} = CC_{boiler} \times 2\% = \text{£ } 615 \text{ /year}$$

$$DC_{boiler} = MC_{boiler} \times 2 = \text{£ } 1\,230$$

$$O_{L,boiler} = O_{boiler} \times n = 186\,616 \times 30 = 5\,598\,479 \text{ kWh}$$

$$CC_{NPV,replacement,boiler} = CC_{boiler} \times (1 + DR)^{-n} = 30\,715 \times (1 + 0.05)^{-15} = \text{£ } 14\,774$$

$$CC_{NPV,boiler} = CC_{boiler} + CC_{NPV,replacement,boiler} = 30\,715 + 14\,774 = \text{£ } 45\,489$$

$$FC_{NPV,boiler} = FC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 5\,319 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 81\,759$$

$$MC_{NPV,boiler} = MC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 615 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 9\,454$$

$$DC_{NPV,boiler} = DC_{boiler} \times (1 + DR)^{-n} = 1\,230 \times (1 + 0.05)^{-30} = \text{£ } 285$$

$$C_{NPV,boiler,total} = CC_{NPV,boiler} + FC_{NPV,boiler} + MC_{NPV,boiler} + DC_{NPV,boiler}$$

$$= 45\,489 + 81\,759 + 9\,454 + 285 = \text{£ } 136\,987$$

$$EC_{boiler} = \frac{C_{NPV,boiler,total}}{O_{L,boiler}} \times 100 = \frac{136987}{5598479} \times 100 = 2.45 \text{ p/kWh}$$

## 2) CHP

$$FI_{CHP} = (O_{CHP,h} + O_{CHP,e}) / \eta_{CHP} = (96\,360 + 48\,180) / 0.80 = 180\,675 \text{ kWh}$$

Assuming an electricity export price,  $EEC$  of 3p/kWh in this example and CHP electricity export to the grid is  $FE_{CHP}$  (kWh/year), annual CHP electricity export cost,  $FC_{CHP,export}$  (£) is:

$$FC_{CHP,export} = FE_{CHP} \times EEC / 100 = Surplus_e \times EEC = 216 \times 3 / 100 = \text{£ } 6$$

$$FC_{CHP} = FI_{CHP} \times GC - FC_{CHP,export} = 180\,675 \times 2.28 / 100 - 6 = \text{£ } 4\,113 \text{ /year}$$

Using the equation in Figure 4.15, CHP capital cost is:

$$CC_{CHP} = 1\,676 \times S_{CHPth}^{-0.3025} \times S_{CHPth} = 1\,676 \times 11^{-0.3025} \times 11 = \text{£ } 8\,929$$

Maintenance costs are assumed to be 2% of capital costs of the CHP and disposal costs are double the annual maintenance costs.

$$MC_{CHP} = CC_{CHP} \times 2\% = \text{£ } 179 \text{ /year}$$

$$DC_{CHP} = MC_{CHP} \times 2 = \text{£ } 358$$

$$O_{L,CHP} = O_{CHP} \times n = (O_{CHP,h} + O_{CHP,e}) \times n = (96\,360 + 48\,180) \times 30 = 4\,336\,200$$

kWh

$$CC_{NPVreplacement,CHP} = CC_{CHP} \times (1 + DR)^{-n} = 8\,929 \times (1 + 0.05)^{-15} = \text{£ } 3\,365$$

$$CC_{NPV,CHP} = CC_{CHP} + CC_{NPVreplacement,CHP} = 8\,929 + 3\,365 = \text{£ } 12\,294$$

$$FC_{NPV,CHP} = FC_{CHP} \times [1 - (1 + DR)^{-n}] / DR = 4\,113 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 63$$

226

$$MC_{NPV,CHP} = MC_{CHP} \times [1 - (1 + DR)^{-n}] / DR = 179 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 2\,752$$

$$DC_{NPV,CHP} = DC_{CHP} \times (1 + DR)^{-n} = 358 \times (1 + 0.05)^{-30} = \text{£ } 83$$

$$C_{NPVCHPtotal} = CC_{NPV,CHP} + FC_{NPV,CHP} + MC_{NPV,CHP} + DC_{NPV,CHP} = \text{£ } 78\,354$$

$$EC_{CHP} = \frac{C_{NPVCHP,total}}{O_{LCHP}} \times 100 = \frac{78354}{4336200} \times 100 = 1.81 \text{ p/kWh}$$

### 3) Grid

$$O_{Le} = D_e \times n = 142\,900 \times 30 = 4\,287\,000 \text{ kWh}$$

$$FC_e = D_e \times EC = 142\,900 \times 8.2 / 100 = \text{£ } 11\,718 \text{ /year}$$

$$FC_{NPV,e} = FC_e \times [1 - (1 + DR)^{-n}] / DR = 11\,718 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 180$$

131

$$EC_e = \frac{FC_{NPV,e}}{O_{Le}} \times 100 = \frac{180131}{4287000} \times 100 = 4.20 \text{ p/kWh}$$

### 4) System energy cost

System energy cost is therefore calculated using equation 4.18:

$$EC_{system} = \frac{[(EC_{CHP} \times (O_{CHP,h} + O_{CHP,e})) + (EC_{boiler} \times O_b) + (EC_{EGrid} \times D_{egrid})]}{(D_h + D_e)}$$

$$= \frac{[(1.81 \times (96360 + 48180)) + (2.45 \times 186616) + (4.2 \times 142900)]}{(266637 + 190900)} = 2.9 \text{ p/kWh}$$

### 5) Emissions and emissions saved

The annual CO<sub>2</sub> emissions  $E_{CO2,BG}$  (kg CO<sub>2</sub>) are:



$$E_{CO_2,CBG} = (D_{egrid} \times EF_e) + (D_g \times EF_g) = (D_{egrid} \times EF_e) + [(FI_{CHP} + FI_{boiler}) \times EF_g] =$$

$$(142\,900 \times 0.43) + [(180\,675 + 233\,270) \times 0.19] = 140\,097 \text{ kg CO}_2$$

System CO<sub>2</sub> Emissions per kWh for the CHP boiler and grid option are:  $E_{CO_2,CBG} / (D_e + D_h) = 140097 / (190900+266637) = 0.31 \text{ kg CO}_2/\text{kWh}$ .

Emissions saved,  $ES_{CO_2,CBG}$  (kg CO<sub>2</sub> saved) for the CHP, Boiler and Grid option is calculated using equation 4.27:

$$ES_{CO_2,CBG} = E_{CO_2,BG} - E_{CO_2,CBG} = 145\,413 - 140\,097 = 5\,317 \text{ kg CO}_2 \text{ saved}$$

For this option, a 3.7% emissions savings is achieved ( $ES_{CO_2,CBG} / E_{CO_2,BG} = 5317 / 145413 = 0.037 = 3.7\%$ ).

#### 6) System cost per emissions saved

Cost per emissions savings,  $ESC$  (£/kg CO<sub>2</sub> saved) is calculated for the CHP, Boiler and Grid option using equation 4.28:

$$ESC = \frac{EC_{system} \times (D_h + D_e)}{100 \times ES_{CO_2}} = \frac{2.9 \times (266637 + 190900)}{100 \times 5317} = 2.5 \text{ £/kgCO}_2 \text{ saved}$$

## 5.2.4 Supply of heat and electricity from ST, Boiler and Grid

### a) System sizing

No limitation in the sizing procedure was selected in this example. Therefore the tool optimises the solar thermal system to find the collector size to achieve an optimum cost of emission saving in £/kg CO<sub>2</sub> saved.

The table shown in Figure 5.13 lists the hot water demand,  $D_{HW}$  and solar irradiation,  $I_S$  for each month and totals for the year. The average collector efficiency is calculated from the simulation tables such as the one in Figure 5.12 for the whole year to obtain an average collector efficiency figure for the year. The yearly figures ( $D_{HW} = 47344$  kWh/year,  $I_S = 11217$  kWh/m<sup>2</sup>/year and  $\eta_{SC} = 27.7$  %) are used to estimate a ST size that would supply hot water in the year equal to the yearly hot water demand. Equation 4.31 is used:

$$A_{sc} = \frac{D_{HW}}{I_S \eta_{SC}} = \frac{47344}{1121.7 \times 0.277} = 153 \text{ m}^2$$

This figure is used as a maximum solar collector size in the simulation to find the optimum collector size which achieves the lowest £/kg CO<sub>2</sub> saved. £/kg CO<sub>2</sub> saved figures are recorded for every ST area in intervals of 1 m<sup>2</sup> until 153 m<sup>2</sup> in this case. The size with the lowest £/kg CO<sub>2</sub> saved in this case is 127 m<sup>2</sup>.

WEEKDAY		WEEKEND		evacuated tube		ST size = 127 m2		storage = 48 kWh			
July	100	100									
Time	Weekday Hot water demand (kWh)	Weekend Hot water demand (kWh)	Ambient temperature (degC)	Solar irradiance (W/m2)	Collector efficiency	ST output (kWh)	week day deficit (kWh)	week day surplus (kWh)	weekend deficit (kWh)	weekend surplus (kWh)	Pump running hours
1	0.4	0.6			0	0	0.4	0.0	0.6	0.5	0
2	0.1	0.8			0	0	0.1	0.0	0.8	0.8	0
3	2.1	0.2			0	0	2.1	1.5	0.2	0.2	0
4	2.6	1.4	12.3	27	0	0	2.6	2.6	0	1.4	0
5	2.6	0.7	13.8	70.5	0	0	2.6	2.6	0	0.7	0
6	1.4	0.4	15.1	143.25	0	0	1.4	1.4	0	0.4	0
7	3.7	0.8	16.4	246	0.18	5.67	0.0	0.0	2.01	0.0	4.84
8	0.4	1.1	17.5	346	0.34	15.03	0.0	0.0	14.58	0.0	13.94
9	13.9	0.6	18.5	429.5	0.42	22.86	0.0	0.0	9.00	0.0	22.29
10	12.6	2.7	19.3	488.75	0.46	28.49	0.0	0.0	15.31	0.0	25.79
11	11.6	1.9	20.0	519.25	0.48	31.49	0.0	0.0	19.94	0.0	29.63
12	14.6	10.2	20.6	519.25	0.48	31.72	0.0	0.0	17.09	0.0	21.52
13	8.7	14.8	20.9	488.75	0.47	29.16	0.0	0.0	20.43	0.0	14.40
14	9.8	7.9	21.1	429.5	0.44	23.95	0.0	0.0	14.14	0.0	16.06
15	7.7	1.5	21.0	346	0.38	16.52	0.0	0.0	8.82	0.0	14.98
16	4.7	1.3	20.8	246	0.24	7.52	0.0	0.0	2.83	0.0	6.17
17	5.7	1.9	20.3	143.25	0	0	5.7	0.0	0.0	1.9	0.0
18	10.8	7.4	19.6	70.5	0	0	10.8	0.0	0.0	7.4	0.0
19	6.8	3.9	18.7	27	0	0	6.8	0.0	0.0	3.9	0.0
20	2.2	12.8			0	0	2.2	0.0	0.0	12.8	0.0
21	3.4	8.9			0	0	3.4	0.0	0.0	8.9	0.0
22	9.1	4.1			0	0	9.1	0.0	0.0	4.1	0.0
23	5.0	3.6			0	0	5.0	0.0	0.0	3.6	0.0
24	3.7	5.3			0	0	3.7	0.0	0.0	5.3	0.0
	143.7	94.6		4540.5			8.2	8.2	124.77	3.9	169.62
									47.91		47.91

Figure 5.12 ST simulation for a typical July day




Figure 5.13 ST sizing

Figure 5.12 shows the hourly simulation of the solar thermal system for a typical July day. As previously mentioned, it is assumed that the solar thermal system supplies only domestic hot water and the collector type used in this tool is evacuated tube. The computer tool evaluates the solar collector output on an hourly basis for a typical day for each month as follows:

Typical evacuated solar collector efficiency is calculated on an hourly basis using equation 4.32. The average collector temperature,  $T_{SCav}$  is assumed to be 55°C. At 10 am the ambient temperature,  $T_{Am}$  is 19.3°C and the incident solar radiation normal to the collector,  $I_s$  is 488.75 kW/m<sup>2</sup>. The solar collector efficiency (%) 10am therefore is:

$$\eta_{sc} = 0.7 - 3.3 \frac{T_{SCav} - T_{Am}}{I_s} = 0.7 - 3.3 \frac{55 - 19.3}{488.75} = 0.46 = 46\%$$

The output of the solar thermal system is calculated using equation 4.31. Assuming a collector area,  $A_{sc}$  of 137 m<sup>2</sup>, then the collector output,  $Q_{sc}$  (kW) is:

$$Q_{sc} = A_{sc} I_s \eta_{sc} = 137 \times 488.75 \times 0.46 = 28.5 \text{ kW}$$

Assuming a constant output throughout the hour then  $Q_{sc} = 28.5$  kWh during that hour.

Hourly deficit and surplus values are calculated, as well as the hourly deficit after hot water storage has been taken into account.

For example, there is no hot water deficit,  $Deficit_{HW}$  on a weekday at 10:00am in July, because the output of the solar collector is greater than the hot water demand at that hour.

$$Deficit_{HW} = 0$$

As there is a deficit during this hour, there is no surplus. Therefore,

$$Surplus_{heat} = Q_{sc} - D_{HW} = 28.5 - 12.6 = 15.9 \text{ kWh}$$

The surpluses and deficits are calculated in this manner for every hour in the day for a weekday and a weekend day as shown in Figure 5.12.

The hot water storage capacity is assumed to be 1/3 of the daily hot water demand, which in this case is 48 kWh. The heat deficit taking into account the heat storage is calculated for every hour. The daily heat surplus as calculated above is assumed to be stored in the hot water storage. Therefore the surplus hot water available to be used that day is assumed to be the daily hot water surplus or if this is greater than the storage capacity then the storage capacity is taken as the surplus hot water available to be used that day. For example, on the July day shown in Figure 5.12, the hot water surplus on a weekday is 47.9 kWh, which is less than the storage capacity. Therefore this figure is used as the surplus hot water to be used that day. The way the calculation is carried out in the spreadsheet is as follows:

- At 17:00 there is a deficit of 5.7 kWh. However in the hot water storage there is 47.9 kWh stored. The hot water from the storage is utilised during that hour and the deficit after storage is therefore 0 at that hour. This leaves  $47.9 - 5.7 = 42.2$  kWh in the storage.
- During the next hour: 18:00, there is a deficit of 10.8 kWh, and the deficit after storage is 0 leaving  $42.2 - 10.8 = 31.4$  kWh in the storage.

This is continued until nothing is left in the storage.

The pump is assumed to be running whenever there is an output from the solar thermal system. The annual pump running hours,  $H$  in this example is 2493 hours and the pump power rating,  $P_p$  is 0.795 kW. The annual pump power consumption,  $D_{ep}$  (kWh) is calculated using equation 4.33:

$$D_{ep} = P_p H = 0.795 \times 2493 = 1982 \text{ kWh}$$

The solar thermal, boiler and grid option electricity demand,  $D_{eSBG}$  (kWh) is calculated by adding the electricity demand and the pump electricity demand:

$$D_{eSBG} = D_d + D_{ep} = 190\,900 + 1\,982 = 192\,900 \text{ kWh}$$

Boiler Size							Grid Demand	
peak heat demand =				134 kW			pump electricity demand =	
boiler efficiency =				0.8			1982 kWh/year	
boiler size =	167	168 kW						
Storage size =	747	747 litres						
January								
Time	Weekday Heat Demand (kWh)			Weekend Heat Demand (kWh)			Week day electricity (kWh)	Weekend electricity (kWh)
	SH	Hw	Total	SH	Hw	Total		
1	11.4	0.4	11.9	11.4	0.6	12.0	7.0	6.7
2	19.5	0.1	19.6	19.4	0.8	20.2	9.5	7.2
3	26.2	2.1	28.3	25.4	0.2	25.6	11.3	8.5
4	20.4	2.6	23.0	19.9	1.4	21.3	11.0	9.0
5	26.9	2.6	29.5	26.4	0.7	27.1	11.3	9.8
6	18.6	1.4	20.0	18.4	0.4	18.8	11.1	10.0
7	130.3	3.7	134.0	126.4	0.8	127.3	14.5	11.1
8	113.4	0.4	113.9	112.4	1.1	113.5	22.8	16.2
9	110.3	13.9	124.2	108.4	0.6	109.0	28.4	19.6
10	41.3	12.6	53.9	41.4	2.7	44.1	30.6	20.0
11	46.9	11.2	58.1	46.4	1.5	47.9	34.4	24.3
12	45.7	14.0	59.8	45.4	9.6	55.0	34.8	24.2
13	40.7	8.7	49.4	40.4	14.8	55.2	33.7	24.1
14	57.2	9.8	67.0	56.4	7.9	64.3	36.2	25.6
15	47.1	7.7	54.8	46.4	1.5	48.0	36.7	24.9
16	68.3	4.7	73.0	67.4	1.3	68.8	36.8	24.7
17	62.9	5.7	68.6	62.4	1.9	64.3	39.2	26.8
18	113.1	10.8	123.9	111.4	7.4	118.8	42.2	29.6
19	89.4	6.8	96.2	89.4	3.9	93.3	46.7	36.1
20	101.4	2.2	103.6	100.4	12.8	113.2	49.4	45.6
21	87.8	3.4	91.2	87.4	8.9	96.3	45.6	46.5
22	57.9	9.1	67.0	57.4	4.1	61.5	45.0	45.6
23	33.4	5.0	38.4	33.4	3.6	37.0	37.9	38.2
24	39.3	3.7	43.0	39.4	5.3	44.7	33.8	34.0
			1552.505433			1487.167933	709.7	568.1
Annual heat load =			238054 kWh/year	Annual electricity load =			192900 kWh/year	

Figure 5.14 Boiler sizing and grid demand for ST+boiler+grid option

The boiler is sized to supply the deficit hot water calculated above and the total space heating load. The boiler is sized on the January heat demand, as this is usually the greatest. Figure 5.14 shows the spreadsheet. In this case boiler size:

$$S_b = \frac{D_{H,P}}{\eta_b} = 134 / 0.8 = 168 \text{ kW (rounded up to the next kW)}$$

The hot water storage is 1/3 of a July day Deficit heat demand of either weekday or weekend day ( $Deficit_{JanuaryWD,h}$  or  $Deficit_{JanuaryWE,h}$ ) depending on which demand is largest. In this case, the storage is therefore assumed to be  $2241 / 3 = 747$  litres.

### b) System costs and emissions

Figure 5.15 shows the spreadsheet calculating the system costs and emissions in the same way as for the CHP+Boiler+Grid option. The calculations are as follows:

#### 1) boiler

$$FI_{boiler} = O_{boiler} / \eta_{CHP} = 238\,054 / 0.80 = 297\,568 \text{ kWh}$$

$$FC_{boiler} = FI_{boiler} \times GC = 297\,568 \times 2.28 / 100 = \text{£ } 6\,785 \text{ /year}$$

$$CC_{boiler} = 1058.7 \times S_b^{-0.3314} \times S_b = 1058.7 \times 168^{-0.3314} \times 168 = \text{£ } 32\,555$$

$$MC_{boiler} = CC_{boiler} \times 2\% = \text{£ } 652 \text{ /year}$$

$$DC_{boiler} = MC_{boiler} \times 2 = \text{£ } 1\,304$$

$$O_{L,boiler} = O_{boiler} \times n = 238\,054 \times 30 = 7\,141\,620 \text{ kWh}$$

$$CC_{NPVreplacement,boiler} = CC_{boiler} \times (1 + DR)^{-n} = 32\,555 \times (1 + 0.05)^{-15} = \text{£ } 15\,660$$

<b>Costs</b>						
Project Lifetime (years) =	30					
Discount rate (%) =	5					
Gas cost =	2.28	Gas emission factor =	0.19			
Electricity cost =	8.2	Electricity emission factor =	0.43			
<b>System</b>						
<b>System = Boiler</b>						
Lifetime (years) =	15					
Efficiency =	0.8	<b>PV</b>				
Annual heat output (kWh) =	238054	7141632				
Fuel input (kWh) =	297568		<b>7141632</b>	<b>kWh</b>		
Capital costs (£) =	32,555	48215				
Annual fuel costs (£) =	6,785	104295				
Annual Maintenance (£) =	652	10023				
Disposal Cost (£) =	1304	302				
			<b>162834</b>	<b>£</b>		
<b>Energy cost (p/kWh) =</b>	<b>2.28</b>					
<b>System = ST</b>						
Lifetime (years) =	30					
Output (kWh) =	39255	1177650				
Capital costs (£) =	107950	107950				
Annual fuel costs (£) =	163	2498				
Annual Maintenance (£) =	2159	33189				
Disposal Cost (£) =	5398	1249				
			<b>144886</b>	<b>£</b>		
<b>Energy cost (p/kWh) =</b>	<b>12.30</b>					
<b>System = Grid</b>						
Annual electricity output (kWh) =	192900					
Life time output (kWh) =	<b>5787000</b>					
annual fuel costs (£) =	15817.8					
NPV fuel cost (£) =	<b>243158.36</b>					
<b>Energy cost (p/kWh) =</b>	<b>4.20</b>					
<b>System costs</b>						
Heat =	3.85	p/kWh				
Electricity =	4.20	p/kWh				
<b>TOTAL =</b>	<b>4.1</b>	<b>p/kWh</b>				
<b>ENERGY SUPPLY</b>						
	Boiler	Electricity	ST			
Energy cost (p/kWh)	2.28	8.20	8.20			
CO2 emission factor (kg/kWh)	0.19	0.43	0.43			
Annual heat/electricity load (kWh)	238054	190918				
Annual Fuel input (kWh)	297,568		1982			
Annual fuel cost (£)	6785	15655	163	<b>4.92</b>	<b>p/kWh</b>	
Annual CO2 emissions (kg)	56538	82095	852	<b>0.30</b>	<b>kg CO2/kWh</b>	
<b>Emissions saved</b>				<b>5928</b>	<b>kg CO2 saved</b>	
				<b>3.1</b>	<b>£/kg CO2 saved</b>	
				<b>4.1</b>	<b>% carbon emissions saved</b>	

Figure 5.15 Costs and emissions of the ST+Boiler+Grid option

$$CC_{NPV, boiler} = CC_{boiler} + CC_{NPVreplacement, boiler} = 32\,555 + 15\,660 = \text{£ } 48\,215$$

$$FC_{NPV, boiler} = FC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 6\,785 \times [1 - (1 + 0.05)^{-30}] / 0.05$$

$$= \text{£ } 104\,295$$



$$MC_{NPV,boiler} = MC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 652 \times [1 - (1 + 0.05)^{-30}] / 0.05$$

$$= \text{£}10\,023$$

$$DC_{NPV,boiler} = DC_{boiler} \times (1 + DR)^{-n} = 1\,304 \times (1 + 0.05)^{-30} = \text{£}302$$

$$C_{NPVboiler,total} = CC_{NPV,boiler} + FC_{NPV,boiler} + MC_{NPV,boiler} + DC_{NPV,boiler}$$

$$= 48\,215 + 104\,295 + 10\,023 + 302 = \text{£}162\,835$$

$$EC_{boiler} = \frac{C_{NPVboiler,total}}{O_{Lboiler}} \times 100 = \frac{162835}{7141620} \times 100 = 2.28 \text{ p/kWh}$$

## 2) ST

$$FI_{ST} = D_{ep} = 1\,982 \text{ kWh}$$

$$FC_{ST} = FI_{ST} \times EC = 1\,982 \times 8.2 / 100 = \text{£}163 \text{ /year}$$

Using a cost figure of £853/m<sup>2</sup>:

$$CC_{ST} = 853 \times A_{sc} = 853 \times 127 = \text{£}107\,950$$

Maintenance costs are assumed to be 2% of capital costs of the ST and disposal costs are double the annual maintenance costs.

$$MC_{ST} = CC_{ST} \times 2\% = \text{£}2\,159 \text{ /year}$$

$$DC_{ST} = MC_{ST} \times 2 = \text{£}5\,398$$

$$O_{L,ST} = O_{ST} \times n = O_{ST} \times n = 39\,255 \times 30 = 1\,177\,650 \text{ kWh}$$

The solar thermal system has lifetime of 30 years in this example. There therefore is no replacement cost and the NPV capital cost is equal to the current capital cost in this example:

$$CC_{NPV, replacement, ST} = \text{£}0$$

$$CC_{NPV, ST} = CC_{ST} = \text{£} 107\,950$$

$$FC_{NPV, ST} = FC_{ST} \times [1 - (1 + DR)^{-n}] / DR = 163 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£} 2\,498$$

$$MC_{NPV, ST} = MC_{ST} \times [1 - (1 + DR)^{-n}] / DR = 2\,159 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£} 33$$

189

$$DC_{NPV, ST} = DC_{ST} \times (1 + DR)^{-n} = 5398 \times (1 + 0.05)^{-30} = \text{£} 1249$$

$$C_{NPV, ST, total} = CC_{NPV, ST} + FC_{NPV, ST} + MC_{NPV, ST} + DC_{NPV, ST} = \text{£} 144\,886$$

$$EC_{ST} = \frac{C_{NPV, CHP, total}}{O_{LCHP}} \times 100 = \frac{144886}{1177650} \times 100 = 12.30 \text{ p/kWh}$$

### 3) Grid

$$O_{Le} = D_{eSBG} \times n = 192\,900 \times 30 = 5\,787\,000 \text{ kWh}$$

$$FC_e = D_e \times EC = 192\,900 \times 8.2 / 100 = \text{£} 15\,818 \text{ /year}$$

$$FC_{NPV, e} = FC_e \times [1 - (1 + DR)^{-n}] / DR = 15\,818 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£} 243$$

158

$$EC_e = \frac{FC_{NPV, e}}{O_{Le}} \times 100 = \frac{243158}{5787000} \times 100 = 4.20 \text{ p/kWh}$$

#### 4) System energy cost

System energy cost is calculated using equation 4.18:

$$EC_{system} = \frac{[(EC_{ST} \times O_{ST}) + (EC_{boiler} \times O_b) + (EC_{EGrid} \times D_{egrid})]}{(D_h + D_e)}$$
$$= \frac{[(12.3 \times 39255) + (2.28 \times 238054) + (4.2 \times 192900)]}{(266637 + 192900)} = 4.1p / kWh$$

#### 5) Emissions and emissions saved

The annual CO<sub>2</sub> emissions  $E_{CO_2,BG}$  (kg CO<sub>2</sub>) are:

$$E_{CO_2,STBG} = (D_{egrid} \times EF_e) + (D_g \times EF_g) = (D_{egrid} \times EF_e) + (FI_{boiler} \times EF_g) = (192\,900 \times 0.43) + (297\,568 \times 0.19) = 139\,485 \text{ kg CO}_2$$

System CO<sub>2</sub> Emissions per kWh for the ST, boiler and grid option are:  $E_{CO_2,SBG} / (D_e + D_h) = 139485 / (192900 + 266637) = 0.30 \text{ kg CO}_2/\text{kWh}$ .

Emissions saved,  $ES_{CO_2,CBG}$  (kg CO<sub>2</sub> saved) for the ST, Boiler and Grid option is:

$$ES_{CO_2,STBG} = E_{CO_2,BG} - E_{CO_2,STBG} = 145\,413 - 139\,485 = 5\,928 \text{ kg CO}_2 \text{ saved}$$

For this option, a 3.7% emissions savings is achieved ( $ES_{CO_2,CBG} / E_{CO_2,BG} = 5928 / 145413 = 0.041 = 4.1\%$ ).

#### 6) System cost per emissions saved

Cost per emissions savings,  $ESC$  (£/kg CO<sub>2</sub> saved) is calculated for the ST, Boiler and Grid option:

$$ESC = \frac{EC_{system} \times (D_h + D_e)}{100 \times ES_{CO_2}} = \frac{4.1 \times (266637 + 192900)}{100 \times 5928} = 3.1 \text{ £/kgCO}_2 \text{ saved}$$

## 5.2.5 Supply of heat and electricity from a ST, CHP, Boiler and Grid

### a) System sizing

**Table 5.2 Extract of optimisation table of ST with CHP**

ST area m <sup>2</sup>	CHP kW <sub>th</sub>	p/kWh	% carbon emissions saved	£/kg CO <sub>2</sub> saved
38	17	3	9.2	1
9	17	2.7	7.7	1.1
10	17	2.7	7.8	1.1
11	16	2.8	7.8	1.1
12	16	2.8	7.9	1.1
13	16	2.8	8	1.1
14	16	2.8	8	1.1
15	15	2.8	8	1.1
16	15	2.8	8	1.1
17	15	2.8	8	1.1
18	15	2.8	8.1	1.1
19	15	2.9	8.2	1.1
20	15	2.9	8.2	1.1
21	15	2.9	8.2	1.1
22	15	2.9	8.3	1.1
23	15	2.9	8.3	1.1
24	14	2.9	8.2	1.1
25	14	2.9	8.3	1.1
26	14	2.9	8.3	1.1
27	14	2.9	8.4	1.1
28	14	2.9	8.4	1.1
29	14	3	8.5	1.1
30	14	3	8.6	1.1

Since no sizing limitation was selected in this example. The tool therefore calculates the optimum CHP size, in the manner described in the CHP+Boiler+Grid option, for different ST collector sizes. This data is listed and the sorted to find an optimum combination of ST and CHP in terms of £/kgCO<sub>2</sub> saved. Table 5.2 shows the first

few lines of this data table in the tool. In this example the optimum combination of ST with CHP is found to be 38 m<sup>2</sup> of ST collectors with a CHP size with a heat rating of 17 kW<sub>th</sub>.

July		1.00	1.00											
Time	Weekday Hot water demand (kWh)	Weekend Hot water demand (kWh)	Ambient temperature (degC)	Solar irradiance (W/m2)	Collector efficiency	ST output (kWh)	weekday deficit (kWh)	W/D deficit after storage (kWh)	weekday surplus (kWh)	weekend deficit (kWh)	W/E deficit after storage (kWh)	weekend surplus (kWh)	Pump running hours	
1	0.4	0.6				0	0	0.4	0.4	0	0.6	0.6	0	0
2	0.1	0.8				0	0	0.1	0.1	0	0.8	0.8	0	0
3	2.1	0.2				0	0	2.1	2.1	0	0.2	0.2	0	0
4	2.6	1.4	12.3	27	0	0	2.6	2.6	0	1.4	1.4	0	0	0
5	2.6	0.7	13.8	70.5	0	0	2.6	2.6	0	0.7	0.7	0	0	0
6	1.4	0.4	15.1	143.25	0	0	1.4	1.4	0	0.4	0.4	0	0	0
7	3.7	0.8	16.4	246	0.18	1.70	2.0	2.0	0	0.0	0.0	0.86	1	1
8	0.4	1.1	17.5	346	0.34	4.50	0.0	0.0	4.05	0.0	0.0	3.41	1	1
9	13.9	0.6	18.5	429.5	0.42	6.84	7.0	7.0	0	0.0	0.0	6.26	1	1
10	12.6	2.7	19.3	488.75	0.46	8.52	4.1	4.1	0	0.0	0.0	5.83	1	1
11	11.6	1.9	20.0	519.25	0.48	3.42	2.1	2.1	0	0.0	0.0	7.56	1	1
12	14.6	10.2	20.6	519.25	0.48	3.49	5.1	5.1	0	0.7	0.7	0.00	1	1
13	8.7	14.8	20.9	488.75	0.47	8.72	0.0	0.0	0	6.0	6.0	0.00	1	1
14	9.8	7.9	21.1	429.5	0.44	7.17	2.7	2.7	0	0.7	0.7	0.00	1	1
15	7.7	1.5	21.0	346	0.38	4.94	2.8	2.8	0	0.0	0.0	3.40	1	1
16	4.7	1.3	20.8	246	0.24	2.25	2.4	2.4	0	0.0	0.0	0.90	1	1
17	5.7	1.9	20.3	143.25	0	0	5.7	1.7	0	1.9	0.0	0	0	0
18	10.8	7.4	19.6	70.5	0	0	10.8	10.8	0	7.4	0.0	0	0	0
19	6.8	3.9	18.7	27	0	0	6.8	6.8	0	3.9	0.0	0	0	0
20	2.2	12.8				0	0	2.2	2.2	0	12.8	0.0	0	0
21	3.4	8.9				0	0	3.4	3.4	0	8.9	6.5	0	0
22	9.1	4.1				0	0	9.1	9.1	0	4.1	4.1	0	0
23	5.0	3.6				0	0	5.0	5.0	0	3.6	3.6	0	0
24	3.7	5.3				0	0	3.7	3.7	0	5.3	5.3	0	0
	143.7	94.6		4540.5			80.2	80.2	4.05	31.1	31.1	28.23	310	310
									4.05			28.23		

Figure 5.16 July day simulation of ST system

Figure 5.16 works in the same way as Figure 5.12 in simulating the solar thermal system for every hour on a July day and Figure 5.17 works in the same way as Figure 5.9 in simulating the CHP system for every hour on a July day. The hourly CHP heat demand is calculated by adding the hourly space heating demand to the hourly solar thermal hot water deficit from Figure 5.16. There is no space heating demand,  $D_{SH}$  during July. The CHP heat demand,  $D_{H,CHP}$  therefore for a weekday at 17:00 would be:

$$D_{H,CHP} = Deficit_{ST} + D_{SH} = 1.7 + 0 = 1.7 \text{ kWh}$$

The boiler is sized to supply the deficit hot water and space heating demands calculated above. The boiler is sized on the January heat demand (the peak deficit

calculated in the CHP spreadsheet for the month of January). Figure 5.18 shows the spreadsheet.

July												July											
Time	Weekday heat demand	CHP running hours	CHP (kWh)			Electricity demand			CHP (kWh)			Time	Weekend day heat demand	CHP running hours	CHP (kWh)			Electricity demand					
			Output	Deficit	Surplus	demand	Output	Deficit	Surplus	Output	Deficit				Surplus	demand	Output	Deficit	Surplus				
1	0.4	1	17	0.0	16.6	4.4	8.5	0.0	4.1	1	0.6	1	17	0.0	16.4	4.2	8.5	0.0	4.3				
2	0.1	1	17	0.0	16.9	5.9	8.5	0.0	2.6	2	0.8	1	17	0.0	16.2	4.5	8.5	0.0	4.0				
3	2.1	1	17	0.0	14.9	7.0	8.5	0.0	1.5	3	0.2	1	17	0.0	16.8	5.3	8.5	0.0	3.2				
4	2.6	1	17	0.0	14.4	6.9	8.5	0.0	1.6	4	1.4	1	17	0.0	15.6	5.6	8.5	0.0	2.9				
5	2.6	1	17	0.0	14.4	7.0	8.5	0.0	1.5	5	0.7	1	17	0.0	16.3	6.1	8.5	0.0	2.4				
6	1.4	1	17	0.0	15.6	6.9	8.5	0.0	1.6	6	0.4	1	17	0.0	16.6	6.3	8.5	0.0	2.2				
7	2.0	1	17	0.0	15.0	9.1	8.5	0.6	0.0	7	0.0	0	0	0.0	0.0	6.9	0	6.9	0.0				
8	0.0	0	0	0.0	0.0	14.2	0	14.2	0.0	8	0.0	0	0	0.0	0.0	10.1	0	10.1	0.0				
9	7.0	1	17	0.0	10.0	17.7	8.5	9.2	0.0	9	0.0	0	0	0.0	0.0	12.2	0	12.2	0.0				
10	4.1	1	17	0.0	12.9	19.1	8.5	10.6	0.0	10	0.0	0	0	0.0	0.0	12.5	0	12.5	0.0				
11	2.1	1	17	0.0	14.9	21.4	8.5	12.9	0.0	11	0.0	0	0	0.0	0.0	15.2	0	15.2	0.0				
12	5.1	1	17	0.0	11.9	21.7	8.5	13.2	0.0	12	0.7	1	17	0.0	16.3	15.1	8.5	6.6	0.0				
13	0.0	1	17	0.0	17.0	21.1	8.5	12.6	0.0	13	6.0	1	17	0.0	11.0	15.0	8.5	6.5	0.0				
14	2.7	1	17	0.0	14.3	22.6	8.5	14.1	0.0	14	0.7	1	17	0.0	16.3	16.0	8.5	7.5	0.0				
15	2.8	1	17	0.0	14.2	22.9	8.5	14.4	0.0	15	0.0	0	0	0.0	0.0	15.5	0	15.5	0.0				
16	2.4	1	17	0.0	14.6	23.0	8.5	14.5	0.0	16	0.0	0	0	0.0	0.0	15.4	0	15.4	0.0				
17	1.7	1	17	0.0	15.3	24.4	8.5	15.9	0.0	17	0.0	0	0	0.0	0.0	16.7	0	16.7	0.0				
18	10.8	1	17	0.0	6.2	26.3	8.5	17.8	0.0	18	0.0	0	0	0.0	0.0	18.5	0	18.5	0.0				
19	6.8	1	17	0.0	10.2	29.1	8.5	20.6	0.0	19	0.0	0	0	0.0	0.0	22.5	0	22.5	0.0				
20	2.2	1	17	0.0	14.8	30.8	8.5	22.3	0.0	20	0.0	0	0	0.0	0.0	28.4	0	28.4	0.0				
21	3.4	1	17	0.0	13.6	28.5	8.5	20.0	0.0	21	6.5	1	17	0.0	10.5	29.0	8.5	20.5	0.0				
22	9.1	1	17	0.0	7.9	28.1	8.5	19.6	0.0	22	4.1	1	17	0.0	12.9	28.4	8.5	19.9	0.0				
23	5.0	1	17	0.0	12.0	23.6	8.5	15.1	0.0	23	3.6	1	17	0.0	13.4	23.8	8.5	15.3	0.0				
24	3.7	1	17	0.0	13.3	21.1	8.5	12.6	0.0	24	5.3	1	17	0.0	11.7	21.2	8.5	12.7	0.0				
80.2		391.0		0.0	310.8	442.9	195.5	260.2	12.8	311		2210		0.0	189.9	354.5	110.5	263.1	19.0				
				0.0			5654.1						0.0						2286.2				

Figure 5.17 July day hourly CHP simulation for ST+CHP+Boiler+Grid option

In this case boiler size:

$$S_b = \frac{D_{H,p}}{\eta_b} = 117 / 0.8 = 147 \text{ kW (rounded up to the next kW)}$$

The hot water storage is 1/3 of a July day Deficit heat demand of either weekday or weekend day ( $Deficit_{JanuaryWD,h}$  or  $Deficit_{JanuaryWE,h}$ ) depending on which demand is largest. In this case, the storage is therefore assumed to be  $1149 / 3 = 384$  litres.

Boiler Size				Grid Demand			
peak heat demand =		117	kW				
boiler efficiency =		0.8				761	kWh/year
boiler size =	146	147	kW				
Hot water storage size =	383	384	litres				
Annual Boiler Load =		119747	kWh/year	Annual EGrid Load =		124100	kWh/year

Figure 5.18 Boiler and grid sizing for ST+CHP+Boiler+Grid option

b) System costs and emissions

<b>Costs</b>					
Project Lifetime (years) =	30				
Discount rate (%) =	5				
Electricity export price (p/kWh) =	3				
Gas cost (p/kWh) =	2.28	Gas emission factor =	0.19		
Electricity cost (kWh) =	8.2	Electricity emission factor =	0.43		
<b>System</b>					
<b>System = Boiler</b>					
Lifetime (years) =	15				
Efficiency =	0.8	<b>PW</b>			
Annual heat output (kWh) =	119747	3592400			
Fuel input (kWh) =	149683		<b>3592400</b>	<b>kWh</b>	
Capital costs (£) =	29,775	44097			
Annual fuel costs (£) =	3,413	52463			
Annual Maintenance (£) =	596	9162			
Disposal Cost (£) =	1192	276			
			<b>105998</b>	<b>£</b>	
<b>Energy cost (p/kWh) =</b>	<b>2.95</b>				
<b>System = ST</b>					
Lifetime (years) =	30				
	m2	38.0			
Output (kWh) =	11746	352380	<b>352380</b>	<b>kWh</b>	
Capital costs (£) =	32300	32300			
Annual Maintenance (£) =	646	9931			
Disposal Cost (£) =	1615	374			
Annual fuel costs (£) =	62,402	959	<b>43564</b>	<b>£</b>	
<b>Energy cost (p/kWh) =</b>	<b>12.36</b>				
<b>System = CHP</b>					
CHP Lifetime (years) =	20				
Efficiency =	0.8				
Annual heat output (kWh) =	141016	4230480			
Annual electricity output (kWh) =	70508	2115240	<b>6345721</b>	<b>kWh</b>	
Fuel input (kWh) =	264405				
Capital costs (£) =	12097	16656			
Annual fuel costs (£) =	5941	91320			
Annual Maintenance (£) =	242	3720			
Disposal Cost (£) =	484	112			
Electricity export (£) =	-88		<b>111809</b>	<b>£</b>	
<b>Energy cost (p/kWh) =</b>	<b>1.76</b>				
<b>System = Grid</b>					
Annual electricity output (kWh) =	124100				
Life time output (kWh) =	<b>3723000</b>				
annual fuel costs (£) =	10176.2				
NPV fuel cost (£) =	<b>156433</b>				
<b>Energy cost (p/kWh) =</b>	<b>4.20</b>				
<b>System costs</b>					
Heat =	2.80	p/kWh			
Electricity =	3.34	p/kWh			
<b>TOTAL =</b>	<b>3.1</b>	<b>p/kWh</b>			
<b>ENERGY SUPPLY</b>					
	Boiler	Electricity	ST	CHP	
Energy cost (p/kWh)	2.28	8.20	8.20	2.28	
CO2 emission factor (kg/kWh)	0.19	0.43	0.43	0.19	
Annual heat/electricity load (kWh)	119747	123339		211524	
Annual Fuel input (kWh)	149,683		761	264,405	
Annual fuel cost (£)	3413	10114	62	5941	<b>4.26</b>
Annual CO2 emissions (kg)	28440	53036	327	50237	<b>0.29</b>
<b>Emissions saved</b>					<b>13374</b>
					<b>1.1</b>
					<b>9.2</b>
					<b>% carbon emissions saved</b>

Figure 5.19 Costs and emissions for ST+CHP+Boiler+Grid option

1) boiler

$$FI_{boiler} = O_{boiler} / \eta_{CHP} = 119\,747 / 0.80 = 149\,683 \text{ kWh}$$

$$FC_{boiler} = FI_{boiler} \times GC = 149\,683 \times 2.28 / 100 = \text{£ } 3\,413 \text{ /year}$$

$$CC_{boiler} = 1058.7 \times S_b^{-0.3314} \times S_b = 1058.7 \times 147^{-0.3314} \times 147 = \text{£ } 29\,775$$

$$MC_{boiler} = CC_{boiler} \times 2\% = \text{£ } 596 \text{ /year}$$

$$DC_{boiler} = MC_{boiler} \times 2 = \text{£ } 1\,192$$

$$O_{L,boiler} = O_{boiler} \times n = 119\,747 \times 30 = 3\,592\,400 \text{ kWh}$$

$$CC_{NPV,replacement,boiler} = CC_{boiler} \times (1 + DR)^{-n} = 29\,775 \times (1 + 0.05)^{-15} = \text{£ } 14\,322$$

$$CC_{NPV,boiler} = CC_{boiler} + CC_{NPV,replacement,boiler} = 29\,775 + 14\,322 = \text{£ } 44\,097$$

$$FC_{NPV,boiler} = FC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 3\,413 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 52\,463$$

$$MC_{NPV,boiler} = MC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 596 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 9\,162$$

$$DC_{NPV,boiler} = DC_{boiler} \times (1 + DR)^{-n} = 1\,192 \times (1 + 0.05)^{-30} = \text{£ } 276$$

$$C_{NPV,boiler,total} = CC_{NPV,boiler} + FC_{NPV,boiler} + MC_{NPV,boiler} + DC_{NPV,boiler}$$

$$= 44\,097 + 52\,463 + 9\,162 + 276 = \text{£ } 105\,998$$

$$EC_{boiler} = \frac{C_{NPV,boiler,total}}{O_{Lboiler}} \times 100 = \frac{105998}{3592400} \times 100 = 2.95 \text{ p/kWh}$$



2) ST

$$FI_{ST} = D_{ep} = 761 \text{ kWh}$$

$$FC_{ST} = FI_{ST} \times EC = 761 \times 8.2 / 100 = \text{£ } 62 \text{ /year}$$

Using a cost figure of £853/m<sup>2</sup>:

$$CC_{ST} = 853 \times A_{sc} = 853 \times 38 = \text{£ } 32\,300$$

Maintenance costs are assumed to be 2% of capital costs of the ST and disposal costs are double the annual maintenance costs.

$$MC_{ST} = CC_{ST} \times 2\% = \text{£ } 646 \text{ /year}$$

$$DC_{ST} = MC_{CHP} \times 2 = \text{£ } 1\,615$$

$$O_{L,ST} = O_{ST} \times n = O_{ST} \times n = 11\,746 \times 30 = 352\,380 \text{ kWh}$$

The solar thermal system has lifetime of 30 years in this example. There therefore is no replacement cost and the NPV capital cost is equal to the current capital cost in this example:

$$CC_{NPV, \text{replacement}, ST} = \text{£ } 0$$

$$CC_{NPV, ST} = CC_{ST} = \text{£ } 32\,300$$

$$FC_{NPV, ST} = FC_{ST} \times [1 - (1 + DR)^{-n}] / DR = 62 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 969$$

$$MC_{NPV, ST} = MC_{ST} \times [1 - (1 + DR)^{-n}] / DR = 646 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 9\,931$$

$$DC_{NPV, ST} = DC_{ST} \times (1 + DR)^{-n} = 1\,615 \times (1 + 0.05)^{-30} = \text{£ } 374$$

$$C_{NPVSTtotal} = CC_{NPV,ST} + FC_{NPV,ST} + MC_{NPV,ST} + DC_{NPV,ST} = \text{£ } 43\,564$$

$$EC_{ST} = \frac{C_{NPVCHP,total}}{O_{LCHP}} \times 100 = \frac{43564}{352380} \times 100 = 12.36 \text{ p/kWh}$$

### 3) CHP

$$FI_{CHP} = (O_{CHP,h} + O_{CHP,e}) / \eta_{CHP} = (141\,016 + 70\,508) / 0.80 = 264\,405 \text{ kWh}$$

$$FC_{CHP,export} = FE_{CHP} \times EEC / 100 = \text{Surplus}_e \times EEC = 2\,931 \times 3 / 100 = \text{£ } 88$$

$$FC_{CHP} = FI_{CHP} \times GC - FC_{CHP,export} = 264\,405 \times 2.28 / 100 - 88 = \text{£ } 5\,941 \text{ /year}$$

$$CC_{CHP} = 1\,676 \times S_{CHPth}^{-0.3025} \times S_{CHPth} = 1\,676 \times 17^{-0.3025} \times 17 = \text{£ } 12\,097$$

$$MC_{CHP} = CC_{CHP} \times 2\% = \text{£ } 242 \text{ /year}$$

$$DC_{CHP} = MC_{CHP} \times 2 = \text{£ } 484$$

$$O_{L,CHP} = O_{CHP} \times n = (O_{CHP,h} + O_{CHP,e}) \times n = (141\,016 + 70\,508) \times 30 = 6\,345\,721$$

kWh

$$CC_{NPVreplacement,CHP} = CC_{CHP} \times (1 + DR)^{-n} = 12\,097 \times (1 + 0.05)^{-15} = \text{£ } 4\,559$$

$$CC_{NPV,CHP} = CC_{CHP} + CC_{NPVreplacement,CHP} = 12\,097 + 4\,559 = \text{£ } 16\,656$$

$$FC_{NPV,CHP} = FC_{CHP} \times [1 - (1 + DR)^{-n}] / DR = 5\,941 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 91$$

320

$$MC_{NPV,CHP} = MC_{CHP} \times [1 - (1 + DR)^{-n}] / DR = 242 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 3$$

720

$$DC_{NPV,CHP} = DC_{CHP} \times (1 + DR)^{-n} = 484 \times (1 + 0.05)^{-30} = \text{£ } 112$$

$$C_{NPVCHPtotal} = CC_{NPV,CHP} + FC_{NPV,CHP} + MC_{NPV,CHP} + DC_{NPV,CHP} = \text{£ } 111\,809$$

$$EC_{CHP} = \frac{C_{NPVCHP,total}}{O_{LCHP}} \times 100 = \frac{111809}{6345721} \times 100 = 1.76 \text{ p/kWh}$$

#### 4) Grid

$$O_{Le} = D_{eSCBG} \times n = 124\,100 \times 30 = 3\,723\,000 \text{ kWh}$$

$$FC_e = D_{eSCBG} \times EC = 124\,100 \times 8.2 / 100 = \text{£ } 10\,176 \text{ /year}$$

$$FC_{NPV,e} = FC_e \times [1 - (1 + DR)^{-n}] / DR = 10\,176 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 156$$

433

$$EC_{EGrid} = \frac{FC_{NPV,e}}{O_{Le}} \times 100 = \frac{156433}{3723000} \times 100 = 4.20 \text{ p/kWh}$$

#### 4) System energy cost

$$EC_{system,SCBG} = \frac{[(EC_{ST} \times O_{ST}) + (EC_{CHP} \times (O_{CHP,h} + O_{CHP,e})) + (EC_{boiler} \times O_b) + (EC_{EGrid} \times D_{eSCBG})]}{(D_h + D_e)}$$

$$= \frac{[(12.36 \times 11746) + (1.76 \times (141016 + 70508)) + (2.95 \times 119747) + (4.2 \times 124100)]}{(266637 + 192900)} = 3.1 \text{ p/kWh}$$

#### 5) Emissions and emissions saved

The annual CO<sub>2</sub> emissions  $E_{CO2,SCBG}$  (kg CO<sub>2</sub>) are:

$$E_{CO2,SCBG} = (D_{egrid} \times EF_e) + (D_g \times EF_g) = (D_{egrid} \times EF_e) + ((FI_{boiler} + FI_{CHP}) \times EF_g) =$$

$$(124\,100 \times 0.43) + ((149\,683 + 264\,405) \times 0.19) = 132\,040 \text{ kg CO}_2$$

System CO<sub>2</sub> Emissions per kWh for the ST, CHP, boiler and grid option are:

$$E_{CO_2,SCBG} / (D_e + D_h) = 132040 / (192900+266637) = 0.29 \text{ kg CO}_2/\text{kWh}.$$

Emissions saved,  $ES_{CO_2,CSBG}$  (kg CO<sub>2</sub> saved) for the ST, CHP, Boiler and Grid option is:

$$ES_{CO_2,SCBG} = E_{CO_2,BG} - E_{CO_2,STBG} = 145\,413 - 132\,040 = 13\,374 \text{ kg CO}_2 \text{ saved}$$

For this option, a 9.2% emissions savings is achieved ( $ES_{CO_2,SCBG} / E_{CO_2,BG} = 13374 / 145413 = 0.092 = 9.2\%$ ).

#### 6) System cost per emissions saved

$$ESC_{SCBG} = \frac{EC_{system,SCBG} \times (D_h + D_e)}{100 \times ES_{CO_2,SCBG}} = \frac{3.1 \times (266637 + 192900)}{100 \times 13374} = 1.1 \text{ £ / kg CO}_2 \text{ saved}$$

### 5.2.6 Supply of heat and electricity from PV, Boiler and Grid

#### a) System sizing

In this case it was assumed that there select is no restriction on the amount of roof area and capital cost and the PV panel are sized to provide the optimum annual electricity demand.

Monthly electricity demands and monthly irradiation values are listed in the table in Figure 5.21. The maximum PV area assumed in the optimisation is a PV size with a monthly output equal to the demand in the month of July. In July, the electricity

demand,  $D_e$  is 12 703 kWh, the incident solar irradiation,  $I_s$  is 140.8 kWh/m<sup>2</sup>, the efficiency of the PV cells,  $\eta_{PV}$  is 14%, and the efficiency of the power conditioner (inverter, controller), transformer and interconnection (1-  $L$ ) is (1 - 0.25) = 75%. Equation 4.29 is used to calculate the PV area with an output equal to the demand in July:

$$S_{PV} = \frac{D_e}{I_s(1-L)\eta_{PV}} = \frac{12703}{140.8 \times (1-0.25) \times 0.14} = 860m^2$$

**Table 5.3 Extract of PV size optimisation table**

PV size (m <sup>2</sup> )	Energy cost (p/kWh)	Emissions (kg CO <sub>2</sub> /kWh)	(£/kg CO <sub>2</sub> saved)
550	4.2	0.266	0.8
552	4.2	0.266	0.8
553	4.2	0.266	0.8
554	4.2	0.266	0.8
555	4.2	0.266	0.8
556	4.2	0.266	0.8
557	4.2	0.266	0.8
558	4.2	0.266	0.8
559	4.2	0.266	0.8
560	4.2	0.266	0.8
561	4.2	0.266	0.8
562	4.2	0.266	0.8
563	4.2	0.266	0.8
564	4.2	0.266	0.8
565	4.2	0.266	0.8
566	4.2	0.266	0.8
567	4.2	0.266	0.8
568	4.3	0.265	0.8
569	4.3	0.265	0.8
570	4.3	0.265	0.8
571	4.3	0.265	0.8
572	4.3	0.265	0.8
573	4.3	0.265	0.8
574	4.3	0.265	0.8
575	4.3	0.265	0.8
576	4.3	0.265	0.8
577	4.3	0.265	0.8
578	4.3	0.265	0.8
579	4.3	0.265	0.8
580	4.3	0.265	0.8

Different PV sizes are therefore simulated in the PV spreadsheet as described below in intervals of 1m<sup>2</sup> up to 860m<sup>2</sup>. This data is listed and then sorted to find an optimum PV size in terms of £/kgCO<sub>2</sub> saved. Table 5.3 shows the first few lines of this data table in the tool. In this example the optimum PV size,  $S_{PV}$  is found to be 550 m<sup>2</sup>.

Figure 5.20 shows the hourly simulation of the PV system for a typical January day. The system is simulated for a typical day in each month, to get an understanding of the yearly performance of the system.

<b>OPTION 3a:</b>		<b>PV + Boiler + Grid</b>						
<b>PV</b>								
<b>January</b>	<b>WEEKDAY</b>	21.73	<b>WEEKEND</b>	8.69		PV size =	550	m2
Time	Electricity demand (kWh)	Electricity demand (kWh)	Solar irradiance (W/m2)	PV output (kWh)	weekday deficit (kWh)	weekday surplus (kWh)	weekend deficit (kWh)	weekend surplus (kWh)
1	7.0	6.7		0	7.0	0	6.7	0
2	9.5	7.2		0	9.5	0	7.2	0
3	11.3	8.5		0	11.3	0	8.5	0
4	11.0	9.0		0	11.0	0	9.0	0
5	11.3	9.8		0	11.3	0	9.8	0
6	11.1	10.0		0	11.1	0	10.0	0
7	14.5	11.1		0	14.5	0	11.1	0
8	22.8	16.2	76	4.39	18.4	0	11.8	0
9	28.4	19.6	155	8.95	19.5	0	10.6	0
10	30.6	20.0	209.25	12.08	18.5	0	7.9	0
11	34.4	24.3	236.5	13.66	20.7	0	10.6	0
12	34.8	24.2	236.5	13.66	21.1	0	10.6	0
13	33.7	24.1	209.25	12.08	21.7	0	12.0	0
14	36.2	25.6	155	8.95	27.2	0	16.6	0
15	36.7	24.9	59.5	3.44	33.3	0	21.4	0
16	36.8	24.7		0	36.8	0	24.7	0
17	39.2	26.8		0	39.2	0	26.8	0
18	42.2	29.6		0	42.2	0	29.6	0
19	46.7	36.1		0	46.7	0	36.1	0
20	49.4	45.6		0	49.4	0	45.6	0
21	45.6	46.5		0	45.6	0	46.5	0
22	45.0	45.6		0	45.0	0	45.6	0
23	37.9	38.2		0	37.9	0	38.2	0
24	33.8	34.0		0	33.8	0	34.0	0
	709.71	568.09	1337					

Figure 5.20 Hourly PV simulation for a typical January day




Figure 5.21 PV sizing

Hourly PV output,  $O_{PV}$  (kW) is calculated using equation 4.30. For example, at 10am, the incident solar radiation  $I_s$  is  $0.20925 \text{ kW/m}^2$ , the efficiency of the PV cells  $\eta_{PV}$  is 14%, and the efficiency of the power conditioner (inverter, controller), transformer and interconnection,  $(1 - L)$  is  $(1 - 0.25)$ . The output during this hour therefore is:

$$O_{PV} = S_{PV} I_s (1 - L) \eta_{PV} = 550 \times 209.25 \times 0.14 \times (1 - 0.25) = 12.085 \text{ kW}$$

Assuming a constant output for the PV during each hour,  $O_{PV}$  can also have kWh units, as is shown in Table 4.8.

Deficit and surplus are also calculated for each hour for a weekday and a weekend day using equations 4.22 and 4.23. For example at 10am on a weekday:

$$Deficit = D - O_{PV} = 30.6 - 12.085 = 18.5$$

$$Surplus = 0$$

Monthly surplus and deficit figures are also calculated using equations 4.25 and 4.26.

For January:

$$Deficit_{monthly} = [(Deficit_{WD} \times 21.726) + (Deficit_{WE} \times 8.69)]$$

$$= [(632.5 \times 21.726) + (490.9 \times 8.69)] = 18\,008 \text{ kWh}$$

$$Surplus_{monthly} = [(Surplus_{WD} \times 21.726) + (Surplus_{WE} \times 8.69)] = 0 \text{ kWh}$$

The monthly figures are then added up to calculate yearly surplus and deficit figures.

In this example:

$$Deficit_{yearly} = 135\,489 \text{ kWh}$$

$$Surplus_{yearly} = 9\,324 \text{ kWh}$$

It is assumed here that any surplus is exported to the grid and any deficit is imported from the grid.

Boiler Size							Grid Demand		
peak space heat demand =		134 kW							
boiler efficiency =		0.8							
boiler size =		167 <b>168 kW</b>							
Storage size =		747 <b>747 litres</b>							
January									
Time	Weekday Heat Demand (kWh)			Weekend Heat Demand (kWh)			Week day electricity (kWh)	Weekend electricity (kWh)	
	SH	Hw	Total	SH	Hw	Total			
1	11.4	0.4	11.9	11.4	0.6	12.0	7.0	6.7	
2	19.5	0.1	19.6	19.4	0.8	20.2	9.5	7.2	
3	26.2	2.1	28.3	25.4	0.2	25.6	11.3	8.5	
4	20.4	2.6	23.0	19.9	1.4	21.3	11.0	9.0	
5	26.9	2.6	29.5	26.4	0.7	27.1	11.3	9.8	
6	18.6	1.4	20.0	18.4	0.4	18.8	11.1	10.0	
7	130.3	3.7	134.0	126.4	0.8	127.3	14.5	11.1	
8	113.4	0.4	113.9	112.4	1.1	113.5	22.8	16.2	
9	110.3	13.9	124.2	108.4	0.6	109.0	28.4	19.6	
10	41.3	12.6	53.9	41.4	2.7	44.1	30.6	20.0	
11	46.9	11.6	58.5	46.4	1.9	48.3	34.4	24.3	
12	45.7	14.6	60.3	45.4	10.2	55.6	34.8	24.2	
13	40.7	8.7	49.4	40.4	14.8	55.2	33.7	24.1	
14	57.2	9.8	67.0	56.4	7.9	64.3	36.2	25.6	
15	47.1	7.7	54.8	46.4	1.5	48.0	36.7	24.9	
16	68.3	4.7	73.0	67.4	1.3	68.8	36.8	24.7	
17	62.9	5.7	68.6	62.4	1.9	64.3	39.2	26.8	
18	113.1	10.8	123.9	111.4	7.4	118.8	42.2	29.6	
19	89.4	6.8	96.2	89.4	3.9	93.3	46.7	36.1	
20	101.4	2.2	103.6	100.4	12.8	113.2	49.4	45.6	
21	87.8	3.4	91.2	87.4	8.9	96.3	45.6	46.5	
22	57.9	9.1	67.0	57.4	4.1	61.5	45.0	45.6	
23	33.4	5.0	38.4	33.4	3.6	37.0	37.9	38.2	
24	39.3	3.7	43.0	39.4	5.3	44.7	33.8	34.0	
			1553.48				1488.15	709.7	568.1
Annual heat load =		266637 kWh/year					Annual electricity load =		135500 kWh/year

Figure 5.22 Boiler Sizing for PV+Boiler+Grid option

The sizing of the boiler system is exactly as for the Boiler and Grid option, as the boiler supplies all the heat in this technology combination option. Therefore:



$$S_b = \frac{D_{H,p}}{\eta_b} = 134 / 0.8 = 168 \text{ kW (rounded up to the nearest kW)}$$

and the hot water storage is  $2240 / 3 = 747$  litres.

## b) System costs and emissions

### 1) Boiler

$$FI_{boiler} = O_{boiler} / \eta_{boiler} = 266\,637 / 0.80 = 333\,296 \text{ kWh}$$

$$FC_{boiler} = FI_{boiler} \times GC = 333\,296 \times 2.28 / 100 = \text{£ } 7\,599 \text{ /year}$$

$$CC_{boiler} = 1058.7 \times S_b^{-0.3314} \times S_b = 1058.7 \times 168^{-0.3314} \times 168 = \text{£ } 32\,555$$

$$MC_{boiler} = CC_{boiler} \times 2\% = \text{£ } 652 \text{ /year}$$

$$DC_{boiler} = MC_{boiler} \times 2 = \text{£ } 1\,304$$

$$O_{L,boiler} = O_{boiler} \times n = 266\,637 \times 30 = 7\,999\,115 \text{ kWh}$$

$$CC_{NPV,replacement} = CC_{current} \times (1 + DR)^{-n} = 32\,555 \times (1 + 0.05)^{-15} = \text{£ } 15\,660$$

$$CC_{NPV} = CC_{current} + CC_{NPV,replacement} = 32\,555 + 15\,660 = \text{£ } 48\,215$$

$$FC_{NPV,boiler} = FC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 7\,599 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 116\,818$$

$$MC_{NPV,boiler} = MC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 652 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 10$$

023

$$DC_{NPV,boiler} = DC_{boiler} \times (1 + DR)^{-n} = 1\,304 \times (1 + 0.05)^{-30} = \text{£ } 302$$

$$C_{NPVboiler,total} = CC_{NPV,boiler} + FC_{NPV,boiler} + MC_{NPV,boiler} + DC_{NPV,boiler} = \text{£ } 175\,357$$

$$EC_{boiler} = \frac{C_{NPVboiler,total}}{O_{boiler}} \times 100 = \frac{175357}{7999115} \times 100 = 2.19 \text{ p/kWh}$$

Costs			
Project Lifetime (years) =	30		
Discount rate (%) =	5		
Electricity export price =	3.0	p/kWh	
Gas cost =	2.28	Gas emission factor =	0.19
Electricity cost =	8.2	Electricity emission factor =	0.43
System			
<b>System = Boiler</b>			
Lifetime (years) =	15		
Efficiency =	0.8	<b>PV</b>	
Annual heat output (kWh) =	266637	7999115	
Fuel input (kWh) =	333296.45	<b>7999115</b>	<b>kWh</b>
Capital costs (£) =	32,555	48215	
Annual fuel costs (£) =	7,599	116818	
Annual Maintenance (£) =	652	10023	
Disposal Cost (£) =	1304	302	
		<b>175357</b>	<b>£</b>
<b>Energy cost (p/kWh) =</b>	<b>2.19</b>		
<b>System = PV</b>			
Lifetime (years) =	30		
kWp	55.0		
Output (kWh) =	776322	23289660	<b>23289660 kWh</b>
Capital costs (£) =	201756	201756	
Annual Maintenance (£) =	2018	31022	
Disposal Cost (£) =	4036	934	
Export (£) =	-280	0	
		<b>233711</b>	<b>£</b>
<b>Energy cost (p/kWh) =</b>	<b>1.003499</b>		
<b>System = Grid</b>			
Annual electricity output (kWh) =	135500		
Life time output (kWh) =	<b>4065000</b>		
annual fuel costs (£) =	11111		
NPV fuel cost (£) =	<b>170803.3</b>		
<b>Energy cost (p/kWh) =</b>	<b>4.20</b>		
System costs			
Heat =	2.19	p/kWh	
Electricity =	6.92	p/kWh	
TOTAL =	<b>4.2</b>	<b>p/kWh</b>	
ENERGY SUPPLY			
	Boiler	Electricity	PV
Energy cost (p/kWh)	2.28	7.00	0
CO2 emission factor (kg/kWh)	0.19	0.43	0
Annual heat/electricity load (kWh)	266637	135500	55369
Annual Fuel input (kWh)	333,296		
Annual fuel cost (£)	7599	9485	-280
			<b>3.67 p/kWh</b>
Annual CO2 emissions (kg)	63326	58265	0
			<b>0.2660 kg CO2/kWh</b>
<b>Emissions saved</b>			<b>23822 kg CO2 saved</b>
			<b>0.8 £/kg CO2 saved</b>
			<b>16.4 % carbon emissions saved</b>

Figure 5.23 Costs and emissions for PV+Boiler+Grid option

## 2) PV

$$FI_{PV} = 0 \text{ kWh}$$

Assuming an electricity export price,  $EEC$  of 3p/kWh in this example and PV electricity export to the grid is  $FE_{PV}$  (kWh/year), annual PV electricity export cost,  $FC_{PV,export}$  (£) is:

$$FC_{PV,export} = FE_{PV} \times EEC / 100 = Surplus_e \times EEC = 9\,324 \times 3 / 100 = \text{£ } 280 \text{ /year}$$

$$FC_{PV} = FC_{PV,export} = \text{£ } -280 \text{ /year}$$

Using the equation in Figure 4.25, PV capital cost is:

$$CC_{PV} = 525.61 \times S_{PV}^{-0.057} \times S_{PV} = 525.61 \times 550^{-0.057} \times 550 = \text{£ } 201\,756$$

PV maintenance and disposal costs are assumed to be 1% and 2% respectively of the capital costs.

$$MC_{PV} = CC_{PV} \times 1\% = \text{£ } 2\,018 \text{ /year}$$

$$DC_{PV} = CC_{PV} \times 2\% = \text{£ } 4\,036$$

$$O_{L,PV} = O_{PV} \times n = 776\,322 \times 30 = 23\,289\,660 \text{ kWh}$$

The PV system lifetime is the same as the project lifetime in this case. There therefore is no replacement cost for the PV system in this example.

$$CC_{NPV,replacement,PV} = \text{£ } 0$$

$$CC_{NPV,PV} = CC_{PV} = \text{£ } 201\,756$$

$$FC_{NPV,PV} = FC_{PV} \times [1 - (1 + DR)^{-n}] / DR = \text{£ } 0$$

$$MC_{NPV,PV} = MC_{PV} \times [1 - (1 + DR)^{-n}] / DR = 2\,018 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 31$$

022

$$DC_{NPV,PV} = DC_{PV} \times (1 + DR)^{-n} = 4\,036 \times (1 + 0.05)^{-30} = \text{£ } 934$$

$$C_{NPV,PV,total} = CC_{NPV,PV} + FC_{NPV,PV} + MC_{NPV,PV} + DC_{NPV,PV} = \text{£ } 233\,711$$

$$EC_{PV} = \frac{C_{NPV,PV,total}}{O_{LPV}} \times 100 = \frac{233711}{776322} \times 100 = 1.00 \text{ p/kWh}$$

### 3) Grid

$$O_{Le} = D_e \times n = 135\,500 \times 30 = 4\,065\,000 \text{ kWh}$$

$$FC_e = D_e \times EC = 135\,500 \times 8.2 / 100 = \text{£ } 11\,111 \text{ /year}$$

$$FC_{NPV,e} = FC_e \times [1 - (1 + DR)^{-n}] / DR = 11\,111 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 170$$

803

$$EC_e = \frac{FC_{NPV,e}}{O_{Le}} \times 100 = \frac{170803}{4065000} \times 100 = 4.20 \text{ p/kWh}$$

### 4) System energy cost

System energy cost is therefore calculated using equation 4.18:

$$EC_{system} = \frac{[(EC_{boiler} \times O_b) + (EC_{PV} \times O_{PV}) + (EC_{EGrid} \times D_{egrid})]}{(D_h + D_e)}$$

$$= \frac{[(2.19 \times 266637) + (1.00 \times 776322) + (4.2 \times 135500)]}{(266637 + 190900)} = 4.2 \text{ p/kWh}$$

### 5) Emissions and emissions saved

The annual CO<sub>2</sub> emissions  $E_{CO_2,PBG}$  (kg CO<sub>2</sub>) are:

$$E_{CO_2,PBG} = (D_{egrid} \times EF_e) + (D_g \times EF_g) = (D_{egrid} \times EF_e) + (FI_{boiler} \times EF_g) = (135\,500 \times 0.43) + (333\,296 \times 0.19) = 121\,591 \text{ kg CO}_2$$

System CO<sub>2</sub> Emissions per kWh for the PV, boiler and grid option are:  $E_{CO_2,PBG} / (D_e + D_h) = 121591 / (190900+266637) = 0.27 \text{ kg CO}_2/\text{kWh}$ .

Emissions saved,  $ES_{CO_2,PBG}$  (kg CO<sub>2</sub> saved) for the PV, Boiler and Grid option is calculated using equation 4.27:

$$ES_{CO_2,PBG} = E_{CO_2,BG} - E_{CO_2,PBG} = 145\,413 - 121\,591 = 23\,822 \text{ kg CO}_2 \text{ saved}$$

For this option, a 16.4% emissions saving is achieved ( $ES_{CO_2,PBG} / E_{CO_2,BG} = 23822 / 145413 = 0.164 = 16.4\%$ ).

### 6) System cost per emissions saved

Cost per emissions savings,  $ESC$  (£/kg CO<sub>2</sub> saved) is calculated for the PV, Boiler and Grid option using equation 4.28:

$$ESC = \frac{EC_{system} \times (D_h + D_e)}{100 \times ES_{CO_2}} = \frac{4.2 \times (266637 + 190900)}{100 \times 23822} = 0.8 \text{ £/kg CO}_2 \text{ saved}$$

### 5.2.7 Supply of heat and electricity from a CHP, PV, Boiler and Grid

#### a) System sizing

In the CHP+PV+Boiler+Grid option, the CHP is sized first. The CHP size is therefore exactly the same as in the CHP+Boiler+Grid option (see section 5.2.2). The PV is sized on the remaining electricity demand to provide a minimum £/kg CO<sub>2</sub> saved figure in the same manner as in the PV+Boiler+Grid option (section 5.2.5). In this example the optimum PV size was found to be 376m<sup>2</sup> (Figure 5.25).

		<b>PV system</b>					
		PV size =	376	m2			
weekday CHP elctricity	weekend day CHP elctricity	Solar irradiance (w/m2)	PV output (kwh)	weekday deficit (kwh)	weekday surplus (kwh)	weekend deficit (kwh)	weekend surplus (kwh)
Deficit	Deficit						
1.5	1.2		0	1.5	0	1.2	0
4.0	1.7		0	4.0	0	1.7	0
5.8	3.0		0	5.8	0	3.0	0
5.5	3.5		0	5.5	0	3.5	0
5.8	4.3		0	5.8	0	4.3	0
5.6	4.5		0	5.6	0	4.5	0
9.0	5.6		0	9.0	0	5.6	0
17.3	10.7	67.25	2.65503	14.6	0	8.0	0
22.9	14.1	136.5	5.38902	17.5	0	8.7	0
25.1	14.5	184.25	7.27419	17.8	0	7.2	0
28.9	18.8	208.75	8.24145	20.6	0	10.6	0
29.3	18.7	208.75	8.24145	21.1	0	10.5	0
28.2	18.6	184.25	7.27419	21.0	0	11.3	0
30.7	20.1	136.5	5.38902	25.3	0	14.7	0
31.2	19.4	67.25	2.65503	28.6	0	16.7	0
31.3	19.2		0	31.3	0	19.2	0
33.7	21.3		0	33.7	0	21.3	0
36.7	24.1		0	36.7	0	24.1	0
41.2	30.6		0	41.2	0	30.6	0
43.9	40.1		0	43.9	0	40.1	0
40.1	41.0		0	40.1	0	41.0	0
39.5	40.1		0	39.5	0	40.1	0
32.4	32.7		0	32.4	0	32.7	0
28.3	28.5		0	28.3	0	28.5	0
577.7053448	436.090345	1193.5		530.6	0.0	389.0	0.0
12551.3	3789.8						

Figure 5.24 Hourly PV simulation for a typical January day



The monthly figures are then added up to calculate yearly surplus and deficit figures.

In this example:

$$Deficit_{yearly} = 106\,462 \text{ kWh}$$

$$Surplus_{yearly} = 7\,961 \text{ kWh}$$

It is assumed here that any surplus is exported to the grid and any deficit is imported from the grid.

The Boiler size is also the same as in section 5.2.2 (Figure 5.26):

$S_b = 154 \text{ kW}$  and the hot water storage is 430 litres.

BOILER SIZE		GRID DEMAND	
peak space heat demand =		123 kW	
boiler efficiency =		0.8	
boiler size =	154	<b>154 kW</b>	
Storage size =	430	<b>430 litres</b>	
<b>Annual Boiler Load =</b>	<b>186616 kWh/year</b>	<b>Annual EGrid Load =</b>	<b>106500 kWh/year</b>

**Figure 5.26 Boiler and grid sizes for CHP+PV+Boiler+Grid option**

## b) System costs and emissions

The NPV system energy costs are calculated for each technology:

### 1) boiler

$$FI_{boiler} = O_{boiler} / \eta_{CHP} = 186\,616 / 0.80 = 233\,270 \text{ kWh}$$

$$FC_{boiler} = FI_{boiler} \times GC = 233\,270 \times 2.28 / 100 = \text{£ } 5\,319 \text{ /year}$$

$$CC_{boiler} = 1058.7 \times S_b^{-0.3314} \times S_b = 1058.7 \times 154^{-0.3314} \times 154 = \text{£ } 30\,715$$



$$MC_{boiler} = CC_{boiler} \times 2\% = \text{£ } 615 \text{ /year}$$

$$DC_{boiler} = MC_{boiler} \times 2 = \text{£ } 1\,230$$

$$O_{L,boiler} = O_{boiler} \times n = 186\,616 \times 30 = 5\,598\,479 \text{ kWh}$$

$$CC_{NPVreplacement,boiler} = CC_{boiler} \times (1 + DR)^{-n} = 30\,715 \times (1 + 0.05)^{-15} = \text{£ } 14\,774$$

$$CC_{NPV,boiler} = CC_{boiler} + CC_{NPVreplacement,boiler} = 30\,715 + 14\,774 = \text{£ } 45\,489$$

$$FC_{NPV,boiler} = FC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 5\,319 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 81\,759$$

$$MC_{NPV,boiler} = MC_{boiler} \times [1 - (1 + DR)^{-n}] / DR = 615 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 9\,454$$

$$DC_{NPV,boiler} = DC_{boiler} \times (1 + DR)^{-n} = 1\,230 \times (1 + 0.05)^{-30} = \text{£ } 285$$

$$C_{NPVboiler,total} = CC_{NPV,boiler} + FC_{NPV,boiler} + MC_{NPV,boiler} + DC_{NPV,boiler}$$

$$= 45\,489 + 81\,759 + 9\,454 + 285 = \text{£ } 136\,987$$

$$EC_{boiler} = \frac{C_{NPVboiler,total}}{O_{Lboiler}} \times 100 = \frac{136987}{5598479} \times 100 = 2.45 \text{ p/kWh}$$

## 2) PV

$$FC_{PV,export} = FE_{PV} \times EEC / 100 = Surplus_e \times EEC = 7\,961 \times 3 / 100 = \text{£ } 239 \text{ /year}$$

$$FC_{PV} = FC_{PV,export} = \text{£ } -239 \text{ /year}$$

<b>COSTS</b>							
Project Lifetime (years) =	30						
Discount rate (%) =	5						
Electricity export price =	3.0	p/kWh					
Gas cost =	2.28		Gas emission factor =	0.19			
Electricity cost =	8.2		Electricity emission factor =	0.43			
<b>System</b>							
<b>System = Boiler</b>							
Lifetime (years) =	15						
Efficiency =	0.8	PW					
Annual heat output (kWh) =	186616		5598479				
Fuel input (kWh) =	233270		5598479	kWh			
Capital costs (£) =	30,715		45489				
Annual fuel costs (£) =	5,319		81759				
Annual Maintenance (£) =	615		3454				
Disposal Cost (£) =	1230		285				
<b>Energy cost (p/kWh) =</b>	<b>2.45</b>		<b>136987</b>	<b>£</b>			
<b>System = PV</b>							
Lifetime (years) =	30						
kWp	37.6						
Output (kWh) =	532713		15981390	kWh			
Capital costs (£) =	140951		140951				
Annual Maintenance (£) =	1410		21675				
Disposal Cost (£) =	2820		652				
Export (£) =	-239						
<b>Energy cost (p/kWh) =</b>	<b>1.02</b>		<b>163279</b>	<b>£</b>			
<b>System = CHP</b>							
CHP Lifetime (years) =	20						
Efficiency =	0.80	PW					
Annual heat output (kWh) =	36360		2890800				
Annual electricity output (kWh) =	48180		1445400				
Fuel input (kWh) =	180675		4336200	kWh			
Capital costs (£) =	8929		12294				
Annual fuel costs (£) =	4113		63226				
Annual Maintenance (£) =	179		2752				
Disposal Cost (£) =	358		83				
Electricity export (£) =	-6		78354	<b>£</b>			
<b>Energy cost (p/kWh) =</b>	<b>1.81</b>						
<b>System = Grid</b>							
Annual electricity output (kWh) =	106500						
Life time output (kWh) =	3195000						
annual fuel costs (£) =	8733						
NPV fuel cost (£) =	134248						
<b>Energy cost (p/kWh) =</b>	<b>4.20</b>						
<b>System costs</b>							
Heat =	2.37	p/kWh					
Electricity =	5.52	p/kWh					
TOTAL =	3.7	p/kWh					
<b>ENERGY SUPPLY</b>							
	Boiler	Electricity	CHP	PV			
Energy cost (p/kWh)	2.28	8.20	2.28	0			
CO2 emission factor (kg/kWh)	0.19	0.43	0.19	0			
Annual heat/electricity load (kWh)	186616	106500	144540	36432			
Annual Fuel input (kWh)	233,270		180675				
Annual fuel cost (£)	5319	8733	4113	-239	3.92	p/kWh	
Annual CO2 emissions (kg)	44321	45795	34328	0	0.27	kg CO2/kWh	
<b>Emissions saved</b>					20969	kg CO2 saved	
					0.9	£/kg CO2 saved	
					14.5	% carbon emissions saved	

Figure 5.27 Costs and emissions for CHP+PV+Boiler+Grid option

$$CC_{PV} = 525.61 \times S_{PV}^{-0.057} \times S_{PV} = 525.61 \times 376^{-0.057} \times 376 = \text{£ } 140\,951$$

$$MC_{PV} = CC_{PV} \times 1\% = \text{£ } 1\,410 \text{ /year}$$

$$DC_{PV} = CC_{PV} \times 2\% = \text{£ } 2\,820$$

$$O_{L,PV} = O_{PV} \times n = 532\,713 \times 30 = 15\,981\,390 \text{ kWh}$$

$$CC_{NPV, replacement, PV} = \text{£ } 0$$

$$CC_{NPV, PV} = CC_{PV} = \text{£ } 140\,951$$

$$FC_{NPV, PV} = FC_{PV} \times [1 - (1 + DR)^{-n}] / DR = \text{£ } 0$$

$$MC_{NPV, PV} = MC_{PV} \times [1 - (1 + DR)^{-n}] / DR = 1\,410 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 21\,675$$

$$DC_{NPV, PV} = DC_{PV} \times (1 + DR)^{-n} = 2\,820 \times (1 + 0.05)^{-30} = \text{£ } 652$$

$$C_{NPV, PV, total} = CC_{NPV, PV} + FC_{NPV, PV} + MC_{NPV, PV} + DC_{NPV, PV} = \text{£ } 163\,279$$

$$EC_{PV} = \frac{C_{NPV, PV, total}}{O_{LPV}} \times 100 = \frac{163279}{15981390} \times 100 = 1.02 \text{ p/kWh}$$

### 3) CHP

$$FI_{CHP} = (O_{CHP, h} + O_{CHP, e}) / \eta_{CHP} = (96\,360 + 48\,180) / 0.80 = 180\,675 \text{ kWh}$$

$$FC_{CHP, export} = FE_{CHP} \times EEC / 100 = Surplus_e \times EEC = 216 \times 3 / 100 = \text{£ } 6$$

$$FC_{CHP} = FI_{CHP} \times GC - FC_{CHP, export} = 180\,675 \times 2.28 / 100 - 6 = \text{£ } 4\,113 \text{ /year}$$

$$CC_{CHP} = 1\,676 \times S_{CHPth}^{-0.3025} \times S_{CHPth} = 1\,676 \times 11^{-0.3025} \times 11 = \text{£ } 8\,929$$

$$MC_{CHP} = CC_{CHP} \times 2\% = \text{£ } 179 \text{ /year}$$

$$DC_{CHP} = MC_{CHP} \times 2 = \text{£ } 358$$

$$O_{L,CHP} = O_{CHP} \times n = (O_{CHP,h} + O_{CHP,e}) \times n = (96\,360 + 48\,180) \times 30 = 4\,336\,200$$

kWh

$$CC_{NPVreplacement,CHP} = CC_{CHP} \times (1 + DR)^{-n} = 8\,929 \times (1 + 0.05)^{-15} = \text{£ } 3\,365$$

$$CC_{NPV,CHP} = CC_{CHP} + CC_{NPVreplacement,CHP} = 8\,929 + 3\,365 = \text{£ } 12\,294$$

$$FC_{NPV,CHP} = FC_{CHP} \times [1 - (1 + DR)^{-n}] / DR = 4\,113 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 63$$

226

$$MC_{NPV,CHP} = MC_{CHP} \times [1 - (1 + DR)^{-n}] / DR = 179 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 2$$

752

$$DC_{NPV,CHP} = DC_{CHP} \times (1 + DR)^{-n} = 358 \times (1 + 0.05)^{-30} = \text{£ } 83$$

$$C_{NPVCHPtotal} = CC_{NPV,CHP} + FC_{NPV,CHP} + MC_{NPV,CHP} + DC_{NPV,CHP} = \text{£ } 78\,354$$

$$EC_{CHP} = \frac{C_{NPVCHP,total}}{O_{LCHP}} \times 100 = \frac{78354}{4336200} \times 100 = 1.81 \text{ p/kWh}$$

#### 4) Grid

$$O_{Le} = D_e \times n = 106\,500 \times 30 = 3\,195\,000 \text{ kWh}$$

$$FC_e = D_e \times EC = 106\,500 \times 8.2 / 100 = \text{£ } 8\,733 \text{ /year}$$

$$FC_{NPV,e} = FC_e \times [1 - (1 + DR)^{-n}] / DR = 8\,733 \times [1 - (1 + 0.05)^{-30}] / 0.05 = \text{£ } 134\,248$$

$$EC_e = \frac{FC_{NPV,e}}{O_{Le}} \times 100 = \frac{134248}{3195000} \times 100 = 4.20 \text{ p/kWh}$$

#### 4) System energy cost

System energy cost is therefore calculated using equation 4.18:

$$EC_{system} = \frac{[(EC_{CHP} \times (O_{CHP,h} + O_{CHP,e})) + (EC_{PV} \times O_{PV}) + (EC_{boiler} \times O_b) + (EC_{EGrid} \times D_{egrid})]}{(D_h + D_e)}$$

$$= \frac{[(1.81 \times (96360 + 48180)) + (1.02 \times 532713) + (2.45 \times 186616) + (4.2 \times 106500)]}{(266637 + 190900)} = 3.7 \text{ p/kWh}$$

#### 5) Emissions and emissions saved

The annual CO<sub>2</sub> emissions  $E_{CO_2,CPBG}$  (kg CO<sub>2</sub>) are:

$$E_{CO_2,CPBG} = (D_{egrid} \times EF_e) + (D_g \times EF_g) = (D_{egrid} \times EF_e) + [(FI_{CHP} + FI_{boiler}) \times EF_g] =$$

$$(106\,500 \times 0.43) + [(180\,675 + 233\,270) \times 0.19] = 124\,445 \text{ kg CO}_2$$

System CO<sub>2</sub> Emissions per kWh for the CHP, PV, boiler and grid option are:

$$E_{CO_2,CPBG} / (D_e + D_h) = 124445 / (190900 + 266637) = 0.27 \text{ kg CO}_2/\text{kWh}.$$

Emissions saved,  $ES_{CO_2,CPBG}$  (kg CO<sub>2</sub> saved) for the CHP, PV, Boiler and Grid option is calculated using equation 4.27:

$$ES_{CO_2,CPBG} = E_{CO_2,BG} - E_{CO_2,CPBG} = 145\,413 - 124\,445 = 20\,969 \text{ kg CO}_2 \text{ saved}$$

For this option, a 14.5% emissions savings is achieved ( $ES_{CO_2,CPBG} / E_{CO_2,BG} = 20969 / 145413 = 0.145 = 14.5\%$ ).

6) System cost per emissions saved

Cost per emissions savings,  $ESC$  (£/kg CO<sub>2</sub> saved) is calculated for the CHP, PV,

Boiler and Grid option using equation 4.28:

$$ESC = \frac{EC_{system} \times (D_h + D_e)}{100 \times ES_{CO_2}} = \frac{3.7 \times (266637 + 190900)}{100 \times 20969} = 0.9 \text{ £/kgCO}_2 \text{ saved}$$

### 5.2.8 Summary of outputs

**Table 5.4 Summary of Outputs**

	<b>Boiler + Grid</b>	<b>CHP + Boiler + Grid</b>	<b>ST + Boiler + Grid</b>	<b>PV + Boiler + Grid</b>	<b>ST + CHP + Boiler + Grid</b>	<b>CHP + PV + Boiler + Grid</b>
<b>Boiler size (kW)</b>	168	154	168	168	147	154
<b>Grid demand (kWh)</b>	190 900	142 894	192 900	135 500	124 100	106 462
<b>CHP size (kW<sub>thermal</sub>)</b>	-	11	-	-	17	11
<b>ST/PV collector area (m<sup>2</sup>)</b>	-	-	127	550	38	376
<b>System cost (p/kWh)</b>	3.1	2.9	4.1	4.2	3.1	3.7
<b>Emissions (kgCO<sub>2</sub>/ kWh)</b>	0.32	0.31	0.30	0.27	0.29	0.27
<b>Cost per emissions saved (£/ kgCO<sub>2</sub> saved)</b>	-	2.5	3.1	0.8	1.1	0.9
<b>Reduction in emissions (%)</b>	-	3.7	4.1	16.4	9.2	14.5

## Section 1.01 5.3 TOOL EVALUATION PROCEDURE

The procedure for evaluating the viability of renewable energy technologies and CHP schemes for a new or refurbished building project using the tool, as in this example, is carried out as described below.

When starting the computer tool the user may choose between starting a new project or working and modifying an existing project as shown in Figure 5.28. In this case, a new project is initiated to build up the building loads profile.




Figure 5.28 Start interface

### 5.3.1 The Building loads

This is carried out in the following order.

#### a) Entering the building details

In this step the building specifications (type, floor area, occupancy, etc) are entered for all building types.

Rules of Thumb Building Loads

Please enter the details below for building type 1

**Building Type** Residential 2 bedroom flat

**Floor Area** 100 m<sup>2</sup>

**Number of dwellings** 5 (max 100)

Rules of Thumb			Loads	
Low	Medium	High		
<b>Hot Water</b>	75	l/person	<b>750</b>	litres
<b>Heating</b>	60	W/m <sup>2</sup>	<b>30</b>	kW
<b>Electricity</b>	41	kWh/m <sup>2</sup>	<b>20500</b>	kWh

Back Next Building type Finish

Figure 5.29a Entering details for 2 bedroom flats residential building

Rules of Thumb Building Loads

Please enter the details below for building type 2 or press FINISH.

**Building Type** Residential 1 bedroom flat

**Floor Area** 50 m<sup>2</sup>

**Number of dwellings** 15 (max 100)

Rules of Thumb			Loads	
Low	Medium	High		
<b>Hot Water</b>	115	l/person	<b>1725</b>	litres
<b>Heating</b>	60	W/m <sup>2</sup>	<b>45</b>	kW
<b>Electricity</b>	40	kWh/m <sup>2</sup>	<b>30000</b>	kWh

Back Next Building type Finish

Figure 5.29b Entering details for 1 bedroom flats residential building



**Rules of Thumb Building Loads**

Please enter the details below for building type 3 or press FINISH.

**Building Type** Office without canteen

**Floor Area** 500 m2 **Occupancy** 50

Rules of Thumb		Loads	
Low	Medium	Hot Water	500 litres
		Heating	35 kW
		Electricity	16500 kWh

Back Next Building type Finish

**Figure 5.29c Entering details for office type building**

This case study involves three types of buildings with different floor areas and types of occupancy, namely, 2-bedroom flats, 1-bedroom flats, and office space. Energy requirements for each type of building cluster are obtained from rule of thumb data in the tools database. Physical details and rules of thumb for energy consumption of these buildings are given in the user interface windows of Figure 5.29a, Figure 5.29b and Figure 5.29c respectively.

**b) Choosing to use own load profiles or using the computer tool database of load profiles**

Users have the choice to enter their own load profiles for the building by selecting “input” or as in this particular example, the database of load profiles was selected as shown in Figure 5.30.



Figure 5.30 User interface window for load profile selection

c) **Building loads summary**

In this step, a building requirement for heat, hot water and power is then calculated as shown in Figure 5.31.




Figure 5.31 Calculation of building Loads

### 5.3.2 Evaluation of a combination of Grid, boiler, CHP and solar thermal collector systems using ST tool

#### a) Supply of heat and power from a Boiler and Grid

The screenshot shows a dialog box titled "Option: Boiler+Grid". It contains two sections: "Boiler" and "Grid".

Category	Parameter	Value
Boiler	Boiler size (kW)	168
	Hot water storage (litres)	747
Grid	Grid Demand (kWh/year)	190900

At the bottom of the dialog box, there are two buttons: "Back" and "Next".

Figure 5.32 Boiler+EGrid sizes

The screenshot shows a dialog box titled "Costs and Emissions Boiler+Grid Option". It contains a table of parameters and values, with a note at the top: "Please review the values below and change them if necessary."

	Gas	Electricity
Fuel Costs (p/kWh)	2.28	8.2
Project lifetime (years)	30	
Discount rate (%)	5	
<b>BOILER</b>		
Lifetime (years)	15	
Capital Cost (£)	32555	
Maintenance Cost (£/year)	652	
Disposal Cost (£)	1304	


At the bottom of the dialog box, there are two buttons: "Back" and "Next".

Figure 5.33 Costs for Boiler+Grid option

This is the baseline calculation in which the boiler heat rate and associated hot water storage capacity is calculated. A yearly power consumption of the building is also evaluated. Figure 5.32 shows estimated loads for this example.

To determine the economic feasibility of different combinations of technologies, the energy tariffs, life time, capital and maintenance cost are then entered as shown in Figure 5.33. In this example, the costs related to the boiler installation are calculated from rule of thumb estimates which can be changed to real quotes by the project manager.

#### b) Supply of heat and power from a combination of CHP, Boiler and Grid



The screenshot shows a software window titled "Option: CHP+Boiler+Grid" with a close button (X) in the top right corner. The window displays calculated values for four categories: CHP, Boiler, Grid, and Outputs. Each category is presented in a separate box with a title bar and a table of values.

CHP	
<b>CHP size (kW)</b>	<b>11</b>
<b>Storage (kWh)</b>	<b>65</b>

Boiler	
<b>Boiler size (kW)</b>	<b>154</b>
<b>Storage (litres)</b>	<b>746.7</b>

Grid	
<b>Grid Demand (kWh/year)</b>	<b>142900</b>

Outputs	
<b>Emissions saved (%)</b>	<b>3.7</b>
<b>£/kgCO2 saved</b>	<b>2.5</b>

At the bottom of the window, there are two buttons: "Back" and "Next". The "Next" button is highlighted with a dashed border.

Figure 5.34 CHP+Boiler+EGrid case

The computer tool evaluates the size of the CHP and its heat storage system, backup boiler and hot water storage, and calculates the power needed to be met (i.e., imported) from the grid. In addition, the cost of saved CO<sub>2</sub> from such a combination of technologies is determined as shown in Figure 5.34 and Figure 5.35.

**Costs and Emissions CHP+Boiler+Grid Option**

Please review the values below and change them if necessary.

	CHP	BOILER
Lifetime (years)	20	15
Capital Cost (£)	8929	30715
Maintenance Cost (£/year)	179	615
Disposal Cost (£)	358	1230
Electricity export price	3	p/kWh

Back Next

**Figure 5.35 Costs for CHP+Boiler+Grid case**

**c) Supply of heat and power from a combination of Boiler, Solar collector and Grid**

First the tool user is asked whether there is a size limitation on the solar collector that can be installed (e.g., available roof area) as shown in Figure 5.36. However, in this case no limitation factor is considered and the merit of using a solar collector will be evaluated by the computer tool simply to find the optimum size that would save CO<sub>2</sub> emission in a cost effective way.

Next capital, maintenance and disposal costs of the solar collector and boiler are calculated from rules of thumb built into the computer tool but again these could be modified by the user as given Figure 5.37.

Figure 5.38 shows optimum power and heat outputs for the solar thermal collector, boiler and hot water storage and grid mains that would generate a reduction in CO2 emissions of 2.1% compared to the baseline option of a grid and boiler only.




Figure 5.36 selecting a limiting factor in the sizing of solar thermal collectors





Figure 5.37 Costs for ST+Boiler+Grid option



**Figure 5.38 Technology sizes for ST+Boiler+Grid option**

**d) Supply of heat and power from a combination of CHP, Boiler, Solar collector and Grid**

In this case, the CHP and Solar thermal systems are sized to provide as much heat and power as practical. The solar thermal collector capacity is not limited by the area available for installation and the CHP runs for a minimum of 4500 hours a year. Modelling operating parameters and results of this option as show in Figure 5.39 and Figure 5.40 respectively and give an estimate of 4.1% savings of CO<sub>2</sub> emission.

Costs ST+CHP+Boiler+Grid

Please review the values below and change them if necessary.

	ST	CHP	BOILER
<b>Lifetime (years)</b>	30	20	15
<b>Capital Cost (£)</b>	32300	12097	29775
<b>Maintenance Cost (£/year)</b>	646	242	596
<b>Disposal Cost (£)</b>	1615	484	1192

Back Next

Figure 5.39 Costs for ST+CHP+Boiler+Grid option

Option:ST+CHP+Boiler+Grid

Please review the values below and go back to change the input parameters if necessary.

ST

<b>ST annual output (kWh)</b>	<b>11746</b>
<b>ST array size (m2)</b>	<b>38</b>

CHP

<b>CHP Size (kW) heat</b>	<b>17</b>
<b>Storage (kWh)</b>	<b>8.5</b>

Boiler

<b>Boiler size (kW)</b>	<b>147</b>
<b>Storage (litres)</b>	<b>383.5</b>

Grid

<b>Annual Grid Demand (kWh)</b>	<b>124100</b>
---------------------------------	---------------

**Emissions saved (%)**      **9.2**

Back Next

Figure 5.40 Sizes of technologies for ST+CHP+Boiler+Grid




**e) Optimum size selection and comparison of technology combinations of the ST tool using the Monte Carlo method.**


The final step in obtaining optimum heat and power output for different technologies is to apply the Monte Carlo method which performs an iterative process using building load profiles that are stored in the database of the computer tool. In this modelling case for instance the computer tool performs 100 iterations for randomly selected load profiles. The most frequently occurring outputs for the different technology combinations are summarised in the bar charts Figures 5.41 to 5.44 which also indicate the ranges of all the outputs.

Figure 5.41 shows a bar chart of the most frequently occurring energy costs of the different technology combinations against their base cases. The technology combination with the lowest system energy cost for this example is the CHP+Boiler+EGrid option with 2.9p/kWh. The Boiler+EGrid and the ST+CHP+Boiler+EGrid options have a slightly higher energy cost of 3.1p/kWh. The ST+Boiler+EGrid option has a much higher energy cost of 4p/kWh. However all options have a lower cost than the cost of electricity.


Figure 5.42 shows that the ST+CHP+Boiler+EGrid option provides the minimum CO<sub>2</sub> emissions of 0.302 kg per kWh of energy consumption. When compared to the baseline case of boiler and grid only, the ST+CHP+Boiler+EGrid combination offers maximum CO<sub>2</sub> emission reduction of 8.6%, as illustrated by Figure 5.43.




**Figure 5.41 System energy costs for each technology combination**




**Figure 5.42 Emissions for each technology combination**



**Figure 5.43 Emissions reduction for each technology combination**



**Figure 5.44 Cost of emission savings for each technology combination**



**Figure 5.45 Summary of outputs and option comparison with MCM**

Equally important, the lowest cost per CO<sub>2</sub> emission savings is achieved by the ST+CHP+Boiler+EGrid option which is estimated to be 1.1£/kgCO<sub>2</sub> saved as shown in Figure 5.44. It can also be seen that ST+Boiler+EGrid option has the highest cost of emissions savings with 3£/ kgCO<sub>2</sub>.

Figure 5.45 gives a summary of the most probable and cost effective solution for each technology combination. Therefore, the computer tool could constitute a valuable instrument for the user in planning and decision making when considering investment in energy abatement technologies.

**f) Optimum size selection and comparison of technology combinations of the ST tool using one set of load profiles only.**

In order to compare the outputs of the tool with the sample calculation outputs in section 5.2, the tool was also run for one set of load profiles, without the Monte Carlo method being applied. Figure 5.46 shows the summary of outputs of the ST tool when one set of load profiles is used and therefore the Monte Carlo method is not applied. These outputs coincide with the outputs of the sample calculation (Table 5.4) carried out in section 5.2.

	BOILER + GRID	CHP + BOILER + GRID	ST + BOILER + GRID	CHP + ST + BOILER + GRID
<b>TECHNOLOGY SIZES</b>				
Boiler Size (kW)	168	154	168	147
Grid Demand (kWh)	190900	142900	192900	124100
CHP size (kWth)		11		17
ST array size (m2)			127	38
<b>COSTS AND EMISSIONS</b>				
System Cost (p/kWh)	3.1	2.9	4.1	3.1
Emissions (kgCO2/kWh)	0.318	0.307	0.304	0.289
Cost per emission savings (£/kgCO2saved)		2.5	3.1	1.1
Reduction in emissions (%)		3.7	4.1	9.2


**Figure 5.46 Summary of outputs and option comparison without MCM**

### 5.3.3 Evaluation of a combination of Grid, Boiler, CHP and Photovoltaic panels using the PV tool

The procedure for evaluating the PV tool for a combination of technologies including Grid, Boiler, CHP and PV panels is similar to the ST tool described above and the same operating data is used.

#### a) Supply of heat and power from a combination of Boiler, Grid and PV panel

Like in the sizing of the solar thermal collector, the user may select a limiting factor for the size of the panel as given in Figure 5.47. If, however, no constraints on the size of the panel are entered then the tool evaluates the optimum size of the panel that would reduce CO<sub>2</sub> emission cheaply.



**Figure 5.47 Selecting a limiting factor for sizing PV**

Operating parameters, energy outputs and emissions savings of grid, boiler and PV combination are given in Figure 5.48 and Figure 5.49 respectively. Figure 5.49 shows that the PV, boiler and grid combination would save 16.4% in CO<sub>2</sub> emission compared to the baseline case of grid and boiler only. This however would require a PV panel area of 550 m<sup>2</sup>.

Costs and Emissions PV+Boiler+Grid Option

Please review the values below and change them if necessary.

	PV	BOILER
Lifetime (years)	30	15
Capital Cost (£)	201756	32555
Maintenance Cost (£/year)	2018	652
Disposal Cost (£)	4036	1304

Back Next

Figure 5.48 Operating Costs for PV+Boiler+EGrid option

Option: PV+Boiler+Grid

Please review the values below and go back to change the input parameters if necessary.

PV

PV annual output (kWh)	776322
PV array size (m2)	550

Boiler

Boiler size (kW)	168
Storage (litres)	747

Grid

Annual Grid Demand (kWh)	135500
--------------------------	--------

Emissions saved (%) 16.4

Back Next

Figure 5.49 Sizes of technologies for PV+Boiler+EGrid option

b) Supply of heat and power from a combination of PV, CHP, Boiler and Grid

Please review the values below and change them if necessary.

	PV	CHP	BOILER
<b>Lifetime (years)</b>	30	20	15
<b>Capital Cost (£)</b>	140951	8929	30715
<b>Maintenance Cost (£/year)</b>	1410	179	615
<b>Disposal Cost (£)</b>	2820	358	1230

Back Next

Figure 5.50 Costs for PV+CHP+Boiler+EGrid option

Please review the values below and go back to change the input parameters if necessary.

PV

<b>PV annual output (kWh)</b>	532713
<b>PV array size (m2)</b>	376

CHP

<b>CHP Size (kW) heat</b>	11
<b>Storage (kWh)</b>	65

Boiler

<b>Boiler size (kW)</b>	154
<b>Storage (litres)</b>	429.9

Grid

<b>Annual Grid Demand (kWh)</b>	106500
---------------------------------	--------

**Emissions saved (%)** 14.5

Back Next

Figure 5.51 Sizes of technologies for PV+CHP+Boiler+EGrid option


In this case, the CHP system and PV panel are optimally sized to provide the maximum heat and power to satisfy the building load. The CHP would run for a minimum of 4500 hours a year and the PV panel capacity, not being limited by the area available for installation, is optimally sized to provide additional electricity. The boiler and grid supply the peak heat and power loads. The computer model operating parameters and results of this option are shown in Figure 5.50 and Figure 5.51 respectively.

**c) Optimum size selection and comparison of technology combinations of the PV tool using the Monte Carlo method.**


As for the ST tool the optimum heat and power output for different technologies, is obtained by applying the Monte Carlo Method. This iterative process uses building load profiles stored in the database and records the most frequently occurring outputs for the different technology combinations and also indicates the ranges of all the outputs. Figure 5.52 shows a bar chart of the most occurring energy costs of the different technology combinations. The technology combination with the lowest system energy cost for this example is again the CHP+Boiler+EGrid option with 2.9p/kWh. The PV+Boiler+EGrid option has the highest energy cost of 4.2p/kWh.

Figure 5.53 and Figure 5.54 show that the PV+Boiler+EGrid option achieves the lowest emissions of 0.268kgCO<sub>2</sub>/kWh which represents emissions savings of 16.3% compared to the boiler and grid only option. Figure 5.54 shows that the PV+Boiler+EGrid option and the CHP+PV+Boiler+EGrid option achieved the lowest cost per emission savings of £0.8/kgCO<sub>2</sub> saved. The CHP had the highest cost per emission savings with £2.5/kg CO<sub>2</sub> saved.







**Figure 5.52 System energy costs for each technology combination**



**Figure 5.53 Emissions for each technology combination**



**Figure 5.54 Emissions reduction for each technology combination**



**Figure 5.55 Cost of emission savings for each technology combination**

Figure 5.56 gives a summary of the optimum solutions for each technology combination and the computer tool makes it easier to select a technology combination that provides the best results.

	BOILER + GRID	BASE CASE (Boiler + Grid)	CHP + BOILER + GRID	BASE CASE (Boiler + Grid)	PV + BOILER + GRID	BASE CASE (Boiler + Grid)	CHP + PV + BOILER + GRID
<b>TECHNOLOGY SIZES</b>							
Boiler Size (kW)	160	169	154	161	161	154	138
Grid Demand (kWh)	193000	188100	136400	193300	138200	206200	113400
CHP size (kWth)			12				13
PV array size (m2)					537		355
<b>COSTS AND EMISSIONS</b>							
System Cost (p/kWh)	3.1	3.1	2.9	3.1	4.2	3.1	3.7
Emissions (kgCO2/kWh)	0.32	0.317	0.306	0.319	0.268	0.323	0.277
Cost per emission savings (£/kgCO2saved)			2.5		0.8		0.8
Reduction in emissions (%)			3.7		16.3		14.1

**Figure 5.56 Summary of outputs and option comparison**

**d) Optimum size selection and comparison of technology combinations of the ST tool using one set of load profiles only.**

In order to compare the outputs of the tool with the sample calculation outputs in section 5.2, the tool was also run for one set of load profiles, without the Monte Carlo method being applied. Figure 5.57 shows the summary of outputs of the PV tool when one set of load profiles is used and therefore the Monte Carlo method is not applied. These outputs coincide with the outputs of the sample calculation (Table 5.4) carried out in section 5.2.

	BOILER + GRID	CHP + BOILER + GRID	PV + BOILER + GRID	CHP + PV + BOILER + GRID
<b>TECHNOLOGY SIZES</b>				
Boiler Size (kW)	168	153	168	153
Grid Demand (kWh)	190900	138700	137800	106200
CHP size (kWth)		12		0
PV array size (m2)			508	324
<b>COSTS AND EMISSIONS</b>				
System Cost (p/kWh)	3.1	2.9	4.1	3.6
Emissions (kgCO2/kWh)	0.318	0.307	0.268	0.276
Cost per emission savings (£/kgCO2saved)		2.5	0.9	0.9
Reduction in emissions (%)		3.8	15.8	13.4

Buttons: Back, Print Summary

**Figure 5.57 Summary of outputs and option comparison**

## **5.4 LIMITATIONS OF THE COMPUTER TOOL**

The accuracy of the computer tool outputs depends greatly on the assumptions made in the tool development. For instance the solar radiation and ambient temperature data used in the model are those for the London area. Hence, the calculation procedures could be further improved by incorporating global data to make the computer tool applicable to anywhere in the world.

The optimum heat and power rating of a technology obtained from the computer tool may not always exist as a commercial product. For example, the range of available heat and power equipments (i.e., boilers, CHP systems, PV and solar thermal collectors) are limited to those commercialised by manufacturers and hence the computer tool could include suggestion notes on the best nearest equipment ratings available and the effect this would have on the overall cost and emissions. In addition, for accurate and quick cost analysis, an up-to-date database of heating and power equipments properties and costs could be listed with the name of the manufacturer.

Furthermore, the load profiles database does not statistically represent the whole of UK building stock and this in turn affects the accuracy of the tool. As part of this thesis some load profiles for domestic hot water have been collected in a survey. However, more load profiles would be required to represent the UK building stock. As more load profiles are added to the database, the accuracy of the tool would improve.

The accuracy of the computer tool is also affected by the number of iterations the tool performance in order to obtain a converging solution. A high number of

iterations may take a long time and require large computer physical memory to execute. In the current example, the number of iterations using the Monte Carlo method is 100 iterations which take a long time to execute depending on the types of load profiles to process. Hence, speeding up the program execution could be achieved by using faster computer processors or reducing the number of iterations at the expense of the accuracy of the tool's outputs.

The computer tool is also made up of two separate sub-tools that run independently: the ST tool and the PV tool. The ST tool sizes technologies that combine with solar thermal collectors, whereas the PV tool sizes technologies that combine with PV panels. Therefore, the two sub-tools could be combined seamlessly into one tool which is capable of sizing a whole host of combination of technologies including micro-wind turbines and ground source heat pumps. In this way the most optimal energy mix required for the reduction of emissions could be determined.

## **5.5 DISCUSSION AND CONCLUSION**

The tool developed in this study addresses the uncertainty of load profiles in the sizing of renewable energy and CHP technologies and compares different combinations of technologies to find the option with the lowest cost of emissions reduction (£/kgCO<sub>2</sub> saved). As discussed in Chapter 2, there is currently no computer tool available which investigates the use of a combination of renewable energy and CHP technologies to provide heat and power in buildings and at the same time takes into account the uncertainty of building energy load profiles by using the Monte Carlo Method.

The aim in developing this computer tool is to address the needs of an energy project manager which uses historical buildings load profiles in new schemes with a high level of confidence when planning the installation of CHP systems, PV panels and solar thermal collectors individually or in combination with one or more technologies together. In this way, CO<sub>2</sub> emissions in buildings can be reduced as required by existing Building Regulations (Part L2) for England and Wales.

A conventional gas-fired CHP system is not a renewable energy technology, but, given that it uses fuel energy content more efficiently, it is usually considered as an energy saving option, which can ultimately provide a cost effective energy supply, mainly to commercial buildings, where cost-effectiveness is usually a priority in the decision-making process. Renewable energy technologies for buildings, however, are usually more expensive and are rarely considered for application where the cost of reducing CO<sub>2</sub> emission from the building is the overriding priority as the exorbitant capital and installation cost can only be justified if there is some financial incentive to do so. It can however be concluded from the results obtained in this case study that a combination of renewable energy systems and CHP could be a viable option to provide a cost-effective and environmentally friendly supply of energy to buildings.

Finally, the computer tool allows the user to make quick decisions when selecting a technology or combination of technologies to be installed in new or refurbished buildings. In this respect it can be seen from this case study, that if the project is driven by the cost of energy generation (p/kWh), then CHP+Boiler+EGrid option would make better investment returns. On the other hand, if the reduction of CO<sub>2</sub> emissions is more important, then the option of incorporating renewables with or without CHP would be a more attractive proposition. The option of incorporating

renewables and CHP (i.e., CHP+ST+Boiler+EGrid and CHP+PV+Boiler+EGrid options) would offer a better solution if both cost of energy generation (p/kWh) and CO<sub>2</sub> emissions are important.

## **Chapter 6:**

### **Conclusion and Suggestions for Future Work**

#### **6.1 GENERAL CONCLUSIONS**

This thesis demonstrates the need for better knowledge and the necessary tools to integrate effectively renewable energy and energy efficient technologies to supply energy to buildings. The ever increasing building regulations standards (Part L1 and L2) and the government's ambitious plan to make all new buildings zero CO<sub>2</sub> emissions by 2016 could only be achieved if on-site heat and power generation using renewables and energy efficient technologies are deployed effectively.

The computer tool developed in this study compares different combinations of photovoltaic (PV) panels, solar thermal collectors and Combined Heat and Power (CHP) technologies for building applications to find the option with the lowest cost of emissions reduction (£/kgCO<sub>2</sub> saved). The tool could enable the selection of more appropriate technologies for the supply of electricity, hot water and space heating for buildings by optimising the integration of the combined technologies for different building types. The tool aims to facilitate the decision-making process of the designers, by identifying workable solutions for a project, as well as streamlining the number of options from which a reliable decision could be made.



The computer tool developed in this thesis addresses the uncertainty of building energy load profiles in the sizing of renewable energy and CHP technologies by applying the Monte Carlo method. A database of historical building energy load profiles was collated for this purpose. A survey was also conducted to collect hot water load profiles for residential buildings for the computer tool load profile database.

The Monte Carlo Method is used to take into account the uncertainties of building energy load profiles in order to provide a most probable output from the tool. One of the specific outputs of the tool is the techno-economic analysis and carbon savings from which selected renewable energy/CHP combinations can be compared and which provides the decision-makers with the required information.

A case study was used to validate the computer tool and its accuracy. Although renewable energy and CHP technologies are not usually considered together for building applications, it was concluded, from the results obtained in this case study, that a combination of renewable energy systems and CHP could be a viable option to provide a cost-effective and environmentally friendly supply of energy to buildings.

### **6.1.1 Complexity of building load profiles/patterns**

Building energy load profiles are especially useful for the design of renewable energy technologies and CHP systems, and are, therefore, vital data used in the tool developed in this study. Energy load profiles for buildings depend on many factors, such as the type of building, occupancy, climate and occupancy behaviour, which make them difficult to predict.

Past energy use of a building will give the most accurate predictions for future energy requirements. However for a new-build or some refurbishments this data might not be available. In these cases typical load profiles are estimated, by taking the monitored load profile of a similar building, an average of several, or by simulating a typical profile.

Real load profiles were collected to form a database for the tool. Load profiles were collected and collated from the literature and a domestic hot water demand survey. The Monte Carlo Method is used to take into account the uncertainty of the load profiles in the sizing of the technologies.

### **6.1.2 Hot water demand profiles**

A literature search identified a lack of reliable residential hourly domestic hot water demand profile data for the UK. Therefore, as part of this work, a survey was conducted to collect hot water load profiles for residential buildings in the UK. The survey consisted of a questionnaire and a monitoring survey.

The questionnaire consists of two parts: a general questionnaire about the dwelling and a diary study. The questionnaire enabled the load profiles collected to be classified into different building type categories and in the diary study the hot water consumption patterns were recorded.

The monitoring study was carried out in conjunction with the survey questionnaire and was carried out using temperature sensors attached to the hot water pipes of the different appliances within the dwellings. When hot water was used, the temperature recorded by the sensor increased. This enabled the identification of when and from which appliance hot water was used throughout the day in the dwellings. Although

the use of sensors to collect the data, of collecting the data is more precise as it doesn't rely on participants remembering to record their hot water consumption, the questionnaire nevertheless enabled more data to be collected. The data collected by both methods was used to form hourly hot water load profiles to be loaded into the tool.

Typical hot water usages of appliances were calculated using typical flow rates and usage time periods recorded by a clamp-on flow meter. The typical hot water usages for the appliances were combined with the survey questionnaire data and the data collected from the temperature sensors to form hot water load profiles. This data was loaded into the tool load profile database with the other load profile data collected from the literature.

### **6.1.3 The computer Tool**

The computer tool developed in this study provides the user with an aid to selecting renewable energy technologies with CHP systems for the supply of energy to buildings, whilst taking into account the uncertainty of building energy load profiles. The tool optimally sizes combinations of technologies to find the options with the lowest cost of emissions reduction (£/kgCO<sub>2</sub> saved) and allows the user to make quick decisions when selecting a technology or combination of technologies to be installed in buildings.

Visual Basic for Application (VBA) was used to develop the computer tool. The tool was developed in two Excel files each combining a different renewable energy technology (Photovoltaics and Solar Thermal) with CHP. Each tool consists of the following main stages:

- D. The building loads and load profiles are processed.
- E. Sizing and selection of technical parameters of technologies followed by a financial and environmental analysis are carried out.
- F. If load profiles are not known to the tool user, the Monte Carlo Method is used to account for the uncertainty of building energy load profiles by sizing each of the combination options for 100 different load profiles.
- G. For each combination the most likely technology sizes, costs and emissions are obtained and a comparison and evaluation analysis of technologies or combination of technologies is given that would facilitate the selection of the appropriate option.

#### **6.1.4 The case study**

The validation of the computer tool was carried out to select and optimise renewable energy technologies for a mixed-use office and residential building located in the UK. A building, with a total floor area of 1750m<sup>2</sup>, consisting of three clusters of 5 two-bedroom flats of 100m<sup>2</sup> each, 15 one-bedroom flats of 50m<sup>2</sup> each, and 500m<sup>2</sup> of office space with occupancy capacity of 50 people was used for the validation. In this analysis, it is assumed that the building loads and load profiles are not known in advance and hence the tool uses load profiles from its database of load profiles to match each cluster building. Three different technologies are evaluated in different combinations: combined heat and power, solar thermal collectors for hot water and photovoltaic panels for electricity generation.

It can be seen from this case study, that if the project is driven by the cost of energy generation (p/kWh), then CHP+Boiler+EGrid option would make better investment returns. On the other hand, if the reduction of CO<sub>2</sub> emissions is more important, then

the option of incorporating renewables with or without CHP would be a more attractive proposition. The option of incorporating renewables and CHP (i.e., CHP+ST+Boiler+EGrid and CHP+PV+Boiler+EGrid options) would offer a better solution if both cost of energy generation (p/kWh) and CO<sub>2</sub> emissions are important.

## **6.2 CONTRIBUTION TO KNOWLEDGE AND ORIGINALITY**

In this work a computer tool was developed and a hot water demand survey was carried out as described above. The main original points of this research include:

- Development of a computer tool with the built-in capability to determine optimal power ratings, cost and environmental impact of integrated renewable energy and energy efficient technologies to provide heat and power in buildings.
- The computer tool uses a large database of load profiles for different types of buildings.
- An interactive procedure using the Monte Carlo method was employed to take into account the uncertainty of load profiles.
- A case study was used to validate the computer tool and its accuracy.
- A survey was carried out to collect hot water consumption profiles for residential buildings in the UK.

### 6.3 RECOMMENDATIONS FOR FUTURE WORK

As discussed in Chapter 5, the computer tool developed in this study could be improved further by addressing the following:

- The accuracy of the computer model outputs depends greatly on the assumptions made in the tool development. The calculation procedures of the computer tool could therefore be further improved, by for example incorporating weather data for different locations in the world so that the tool could be used by a wider audience.
- For accurate and quick cost analysis, an up-to-date database of heating and power equipment properties and costs could be listed with the name of the manufacturer.
- The optimum heat and power rating of a technology obtained from the computer tool may not always exist as a commercial product as the range of available heat and power equipment is limited to those commercialised by manufacturers. The computer tool could include suggestion notes on the best nearest equipment ratings available and the effect this would have on the overall cost and emissions.
- The accuracy of the computer tool could be improved by adding more building energy load profiles to the tools database. Although some load profiles for domestic hot water have been collected in a survey as part of this thesis, more load profiles would be required to represent the UK building stock.
- The running time of the computer tool could be reduced to make the tool more user-friendly. In the current example, the number of iterations using the Monte

Carlo method is 100 iterations. This takes a long time to execute depending on the types of load profiles to process.

- The two sub-tools (ST tool and the PV tool) could be combined seamlessly into one tool.
- The computer tool could be further widened to include cooling and air conditioning technologies such as vapour compression, absorption chillers, and heat pumps, and other distributed power generation systems such as micro-wind turbines.

## References

- Abu-Sharkh, S., Li, R., Markvart, T., Ross, N., Wilson, P., Yao, R., Steemers, K., Kohler, J., Arnold, R., 2005. *Can micro-grids make a major contribution to UK energy supply?*. Tyndall Centre for Climate Change Research.
- Ackermann, T., Soeder, L., 2002. *An overview of wind energy-status 2002*. Renewable and Sustainable Energy Reviews, Volume 6, 2002.
- Akbari, H., 1995. *Validation of an algorithm to disaggregate whole-building hourly electrical load into end uses*. Energy, Volume 20.
- Alanne, K., Saari, A., 2003. *Sustainable small-scale CHP technologies for buildings: the basis for multi-perspective decision making*. Renewable and Sustainable Energy Reviews, Volume 8.
- Ameli, S.M., Agnew, B., Potts, I., 2007. *Integrated Distributed System Evaluation Software (IDEAS) Simulation of a Micro-Turbine Based CHP system*. Applied Thermal Engineering.
- Anderson, K., Shackley, S., Watson, J., 2003. *First Reactions to the Energy White Paper from the UK's Tyndall Centre*. Tyndall Centre.
- Arbon, I.M., 2002. *Worldwide use of biomass in power generation and combined heat and power schemes*. Proceedings of the Institution of Mechanical Engineers, Volume 216, Part A. IMechE.
- ASHRAE, 1999. *HVAC Applications Handbook*. Atlanta, GA: ASHRAE.
- Atmaca, I., Yigit, A., 2003. *Simulation of solar-powered absorption cooling system*. Renewable Energy.
- Aydinalp, M., Ugursal, V.I., Fung, A.S., 2003. *Modelling residential energy consumption at the national level*. International Journal of Energy Research, Volume 27.
- Balcomb, J.D., Hayter, S.J., Weaver, N.L., 2001. *Hourly Simulation of Grid-Connected PV Systems Using Realistic Building Loads*. Conference Paper presented at the American Solar Energy Society National Solar Conferences Forum 2001.
- Beckman, W.A., Broman, L., Fiksel, A., Klein, S.A., Lindberg, E., Schuler, M., Thornton, J., 1994. *TRNSYS. The most complete solar energy system modelling and simulation software*. Renewable Energy, Volume 5.
- Beihong, Z., Weiding, L., 2006. *An optimal sizing method for cogeneration plants*. Energy and Buildings, Volume 38.



- BERR, 2007. [www.berr.gov.uk/energy/statistics/](http://www.berr.gov.uk/energy/statistics/) (accessed November 2007)
- Boait, P.J., Rylatt, R.M., Stockes, M., 2006. *Optimisation of consumer benefits from microCombined Heat and Power*. Energy and Buildings, Volume 38.
- Bojić, M., Kalogirou, S., Petronijević, K., 2002. *Simulation of a solar domestic water heating system using a time marching model*. Renewable Energy, Volume 27.
- Boyle, G., 2004. *Renewable Energy. Power for a sustainable future. (Second Edition)*, Oxford University Press in association with the Open University.
- BRECSU, 1996. *Good Practice Guide 176: Small-scale combined heat and power for buildings*. Energy Efficiency Best Practice Programme.
- BRECSU, 1996. *Good Practice Guide 204: Combined heat and power (CHP) in universities*. Energy Efficiency best Practice Programme, CHPA.
- BRECSU, 1997. *Good Practice Guide 227: How to appraise CHP. A simple investment appraisal methodology*. Energy Efficiency Best Practice Programme.
- BRECSU, 2000. *ECON 19: Energy Use in Offices*. Best Practice Programme.
- BRECSU, 2000. *Energy Consumption Guide 19: Energy use in offices*. Energy Efficiency Best Practice Programme.
- British Photovoltaic Association, 2004. [www.pv-uk.org.uk/uk/projlist.html](http://www.pv-uk.org.uk/uk/projlist.html). accessed 09/12/2004.
- Brogren, M., Green, A., 2003. *Hammarby Sjöstad-an interdisciplinary case study of the integration of photovoltaics in a new ecologically sustainable residential area in Stockholm*. Solar Energy Materials & Solar Cells 75.
- BSRIA, 2003. *Rules of thumb - guidelines for building services*. Bracknell, UK. BSRIA.
- Burer, M., Tanaka, K., Favrat, D., Yamada, K., 2003. *Multicriteria optimization of a district cogeneration plant integrating a solid oxide fuel cell-gas turbine combined cycle, heat pump and chillers*. Energy 28.
- Carbon Trust, 2004. *CHP Sizer Version 2.0*.
- Carbon Trust, 2004. *Combined Heat and Power for Buildings*. Action Energy from the Carbon Trust.
- Cardona, E., Piacentino, A., 2003. *A methodology for sizing a trigeneration plant in Mediterranean areas*. Applied Thermal Engineering 23.
- Celik, A.N., 2003. *Techno-economic analysis of autonomous PV-wind hybrid energy systems using different sizing methods*. Energy Conversion and Management, Volume 44.

- Christiansen, A.C., 2002. *New renewable energy developments and the climate change issue: a case study of Norwegian politics*. Energy Policy 30.
- Chwieduk, D., 2003. *Towards sustainable-energy buildings*. Applied Energy 76.
- CIBSE, 1999. *AM12: Small-scale combined heat and power for buildings*.
- CIBSE, 1999. *Small-scale combined heat and power for buildings, CIBSE Applications Manual AM12: 1999*. CIBSE, DETR Energy Efficiency Best Practice Programme.
- CIBSE, 2000. *CIBSE TM25: Understanding building integrated photovoltaics*.
- CIBSE, 2000. *Understanding building integrated photovoltaics*. CIBSE, DETR.
- CIBSE, 2004. *Guide G: Public Health Engineering*. London, UK. CIBSE.
- CIBSE, 2006. *Environmental design: CIBSE guide A*. London, UK. CIBSE
- Cloonan, M, 2003. *Energy from waste on the Isle of Mull: A feasibility study of and anaerobic digestion plant*. MSc Thesis, Department of Mechanical Engineering, University of Strathclyde in Glasgow.
- Coates, E.R., Kuhl, M.E., 2003. *Using simulation software to solve engineering economy problems*. Computers & Industrial Engineering, Volume 45.
- Cockroft, J., Kelly, N., 2006. *A comparative assessment of future heat and power sources for the UK domestic sector*. Energy Conversion and Management, Volume 47.
- Cosmi, C., Macchiato, M., Mangiamele, L., Marmo, G., Pietrapertosa, F., Salvia, M., 2003. *Environmental and economic effects of renewable energy sources use on a local case study*. Energy Policy 31.
- DEFRA, 2004. *The Government's Strategy for Combined Heat and Power to 2010*. DEFRA.
- DEFRA, 2005. *Guidelines for company reporting on greenhouse gas emissions*. [www.defra.gov.uk/environment/business/envrp/pdf/envrpgas-annexes.pdf](http://www.defra.gov.uk/environment/business/envrp/pdf/envrpgas-annexes.pdf) (accessed November 2007)
- Dell, R.M., Rand, D.A.J., 2001. *Energy storage – a key technology for global energy sustainability*. Journal of Power Sources, Volume 100.
- Dentice d'Accadia, M., Sasso, M., Sibilio, S., Vanoli, L., 2003. *Micro-combined heat and power in residential and light commercial applications*. Applied Thermal Engineering 23.
- Dolan, P.S., Nehrir, M.H., Gerez, V., 1996. *Development of a Monte Carlo based aggregate model for residential electric water heater loads*. Electric Power Systems

Research, Volume 36.

DTI, 1999. *Photovoltaics in Buildings, a Design Guide*.

DTI, 1999. *Photovoltaics in Buildings: A Design Guide*.

DTI, 2003. *Energy White Paper*. Department for Transport, DEFRA.  
<http://www.dti.gov.uk/energy/whitepaper/ourenergyfuture.pdf> (accessed November 2004)

DTI, 2004. *UK energy in brief July 2004*. A National Statistics Publication.

DTI, 2006. *Sustainable energy technology route maps: Energy from Photovoltaics*.  
[www.dti.gov.uk/files/file15413.pdf](http://www.dti.gov.uk/files/file15413.pdf) (accessed September 2006)

DTI, 2007. *Energy White Paper: Meeting the energy challenge*.

DTI, 2007. UK Energy Statistics.  
[http://www.dti.gov.uk/energy/stats/dukes1\\_1\\_1.xls](http://www.dti.gov.uk/energy/stats/dukes1_1_1.xls) (accessed November 2007)

Duffie, J.A., Beckman, W.A., 1991. *Solar Engineering of Thermal Processes*. New York: Wiley.

Duffin, T., 2000. *Market opportunities for renewables*. Power generation by renewables, IMechE seminar publication. Professional Engineering Publishing.

EC, 2001. *Directive 2001/77/EC of the European parliament and of the council of 27 September 2001 on the promotion of electricity produced from renewable energy sources in the internal electricity market*. Official Journal of the European Communities.

EC, 2004. *Directive 2004/8/EC of the European parliament and of the council of 11 February 2004 on the promotion of cogeneration based on a useful heat demand in the internal energy market and amending Directive 92/42/EEC*. Official Journal of the European Union.

Elam, C.C., Padro, C.E.G., Sandrock, G., Luzzi, A., Lindblad, P., Hagen, E.F., 2003. *Realising the hydrogen future: the International Energy Agency's efforts to advance hydrogen energy technologies*. International Journal of Hydrogen Energy, Volume 28.

Elexon, 2006. *Load profiles and their use in electricity settlement*.  
[www.elexon.co.uk](http://www.elexon.co.uk) (accessed September 2006)

El-Shatter, Th.F, Eskandar, M.N., El-Hagry, M.T., 2002. *Hybrid PV/fuel cell system design and simulation (Technical Note)*. Renewable Energy 27.

Energy Efficiency Best Practice in Housing, 2004. *Renewable energy sources for homes in urban environments*. Energy Saving Trust.

- EREC, 2004. *Renewable Energy in Europe*.  
[www.ren21.net/pdf/EREC\\_Building%20markets.pdf](http://www.ren21.net/pdf/EREC_Building%20markets.pdf) (accessed October 2007)
- EREC, 2004. *Renewable Energy Scenario to 2040*.
- ESD, 2005. *Solar water heating factsheet January 2005*. ESD, Housing Corporation.
- EST, 2001. *Domestic CHP. What are the potential benefits?* EST/ EA Technology Limited.
- EST, 2003. *Renewable energy in housing*. Energy Efficiency Best Practice in Housing.
- EST, 2005. *Contract for domestic hot water energy monitoring*. EST/EVAL/05/19. EST.
- EST, 2005. *Renewable Energy Factsheet. Solar water heating*. EST, London.
- EST, 2006. *Cost data for Boilers, CHP, solar thermal systems and PV systems*  
[www.energysavingtrust.org.uk](http://www.energysavingtrust.org.uk) (accessed October 2006)
- EST, 2008. [www.energysavingtrust.org.uk/resources/case\\_studies](http://www.energysavingtrust.org.uk/resources/case_studies) (accessed June 2008)
- ESTIF, 2007. *Solar thermal markets in Europe (Trends and market statistics 2006)*. ESTIF.
- ETSU, 2001. *Analysis of performance data from four active solar water heating installations: Interim Report*. ETSU, DTI.
- European Commission Directorate General Joint Research Centre, 2007. *PVGIS Irradiance data* <http://re.jrc.cec.eu.int/pvgis/apps/radday.php> (accessed September 2007)
- European Commission, 2008. Directorate-General for Energy and Transport.  
[www.managenergy.net](http://www.managenergy.net) (accessed 10/06/2008)
- European Photovoltaic Industry Association, 2001. *Solar Electricity in 2010*.
- European Photovoltaic Industry Association, Greenpeace, 2001. *Solar Generation, solar electricity for over 1 billion people and 2 million jobs by 2020*.
- Eurostat, 2007. *Energy Statistics*. <http://epp.eurostat.cec.eu/> (accessed October 2007)
- Everett, Horton, Doggart, Willoughby, 1985. *Linford Low Energy Houses*. Energy Technology Support Unit (ETSU).
- Faber Maunsell, 2003. *Solar power feasibility study for eastside*, Groundwork Birmingham.

- Faber Maunsell, 2003. *Solar power feasibility study for eastside*, Groundwork Birmingham.
- Faiers, A., 2006. *Consumer attitudes towards domestic solar power systems*. Energy Policy, Volume 34.
- Fishbone, L.G., Abilock, H., 1981. *MARKAL, a linear programming model for energy systems analysis, Technical description of the BNL Version*. Energy Res.
- Florides, G.A., Tassou, S.A., Kalogirou, S.A., Wrobel, L.C., 2002. *Review of solar and low energy cooling technologies for buildings*. Renewable and Sustainable Energy Reviews, Volume 6.
- Gamou, S., Yokoyama, R., Ito, K., 2002. *Optimal unit sizing of cogeneration systems in consideration of uncertain energy demands as continuous random variables*. Energy Conversion and Management, Volume 43.
- Goldemberg, J., Coelho, S.T., Lucon, O., 2004. *How adequate policies can push renewables*. Energy Policy, Volume 32.
- Goldner, F.S., 1994. *Energy Use and Domestic Hot Water Consumption, Final Report, Phase 1*. Prepared for the New York Energy Research and Development Authority. Brooklyn, NY. November 1994.
- Grant, N., 2002. *Water Conservation Products: A Preliminary Review*. (web based)
- Green, M.A., 2000. *Photovoltaics: technology overview*. Energy Policy, Volume 28.
- Groscurth, H.-M., de Almeida, A., Bauen, A., Costa, F.B., Ericson, S.-O., Griegrich, J., von Grabczewski, N., Hall, D.O., Hohmeyer, O., Jörgensen, K., Kern, C., Kühn I., Löfstedt, R., da Silva Mariano, J., Mariano, P.M.G., Meyer, N.I., Nielsen, P.S., Nunes, C., Patyk, A., Reinhardt, G.A., Rosillo-Calle, F., Scrase, I., Widmann, B., 2000. *Total costs and benefits of biomass in selected regions of the European Union*. Energy, Volume 25.
- Gross, R., Leach, M., Bauen, A., 2003. *Progress in renewable energy*. Environment International 29.
- Hacker, R., 2005. *Response to the consultation on Microgeneration Strategy and Low Carbon Building Programme*. PV-UK.
- Hargreaves, L., 2004. *Current thinking on combined heat and power for the built environment*. InsideENERGY, The Continuing Professional Development programme, Module 009.
- Hawkes, A., Leach, M., 2005. *Solid oxide fuel cell systems for residential micro-combined heat and power in the UK: Key economic drivers*. Journal of Power Sources, Volume 149.
- Haworth, K., James, D., 2004. *The Dawning of the CHP Age*. Newbuilder.

- Hedstroem, L., Wallmark, C., Alvfors, P., Rissanen, M., Stridh, B., Ekman, J., 2004. *Description and modelling of the solar-hydrogen-biogas-fuel cell system in GlashusEtt*. Journal of Power Sources, Volume 131.
- Henning, D., 1998. *Cost minimisation for a local utility through CHP, heat storage and load management*. Int J Energy Res.
- Herbert, P. *The environmental building*. Structural Survey, Volume 16, Number 2.
- Higham, DJ, 2004. *An Introduction to Financial Option Valuation*. Cambridge University Press.
- Huang, J.P., Poh, K.L., Ang, B.W., 1995. *Decision analysis in energy and environmental modelling*. Energy, Volume 20.
- IEA, 2002. *Energy conservation through energy storage programme*.
- IEA, 2003. *Renewables for Power Generation: Status and prospects*.
- IEA, 2003. *Trends in photovoltaic applications*. Photovoltaic Power Systems Programme.
- IEA, 2006. *PV costs*. [www.iea.org/](http://www.iea.org/) (accessed September 2006)
- IEA, 2007. *Key World Energy Statistics*.
- IEA, 2007. *Trends in photovoltaic applications. Survey report of selected IEA countries between 1992 and 2006*. Photovoltaic Power Systems Programme.
- IEA, 2008. [www.iea-pvps.org/cases/gbr\\_01.htm](http://www.iea-pvps.org/cases/gbr_01.htm) (accessed 10/06/2008)
- Ilex Energy Consulting, 2003. *NAP implications and options for CHP*. DEFRA.
- Iniyani, S., 2001. *A survey of social acceptance in using renewable energy sources for the new millennium*. Renewable Energy, Volume 24.
- Institute of Plumbing and Heating Engineering, 2002. *Plumbing Engineering Services Design Guide*. Essex, UK. Institute of Plumbing and Heating Engineering.
- Intergovernmental Panel on Climate Change (IPCC), 2001. *Climate Change 2001: The Scientific Basis*. Cambridge University Press.
- International Energy Agency, 2003. *Renewables for Power Generation: Status and Prospects*.
- Iqbal, M.T., 2003. *Simulation of a small wind fuel cell hybrid energy system*. Renewable Energy 28.
- Isukapalli, S., 1999. *Uncertainty Analysis of Transport-Transformation Models*. Rutgers, State University Of New Jersey, New Brunswick, New Jersey.

- Jaeger-Waldau, A., 2003. *PV Status Report 2003*. European Commission, Directorate General, Joint Research Centre.
- Jaeger-Waldau, A., 2007. *Photovoltaics and renewable energies in Europe*. Renewable and Sustainable Energy Reviews, Volume 11.
- Jebaraj, S., Iniyar, S., 2004. *A review of energy models*. Renewable and Sustainable Energy Reviews.
- Jordan, U., Vajen, K., 2000. *Influence of the DHW load profile on the fractional energy savings: a case study of a solar combi-system with TRNSYS simulation*. Solar Energy, Volume 69 (Supplement).
- Jordan, U., Vajen, K., 2001. *Realistic Domestic Hot-Water Profiles in Different Time Scales*. Solar Heating and Cooling Program of the International Energy Agency, Task 26: Solar Combisystems.
- Jurado, F., Cano, A., Carpio, J., 2003. *Modelling of combined cycle power plants using biomass*. Renewable Energy 28.
- Kalogirou, S.A., 2001. *Use of TRNSYS for modelling and simulation of a hybrid pv-thermal solar system for Cyprus*. Renewable Energy, Volume 23.
- Kalos, M.H., Whitlock, P.A., 1986. *Monte Carlo Methods. Volume I: Basics*. John Wiley & Sons, USA.
- Kaul, S., Edinger, R., 2004. *Efficiency versus cost of alternative fuels from renewable resources: outlining decision parameters*. Energy Policy, Volume 32.
- King, Sir D, 2004. *Presentation at the CIBSE National Conference 2004*.
- Kwant, K.W., 2003. *Renewable energy in The Netherlands: policy and instruments*. Biomass and Bioenergy, Volume 24.
- Langdon, D., Everest, 2004. *Combined heat and power*. Building Services Journal, October 2004.
- Lindenberger, D., Bruckner, T., Morrison, R., Groscurth, H-M. Kuemmel, R., 2004. *Modernization of local energy systems*. Energy 29.
- Lloyd, C.R., 2001. *Renewable energy options for hot water systems in remote areas*. Renewable Energy 22.
- Lund, H., Muenster, E., 2003. *Management of surplus electricity-production from a fluctuating renewable-energy source*. Applied Energy 76.
- Lund, H., Muenster, E., 2003. *Modelling of energy systems with a high percentage of CHP and wind power*. Renewable Energy 28.
- Lund, H., Østergaard, P.A., 2000. *Electric grid and heat planning scenarios with*

*centralised and distributed sources of conventional, CHP and wind generation.* Energy, Volume 25.

Lund, P.D., 2005. *Sizing and applicability considerations of solar combisystems.* Solar Energy, Volume 78.

Lund, P.D., Peltola, S.S., 1992. *SOLCHIPS – A fast predesign and optimization tool for solar heating with seasonal storage.* Solar Energy 48.

Lund, PD., 1995. *EUROSOL-Ein numerisches EDV-Programm zur Berechnung der Warmeertrage von Solaranlagen zur Warmwasserbereitung und Rauheizung.* Proceedings of the Funftes Symposium Thermische Solarenergie, Staffelstein, Germany.

Lutz, J.D., Liu, X., McMahon, J.E., Dunham, C., Shown, L.J., McGrue, Q.T., 1996. *Modelling patterns of hot water use in households.* Energy Analysis Program, Energy and Environment Division, Ernest Orlando Lawrence Berkeley National Laboratory.

Macmillan, S., Koehler, J., 2004. *Modelling energy use in the global building stock: a pilot survey to identify available data sources.* Tyndall Centre for Climate Change Research.

Maeng, H., Andersen, K.K., Andersen, A.N., 2002. *EnergyPRO Users Guide.* [www.emd.dk](http://www.emd.dk)

Maidment, G.G., Prosser, G., 2000. *The use of CHP and absorption cooling in cold storage.* Applied Thermal Engineering 20.

Maidment, G.G., Tozer, R.M., 2002. *Combined cooling heat and power in supermarkets.* Applied Thermal Engineering, Volume 22.

Market Transformation Programme, 2007. *BNWAT17: Pilot study to undertake initial evaluation of equipment for Domestic Hot Water consumption monitoring.* [www.mtprog.com](http://www.mtprog.com) (accessed November 2007)

Martens, A., 1998. *The energetic feasibility of CHP compared to the separate production of heat and power.* Applied Thermal Engineering.

Matrawy, K.K., Farkas, I., 1996. *Technical Note: New technique for short term storage sizing.* Renewable Energy, Volume 11.

McIlveen-Wright, D.R., McMullan, J.T., Guiney, D.J., 2003. *Wood-fired fuel cells in selected buildings.* Journal of Power Sources, Volume 118.

McKendry, P., 2002. *Energy production from biomass (part 1): overview of biomass.* Bioresource Technology 83.

McKendry, P., 2002. *Energy production from biomass (part 2): conversion technologies.* Bioresource Technology 83.



- McKendry, P., 2002. *Energy production from biomass (part 3): gasification technologies*. Bioresource Technology 83.
- McQueen, D.H.O., Hyland, P.R., Watson, S.J., 2004. *Monte Carlo Simulation of Residential Electricity Demand for Forecasting Maximum Demand on Distribution Networks*. IEEE Transactions on Power Systems, Volume 19.
- McVeigh, J.C., 1977. *Sun Power: An Introduction to the Applications of Solar Energy*. Pergamon Press, Oxford, UK.
- Merton Rule, 2008. *The Merton Rule. Best Practice in Low Carbon Planning*. [www.themertonrule.org/the-merton-rule](http://www.themertonrule.org/the-merton-rule) (accessed May 2008)
- Meyer, N.I., 2003. *European schemes for promoting renewables in liberalised markets*. Energy Policy 31.
- Michalik, G., Khan, M.E., Bonwick, W.J., Mielczarski, W., 1997. *Structural modelling of energy demand in the residential sector: 1. Development of structural models*. Energy, Volume 22.
- Michalik, G., Khan, M.E., Bonwick, W.J., Mielczarski, W., 1997. *Structural modelling of energy demand in the residential sector: 2. The use of linguistic variables to include uncertainty of customers' behaviour*. Energy, Volume 22.
- Mihalakakou, G., Psiloglou, B., Santamouris, M., Nomidis, D., 2002. *Application of renewable energy sources in the Greek islands of the South Aegean Sea*. Renewable Energy 26.
- Morthorst, P.E., 2003. *National environmental targets and international emission reduction instruments*. Energy Policy, Volume 31.
- Mott Green Wall, 2002. *Building integrated photovoltaics*. Building Services Journal, November 2002 issue.
- Murphy, J.D., McKeogh, E., Kiely, G., 2004. *Technical/economic/environmental analysis of biogas utilisation*. Applied Energy 77.
- National Grid Group, 2004. *Demand Forecasting, Summer and Winter Demands 2002*. [http://www.nationalgrid.com/uk/activities/mn\\_demand.html](http://www.nationalgrid.com/uk/activities/mn_demand.html)
- Newborough, M., 2004. *Assessing the benefits of implementing micro-CHP systems in the UK*. Proceedings of the Institution of Mechanical Engineers, Volume 218, Part A: J Power and Energy.
- Nishio, K., Asano, H., 2006. *A residential end-use demand model for analysing the energy conservation potential of new energy efficient technologies*.
- Northcott, D., 2002. *Capital Investment Decision-Making*. Thomson, UK.
- Nottingham City Council, 2004. *Electricity load profile data*.

Office for National Statistics, 2007. [www.statistics.gov.uk](http://www.statistics.gov.uk) (accessed September 2007)

OPET, 2004. *Small-scale cogeneration in non-residential buildings*.

Østergaard, P.A., 2003. *Transmission-grid requirements with scattered and fluctuating renewable electricity-sources*. Applied Energy 76.

Paatero, J.V., Lund, P.D., 2006. *A model for generating household electricity load profiles*. International Journal of Energy Research, Volume 30.

Paradis, R., 2004. *Energy Analysis Tools*. National Institute of Building Sciences, Washington DC, USA.

Parker, D.S., 2003. *Research highlights from a large scale residential monitoring study in a hot climate*. Energy and Buildings, Volume 35.

Peacock, A.D., Newborough, M., 2006. *Impact of micro-combined heat-and-power systems on energy flows in the UK electricity supply industry*. Energy, Volume 31.

Pett, J., Guertler, P., 2004. *User behaviour in energy efficient homes*. Association for the Conservation of Energy, London, UK.

Polysun, 2000. *User's manual for Polysun 3.3*. SPF, Switzerland.

Pons, D.J., Raine, J.K., 2003. *Relative effectiveness of mechanisms for simulating uncertainty in quantitative systems*. Proceedings of the Institution of Mechanical Engineers, Volume 217, IMechE.

Reneke, J.A., Wiecek, M.M., 2002. *Performance-based multicriteria decision making for service sector systems*.

RETScreen International, 2004. *Clean Energy Project Analysis: RETScreen Engineering & Cases Textbook. Photovoltaic project analysis*. CANMET Energy Technology Centre, Canada.

RETScreen International, 2004. *Clean Energy Project Analysis: RETScreen Engineering & Cases Textbook. Solar Water Heating Project Analysis Chapter*. CANMET Energy Technology Centre, Canada.

RICS Foundation, 2004. *Renewable energy and the built environment, The research agenda*. [www.rics-foundation.org/](http://www.rics-foundation.org/)

Ro, K., Rahman, S., 2003. *Control of grid-connected fuel cell plants for enhancement of power system stability*. Renewable Energy, Volume 28.

Roberts, S., 1992. *Solar electricity – Practical guide to designing and installing small PV systems*. Prentice Hall, International Edition.

Rogers, M., 2001. *Engineering Project Appraisal*. Blackwell Sciences Ltd., UK.

Salameh, M.G., 2003. *Can renewable and unconventional energy sources bridge the global energy gap in the 21<sup>st</sup> century?* Applied Energy 75.

SEA, 2004. *Solar for London*.

Shackley, S., Green, K., 2007. *A conceptual framework for exploring transitions to decarbonised energy systems in the United Kingdom*. Energy, Volume 32.

Sigma Elektroteknik, A.S., 2001. *Personal combustion power plant*. Holen, Norway.

Silveira, J.L., Tuna, C.E., 2003. *Thermoeconomic analysis method for optimization of combined heat and power systems. Part 1*. Progress in Energy and Combustion Science 29.

Sims, R.E.H, Rogner, H., Gregory, K., 2003. *Carbon emission and mitigation cost comparisons between fossil fuel, nuclear and renewable energy resources for electricity generation*. Energy Policy 31.

Sims, R.E.H., 2004. *Renewable energy: a response to climate change*. Solar Energy 76.

Stallcup, J., 2004. *Applying Demand Factor and Diversity Factor per the NEC*. Code Issues.

Stokes, M., Rylatt, M., Lomas, K., 2004. *A simple model of domestic lighting demand*. Energy and Buildings, Volume 36.

Sugiura, K., Naruse, I., 2002. *Feasibility study of the co-generation system with direct internal reforming-molten carbonate fuel cell (DIR\_MCFC) for residential use*. Journal of Power Sources, Volume 106.

Takoudis, G., Ault, G., 2004. *Development of a monte carlo model for assessing offshore wind farm cable reliability and the worth of redundancy. A comparison of various collector configurations*. MSc Thesis, Department of Mechanical Engineering, University of Strathclyde.

Tanaka, H., Tomita, T, Okumiya, M., 2000. *Feasibility of a district energy system with seasonal water thermal storage*. Solar Energy, Volume 69.

TV Energy, 2008. [www.tvenergy.org/case-studies.htm](http://www.tvenergy.org/case-studies.htm) (accessed 09/06/2008)

Ulleberg, Ø, Mørner, S.O., 1997. *Trnsys simulation models for solar-hydrogen systems*. Elsevier Science Ltd.

UNFCCC, 1997. *Kyoto Protocol to the United Nations Framework on Climate Change*. <http://unfccc.int/resource/docs/convkp/kpeng.pdf> (accessed April 2005)

United States Department of Energy Office of Energy Efficiency and Renewable Energy, 2000. *M&V Guidelines: Measurement and Verification for Federal Energy Projects, Version 2.2, Chapter 35: Renewable Energy Technologies*. Federal Energy

- Management Program. <http://www.eere.energy.gov/femp/pdfs/26265.pdf>
- United States Department of Energy Office of Energy Efficiency and Renewable Energy, 2008. [www.eere.energy.gov/buildings/tools\\_directory](http://www.eere.energy.gov/buildings/tools_directory) (accessed 17.06.08)
- University of Strathclyde, 2006. *Economics of CHP* [http://esru.strsth.ac.uk/EandE/Web\\_sites/97-8/CHP\\_sizing\\_case/econ.html](http://esru.strsth.ac.uk/EandE/Web_sites/97-8/CHP_sizing_case/econ.html) (accessed July 2006)
- University of Waterloo, 1994. *WATSUN Computer Program, Version 13.2*. University of Waterloo, Canada.
- University of Wisconsin, 1990. *TRYNSYS: A transient simulation program*. Solar energy laboratory, University of Wisconsin, Madison, USA.
- Utley, J.I., Shorrocks, L.D., 2006. *Domestic Energy Fact File (2006)*. Defra, BRE, Energy Saving Trust.
- Van der Horst, D., 2005. *UK biomass energy since 1990: the mismatch between project types and policy objectives*. Energy Policy, Volume 33.
- Viessmann, 2007. *Pump power ratings from discussion with Viessmann*.
- Voorspools, K., D'haeseleer, W., 2006. *Reinventing hot water? Towards optimal sizing and management of cogeneration: A case study for Belgium*. Applied Thermal Engineering.
- Wallmark, C., Alvfors, P., 2003. *Technical design and economic evaluation of a stand-alone PEFC system for buildings in Sweden*. Journal of Power Sources, Volume 28.
- Wiehagen, J., Sikora, J.L., 2002. *Performance Comparison of Residential Hot Water Systems*. National Renewable Energy Laboratory, Colorado, USA.
- Williams, B.C., McMullan, J.T., 2003. *Techno-economic analysis of fuel conversion and power generation systems – the development of a portable chemical process simulator with capital cost and economic performance analysis capabilities*. Int. J. Energy Res., Volume 20.
- Williams, J.M., Knight, I.P., Roberts, G., 2000. *Knowledge based tool to aid the preliminary evaluation of CHP for a building*. CIBSE [www.cibse.org/pdfs/CHP%20knowledge%20based%20tool.pdf](http://www.cibse.org/pdfs/CHP%20knowledge%20based%20tool.pdf)
- Win, C.B., 1980. *Solar simulation computer programs*. In: Dickinson et al, 1980. *Solar energy technology handbook*. Marcel Dekker, New York.
- Winter, C.-J., 2003. *On the HYway – sustainable assets in Germany's energy state's portfolio*. International Journal of Hydrogen Energy, Volume 28.
- Woolf, J., 2003. *Renew: a renewable energy design tool for architects*. Renewable

Energy, Volume 28.

Wordsworth, A., Grubb, M., 2003. *Quantifying the UK's incentives for low carbon investment*. Climate Policy, Volume 3.

Wu, X., Jenkins, N., Strbac, G., Watson, J., Mitchell, C., 2004. *Integrating Renewables and CHP into the UK Electricity System*. Tyndall Centre for Climate Change Research.

Yao, R., Steemers, K., 2005. *A method of formulating energy load profile for domestic buildings in the UK*. Energy and Buildings, UK.

## Appendix

### ***Domestic Hot Water and Heating Demand Survey***

This questionnaire aims to establish typical residential hot water consumption patterns.

*Please tick or complete the relevant boxes in the sections below.*

*Thank you very much for your time.*

#### **GENERAL**

City/County of residence

Property type      Flat       Bedsit       Terraced       Semi   
Detached       Other (please specify)

Year of build      <1900       1900-40       1941-60       1960s       1970s   
1980s       1990s       2000s       Don't know

No of bedrooms      1       2       3       4       5+

No of showers      0       1       2       3       4+

No of baths      0       1       2       3       4+

Dwelling size (m<sup>2</sup>)      0-50       51-100       101-150       151-200       >200

Adult occupancy      1       2       3       4       5+

Children occupancy      0       1       2       3       4+

On average, how many days in the week is your house occupied during the day (9am – 5pm)?  
1       2       3       4       5       6       7

#### **APPLIANCES**

Oven fuel:      Electricity       Mains gas       Other (please specify)

Hob fuel:      Electricity       Mains gas       Other (please specify)

Washing machine water supply:      Hot & cold supply       Cold supply only       Don't know       Don't have one

Dishwasher water supply:      Hot & cold supply       Cold supply only       Don't know       Don't have one

**HEATING SYSTEM**

Main Heating System      Conventional boiler     Combination boiler     Don't know   
Other (please specify)       None

Distribution system      Radiators     Under-floor heating     Don't know   
Other (please specify)

Main Heating Fuel      Electricity     Natural Gas       Oil       Coal   
Other (please specify)       Don't know

Heating period (please tick months you usually heat your house)  
January       February       March       April   
May       June       July       August   
September       October       November       December

Is your heating controlled by a timer or a thermostat?      Timer       Thermostat       Don't know

Do you have a fireplace?      Yes       No

Fireplace fuel      Gas       Wood       Coal   
Other (please specify)

**HOT WATER SYSTEM**

What hot water system do you have?      Same as for heating     Other (please specify)

Fuel      Same as for heating     Other (please specify)

Is your hot water supply controlled by a timer or is it instantaneous?      Timer       Instantaneous       Don't know

**COMMENTS**

**1 - Weekly consumption pattern**

Week  (1-52) Date

reading at the start of the week      reading at the end of the week

Gas reading      

Electricity reading      

Water reading      

**Heating**

Thermostat setting

*Please tick your thermostat setting for every day of the week*

°C

Day	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
Monday																					
Tuesday																					
Wednesday																					
Thursday																					
Friday																					
Saturday																					
Sunday																					

Day	1	2	3	4	5
Monday					
Tuesday					
Wednesday					
Thursday					
Friday					
Saturday					
Sunday					

Or Timer settings

ON 1  °C

OFF 1  °C

ON 2  °C

OFF 2  °C

**Hot water**

Timer settings

ON 1  °C

OFF 1  °C

ON 2  °C

OFF 2  °C



**2a - Weekly Bathroom DHW consumption**

Week  (1-52)      Date

Please tick when the bath, shower, wash handbassin, and other hot water is used in the bathroom.

**BATH**

Time	Example	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00								
01:00								
02:00								
03:00								
04:00								
05:00								
06:00								
07:00								
08:00								
09:00								
10:00								
11:00								
12:00								
13:00								
14:00								
15:00								
16:00	✓							
17:00								
18:00								
19:00								
20:00								
21:00								
22:00								
23:00								

**SHOWER**

Time	Example	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00								
01:00								
02:00								
03:00								
04:00								
05:00								
06:00								
07:00	✓							
08:00								
09:00								
10:00								
11:00								
12:00								
13:00								
14:00								
15:00								
16:00								
17:00								
18:00								
19:00								
20:00								
21:00								
22:00								
23:00								

**WASH HANDBASSIN**

Time	Example	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00								
01:00								
02:00								
03:00								
04:00								
05:00								
06:00								
07:00								
08:00	✓							
09:00								
10:00								
11:00								
12:00								
13:00	✓							
14:00								
15:00								
16:00								
17:00	✓							
18:00								
19:00	✓							
20:00								
21:00	✓							
22:00								
23:00								

**OTHER (please specify)**

Time	Example	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00								
01:00								
02:00								
03:00								
04:00								
05:00								
06:00								
07:00								
08:00								
09:00								
10:00								
11:00								
12:00								
13:00								
14:00								
15:00								
16:00								
17:00								
18:00								
19:00								
20:00								
21:00								
22:00								
23:00								

**2b - Weekly Kitchen DHW consumption**

Week  (1-52)      Date

Please tick when the sink, dishwasher, washing machine, and other hot water is used in the kitchen.

**SINK (washing dishes)**

Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

**DISHWASHER**

Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

**WASHING MASHINE**

Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

**OTHER (please specify)**

Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

**2c – Weekly other DHW consumption**

Week  (1-52)      Date

Please tick when hot water is used in this room. Please also indicate its use.

USE (please specify)							
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

USE (please specify)							
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

USE (please specify)							
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

USE (please specify)							
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
00:00							
01:00							
02:00							
03:00							
04:00							
05:00							
06:00							
07:00							
08:00							
09:00							
10:00							
11:00							
12:00							
13:00							
14:00							
15:00							
16:00							
17:00							
18:00							
19:00							
20:00							
21:00							
22:00							
23:00							

