

DGA Method-Based ANFIS Expert System for Diagnosing Faults and Assessing Quality of Power Transformer Insulation Oil

Mohd Muhridza Bin Yaacob¹, Ahmed Raisan Hussein¹ & Mohd Fauzi Bin Othman²

¹ Institute of High Voltage and High Current, Faculty of Electrical Engineering, Universiti Teknologi Malaysia, Malaysia

² Centre for Artificial Intelligence and Robotic, Faculty of Electrical Engineering, Universiti Teknologi Malaysia, Malaysia

Correspondence: Ahmed Raisan Hussein, Institute of High Voltage and High Current, Faculty of Electrical Engineering, Universiti Teknologi Malaysia, 81310, UTM Skudai, Johor, Malaysia. Tel: 60-107-553-5695. Fax: 6107-557-8150. E-mail: ahmad_rissan@yahoo.com

Received: April 28, 2015

Accepted: August 28, 2015

Online Published: December 21, 2015

doi:10.5539/mas.v10n1p13

URL: <http://dx.doi.org/10.5539/mas.v10n1p13>

Abstract

Accurate fault diagnostics and assessment of electrical power transformer insulation oil for lifelong endurance are the key issues addressed in this research. The durability of a transformer is significantly determined by the quality of its insulation oil, which deteriorates over time due to temperature fluctuations and moisture content. Protecting transformers from potential failure through early and precise diagnosis of faults and through efficient assessment of oil quality during the actual conduct of the operation can avoid sizeable economic losses. The ANFIS Expert System that uses intelligent software plays an important role in this regard. The dissolved gas analysis (DGA) in oil is a reliable method for diagnosing faults and assessing insulation oil quality in transformers. The safeguarding teams of transformer power stations often suffer from the occurrence of sudden faults, which result in severe damages and heavy monetary loss. The oil in transformers must be appropriately treated to circumvent such failures. In this research, an ANFIS Expert System was used to diagnose faults and to assess the status and quality of insulation oil in power transformers. A suitable treatment was identified using the Rogers ratio method depending on the DGA in oil. The graphical user interface from the MATLAB environment was used and proven effective for fault diagnosis and oil quality evaluation. The training algorithm is capable of assessing oil quality according to the specifications of the IEEE standard C57-104 and the IEC standard 60599.

Keywords: expert system, IEC method, insulation oil, fault diagnosis, power transformer, Rogers method

1. Introduction

Electricity has become an important part of human life. At present, it is difficult to imagine life without electricity. Electricity has become a basic need for people, agriculture, and the industry; hence, it has a strong impact on the economy of any country. A suitable method for accurate fault diagnostics and assessment of the oil quality of electrical power transformer is needed to ensure long-term protection. The longevity of a transformer is determined by its insulating quality. Generally, insulation deteriorates over time due to fluctuations in temperature, moisture, oxygen, and other environmental factors. Diagnosis of faults and assessment of oil quality are important steps in protecting transformers from operational failures. Power transformers are exceptionally expensive and damage to the insulation system often causes high economic loss (Sun et al., 2010). In the past, several methods were adopted for the diagnosis of faults and for assessing oil quality in transformers; different standards with approved specifications were developed, including the IEEE standard C57-104 and the IEC standard 60599 (Committee et al., 2009; Rogers, 1978). Most of the assessment and diagnosis methods were based on dissolved gas analysis (DGA). Despite many efforts, efficient and precise methods for determining the nature of faults and the subsequent rectification mechanisms that can attain superior performance.

Electrical transformer oils are known to possess a dual function: insulation and cooling. The superior insulation and cooling capacity of electrical transformer oils that enables the transformer to withstand severely elevated changes in temperature over an extended period of operation protects transformers from faults. However, high electrical pressure, temperature, and harsh environmental conditions produce hydrocarbons (gases) in transformer oils, which affect its function negatively. Therefore, preventive maintenance schedules for fault

diagnosis and quality assessment of transformer oils are obligatory (Shirkhodaie et al., 1998).

Several methods have been developed for fault diagnosis. Methods for assessing oil quality, on the other hand, is another topic. The various types of incipient faults that occur in transformers are arcing, corona discharge, low energy sparking, severe overloading, and overheating. These are some of the mechanisms that can result in chemical decomposition of the insulating material, as well as in the formation of various combustible and non-combustible gases, such as methane (CH_4), ethane (C_2H_6), ethylene (C_2H_4), acetylene (C_2H_2), and hydrogen (H_2). Decomposition generates gaseous products that can be dissolved in mineral oil (Silva et al., 2000). DGA, a popular conventional method for assessing the condition of an oil-filled transformer, involves analysis of the gases dissolved in the insulating medium. This method is widely used by electric companies and has received worldwide recognition because of its reliability in the detection of incipient faults in power transformers. However, DGA method provides results based on empirical evidence; hence, the approach does not offer a mathematical description. In response, several soft computing techniques based on DGA have been proposed to enhance the diagnosis capabilities and effectiveness of the existing DGA method (Satyanarayana et al., 2008).

2. Dissolved Gas Analysis

The DGA in oil involves taking a sample of transformer oil to determine the concentration and ratio of gases in the sample. These gases are formed by the following factors: high temperatures, partial discharge, arcing, and corona. These factors lead to the decomposition of the oil hydrocarbons (compounds of carbon and hydrogen). These gases are classified into two types: combustible gas and non-combustible gas. Combustible gases include carbon monoxide (CO), hydrogen (H_2), methane (CH_4), acetylene (C_2H_2), ethylene (C_2H_4), and ethane (C_2H_6). Noncombustible gases include, oxygen (O_2), nitrogen (N_2), and carbon dioxide (CO_2). When these gases are present in the oil sample, these exist at different rates and are generated with different rates. Some of the gases vary in ratio from time to time, depending on the changes in temperature and the age of the transformers (Anon n.d, 2000).

2.1 Rogers Ratio Method

In this method, four ratios are accounted for: CH_4/H_2 , $\text{C}_2\text{H}_2/\text{CH}_4$, $\text{C}_2\text{H}_4/\text{C}_2\text{H}_6$, and $\text{C}_2\text{H}_2/\text{C}_2\text{H}_4$. Diagnosis of faults is accomplished via a simple coding scheme based on ranges presented in Table 1. Ratios are coded to identify 12 types of faults in transformers to identify the types of faults as shown Table 2 (Muhamad et al., 2007).

Table 1. Rogers ratio code

	< 0.1	5
CH_4/H_2	0.1- 1	0
	1--3	1
	> 3	2
$\text{C}_2\text{H}_6/\text{CH}_4$	< 1	0
	> 1	1
$\text{C}_2\text{H}_4/\text{C}_2\text{H}_6$	< 1	0
	1-3	1
	> 3	2
$\text{C}_2\text{H}_2/\text{C}_2\text{H}_4$	< 0.5	0
	0.5-3	1
	> 3	2

Table 2. Fault types according to rogers ratio method

No.	CH_4/H_2	$\text{C}_2\text{H}_6/\text{CH}_4$	$\text{C}_2\text{H}_4/\text{C}_2\text{H}_6$	$\text{C}_2\text{H}_2/\text{C}_2\text{H}_4$	Fault type
1	0	0	0	0	No fault
2	1-2	0	0	0	<150 °C thermal fault
3	1-2	1	0	0	150–200 °C thermal fault
4	0	1	0	0	200–300 °C thermal fault
5	0	0	1	0	General conductor overheating
6	1	0	1	0	Winding circulating currents
7	1	0	2	0	Core and tank circulating currents overheated joints
8	5	0	0	0	Partial discharge
9	5	0	0	1-2	Partial discharge with tracking

10	0	0	0	1	Flashover without power follow-through
11	0	0	1-2	1-2	Arc with power follow-through
12	0	0	2	2	Continuous sparking to floating potential

2.2 IEC Ratio Method

In the IEC ratio method, the objective is to create three ratios (C_2H_2/C_2H_4 , CH_4/H_2 , and C_2H_4/C_2H_6), to allow comparison between the result of this method and that of the Rogers method. In this method, the ratio, C_2H_6/CH_4 , was excluded because it indicates a limited temperature range of decomposition. The coding of the three gas ratios are presented in Table 3. The nine fault types are shown in Table 4 (Sarma & Kalyani, 2004).

Table 3. Iec code ratio

IEC Ratio of characteristic gases	$\frac{C_2H_2}{C_2H_4}$	$\frac{CH_4}{H_2}$	$\frac{C_2H_4}{C_2H_6}$
< 0.1	0	1	0
0.1-1	1	0	0
1-3	1	2	1
> 3	2	2	2

Table 4. Fault types according to the iec ratio method

Case No.	$\frac{C_2H_2}{C_2H_4}$	$\frac{CH_4}{H_2}$	$\frac{C_2H_4}{C_2H_6}$	Characteristic fault
0	0	0	0	No fault
1	0 But not significant	1	0	Partial discharges of low energy density
2	1	1	0	Partial discharges of low energy density
3	1-2	0	1-2	Discharges of low energy
4	1	0	2	Discharges of High Energy
5	0	0	1	Thermal fault of low Temperature <150 °C
6	0	2	0	Thermal fault of low Temperature <150 °C–300 °C
7	0	2	1	Thermal fault of medium temperature range 300 °C–700 °C
8	0	2	2	Thermal fault of high temperature >700 °C

3. ANFIS Expert System

Expert systems fall under the artificial intelligence category of computer applications. Designing an expert system needs a knowledge engineer - an individual who studies how human experts make decisions and translates the findings into rules that a computer can understand. ANFIS, derived from the term adaptive network-based fuzzy inference engine, was first proposed. This system was designed to allow if-then rules and membership functions to be constructed based on the historical data of established metrics. The system was also designed with an adaptive nature for automatic tuning purposes (Foong et al., 2009).

3.1 Design ANFIS Expert System

The expert system was designed according to the flowchart shown fig 1. The design provides an interface where the user can input gas values derived from the analysis of samples of transformer oil through dissolved gas ratios. Subsequently, the user can choose the method to be used in the analysis process. The system then uses ANFIS to process the data.




Figure 1. Flowchart for ANFIS Expert System Design

3.2 Design of the ANFIS Expert System Interface

The user interface of the ANFIS expert system was designed using GUI access provided in the MATLAB environment. As depicted in Figure 2, the user input interface allows the following items to be entered: gas values, analysis methods (Rogers ratio method or IEC ratio method), gas ratios, fault type diagnosis, and assessment of the quality of insulating oil (Gao et al., 1998).




Figure 2. Interface of the ANFIS Expert System

3.3 ANFIS Models

Fuzzy inference is the process of formulating the mapping from a given input to an output using fuzzy logic. The mapping is then used as a basis for making decisions. The process of fuzzy inference involves membership functions, logical operations, and if-then rules. Fuzzy Inference System (FIS) maps the input characteristics to input membership functions in rules to output membership function to single-value output. The shape of membership functions depends on the parameters. ANFIS chooses the parameters of membership functions automatically during the learning phase to match the system's output with the target output. Hence, ANFIS can be used for modeling a system where input/output data are available for modeling but no predetermined model for the system exists. Parameters of membership functions could be defined to fit the membership functions of the input/output data, as depicted in Figure 3.




Figure 3. ANFIS structure

ANFIS was tested using 180 training samples. In ANFIS, the diagnosis of each crisp value of gas ratio is represented by a trapezoidal membership function (Figure 4). The set of fuzzy rules relates the input variables to the output. The fuzzy inference engine in the ANFIS network uses if-then rule-based system, given by IF

antecedent and Then Consequent, a fuzzy rule set of 12 rules for Rogers Ratio Method based ANFIS and a fuzzy rule set of 9 rules for IEC Ratio Method based ANFIS.




Figure 4. Input membership functions for ANFIS

For the assessment of the quality of transformer oil, the input variable TCG uses a different set of terms (Low, Moderate, High, V. High, and Severe). The input membership functions and the different set of terms are shown in Figure 5. Only one output variable is assigned to transformer oil quality. This is called oil degradation index (ODI). ODI value is computed for each input. The input membership functions are designed to give a constant output over a substantial range. The membership of each input variable varies over a definite range, uniformly on both sides (trapezoidal). This is an extremely useful property for monitoring normal changes due to operation and ageing. Another significant feature of the ODI value is its correlation with the specific reconditioning procedures for transformer oil. The output membership functions are shown in Figure 6. MF 1= Good Oil, MF 2 = Single Filtering and Degassing, MF 3 = Double Filtering and Degassing, MF 4 = Reclamation and MF 5 = Don't Use the Oil.




Figure 5. Input membership function used in oil reconditioning




Figure 6. Output membership function

The ANFIS responses obtained from the tested set are shown in Figure 7 and 8. The FIS output clearly shows that the proposed method can be effectively used for diagnosing incipient faults of power transformers.




Figure 7. Testing output for Rogers Ratio Method-Based ANFIS




Figure 8. Testing the output of IEC Ratio Method-Based ANFIS

4. Results and Discussion

Sampling of power transformer oils was performed at the sites where these transformers are located for more than 15 years. The 30 samples used for the detection of the DGA in oil and the results of the analysis, are presented in Table 5. Insertion of the data ratios of gas-derived samples from Table 5 to the expert system

interface was tested in each case. The results, as summarized in Table 6, are good and in agreement with the specifications of approved standards for diagnosing faults and assessing quality of insulating oils. The results obtained through the ANFIS Expert System suggest that identifying the status of transformer oil while in service is an important and necessary maintenance step to ensure long-term functioning of the transformer oil. The results of the test, as presented in Table 6, are satisfactory. Results observed prior to identifying faults are accurate statements of the type of fault and the assessment of the quality of the oil, which are guides in providing treatment. In some cases, faults that could not be diagnosed by the Rogers ratio method were diagnosed successfully using the IEC ratio method, and vice versa.

Table 5. Value of gases in ppm data input to ANFIS expert system

NO.	CH ₄	H ₂	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂
1	47	191	43	15	0.0001
2	200	50	300	200	50
3	245	36	144	332	0.0001
4	187	86	136	363	0.0001
5	24	10	372	24	0.0001
6	7	17	13	3	0
7	42	206	16	82	221
8	999	769	234	1599	31
9	50	1000	40	30	10
10	107	127	11	154	224
11	9739	2004	2750	5114	0
12	144	60	67	449	9
13	3	4	2	1	0
14	53	65	41	95	14
15	79	33	30	215	5
16	370	1249	56	606	1371
17	1053	507	297	1440	17
18	77	57	19	21	0
19	10	160	3	1	1
20	770	199	217	1508	72
21	695	416	74	867	0
22	27	10	49	4	1
23	940	1450	211	322	61
24	1.7	2.35	0.6	1.2	0.1
25	96	240	20	8	5
26	4000	960	1290	1560	6
27	73	980	58	12	0
28	1500	280	1200	150	40
29	8517	2844	10196	4422	39
30	4	8	350	24	2

Table 6. Results of diagnosing faults and assessing the quality of insulating oil

NO.	Fault Type		Oil Treatment
	Rogers Ratio	IEC Ratio	
1	Normal deterioration	No Fault	Single filtering & degassing
2	Overheating – 150–200 °C	Unidentifiable	Single filtering & degassing
3	Unidentifiable	Thermal fault of medium Temperature 300–700 °C	Double filtering & degassing
4	Winding Circulating Currents	Thermal fault of medium Temperature 300–700 °C	Double filtering & degassing
5	Overheating – 150–200 °C	Thermal fault of low temperature –	Single filtering &

6	Overheating – 200–300 °C	150–300 °C No Fault	degassing Good Oil
7	Arc with Power Follow-Through	Discharges of High Energy	Double filtering & degassing
8	Core and Tank Circulating Currents	Thermal fault of High Temperature – above 700 °C	Reclamation
9	Partial discharge	Partial Discharges of High Energy Density	Double filtering & degassing
10	Arc with Power Follow-Through	Discharges of High Energy	Double filtering & degassing
11	Unidentifiable	Thermal fault of medium Temperature 300–700 °C	Do Not use
12	Core and Tank Circulating Currents	Thermal fault of High Temperature – above 700 °C	Double filtering & degassing
13	Flashover without Power Follow-Through	Unidentifiable	Good Oil
14	General Conductor Overheating	Discharges of Low Energy	Single filtering & degassing
15	Core and Tank Circulating Currents	Thermal fault of High Temperature – above 700 °C	Single filtering & degassing
16	Arc with Power Follow-Through	Discharges of High Energy	Reclamation
17	Core and Tank Circulating Currents	Thermal fault of High Temperature – above 700 °C	Reclamation
18	Winding Circulating Currents	Thermal fault of medium Temperature 300–700 °C	Single filtering & degassing
19	Partial Discharge with Tracking	Partial Discharges of High Energy Density	Single filtering & degassing
20	Unidentifiable	Thermal fault of High Temperature – above 700 °C	Reclamation
21	Core and Tank Circulating Currents, overheated joints	Thermal fault of High Temperature – above 700 °C	Double filtering & degassing
22	Overheating – 150–200 °C	Unidentifiable	Good Oil
23	General Conductor Overheating	Discharges of Low Energy	Reclamation
24	General Conductor Overheating	Thermal fault of low temperature – below 150 °C	Good Oil
25	Flashover without Power Follow-Through	Unidentifiable	Single filtering & degassing
26	Unidentifiable	Thermal fault of medium Temperature 300–700 °C	Do Not use
27	Partial discharge	Partial Discharges of Low Energy Density	Double filtering & degassing
28	Slight Overheating - below 150 °C	Unidentifiable	Reclamation
29	Overheating – 150–200 °C	Thermal fault of low temperature – 150–300 °C	Do Not use
30	Unidentifiable	No Fault	Single filtering & degassing

5. Conclusion

We introduced a simple but accurate ANFIS Expert System to identify the type of fault and to assess the quality of insulating oil in power transformers. The DGA in oil, being the reliable method, was used for fault diagnosis and insulation oil quality evaluation. The Rogers ratio and the IEC ratio methods using DGA in oil were used where the software employed ANFIS through the MATLAB program. The expert system was found reliable for diagnosing faults and assessing the quality of insulating oil. The results are satisfactory based on their adherence to the specifications of the IEEE standard C57-104 and the IEC standard 60599. Thus, the software results can

be used by maintenance teams to rectify the occurrence of sudden faults that result in power disruption and economic loss. The nature of faults was accurately and efficiently detected and the oil replacement was determined as the output.

References

Anon. The J & P Transformer Book J & P Books.

Committee, T., Power, I., & Society, E. (2009). IEEE Std C57.104'-2008 (Revision of IEEE Std C57.104-1991). IEEE Guide for the Interpretation of Gases Generated in Oil-Immersed Transformers.

Foong, K. C., Chee, C. T., & Wei, L. S. (2009). *Adaptive network fuzzy inference system (ANFIS) handoff algorithm*. *International Conference on Future Computer and Communication, ICFCC, 1(2)*, 195–198.

Gao, N., Zhang, G. J., Qian, Z., Yan, Z., & Zhu, D. H. (1998). *Diagnosis of DGA based on fuzzy and ANN methods*. Proceedings of 1998 International Symposium on Electrical Insulating Materials. 1998 Asian International Conference on Dielectrics and Electrical Insulation. 30th Symposium on Electrical Insulating Ma.

Muhamad, N. A. et al. (2007). Comparative Study and Analysis of DGA Methods for Transformer Mineral Oil. *2007 IEEE Lausanne Power Tech*, 45–50. Retrieved from <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=4538290>

Nunes, D. S. I., Imamura, M. M., & Souza, A. N. D. (2000). *The application of neural networks to the analysis of dissolved gases in insulating oil used in transformers*. SMC 2000 conference proceedings. 2000 IEEE International Conference on systems, man and cybernetics. Cybernetics evolving to systems, humans, organizations, and their complex interactions, 4, 2643–2648.

Rogers, R. R. (1978). IEEE and IEC Codes to Interpret Incipient Faults in Transformers, Using Gas in Oil Analysis. *IEEE Transactions on Electrical Insulation*, 13(5), 349-354.

Sarma, D. V. S. S., & Kalyani, G. N. S. (2004). *Ann approach for condition monitoring of power transformers using DGA*. IEEE Region 10 Conference TENCON 2004, 444–447. Retrieved from <http://ieeexplore.ieee.org/lpdocs/epic03/wrapper.htm?arnumber=1414803>

Satyanarayana, K. V. et al. (2008). Application of Artificial Intelligence for the Assessment of the Status of Power Transformers, 104–107.

Shirkhodaie, A., Muthuswamy, S. K., & Saravanan, S. S. (1998). A Hybrid Neuro-Fuzzy Based Fault Diagnostic. *Technique for Bearings Condition-Based Maintenance*, 724.

Sun, X., Sun, X., Liang, Y., Lv, D., Liu, D., & Bian, J. (2010). *Application of Kernel C-means clustering and Dempster-Shafer theory of evidence in power transformers fault diagnosis*. Proceedings - 2010 7th International Conference on Fuzzy Systems and Knowledge Discovery, 3, 1060–1063.

Copyrights

Copyright for this article is retained by the author(s), with first publication rights granted to the journal.

This is an open-access article distributed under the terms and conditions of the Creative Commons Attribution license (<http://creativecommons.org/licenses/by/3.0/>).