

Electrical Harmonic Effects of Controlled System Switch's On-Off Angle, during Ferroresonance Events

Hilmi Zenk^{1,*}, A. Sefa Akpınar²

¹Vocational School of Technical Sciences, Giresun University, Gazipasa Campus, 28200, Giresun, Turkey

²Department of Electrical and Electronics Eng., Eng. Faculty, Karadeniz Technical University, Kanuni Campus, 61000, Trabzon, Turkey

*Corresponding Author: hzenk@msn.com

Copyright © 2014 Horizon Research Publishing All rights reserved.

Abstract Power transmission and distribution, system reliability, and to provide the basis for the protection of electrical equipment is important. The Transformers in the power system is one of the most widely used elements. Transformers working in the linear region with a yield of electromagnetic energy provide a high rate conversion. However, with the onset of saturation of the transformer ferromagnetic core begins to fall due to the efficiency of energy conversion losses start to increase. Any power system elements constituting a sudden ferroresonance are enough potential for the realization of the event. These elements of the transformer inductance and non-linear loads can be summarized in the resistance and capacitance. In this study, high-voltage transmitter to the controlled switched my order to make semiconductor power electronic switching elements connected with the resistance and capacitance cargoes including ferroresonance instantly switches opening and closing built resonance will occur in the electrical events, actual circuit conditions were investigated.

Keywords Voltage Transformer, Ferroresonance, Overvoltage, Harmonics, Circuit Breaker Switch On-Off Angle Position (SAP), FFT Analysis

1. Introduction

In recent years, the rapidly growing energy needs and, in parallel, rising energy prices and environmental factors such as pollution, renewable energy sources and in particular to people in proportion more efficient use of the energy produced is headed. Renewable resources is continuous and does not cause environmental pollution in this area has attracted the attention of many researchers. However, if the energy produced in whatever way you produced, reducing losses and improving the quality of power is an area that is always worth working on.

Determines of the power quality their basic components, electrical energy supply continuity, frequency, voltage effective value of the voltage transient period occurs because

the pits and hills, sudden voltage changes between phases unbalance, voltage and current waveforms that occur in harmonics and flicker as listed [1].

Electric power generation, transmission and distribution is a very complicated process. Transmission line; generators, transformers, capacitors, there are loads of protection elements. In such a transmission system, the presence of such elements or some malfunction of the circuit in the event of different work situation can cause various physical events [2]. One of these events, many researchers focus on is the Ferroresonance event. Transformer in a power system where you will also remain disabled even with some of the load groups or Ferroresonance can occur with very little loading [3]. Ferroresonance has a wide variety of events, generally iron-core coil with saturable occurring between capacitors known as nonlinear resonance condition [4].

In the case of Ferroresonance, overvoltage and very irregular wave patterns revealing these cases, one or more may be saturated inductance in series are often stimulated by the co-located with capacitive circuit occurs [5]. Power transformers, reactors, transformers and electromagnetic voltage measurement will be effective until the system is inherently included in the system which is in close proximity capacitive elements occurs between [6]. Ferroresonance in electric power systems are known for many years that the event has occurred. Ferroresonance to understand and analyze a variety of models are used[7]. Hayashi almost periodic solutions of nonlinear differential equations to do is to use the harmonic balance method [8]. Depending on the frequency content of the fluctuations normally harmonic ferroresonance basic, sub-harmonic, quasi-periodic and can be classified as irregular ferroresonance [9]. In this study, a single-phase system on the high-voltage instrument transformers with a real ferroresonance event which is formed, the system's electrical parameters were analyzed and the results interpreted and ferroresonance effect consisting of the various current and voltage waveforms are analyzed. In addition, the same system in Matlab/Simulink was created as a virtual digital environment, again mentioned parameters were examined and comparing this with the results of real circuits. The effect of power systems Ferroresonance

transformers, transmission lines and can be devastating on all equipment [10]. Because ferroresonance events occurring on the system during the nominal voltage surge may reach levels about three times [11].

2. Ferroresonance Equivalent Circuit Model

Figure 1 in the non-linear inductance and parallel resistance are shown in parallel with the transformer.




Figure 1. Ferroresonance Analysis of RC Circuit Models

Hysteresis losses are neglected, so the total iron loss resistance shows. The core of the non-linearity is given in equation (1).

$$i_m = a\lambda + b\lambda^n \quad (1)$$

C capacitor, supply voltage and frequency are affected. Source voltage,

$$v(t) = V_{\max} \cos(\omega_f t) \quad (2)$$

is defined by the expression. Duffing, resonance, sub-and super altrezonans resonance of the first researchers who work on issues and evidence given by equation (3) can be likened to the Duffing oscillator [12-16]. In equations "n" indicates the degree of expression magnetization.

$$\lambda + k\lambda + a_1\lambda + b_1\lambda^n = G \cos(\omega_f t) \quad (3)$$

The other parameters of the equation, k, a1, b1 and G equations (4-7), respectively.

$$a_1 = a/C \quad (4)$$

$$b_1 = b/C \quad (5)$$

$$G = V_{\max} \omega_f t \quad (6)$$

$$k = 1/RC \quad (7)$$

3. Designed System Model

Models of the computer system and the actual system designed using the same parameters in this section are

individually designed.

3.1. Matlab/Simulink Model

Power system modeling using Matlab / Simulink is used. In this study asarlan ferroresonance event that occurs on the system in Matlab / Simulink simulation was performed in the circuit model shown in Figure 2.




Figure 2. Ferroresonance Circuit Simulink Models

The parameters of the voltage transformer used in the circuit is shown in Table I.

Table 1. The parameters of voltage transformer

Nominal Power	P _n	860 VA
Frequency	f _n	50 Hz
Winding 1	V ₁ (rms)	220 V
Winding 1	R ₁ (pu)	0,002
Winding 1	L ₁ (pu)	0,08
Winding 2	V ₂ (rms)	31500
Winding 2	R ₂ (pu)	0,002
Winding 1	L ₂ (pu)	0,08
Saturation Char.	i _n (pu)	φ _n (pu)
n=1	0	0
n=2	0,0	0,85
n=3	0,015	1,2
n=4	0,03	1,35
n=5	0,06	1,5
n=6	0,09	1,56
n=7	0,12	1,572

3.2. Real-Circuit Model

Designed as the first element in the system, the mains voltage is logged and the system should be replaced when the voltage level of the AC voltage supply circuit is prepared for the adjustment. The purpose of this circuit is used, the actual voltage levels of the circuit to ensure operation of the second voltage transformer primary to provide a first transformer to the ends of the standard voltage is controlling. Designed for high voltage transformer isolated and regulated power supply circuit in Figure 3 is given.



Figure 3. Isolated and regulated power supply circuit

The first voltage transformer, booster transformer (T_1) was used. T_1 analyzed for the purpose of using ferroresonance second voltage transformer (T_2) in the actual system voltage insulation is to keep running and circuits. T_2 obtained after the high voltage of 31.5 kV Ferroresonance circuit of the second voltage transformer primary is connected to the ends to the ends that the AB. The second voltage transformer ferroresonance event is tested and the main system components. The secondary of the second voltage transformer with the first two corners, at the ends 110V 1a-1b, 2a-2b and the second of its ends, which is measured at 220V. So the second voltage transformer voltage will be used as stepdown.



Figure 4. System Used in Voltage Transformer and Connections.

3.3. On-Off Angle Control System (ACS)

Angle control system, the microcontroller is controlled by a power electronic circuit switch, connects the phase voltage measured and the desired phase angle a keypad

entered with switch-on or switch-off function which is a system.

This system firstly Figure 5 as seen in the circuit produced with the aid of the sampling point, is sent to one of input ports of the microcontroller. Sampling the form of a square wave signal at the output of the circuit is embedded in the program and not the mark of a variable defined time to start counting results.




Figure 5. Sampling Circuit.

Figure 6 in terms of switching control system block diagram is shown. Figure 7 in the supply voltage to the load is connected MACS connecting key generates a shutdown signal with a delay of 90 electrical degrees seen. The same circuit breaker switch with a delay of 30 degrees to produce the trip signal is observed.




Figure 6. Switching angle control system block diagram.




Figure 7. Voltage and Current Sensor Circuits.

Several key points of the system for measurement of electrical parameters of Figure 8 seen in current and voltage as hall-effect sensors are used.




Figure 8. Voltage and Current Sensor Circuits.

The sensor outputs data in the DAQ-PCI-6221 data collected from the system by the transmission device and located at certain points of the system controlled on-off

switch at the desired angle to do is send the control signals. Computer-controlled on-off angle control system (CACS) block diagram is shown in figure 9.




Figure 9. Voltage and Current Sensor Circuits.

Ferroresonance first event with this system through the computer monitoring, data recording in the user wants, then the system will react in different closing angles has been observed. All of the design of the system, the main block diagram of Figure 10 seen from.




Figure 10. All the main block diagram of the system

4. System Simulation and Real-Time Results

4.1. System Simulink Model Results

Figure 11 at 33 kV system, the voltage time curve is observed. In closed position switch voltage of capacitor (Vca) 200 milliseconds were measured.




Figure 11. Voltage of C_a capacitor (V_{ca})

In Figure 4 typical ferroresonance voltage graph is shown. Following the opening and closing of the switch to make changes in the system parameters shown 0.2 seconds.




Figure 12. Some of the electrical parameters of the transformer change.

The model of the FFT analysis for the C_a capacity is given in the chart in figure 13. As will be seen from the

chart, there are regions of high frequency during starting. Here, near normal or low frequency region around 12 kV while there are 3-6 kV high frequencies in the band 25-35 kHz were observed.




Figure 13. Ferroresonance case C_a capacitor FFT analysis

Analyzing figure 14 shows a diagram of transformer input voltage (e_1) is derived from. In the chart, his on-off switch regions is natural that during the high-voltage on-off voltage, then returned to the pre-condition that has been shown to return between 5-6 kV. However, the sudden closing time of rising tension will damage the components on the system, which leads indeed is a serious malfunction.




Figure 14. Ferroresonance case input voltage (e_1) FFT analysis.

In figure 15 the frequency of the voltage applied to input transformers analysis chart is shown.

As can be seen from the chart 15-16 kV voltage level of high frequency components during the initial steady state shows the frequency at which to get. The voltage and frequency ranges to be considered together.

4.2. Real System Model Results

In Figure 16 typical on real system ferroresonance - voltage graph is shown. Following the opening and closing of the switch to make changes in the system parameters shown 0.2 seconds.




Figure 15. Ferroresonance case input voltage (e1) FFT analysis.




Figure 16. Some of the electrical parameters of the transformer change.

The model of the FFT analysis for the C_a capacity is given in the chart in figure 17. As will be seen from the chart, there are regions of high frequency during starting. Here, near normal or low frequency region around 12 kV while there are 2-4 kV high frequencies in the band 27-37 kHz were observed.

Analyzing figure 18 shows a diagram of transformer input voltage (e_1) is derived from. In the chart, his on-off switch regions is natural that during the high-voltage on-off voltage, then returned to the pre-condition that has been

shown to return between 2,5-3,5 kV. However, the sudden closing time of rising tension will damage the components on the system, which leads indeed is a serious malfunction.




Figure 17. Ferroresonance case C_a capacitor FFT analysis




Figure 18. Ferroresonance case input voltage (e1) FFT analysis.




Figure 19. Ferroresonance case e_1 voltage FFT analysis.

In figure 19 the frequency of the voltage applied to input transformers analysis chart is shown. As can be seen from the chart 4-6 kV voltage level of high frequency components during the initial steady state shows the frequency at which to get. The voltage and frequency ranges to be considered together.

5. System Switch Positions Effect

To understand the impact of circuit breaker positions in the real system is connected to switches as desired measure the voltage of the phase conductor with an electrical delay closing (ON) or open (OFF) process operate. As a result of this process is affected by how ferroresonance are described. The circuit breaker switch 30° as in the opening angle, closing angle, and 60° a number of times with the result obtained when switching is given.

Sensor circuits experimental system, is prepared, ferroresonans circuits, IGBT switches and drive circuits symmetrical DC supply source, the measurement panel, such as segments forming system is shown in Figure 20.




Figure 20. A general view of the entire system

Figure 21 in the closing-opening signal to the electronic key with the key generated by the PWM signal is observed. Similarly in figure 22 TR1 transformer some parameters graph is shown.




Figure 21. a) Random signals from the operator, MACS controlled closing-opening angle signal generating block, b) MACS block, which produces angle-controlled signals. According to the power supply seems to be closing 30° opening 60° .




Figure 22. TR1 transformer electrical parameters of the change.




Figure 23. TR2 transformer electrical parameters of the change.

Following the opening and closing of the switch to make changes in the system parameters shown 0.2 seconds. Circuit breaker switch ON-OFF operation of the random in his extreme elevations in these times of unprecedented signal causes the current value of these transactions has decreased is the time to have done recently.

Figure 23 and TR2 of the voltage transformer, Magnetic

Flux, magnetizing current, etc very parameters. In a similar manner to the TR1 here breaker switches to the OFF position instantly more normal state of all parameters, which rises up to 3 times.

In the conditions described above in figure 24, step down transformers in the system in which the on-off hysteresis exchange is formed. When examined in detail here the hysteresis loop, the inner loop can be seen. This small inner loop of the harmonics in the voltage signal, the peak in the current signal can be said that the reason that the current signs.




Figure 24. TR2 voltage, hysteresis loop.

6. Conclusion

In this study, modeled and implemented in systems consisting of the harmonics of these analyzes were analyzed and results were analyzed separately. In the analysis on a high-voltage instrument transformers together with formation of high-frequency components are ferroresonance has emerged. On the system frequency of 50 Hz is outside the high-frequency components. This voltage and high frequency changes are disruptive to the system. This study also practical simulation curves with the curves gives the possibility to compare.

Energy-carrying systems, which have devastating effects ferroresonance event, the impact on a single-phase system was investigated. In this study, a 33 kV transmission system Ferroresonance event Matlab/Simulink modeling with the program and establishing a real comparison of models is provided.

FFT analysis of harmonics that occur in the system modeling been done and the results of these analyzes also are evaluated. Whether on energy systems in the analysis consists ferroresonance With the high frequency components have emerged.

Switch opening and closing cycle is completed with the next FFT analysis in the range of 3-6 kV voltage, high-frequency component at the level of 5-7 kHz who is

dominant. Wherein the particular frequency contained study is shown. Very high amplitude on the frequency to 5kHz, although there are very few seen. These frequencies are likely to be inter-harmonics. With Ferroresonance event has occurred on the system frequency of 50 Hz is in excess of the high frequency components.

Simulation and genuineness of the closing-opening angle on the system control and the results were similar in terms of opening and closing of the system when it is the smallest mark to be made, it is concluded that.

REFERENCES

- [1] Akpinar-S, Nasar-SA, Harmonic Balance Analysis of the Subharmonic Ferroresonance, *Electric Machines And Power Systems*, Vol.18, pp.409-428, 1990.
- [2] E. Barbisio, O Bottauscio, M. Chiampi, G. Crotti, D. Giordano, Parameters Affecting Ferroresonance in LCR Electric Circuits, *IEEE Transactions On Magnetics*, Vol.44, No.6, June, 2008.
- [3] K.Al-Anbarri, R. Ramanujam, , CH. S. Rao, K. Kuppusamy, Effect of Circuit Configurad On on Chaotic Ferroresonance in Power in a Power Transformer, *Electric Power Components and Systems*, 30 pp. 1015-1031, 2002.
- [4] P. Ferracci, Ferroresonance Cahier Technique Schneider, Vol.190, 1998.
- [5] M. R. Irvani, Modelling and Analysis Guidelines for Slow Transients – Part: The Study of Ferroresonance. *IEEE Transactions on Power Delivery*, Vol.15, No.1, pp.255-265, 2000.
- [6] Y.K. Tong, NGC Experience on Ferroresonance in Power Transformers on HV Transmission Systems. *IEE, Savoy Place, IEE Colloquium on Warning, Ferroresonance Can Damage Your Plant Londra*, 1997.
- [7] T. Ta-Peng and N. Chia-Ching, Analysis of Ferroresonant Overvoltages at Maanshan Nuclear Power Station in Taiwan, *IEEE Transactions On Power Delivery*, Vol.21, No.2, pp.1006-1012, April 2006.
- [8] D.A. Jacobson, D.R. Swatek, R.W. Mazur, Mitigating Potential Transformer Ferroresonance in a 230kV Converter Station, *Computer Analysis of Electric Power System Transients: Selected Readings*. IEEE Press. Pp.359-365, 1997.
- [9] A.M. Haşimov, A. Nayir, Y.V. Dimitriyev, Uzun Enerji İletim Hatlarında Yüksek Harmonikli Ferrerezonans Aşırı Gerilimlerinden Korunma, *Yıldız Teknik Üniversitesi Dergisi*, Vol.2, pp.19-24, 2001.
- [10] R.G. Kavasseri, Analytical Prediction of Subharmonic Oscilations in a Ferroresonant Circuit, *Proc. 35th North American Power Symposium*, Rolla, Missouri, October 2003.
- [11] A.H. Nayfeh, *Introduction to Perturbation Techniques*. John Wiley and Sons, 1981.
- [12] T. Ç. Akıncı, G. Morkyani, G. Gökmen, N. Ekren, S. Şeker, Analysis Of Ferroresonance On Single Phase Line Model, 5.

- Uluslararası İleri Teknolojiler Sempozyumu (IATS'09), 13-15 May. 2009, Karabük, Turkey.
- [13] Ö. Kara, M. Bağrıyanık, Ferrerezonansin Anlaşılması Ve Transformatör Merkezlerinde Yapılan Kompanzasyonun Ferrerezonans Üzerindeki Etkileri.
- [14] A. Nayır, Research And Protection Of Energy Transmission Lines From The Ferrerezonance Overvoltages, Journal of Engineering and Natural Sciences, Sigma 29, pp.138-147, 2011.
- [15] H. Zenk, A. S. Akpınar, High Voltage Instrument Transformers Ferrerezonance Events Occurring In The Investigation Of The Circuit Breaker Switch Positions, Electrical and Electronic Engineering, Vol.4, No.1, February, 2014.
- [16] Türkiye Elektrik İletim A.Ş., Online available from <http://www.guckalitesi.gen.tr/tr/root/index.php>