

Exact Convex Relaxation of Optimal Power Flow in Radial Networks

Lingwen Gan, Na Li, Ufuk Topcu, and Steven H. Low

Abstract

The optimal power flow (OPF) problem determines power generation/demand that minimize a certain objective such as generation cost or power loss. It is nonconvex. We prove that, for radial networks, after shrinking its feasible set slightly, the global optimum of OPF can be recovered via a second-order cone programming (SOCP) relaxation under a condition that can be checked a priori. The condition holds for the IEEE 13-, 34-, 37-, 123-bus networks and two real-world networks, and has a physical interpretation.

I. INTRODUCTION

The optimal power flow (OPF) problem determines power generations/demands to minimize a certain objective such as generation cost or power loss. It has been one of the fundamental problems in power system operation since it was proposed in 1962 [1]. The OPF problem is increasingly important for distribution networks due to the advent of distributed generation (e.g., rooftop photovoltaic panels) and controllable loads (e.g., electric vehicles). Distributed generation is difficult to predict, calling the traditional “generation follows demand” strategy into question. Meanwhile, controllable loads provide significant potential to compensate for the randomness in distributed generation. To achieve this, solving the OPF problem in real-time is inevitable. Distribution networks are usually radial (with a tree topology).

The OPF problem is difficult to solve due to the nonconvex physical laws that govern power flow, and there are in general three ways to deal with this challenge: (i) linearize the power flow laws; (ii) look for local optima of the OPF problem; and (iii) convexify power flow laws, which are described in turn.

The power flow laws can be approximated by linear equations known as the DC power flow model [2]–[4], if 1) line resistances are small; 2) voltages are near their nominal values; and 3) voltage angle differences between adjacent buses are small. With DC power flow model, the OPF problem reduces to a linear program. This method is widely used in practice for transmission networks and often quite effective, but does not apply to distribution

This work was supported by NSF NetSE grant CNS 0911041, ARPA-E grant de-ar0000226, Southern California Edison, National Science Council of Taiwan, R.O.C, grant NSC 103-3113-P-008-001, Resnick Institute, and AFOSR award number FA9550-12-1-0302.

Lingwen Gan, Na Li, and Steven H. Low are with the Engineering and Applied Science Department, California Institute of Technology, Pasadena, CA 91125 USA (e-mail: lgan@caltech.edu).

Ufuk Topcu is with the Electrical and Systems Engineering Division, University of Pennsylvania, Philadelphia, PA 19104 USA.

networks where line resistances are high and voltages deviate significantly from their nominal values. This method also does not apply to problems where reactive power flow or voltage deviations need to be optimized explicitly, e.g., power routing with FACTS devices [5] and Volt/VAR control [6].

Various algorithms have been developed to find local optima of the OPF problem, e.g., successive linear/quadratic programming [7], trust-region based methods [8], [9], Lagrangian Newton method [10], and interior-point methods [11]–[13]. Some of these algorithms, especially the Newton-Ralphson based ones, are quite successful empirically, but in general, these algorithms are not guaranteed to convergence, nor converge to (nearly) optimal solutions.

There are two types of convex relaxations of the OPF problem: semidefinite programming (SDP) relaxations and second-order cone programming (SOCP) relaxations. It is proposed in [14], [15] to transform the nonconvex power flow constraints into linear constraints on a rank-one positive semidefinite matrix, and then remove the rank-one constraint to obtain an SDP relaxation. If the solution of the SDP relaxation is feasible for the OPF problem, then a global optimum of the OPF problem can be recovered. The SDP relaxation is called *exact* in this case. Strikingly, the SDP relaxation is exact for the IEEE 14-, 30-, 57-, and 118-bus networks [15], and a more recent study on the computational speed and exactness of the SDP relaxation can be found in [16]. Different SOCP relaxations have been proposed for different models, first in [17] for a branch flow model in polar coordinate, then in [18], [19] for a branch flow model due to [20], [21], and in [22] for a bus injection model. In this paper we focus on the SOCP relaxation proposed in [18], [19] and prove a sufficient condition for the relaxation to be exact. For radial networks, SOCP relaxation and SDP relaxation are equivalent in the sense that there is a bijection between their feasible sets [23]. Hence one should always solve SOCP relaxation instead of SDP relaxation for radial networks since the former has a much lower computational complexity.

SDP/SOCP relaxations are in general not exact and counterexamples can be found in [24]. Significant amount of work has been devoted to finding sufficient conditions under which these relaxations are exact for radial networks; see [?] for a survey. For *AC radial* networks, these conditions roughly fall into three categories:

- 1) The power injection constraints satisfy certain patterns [18], [19], [22], [25]–[28], e.g., there are no lower bounds on the power injections (load over-satisfaction). This sufficient condition, first proved in [26] and subsequently generalized in [28], includes as special cases the load over-satisfaction condition in [18], [19], [22], [25] and in [29, Theorem 7], as well as the sufficient condition in [27, Theorem 2].
- 2) The phase angle difference across each line is bounded in terms of its r/x ratio [27], [29], [30]. When the voltage magnitude is fixed this condition provides a nice geometric insight on why convex relaxations are exact.
- 3) The voltage upper bounds are relaxed plus some other conditions [31], [32]. The main result in this paper generalizes and unifies this set of sufficient conditions; see Section V.

Summary of contributions

The goal of this paper is to show that in radial networks, the SOCP relaxation is exact under a mild condition that can be checked a priori, after modifying the OPF problem. In particular, contributions of this paper are threefold.

First, we prove that *if optimal power injections lie in a region where voltage upper bounds do not bind, then the SOCP relaxation is exact under a mild condition*. The condition can be checked a priori and holds for the IEEE 13-, 34-, 37-, 123-bus networks and two real-world networks. The condition has a physical interpretation: it follows from the physical intuition that all upstream reverse power flows should increase if the power loss on a line is reduced. Second, we *modify the OPF problem by imposing additional constraints on power injections*. The modification ensures the exactness of the SOCP relaxation under the aforementioned condition, while only eliminating feasible points that are close to voltage upper bounds. A modification is necessary to ensure an exact SOCP relaxation since otherwise examples exist where the SOCP relaxation is not exact. Third, *this paper unifies and generalizes the results in [31], [32]*.

The rest of this paper is organized as follows. The OPF problem and the SOCP relaxation are introduced in Section II. In Section III, a sufficient condition that guarantees the exactness of the SOCP relaxation is provided. The condition consists of two parts: C1 and C2. C2 cannot be checked a priori, hence in Section IV, we propose a modified OPF problem whose corresponding SOCP is exact under C1. We compare C1 with prior works in Section V and present case studies in Section VI.

II. THE OPTIMAL POWER FLOW PROBLEM

This paper studies the optimal power flow (OPF) problem in distribution networks, which includes Volt/VAR control and demand response as special cases. In the following we present a model that incorporates nonlinear power flow and a variety of controllable devices including distributed generators, inverters, controllable loads, and shunt capacitors.

A. Power flow model

A distribution network is composed of buses and lines connecting these buses, and usually has a tree topology. The root of the tree is a *substation bus* that is connected to the transmission network. It has a fixed voltage and redistributes the bulk power it receives from the transmission network to other buses. Index the substation bus by 0 and the other buses by $1, \dots, n$. Let $\mathcal{N} := \{0, \dots, n\}$ denote the collection of all buses and define $\mathcal{N}^+ := \mathcal{N} \setminus \{0\}$. Each line connects an ordered pair (i, j) of buses where bus j lies on the unique path from bus i to bus 0. Let \mathcal{E} denote the collection of all lines, and abbreviate $(i, j) \in \mathcal{E}$ by $i \rightarrow j$ whenever convenient.

For each bus $i \in \mathcal{N}$, let V_i denote its complex voltage and define $v_i := |V_i|^2$. Specifically the substation voltage v_0 is given and fixed. Let $s_i = p_i + \mathbf{i}q_i$ denote the power injection of bus i where p_i and q_i denote the real and reactive power injections respectively. Let \mathcal{P}_i denote the path (a collection of buses in \mathcal{N} and lines in \mathcal{E}) from bus i to bus 0. For each line $(i, j) \in \mathcal{E}$, let $z_{ij} = r_{ij} + \mathbf{i}x_{ij}$ denote its impedance. Let I_{ij} denote the complex current from bus i to bus j and define $\ell_{ij} := |I_{ij}|^2$. Let $S_{ij} = P_{ij} + \mathbf{i}Q_{ij}$ denote the sending-end power flow from bus i to bus j where P_{ij} and Q_{ij} denote the real and reactive power flow respectively. Some of the notations are summarized in Fig. 1. We use a letter without subscripts to denote a vector of the corresponding quantities, e.g., $v = (v_i)_{i \in \mathcal{N}^+}$,

$\ell = (\ell_{ij})_{(i,j) \in \mathcal{E}}$. Note that subscript 0 is not included in nodal quantities such as v and s . For a complex number $a \in \mathbb{C}$, let \bar{a} denote the conjugate of a .




Fig. 1. Some of the notations.

Given the network graph $(\mathcal{N}, \mathcal{E})$, the impedance z , and the substation voltage v_0 , then the other variables (s, S, v, ℓ, s_0) are described by the *branch flow model*:

$$S_{ij} = s_i + \sum_{h: h \rightarrow i} (S_{hi} - z_{hi} \ell_{hi}), \quad \forall (i, j) \in \mathcal{E}; \quad (1a)$$

$$0 = s_0 + \sum_{h: h \rightarrow 0} (S_{h0} - z_{h0} \ell_{h0}); \quad (1b)$$

$$v_i - v_j = 2\text{Re}(\bar{z}_{ij} S_{ij}) - |z_{ij}|^2 \ell_{ij}, \quad \forall (i, j) \in \mathcal{E}; \quad (1c)$$

$$\ell_{ij} = \frac{|S_{ij}|^2}{v_i}, \quad \forall (i, j) \in \mathcal{E} \quad (1d)$$

for radial networks [21], [33].

B. The OPF problem

We consider the following controllable devices in a distribution network: distributed generators, inverters, controllable loads such as electric vehicles and smart appliances, and shunt capacitors. Real and reactive power generation/consumption of these devices can be controlled to achieve certain objectives. For example, in Volt/VAR control, reactive power injection of inverters and shunt capacitors are controlled to regulate voltages; in demand response, real power consumption of controllable loads is reduced or shifted in response to power supply conditions. Mathematically, power injection s is the control variable, after specifying which the other variables (S, v, ℓ, s_0) are determined by the power flow laws in (1).

The power injection s_i of a bus $i \in \mathcal{N}^+$ is constrained to be in an pre-specified set \mathcal{S}_i , i.e.,

$$s_i \in \mathcal{S}_i, \quad i \in \mathcal{N}^+. \quad (2)$$

The set \mathcal{S}_i for some controllable devices are:

- If s_i represents a shunt capacitor with nameplate capacity \bar{q}_i , then $\mathcal{S}_i = \{s \in \mathbb{C} \mid \text{Re}(s) = 0, \text{Im}(s) = 0 \text{ or } \bar{q}_i\}$. Note that \mathcal{S}_i is nonconvex and disconnected in this case.
- If s_i represents a solar panel with generation capacity \bar{p}_i , that is connected to the grid through an inverter with nameplate capacity \bar{s}_i , then $\mathcal{S}_i = \{s \in \mathbb{C} \mid 0 \leq \text{Re}(s) \leq \bar{p}_i, |s| \leq \bar{s}_i\}$.

- If s_i represents a controllable load with constant power factor η , whose real power consumption can vary continuously from $-\bar{p}_i$ to $-\underline{p}_i$ (here $\underline{p}_i \leq \bar{p}_i \leq 0$), then $\mathcal{S}_i = \left\{ s \in \mathbb{C} \mid \underline{p}_i \leq \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) = \sqrt{1 - \eta^2} \text{Re}(s)/\eta \right\}$.

Note that s_i can represent the aggregate power injection of multiple such devices with an appropriate \mathcal{S}_i , and that the set \mathcal{S}_i is not necessarily convex or connected.

An important goal of control is to regulate the voltages within a range. This is captured by pre-specified voltage lower and upper bounds \underline{v}_i and \bar{v}_i (in per unit value), i.e.,

$$\underline{v}_i \leq v_i \leq \bar{v}_i, \quad i \in \mathcal{N}^+. \quad (3)$$

For example, if 5% voltage deviation from nominal values is allowed, then $0.95^2 \leq v_i \leq 1.05^2$. We consider the control objective

$$C(s, s_0) = \sum_{i \in \mathcal{N}} f_i(\text{Re}(s_i)) \quad (4)$$

where $f_i : \mathbb{R} \rightarrow \mathbb{R}$ denotes the generation cost at bus i for $i \in \mathcal{N}$. If $f_i(x) = x$ for $i \in \mathcal{N}$, then C is the total power loss in the network.

The OPF problem seeks to minimize the generation cost (4), subject to power flow constraint (1), power injection constraint (2), and voltage constraint (3):

$$\mathbf{OPF:} \quad \min \sum_{i \in \mathcal{N}} f_i(\text{Re}(s_i))$$

over s, S, v, ℓ, s_0

$$\text{s.t.} \quad S_{ij} = s_i + \sum_{h: h \rightarrow i} (S_{hi} - z_{hi} \ell_{hi}), \quad \forall (i, j) \in \mathcal{E}; \quad (5a)$$

$$0 = s_0 + \sum_{h: h \rightarrow 0} (S_{h0} - z_{h0} \ell_{h0}); \quad (5b)$$

$$v_i - v_j = 2\text{Re}(\bar{z}_{ij} S_{ij}) - |z_{ij}|^2 \ell_{ij}, \quad \forall (i, j) \in \mathcal{E}; \quad (5c)$$

$$\ell_{ij} = \frac{|S_{ij}|^2}{v_i}, \quad \forall (i, j) \in \mathcal{E}; \quad (5d)$$

$$s_i \in \mathcal{S}_i, \quad i \in \mathcal{N}^+; \quad (5e)$$

$$\underline{v}_i \leq v_i \leq \bar{v}_i, \quad i \in \mathcal{N}^+. \quad (5f)$$

The following assumptions are made on OPF throughout this work.

- A1 The network $(\mathcal{N}, \mathcal{E})$ is a tree. Distribution networks are usually radial networks.
- A2 The substation voltage v_0 is fixed and given. In practice, v_0 can be modified several times a day, and therefore can be considered as a given constant at the minutes timescale of OPF.
- A3 Line resistances and reactances are strictly positive, i.e., $r_{ij} > 0$ and $x_{ij} > 0$ for $(i, j) \in \mathcal{E}$. In practice, $r_{ij} > 0$ since lines are passive (consume power), and $x_{ij} > 0$ since lines are inductive.
- A4 Voltage lower bounds are strictly positive, i.e., $\underline{v}_i > 0$ for $i \in \mathcal{N}^+$. In practice, \underline{v}_i is slightly below 1p.u..

The equality constraint (5d) is nonconvex, and one can relax it to inequality constraints to obtain the following second-order cone programming (SOCP) relaxation [18], [19]:

$$\begin{aligned}
\mathbf{SOCP:} \quad & \min \sum_{i \in \mathcal{N}} f_i(\text{Re}(s_i)) \\
& \text{over } s, S, v, \ell, s_0 \\
& \text{s.t. (5a) – (5c), (5e) – (5f);} \\
& \ell_{ij} \geq \frac{|S_{ij}|^2}{v_i}, \quad \forall (i, j) \in \mathcal{E}.
\end{aligned} \tag{6}$$

Note that SOCP is not necessarily convex, since we allow f_i to be nonconvex for some $i \in \mathcal{N}$ and S_i to be nonconvex for some $i \in \mathcal{N}^+$. Nonetheless, we call it SOCP for brevity.

If an SOCP solution $w = (s, S, v, \ell, s_0)$ is feasible for OPF, i.e., w satisfies (5d), then w is a global optimum of OPF. This motivates the following definition of *exactness* for SOCP.

Definition 1. *SOCP is exact if every of its solutions satisfies (5d).*

III. A SUFFICIENT CONDITION

We provide a sufficient condition that ensures SOCP to be exact in this section. This condition is composed of two parts: C1 and C2. C1 is a mild condition that only depends on SOCP parameters. It follows from the physical intuition that all upstream reverse power flows should increase if the power loss on a line is reduced. C2 depends on SOCP solutions and cannot be checked a priori, but motivates us to modify OPF such that the corresponding SOCP is exact under C1. The modified OPF problem will be discussed in Section IV.

A. Statement of the condition

We start with introducing the notations that will be used in the statement of the condition. One can ignore the ℓ terms in (1a) and (1c) to obtain the *Linear DistFlow Model* [21], [33]

$$\begin{aligned}
S_{ij} &= s_i + \sum_{h: h \rightarrow i} S_{hi}, \quad \forall (i, j) \in \mathcal{E}; \\
v_i - v_j &= 2\text{Re}(\bar{z}_{ij} S_{ij}), \quad \forall (i, j) \in \mathcal{E}.
\end{aligned}$$

Let (\hat{S}, \hat{v}) denote the solution of the Linear DistFlow model, then

$$\begin{aligned}
\hat{S}_{ij}(s) &= \sum_{h: i \in \mathcal{P}_h} s_h, \quad \forall (i, j) \in \mathcal{E}; \\
\hat{v}_i(s) &:= v_0 + 2 \sum_{(j,k) \in \mathcal{P}_i} \text{Re}(\bar{z}_{jk} \hat{S}_{jk}(s)), \quad \forall i \in \mathcal{N}
\end{aligned}$$

as in Fig. 2. Physically, $\hat{S}_{ij}(s)$ denote the sum of power injections s_h towards bus 0 that go through line (i, j) . Note that $(\hat{S}(s), \hat{v}(s))$ is affine in s , and equals (S, v) if and only if line loss $z_{ij}\ell_{ij}$ is 0 for $(i, j) \in \mathcal{E}$. For two complex numbers $a, b \in \mathbb{C}$, let $a \leq b$ denote $\text{Re}(a) \leq \text{Re}(b)$ and $\text{Im}(a) \leq \text{Im}(b)$. For two vectors a, b of the same dimension, $a \leq b$ denotes componentwise inequality. Define $<$, $>$, and \geq similarly.




Fig. 2. Illustration of \hat{S}_{ij} and \hat{v}_i . The shaded region is downstream of bus i , and contains the buses $\{h : i \in \mathcal{P}_h\}$. Quantity $\hat{S}_{ij}(s)$ is defined to be the sum of bus injections s in the shaded region. The dashed lines constitute the path \mathcal{P}_i from bus i to bus 0. Quantity $\hat{v}_i(s)$ is defined as v_0 plus the terms $2\text{Re}(\bar{z}_{jk}\hat{S}_{jk}(s))$ over the dashed path.

Lemma 1. *If (s, S, v, ℓ, s_0) satisfies (1a)–(1c) and $\ell \geq 0$ componentwise, then $S \leq \hat{S}(s)$ and $v \leq \hat{v}(s)$.*

Lemma 1 implies that $\hat{v}(s)$ and $\hat{S}(s)$ provide upper bounds on v and S . The lemma is proved in Appendix A. Let $\hat{P}(s)$ and $\hat{Q}(s)$ denote the real and imaginary part of $\hat{S}(s)$ respectively. Then

$$\begin{aligned} \hat{P}_{ij}(s = p + \mathbf{i}q) &= \hat{P}_{ij}(p) = \sum_{h: i \in \mathcal{P}_h} p_h, & (i, j) \in \mathcal{E}; \\ \hat{Q}_{ij}(s = p + \mathbf{i}q) &= \hat{Q}_{ij}(q) = \sum_{h: i \in \mathcal{P}_h} q_h, & (i, j) \in \mathcal{E}. \end{aligned}$$

Assume that there exists \bar{p}_i and \bar{q}_i such that

$$\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) \leq \bar{q}_i\}$$

for $i \in \mathcal{N}^+$ as in Fig. 3, i.e., $\text{Re}(s_i)$ and $\text{Im}(s_i)$ are upper bounded by \bar{p}_i and \bar{q}_i respectively. Note that we do *not*




Fig. 3. We assume that \mathcal{S}_i lies in the left bottom corner of (\bar{p}_i, \bar{q}_i) , but do not assume that \mathcal{S}_i is convex or connected.

assume \mathcal{S}_i to be convex or connected. Define $a^+ := \max\{a, 0\}$ for $a \in \mathbb{R}$, let $I := \text{diag}(1, 1)$ denote the 2×2 identity matrix, and define

$$u_i := u_{ij} := \begin{pmatrix} r_{ij} \\ x_{ij} \end{pmatrix}, \quad \underline{A}_i := \underline{A}_{ij} := I - \frac{2}{\underline{v}_i} \begin{pmatrix} r_{ij} \\ x_{ij} \end{pmatrix} \begin{pmatrix} \hat{P}_{ij}^+(\bar{p}) & \hat{Q}_{ij}^+(\bar{q}) \end{pmatrix}$$

for $(i, j) \in \mathcal{E}$. Since $(i, j_1) \in \mathcal{E}$ and $(i, j_2) \in \mathcal{E}$ implies $j_1 = j_2$, \underline{A}_i and u_i are well-defined for $i \in \mathcal{N}^+$.

Further, let $\mathcal{L} := \{l \in \mathcal{N} \mid \nexists k \in \mathcal{N} \text{ such that } k \rightarrow l\}$ denote the collection of leaf buses in the network. For a leaf bus $l \in \mathcal{L}$, let $n_l + 1$ denote the number of buses on path \mathcal{P}_l , and suppose

$$\mathcal{P}_l = \{l_{n_l} \rightarrow l_{n_l-1} \rightarrow \dots \rightarrow l_1 \rightarrow l_0\}$$

with $l_{n_l} = l$ and $l_0 = 0$ as in Fig. 4. Let




Fig. 4. The shaded region denotes the collection \mathcal{L} of leaf buses, and the path \mathcal{P}_l of a leaf bus $l \in \mathcal{L}$ is illustrated by a dashed line.

$$\mathcal{S}_{\text{volt}} := \{s \in \mathbb{C}^n \mid \hat{v}_i(s) \leq \bar{v}_i \text{ for } i \in \mathcal{N}^+\}$$

denote the power injection region where $\hat{v}(s)$ is upper bounded by \bar{v} . Since $v \leq \hat{v}(s)$ (Lemma 1), the set $\mathcal{S}_{\text{volt}}$ is a power injection region where voltage upper bounds do not bind.

The following theorem provides a sufficient condition that guarantees the exactness of SOCP.

Theorem 1. Assume that f_0 is strictly increasing, and that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. Then SOCP is exact if the following conditions hold:

- C1 $\underline{A}_{l_s} \underline{A}_{l_{s+1}} \cdots \underline{A}_{l_{t-1}} u_{l_t} > 0$ for any $l \in \mathcal{L}$ and any s, t such that $1 \leq s \leq t \leq n_l$;
- C2 every SOCP solution $w = (s, S, v, \ell, s_0)$ satisfies $s \in \mathcal{S}_{\text{volt}}$.

Theorem 1 implies that if C2 holds, i.e., optimal power injections lie in the region $\mathcal{S}_{\text{volt}}$ where voltage upper bounds do not bind, then SOCP is exact under C1. The theorem is proved in Appendix B. C2 depends on SOCP solutions and cannot be checked a priori. This drawback motivates us to modify OPF such that the corresponding SOCP is exact under C1, as will be discussed in Section IV.

B. Interpretation of C1

We illustrate C1 through a linear network as in Fig. 5. The collection of leaf buses is a singleton $\mathcal{L} = \{n\}$, and the path from the only leaf bus n to bus 0 is $\mathcal{P}_n = \{n \rightarrow n-1 \rightarrow \dots \rightarrow 1 \rightarrow 0\}$. Then, C1 takes the form

$$\underline{A}_s \underline{A}_{s+1} \cdots \underline{A}_{t-1} u_t > 0, \quad 1 \leq s \leq t \leq n.$$




Fig. 5. In the above linear network, $\mathcal{L} = \{n\}$ and $\mathcal{P}_n = \{n \rightarrow n-1 \rightarrow \cdots \rightarrow 1 \rightarrow 0\}$. C1 requires that given any highlighted segment $(s-1, t)$ where $1 \leq s \leq t \leq n$, the multiplication of \underline{A} over $(s-1, t-1)$ times u_t is strictly positive (componentwise).

That is, given any network segment $(s-1, t)$ where $1 \leq s \leq t \leq n$, the multiplication $\underline{A}_s \underline{A}_{s+1} \cdots \underline{A}_{t-1}$ of \underline{A} over the segment $(s-1, t-1)$ times u_t is strictly positive.

C1 only depends on SOCP parameters $(r, x, \bar{p}, \bar{q}, \underline{v})$ and therefore can be checked a priori. Furthermore, C1 can be checked efficiently since \underline{A} and u are simple functions of $(r, x, \bar{p}, \bar{q}, \underline{v})$ that can be computed in $O(n)$ time, and there are no more than $n(n+1)/2$ inequalities in C1.

Proposition 1. *If $(\bar{p}, \bar{q}) \leq (\bar{p}', \bar{q}')$ and C1 holds for $(r, x, \bar{p}', \bar{q}', \underline{v})$, then C1 also holds for $(r, x, \bar{p}, \bar{q}, \underline{v})$.*

Proposition 1 implies that the smaller power injections, the more likely C1 holds. It is proved in Appendix C.

Proposition 2. *If $(\bar{p}, \bar{q}) \leq 0$, then C1 holds.*

Proposition 2 implies that if every bus only consumes real and reactive power, then C1 holds. This is because when $(\bar{p}, \bar{q}) \leq 0$, the quantities $\hat{P}_{ij}(\bar{p}) \leq 0$, $\hat{Q}_{ij}(\bar{q}) \leq 0$ for $(i, j) \in \mathcal{E}$. It follows that $\underline{A}_i = I$ for $i \in \mathcal{N}^+$. Hence, $\underline{A}_s \cdots \underline{A}_{t-1} u_t = u_t > 0$ for any $l \in \mathcal{L}$ and any s, t such that $1 \leq s \leq t \leq n_l$.

For practical parameter ranges of $(r, x, \bar{p}, \bar{q}, \underline{v})$, line resistance and reactance $r_{ij}, x_{ij} \ll 1$ for $(i, j) \in \mathcal{E}$, line flow $\hat{P}_{ij}(\bar{p}), \hat{Q}_{ij}(\bar{q}) = O(1)$ for $(i, j) \in \mathcal{E}$, and voltage lower bound $\underline{v}_i \approx 1$ for $i \in \mathcal{N}^+$. Hence, \underline{A}_i is close to I for $i \in \mathcal{N}^+$, and therefore C1 is likely to hold. As will be seen in the numeric studies in Section VI, C1 holds for several test networks, including those with big (\bar{p}, \bar{q}) (high penetration of distributed generation).

C1 has a physical interpretation. Recall that $S_{k,k-1}$ denotes the reverse power flow on line $(k, k-1)$ for $k = 1, \dots, n$ and introduce $S_{0,-1} := -s_0$ for convenience. If the power loss on a line is reduced, then all upstream reverse power flows seem nature to increase. More specifically, the power loss on line $(t, t-1)$ where $t \in \{1, 2, \dots, n\}$ can be reduced by decreasing the current $\ell_{t,t-1}$ by $d\ell_{t,t-1} < 0$, and physical intuition tells us that reverse power flow $S_{s-1,s-2}$ is likely to increase, i.e., $dS_{s-1,s-2} > 0$, for $s = 1, 2, \dots, t$. Now assume that indeed $dS_{s-1,s-2} = dP_{s-1,s-2} + \mathbf{i}dQ_{s-1,s-2} > 0$ for $s = 1, \dots, t$. It can be verified that $(dP_{t-1,t-2} \quad dQ_{t-1,t-2})^T = -u_t d\ell_{t,t-1}$, and one can compute from (1) the Jacobian matrix

$$A_k := \begin{pmatrix} \frac{\partial P_{k-1,k-2}}{\partial P_{k,k-1}} & \frac{\partial P_{k-1,k-2}}{\partial Q_{k,k-1}} \\ \frac{\partial Q_{k-1,k-2}}{\partial P_{k,k-1}} & \frac{\partial Q_{k-1,k-2}}{\partial Q_{k,k-1}} \end{pmatrix} = I - \frac{2}{v_i} \begin{pmatrix} r_{k,k-1} \\ x_{k,k-1} \end{pmatrix} (P_{k,k-1} \quad Q_{k,k-1})$$

for $k = 1, \dots, n$. Therefore reverse power flow $S_{s-1,s-2}$ changes by $dS_{s-1,s-2} = dP_{s-1,s-2} + \mathbf{i}dQ_{s-1,s-2}$ where

$$(dP_{s-1,s-2} \quad dQ_{s-1,s-2})^T = -A_s A_{s+1} \cdots A_{t-1} u_t d\ell_{t,t-1},$$

according to the chain rule, for $s = 1, \dots, t$. Then, $dS_{s-1,s-2} > 0$ implies

$$A_s A_{s+1} \cdots A_{t-1} u_t > 0 \quad (7)$$

for $s = 1, 2, \dots, t$. Note that \underline{A}_k is obtained by replacing (P, Q, v) in A_k by $(\hat{P}^+(\bar{p}), \hat{Q}^+(\bar{q}), v)$ (so that \underline{A}_k only depends on SOCP parameters), and then (7) becomes C1.

C. Proof idea

We present the proof idea of Theorem 1 via a 3-bus linear network as in Fig. 6, and the proof for general tree




Fig. 6. A 3-bus linear network.

networks is provided in Appendix B. Assume that f_0 is strictly increasing, and that C1 and C2 hold. If SOCP is not exact, then there exists an SOCP solution $w = (s, S, v, \ell, s_0)$ that violates (5d). We are going to construct another feasible point $w' = (s', S', v', \ell', s'_0)$ of SOCP that has a smaller objective value than w . This contradicts with w being optimal, and therefore SOCP is exact.

The construction of w' is as follows. There are two ways (5d) gets violated: 1) violated on line (1, 0); 2) satisfied on line (1, 0) but violated on line (2, 1). To illustrate the proof idea, we focus on the second case, i.e., the case where $\ell_{10} = |S_{10}|^2/v_1$ and $\ell_{21} > |S_{21}|^2/v_2$. In this case, the construction of w' is

$$\textbf{Initialization:} \quad s' = s; \quad (8a)$$

$$S'_{21} = S_{21}; \quad (8b)$$

$$\textbf{Forward sweep:} \quad \ell'_{21} = |S'_{21}|^2/v_2; \quad (8c)$$

$$S'_{10} = S'_{21} - z_{21}\ell'_{21} + s'_1; \quad (8d)$$

$$\ell'_{10} = |S'_{10}|^2/v_1; \quad (8e)$$

$$S'_{0,-1} = S'_{10} - z_{10}\ell'_{10}; \quad (8f)$$

$$\textbf{Backward sweep:} \quad v'_1 = v_0 + 2\text{Re}(\bar{z}_{10}S'_{10}) - |z_{10}|^2\ell'_{10}; \quad (8g)$$

$$v'_2 = v'_1 + 2\text{Re}(\bar{z}_{21}S'_{21}) - |z_{21}|^2\ell'_{21} \quad (8h)$$

where $s'_0 = -S'_{0,-1}$. The construction consists of three steps:

- S1 In the initialization step, s' and S'_{21} are initialized as the corresponding values in w . Hence, w' satisfies (5e).
- S2 In the forward sweep step, $\ell'_{k,k-1}$ and $S'_{k-1,k-2}$ are recursively constructed for $k = 2, 1$ by alternatively applying (5d) (with v' replaced by v) and (5a)/(5b). This recursive construction updates ℓ' and S' alternatively along the path \mathcal{P}_2 from bus 2 to bus 0, and is therefore called a *forward sweep*. It is clear that w' satisfies (5a) and (5b). Besides, w' satisfies (6) if and only if $v' \geq v$.
- S3 In the backward sweep step, v'_k is recursively constructed for $k = 1, 2$ by applying (5c). This recursive construction updates v' along the negative direction of \mathcal{P}_2 from bus 0 to bus 2, and is therefore called a *backward sweep*. It is clear that w' satisfies (5c).

We will show that w' is feasible for SOCP and has a smaller objective value than w . This result follows from the following two claims.

Claim 1. $C1 \Rightarrow S'_{k,k-1} > S_{k,k-1}$ for $k = 0, 1 \Rightarrow v' \geq v$.

Claim 2. $C2 \Rightarrow v' \leq \bar{v}$.

It follows from Claims 1 and 2 that $\underline{v} \leq v \leq v' \leq \bar{v}$, and therefore w' satisfies (5f). As discussed in Step S2, w' also satisfies (6) since $v' \geq v$. Hence, w' is feasible for SOCP. The point w' has a smaller objective value than w because

$$\sum_{i \in \mathcal{N}} f_i(\text{Re}(s'_i)) - \sum_{i \in \mathcal{N}} f_i(\text{Re}(s_i)) = f_0(-\text{Re}(S'_{0,-1})) - f_0(-\text{Re}(S_{0,-1})) < 0.$$

This contradicts the optimality of w , and therefore SOCP is exact. To complete the proof, we are left to prove Claims 1 and 2.

Proof of Claim 1: First show that C1 implies $S'_{k,k-1} > S_{k,k-1}$ for $k = 0, 1$. Define $\Delta s := s' - s$, $\Delta S := S' - S$, $\Delta \ell := \ell' - \ell$, and $\Delta v := v' - v$. It is assumed that $\ell_{21} > |S_{21}|^2/v_2$, and therefore $\ell'_{21} = |S'_{21}|^2/v_2 = |S_{21}|^2/v_2 < \ell_{21}$, i.e., $\Delta \ell_{21} < 0$. It follows that

$$\Delta S_{10} = \Delta S'_{21} - z_{21} \Delta \ell_{21} + \Delta s_1 = -z_{21} \Delta \ell_{21} > 0.$$

Recalling that $S = P + \mathbf{i}Q$ and that $u_2 = (r_{21} \ x_{21})^T$, one has $(\Delta P_{10} \ \Delta Q_{10})^T = -u_2 \Delta \ell_{21}$. It follows from (8e)–(8f) that $S'_{0,-1} = S'_{10} - z_{10} |S'_{10}|^2/v_1$. It is assumed that $\ell_{10} = |S_{10}|^2/v_1$, therefore $S_{0,-1} = S_{10} - z_{10} |S_{10}|^2/v_1$. Hence, $\Delta S_{0,-1} = \Delta S_{10} - z_{10} (|S'_{10}|^2 - |S_{10}|^2)/v_1$, which can be written as

$$\begin{pmatrix} \Delta P_{0,-1} \\ \Delta Q_{0,-1} \end{pmatrix} = B_1 \begin{pmatrix} \Delta P_{10} \\ \Delta Q_{10} \end{pmatrix} = -B_1 u_2 \Delta \ell_{21} \quad (9)$$

where

$$B_1 = I - \frac{2}{v_1} \begin{pmatrix} r_{10} \\ x_{10} \end{pmatrix} \begin{pmatrix} P_{10} + P'_{10} & Q_{10} + Q'_{10} \\ 2 & 2 \end{pmatrix}.$$

When C1 holds, one has $\underline{A}_1 u_2 > 0$, and therefore

$$\begin{aligned} B_1 u_2 &= \underline{A}_1 u_2 + (B_1 - \underline{A}_1) u_2 \\ &> (B_1 - \underline{A}_1) u_2 \\ &= \begin{pmatrix} r_{10} \\ x_{10} \end{pmatrix} \begin{pmatrix} \frac{2\hat{P}_{10}^+(\bar{p})}{v_1} - \frac{P_{10} + P'_{10}}{v_1}, & \frac{2\hat{Q}_{10}^+(\bar{q})}{v_1} - \frac{Q_{10} + Q'_{10}}{v_1} \end{pmatrix}. \end{aligned} \quad (10)$$

According to Lemma 1, one has $P_{10} \leq \hat{P}_{10}(p) \leq \hat{P}_{10}(\bar{p}) \leq \hat{P}_{10}^+(\bar{p})$. Similarly, $P'_{10} \leq \hat{P}_{10}^+(\bar{p})$. Therefore

$$\frac{2\hat{P}_{10}^+(\bar{p})}{v_1} \geq \frac{2\hat{P}_{10}(\bar{p})}{v_1} \geq \frac{P_{10} + P'_{10}}{v_1}.$$

Similarly, one has

$$\frac{2\hat{Q}_{10}^+(\bar{q})}{v_1} \geq \frac{Q_{10} + Q'_{10}}{v_1}.$$

Then it follows from (10) that $B_1 u_2 > (B_1 - \underline{A}_1) u_2 \geq 0$. Then it follows from (9) that $\Delta S_{0,-1} > 0$. This completes the proof that C1 implies $\Delta S_{k,k-1} > 0$ for $k = 0, 1$.

Next we show that $\Delta S_{k,k-1} > 0$ for $k = 0, 1$ implies $v' \geq v$. When $\Delta S_{10} > 0$, one has

$$\text{Re}(\bar{z}_{10} \Delta S_{10}) = r_{10} \Delta P_{10} + x_{10} \Delta Q_{10} > 0.$$

Similarly, when $\Delta S_{0,-1} > 0$, one has $\text{Re}(\bar{z}_{10} \Delta S_{0,-1}) > 0$. Then it follows from (8g) that

$$\begin{aligned} \Delta v_1 &= 2\text{Re}(\bar{z}_{10} \Delta S_{10}) - |z_{10}|^2 \Delta \ell_{10} \\ &> \text{Re}(\bar{z}_{10} \Delta S_{10}) - |z_{10}|^2 \Delta \ell_{10} \\ &= \text{Re}(\bar{z}_{10} (\Delta S_{10} - z_{10} \Delta \ell_{10})) \\ &= \text{Re}(\bar{z}_{10} \Delta S_{0,-1}) > 0. \end{aligned}$$

Similarly, one has

$$\Delta v_2 = \Delta v_1 + \text{Re}(\bar{z}_{21} \Delta S_{21}) + \text{Re}(\bar{z}_{21} \Delta S_{10}) > \Delta v_1 > 0.$$

Hence, $v' > v$. This completes the proof of Claim 1. \square

Proof of Claim 2: When C2 holds, it follows from Lemma 1 that $v' \leq \hat{v}(s') = \hat{v}(s) \leq \bar{v}$. \square

Remark 1. *Theorem 1 still holds if there is an additional power injection constraint $s \in \mathcal{S}$ in OPF, where \mathcal{S} can be an arbitrary set. This is because we set $s' = s$ in the construction of w' (the initialization step), and therefore $s \in \mathcal{S}$ implies $s' \in \mathcal{S}$. Hence, the introduction of additional constraint $s \in \mathcal{S}$ does not affect the proof that w' is feasible for SOCP and has a smaller objective value than w . As a result, Theorem 1 still holds.*

IV. A MODIFIED OPF PROBLEM

C2 in Theorem 1 depends on SOCP solutions and cannot be checked a priori. This drawback motivates us to impose additional constraint

$$s \in \mathcal{S}_{\text{volt}} \quad (11)$$

on OPF such that C2 holds automatically. Constraint (11) is equivalent to $\hat{v}_i(s) \leq \bar{v}_i$ for $i \in \mathcal{N}^+ - n$ affine constraints on s . Since $v_i \leq \hat{v}_i(s)$ (Lemma 1), the voltage upper bound constraints $v_i \leq \bar{v}_i$ in (5f) do not bind after imposing (11). To summarize, the modified OPF problem is

$$\begin{aligned}
\mathbf{OPF-m:} \quad & \min \sum_{i \in \mathcal{N}} f_i(\operatorname{Re}(s_i)) \\
& \text{over } s, \mathcal{S}, v, \ell, s_0 \\
& \text{s.t. (5a) – (5e);} \\
& \underline{v}_i \leq v_i, \hat{v}_i(s) \leq \bar{v}_i, \quad i \in \mathcal{N}^+.
\end{aligned} \tag{12}$$

A modification is necessary to ensure that SOCP is exact, since it is in general not exact otherwise. Remarkably, the feasible sets of OPF-m and OPF are similar since $\hat{v}_i(s)$ is close to v_i in practice [6], [21], [33].

One can still relax (5d) to (6) to obtain a relaxation of OPF-m:

$$\begin{aligned}
\mathbf{SOCP-m:} \quad & \min \sum_{i \in \mathcal{N}} f_i(\operatorname{Re}(s_i)) \\
& \text{over } s, \mathcal{S}, v, \ell, s_0 \\
& \text{s.t. (5a) – (5c), (6), (5e), (12).}
\end{aligned}$$

Note again that SOCP-m is not necessarily convex, since we allow f_i and \mathcal{S}_i to be nonconvex.

Since OPF-m is obtained by imposing additional constraint (11) on OPF, it follows from Remark 1 that:

Theorem 2. *Assume that f_0 is strictly increasing, and that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \operatorname{Re}(s) \leq \bar{p}_i, \operatorname{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. Then SOCP-m is exact if C1 holds.*

Theorem 2 implies that after restricting the power injection s to the region $\mathcal{S}_{\text{volt}}$ where voltage upper bounds do not bind, the corresponding SOCP-m relaxation is exact under C1—a mild condition that can be checked a priori.

Theorem 3. *If f_i is convex for $i \in \mathcal{N}$, \mathcal{S}_i is convex for $i \in \mathcal{N}^+$, and SOCP-m is exact, then SOCP-m has at most one solution.*

Theorem 3 implies that SOCP-m has at most one solution if it is convex and exact. It is proved in Appendix D.

V. CONNECTION WITH PRIOR RESULTS

We compare the sufficient condition in Theorem 1 for the exactness of the SOCP relaxation for radial networks with those in the literature. As mentioned earlier there are mainly three categories of existing sufficient conditions:

- 1) The power injection constraints satisfy certain patterns [18], [19], [22], [25]–[28], e.g., there are no lower bounds on the power injections (load over-satisfaction).
- 2) The phase angle difference across each line is bounded in terms of its r/x ratio [27], [29], [30].
- 3) The voltage upper bounds are relaxed plus some other conditions [31], [32].

It is interesting to contrast the result in [19] and Theorem 1. The sufficient condition in [19] relaxes the lower bound on power injections but allows arbitrary constraints on the voltage magnitudes whereas the condition in Theorem 1 relaxes the upper bound on voltage magnitudes but allows arbitrary constraints on power injections as long as they are upper bounded. As shown in Section IV voltage upper bounds can be imposed provided we constrain the power injections. The condition in [19] requires the objective function be strictly increasing in each ℓ_{ij} and nondecreasing in each s_i whereas that in Theorem 1 requires it be strictly increasing in s_0 .

We now show that Theorem 1 unifies and generalizes the results [31], [32] due to the following theorem proved in Appendix E. It says that C1 holds if at least one of the following holds: there is no distributed generation or shunt capacitors; lines use the same type of cable; there is no distributed generation and lines get thinner as they branch out; there are no shunt capacitors and lines get thicker as they branch out.

Theorem 4. *Assume that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. Then C1 holds if any one of the following statements is true:*

- (i) $\hat{P}_{ij}(\bar{p}) \leq 0, \hat{Q}_{ij}(\bar{q}) \leq 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$.
- (ii) $r_{ij}/x_{ij} = r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$; and $\underline{v}_i - 2r_{ij}\hat{P}_{ij}^+(\bar{p}) - 2x_{ij}\hat{Q}_{ij}^+(\bar{q}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$.
- (iii) $r_{ij}/x_{ij} \geq r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$; and $\hat{P}_{ij}(\bar{p}) \leq 0, \underline{v}_i - 2x_{ij}\hat{Q}_{ij}^+(\bar{q}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$.
- (iv) $r_{ij}/x_{ij} \leq r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$; and $\hat{Q}_{ij}(\bar{q}) \leq 0, \underline{v}_i - 2r_{ij}\hat{P}_{ij}^+(\bar{p}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$.
- (v)
$$\begin{pmatrix} \prod_{(k,l) \in \mathcal{P}_j} \left(1 - \frac{2r_{kl}\hat{P}_{kl}^+(\bar{p})}{\underline{v}_k}\right) & - \sum_{(k,l) \in \mathcal{P}_j} \frac{2r_{kl}\hat{Q}_{kl}^+(\bar{q})}{\underline{v}_k} \\ - \sum_{(k,l) \in \mathcal{P}_j} \frac{2x_{kl}\hat{P}_{kl}^+(\bar{p})}{\underline{v}_k} & \prod_{(k,l) \in \mathcal{P}_j} \left(1 - \frac{2x_{kl}\hat{Q}_{kl}^+(\bar{q})}{\underline{v}_k}\right) \end{pmatrix} \begin{pmatrix} r_{ij} \\ x_{ij} \end{pmatrix} > 0$$
 for all $(i, j) \in \mathcal{E}$.

The results in [31], [32] say that, if there are no voltage upper bounds, i.e., $\bar{v} = \infty$, then SOCP is exact if any one of (i)–(v) holds. Note that C2 holds automatically when $\bar{v} = \infty$, and that C1 holds if any one of (i)–(v) holds according to Theorem 4. The following corollary follows immediately from Theorem 2 and Theorem 4.

Corollary 1. *Assume that f_0 is strictly increasing, and that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. Then SOCP-m is exact if any one of (i)–(v) holds.*

VI. CASE STUDIES

In this section, we use several test networks to demonstrate that

- 1) SOCP is much more efficient to compute than SDP.
- 2) C1 holds. We will define a notion of *C1 margin* that quantifies how well C1 is satisfied, and show that the margin is sufficiently large for the test networks.

TABLE I
LINE IMPEDANCES, PEAK SPOT LOAD, AND NAMEPLATE RATINGS OF CAPACITORS AND PV GENERATORS OF THE 47-BUS NETWORK.

Network Data																	
Line Data				Line Data				Line Data				Load Data		Load Data		PV Generators	
From Bus	To Bus	R (Ω)	X (Ω)	From Bus	To Bus	R (Ω)	X (Ω)	From Bus	To Bus	R (Ω)	X (Ω)	Bus No	Peak MVA	Bus No	Peak MVA	Bus No	Nameplate Capacity
1	2	0.259	0.808	8	41	0.107	0.031	21	22	0.198	0.046	1	30	34	0.2		
2	13	0	0	8	35	0.076	0.015	22	23	0	0	11	0.67	36	0.27	13	1.5MW
2	3	0.031	0.092	8	9	0.031	0.031	27	31	0.046	0.015	12	0.45	38	0.45	17	0.4MW
3	4	0.046	0.092	9	10	0.015	0.015	27	28	0.107	0.031	14	0.89	39	1.34	19	1.5 MW
3	14	0.092	0.031	9	42	0.153	0.046	28	29	0.107	0.031	16	0.07	40	0.13	23	1 MW
3	15	0.214	0.046	10	11	0.107	0.076	29	30	0.061	0.015	18	0.67	41	0.67	24	2 MW
4	20	0.336	0.061	10	46	0.229	0.122	32	33	0.046	0.015	21	0.45	42	0.13		
4	5	0.107	0.183	11	47	0.031	0.015	33	34	0.031	0.010	22	2.23	44	0.45		Shunt Capacitors
5	26	0.061	0.015	11	12	0.076	0.046	35	36	0.076	0.015	25	0.45	45	0.2		Bus Nameplate
5	6	0.015	0.031	15	18	0.046	0.015	35	37	0.076	0.046	26	0.2	46	0.45		No. Capacity
6	27	0.168	0.061	15	16	0.107	0.015	35	38	0.107	0.015	28	0.13				
6	7	0.031	0.046	16	17	0	0	42	43	0.061	0.015	29	0.13		Base Voltage (kV) = 12.35	1	6000 kVAR
7	32	0.076	0.015	18	19	0	0	43	44	0.061	0.015	30	0.2		Base kVA = 1000	3	1200 kVAR
7	8	0.015	0.015	20	21	0.122	0.092	43	45	0.061	0.015	31	0.07		Substation Voltage = 12.35	37	1800 kVAR
8	40	0.046	0.015	20	25	0.214	0.046					32	0.13			47	1800 kVAR
8	39	0.244	0.046	21	24	0	0					33	0.27				

- 3) The feasible sets of OPF and OPF-m are similar. We will define a notion of *modification gap* that quantifies how different the feasible sets of OPF and OPF-m are, and show that the gap is small for the test networks.

A. Test networks

Our test networks include modified IEEE 13-, 34-, 37-, 123-bus networks [34] and two real-world networks [18], [35] in the service territory of Southern California Edison (SCE), a utility company in California, USA [36].

The IEEE networks are unbalanced three-phase radial networks with some elements (regulators, circuit switches, transformers, and distributed loads) that are not modeled in (1). Therefore we modify the networks as follows.

- 1) Assume that each bus has three phases and split its load uniformly among the three phases.
- 2) Assume that the three phases are decoupled so that the network becomes three identical single phase networks.
- 3) Model closed circuit switches as shorted lines and ignore open circuit switches. Model regulators as multiplying the voltages by constant factors.¹ Model transformers as lines with proper impedance. Model the distributed load on a line as two identical spot loads, one at the each end of the line.

The SCE networks, a 47-bus one and a 56-bus one, are shown in Fig. 7 with parameters given in Tables I and II.

These networks have increasing penetration of distributed generation (DG). While the IEEE networks do not have any DG, the SCE 47-bus network has 56.6% DG penetration (6.4MW nameplate distributed generation capacity

¹The constant factors are taken to be 1.08 in the simulations.




Fig. 7. Topologies of the SCE 47-bus and 56-bus networks [18], [35].

against 11.3MVA peak spot load) [18], and the SCE 56-bus network has 130.4% DG penetration (5MW nameplate distributed generation capacity against 3.835MVA peak spot load) [35] as listed in Table III.

B. SOCP is more efficient to compute than SDP

We compare the computation times of SOCP and SDP for the test networks, and summarize the results in Table III. All simulations in this paper use matlab 7.9.0.529 (64-bit) with toolbox cvx 1.21 on Mac OS X 10.7.5 with 2.66GHz Intel Core 2 Duo CPU and 4GB 1067MHz DDR3 memory.

We use the following OPF setup throughout the simulations.

- 1) The objective is minimizing power loss in the network.
- 2) The power injection constraint is as follows. For each bus $i \in \mathcal{N}^+$, there may be multiple devices including loads, capacitors, and PV panels. Assume that there is a total of A_i such devices and label them by $1, 2, \dots, A_i$.

TABLE II

LINE IMPEDANCES, PEAK SPOT LOAD, AND NAMEPLATE RATINGS OF CAPACITORS AND PV GENERATORS OF THE 56-BUS NETWORK.

Network Data																	
Line Data				Line Data				Line Data				Load Data		Load Data		Load Data	
From Bus.	To Bus.	R (Ω)	X (Ω)	From Bus.	To Bus.	R (Ω)	X (Ω)	From Bus.	To Bus.	R (Ω)	X (Ω)	Bus No.	Peak MVA	Bus No.	Peak MVA	Bus No.	Peak MVA
1	2	0.160	0.388	20	21	0.251	0.096	39	40	2.349	0.964	3	0.057	29	0.044	52	0.315
2	3	0.824	0.315	21	22	1.818	0.695	34	41	0.115	0.278	5	0.121	31	0.053	54	0.061
2	4	0.144	0.349	20	23	0.225	0.542	41	42	0.159	0.384	6	0.049	32	0.223	55	0.055
4	5	1.026	0.421	23	24	0.127	0.028	42	43	0.934	0.383	7	0.053	33	0.123	56	0.130
4	6	0.741	0.466	23	25	0.284	0.687	42	44	0.506	0.163	8	0.047	34	0.067	Shunt Cap	
4	7	0.528	0.468	25	26	0.171	0.414	42	45	0.095	0.195	9	0.068	35	0.094	Bus	Mvar
7	8	0.358	0.314	26	27	0.414	0.386	42	46	1.915	0.769	10	0.048	36	0.097	19	0.6
8	9	2.032	0.798	27	28	0.210	0.196	41	47	0.157	0.379	11	0.067	37	0.281	21	0.6
8	10	0.502	0.441	28	29	0.395	0.369	47	48	1.641	0.670	12	0.094	38	0.117	30	0.6
10	11	0.372	0.327	29	30	0.248	0.232	47	49	0.081	0.196	14	0.057	39	0.131	53	0.6
11	12	1.431	0.999	30	31	0.279	0.260	49	50	1.727	0.709	16	0.053	40	0.030	Photovoltaic	
11	13	0.429	0.377	26	32	0.205	0.495	49	51	0.112	0.270	17	0.057	41	0.046	Bus	Capacity
13	14	0.671	0.257	32	33	0.263	0.073	51	52	0.674	0.275	18	0.112	42	0.054		
13	15	0.457	0.401	32	34	0.071	0.171	51	53	0.070	0.170	19	0.087	43	0.083	45	5MW
15	16	1.008	0.385	34	35	0.625	0.273	53	54	2.041	0.780	22	0.063	44	0.057		
15	17	0.153	0.134	34	36	0.510	0.209	53	55	0.813	0.334	24	0.135	46	0.134	$V_{\text{base}} = 12\text{kV}$	
17	18	0.971	0.722	36	37	2.018	0.829	53	56	0.141	0.340	25	0.100	47	0.045	$S_{\text{base}} = 1\text{MVA}$	
18	19	1.885	0.721	34	38	1.062	0.406					27	0.048	48	0.196	$Z_{\text{base}} = 144\Omega$	
4	20	0.138	0.334	38	39	0.610	0.238					28	0.038	50	0.045		

TABLE III

DG PENETRATION, C1 MARGINS, MODIFICATION GAPS, AND COMPUTATION TIMES FOR DIFFERENT TEST NETWORKS.

	DG penetration	numerical precision	SOCP time	SDP time	C1 margin	estimated modification gap
IEEE 13-bus	0%	10^{-10}	0.5162s	0.3842s	27.6762	0.0362
IEEE 34-bus	0%	10^{-10}	0.5772s	0.5157s	20.8747	0.0232
IEEE 37-bus	0%	10^{-9}	0.5663s	1.6790s	$+\infty$	0.0002
IEEE 123-bus	0%	10^{-8}	2.9731s	32.6526s	52.9636	0.0157
SCE 47-bus	56.6%	10^{-8}	0.7265s	2.5932s	2.5416	0.0082
SCE 56-bus	130.4%	10^{-9}	1.0599s	6.0573s	1.2972	0.0053

Let $s_{i,a}$ denote the power injection of device a for $a = 1, 2, \dots, A_i$. If device a is a load with given real and reactive power consumptions p and q , then we impose

$$s_{i,a} = -p - \mathbf{i}q. \quad (13)$$

If device a is a load with given peak apparent power s_{peak} , then we impose

$$s_{i,a} = -s_{\text{peak}} \exp(j\theta) \quad (14)$$

where $\theta = \cos^{-1}(0.9)$, i.e. power injection $s_{i,a}$ is considered to be a constant, obtained by assuming a power

factor of 0.9 at peak apparent power. If device a is a capacitor with nameplate \bar{q} , then we impose

$$\operatorname{Re}(s_{i,a}) = 0 \text{ and } 0 \leq \operatorname{Im}(s_{i,a}) \leq \bar{q}. \quad (15)$$

If device a is a PV panel with nameplate \bar{s} , then we impose

$$\operatorname{Re}(s_{i,a}) \geq 0 \text{ and } |s_{i,a}| \leq \bar{s}. \quad (16)$$

The power injection at bus i is

$$s_i = \sum_{a=1}^{A_i} s_{i,a}$$

where $s_{i,a}$ satisfies one of (13)–(16).

- 3) The voltage regulation constraint is considered to be $0.9^2 \leq v_i \leq 1.1^2$ for $i \in \mathcal{N}^+$. Note that we choose a small voltage lower bound 0.9 so that OPF is feasible for all test networks. We choose a big voltage upper bound 1.1 such that Condition C2 holds, and SDP/SOCP is exact if Condition C1 holds.




Fig. 8. Comparison of the computation times for SOCP and SDP.

It can be seen from Fig. 8 that the computation time of SOCP scales up much more slowly than that of SDP as the number of buses increases, and that the improvement in efficiency (i.e., the ratio of SDP computation time to SOCP computation time) increases dramatically as the number of buses increases. Hence, even though the computation times of SOCP and SDP are similar for small networks, we expect SOCP to be much more efficient for medium to large networks.

SOCP and SDP can only be solved to certain numerical precision. The best numerical precision (without applying pre-conditioning techniques) that can be obtained by our simulation platform are listed in Table III.

C. C1 holds with a large margin

We show that C1 holds with a large margin for all test networks. Recall that C1 is more difficult to satisfy as (\bar{p}, \bar{q}) increases (Proposition 1). One can scale up distributed generation (positive component of \bar{p} , \bar{q}) and shunt

capacitors (positive component of \bar{q}) until C1 breaks down, and call the scaling factor when this happens the *C1 margin*. More specifically, for any scaling factor $\eta \geq 0$, set

$$\bar{p}_i(\eta) := \text{real load at } i + \eta * \text{PV nameplate at } i$$

$$\bar{q}_i(\eta) := \text{reactive load at } i + \eta * (\text{PV nameplate at } i + \text{shunt capacitor nameplate at } i)$$

for $i \in \mathcal{N}^+$. When $\eta = 0$, one has $(\bar{p}(\eta), \bar{q}(\eta)) \leq 0$ and therefore C1 holds according to Proposition 2. According to Proposition 1, there exists a unique $\eta^* \in \mathbb{R}^+ \cup \{+\infty\}$, such that

$$0 \leq \eta < \eta^* \Rightarrow \text{C1 holds for } (r, x, \bar{p}(\eta), \bar{q}(\eta), \underline{v}); \quad (17a)$$

$$\eta > \eta^* \Rightarrow \text{C1 does not hold for } (r, x, \bar{p}(\eta), \bar{q}(\eta), \underline{v}). \quad (17b)$$

Definition 2. *C1 margin is defined as the unique $\eta^* \geq 0$ that satisfies (17).*

Physically, η^* is the number of multiples one can scale up distributed generation and shunt capacitors before C1 breaks down. Noting that $\bar{p} = \bar{p}(1)$ and $\bar{q} = \bar{q}(1)$, C1 holds for $(r, x, \bar{p}, \bar{q}, \underline{v})$ if and only if $\eta^* > 1$ (ignore the corner case where $\eta^* = 1$). The larger η^* is, the “more safely” C1 holds. The C1 margins for different test networks are summarized in Table III. The minimum C1 margin is 1.30, meaning that one can scale up distributed generation and shunt capacitors by 1.39 before C1 breaks down. C1 margin of the IEEE 37-bus network is $+\infty$, and this is because there is no distributed generation or shunt capacitors in the IEEE 37-bus network.

C1 margin is above 10 for all IEEE networks, but much smaller for SCE networks. This is because SCE networks have high penetration of distributed generation—big positive \bar{p}, \bar{q} —that makes C1 more difficult to hold. On the other hand, the SCE 56-bus network already has a DG penetration of over 130%, and one can still scale up DG by a factor of 1.30 before C1 breaks down. This finishes the demonstration that C1 is mild.

D. The feasible sets of OPF and OPF-m are similar

We show that OPF-m eliminates some feasible points of OPF that are close to the voltage upper bounds for each of the test networks. Let \mathcal{F}_{OPF} denote the feasible set of OPF and let $\|\cdot\|_\infty$ denote the ℓ_∞ norm.² Define

$$\begin{aligned} \varepsilon &:= \max \|\hat{v}(s) - v\|_\infty \\ &\text{s.t. } (s, S, v, \ell, s_0) \in \mathcal{F}_{\text{OPF}} \end{aligned} \quad (18)$$

as the maximum deviation of v from \hat{v} over all OPF feasible points.

The value ε serves as a measure for the difference between the feasible sets of OPF and OPF-m. Consider the

²The ℓ_∞ norm of a vector $x = (x_1, \dots, x_n) \in \mathbb{R}^n$ is $\|x\|_\infty = \max\{|x_1|, \dots, |x_n|\}$.

OPF problem with a stricter voltage upper bound constraint:

$$\begin{aligned}
\mathbf{OPF}\text{-}\varepsilon: \quad & \min \quad \sum_{i \in \mathcal{N}} f_i(\text{Re}(s_i)) \\
& \text{over} \quad s, S, v, \ell, s_0 \\
& \text{s.t.} \quad (5\text{a}) - (5\text{e}); \\
& \quad \underline{v}_i \leq v_i \leq \bar{v}_i - \varepsilon, \quad i \in \mathcal{N}^+.
\end{aligned}$$

The feasible set $\mathcal{F}_{\text{OPF-}\varepsilon}$ is contained in \mathcal{F}_{OPF} , and therefore

$$\hat{v}_i(s) \leq v_i + \varepsilon \leq \bar{v}_i - \varepsilon + \varepsilon = \bar{v}_i \text{ for } i \in \mathcal{N}^+$$

for every $(s, S, \ell, v, s_0) \in \mathcal{F}_{\text{OPF-}\varepsilon}$ according to the definition of ε . It follows that $\mathcal{F}_{\text{OPF-}\varepsilon} \subseteq \mathcal{F}_{\text{OPF-m}}$ and therefore

$$\mathcal{F}_{\text{OPF-}\varepsilon} \subseteq \mathcal{F}_{\text{OPF-m}} \subseteq \mathcal{F}_{\text{OPF}}$$

as in Fig. 9. If ε is small, then $\mathcal{F}_{\text{OPF-m}}$ is similar to \mathcal{F}_{OPF} . Furthermore, any point w that is feasible for OPF but




Fig. 9. Feasible sets of OPF- ε , OPF-m, and OPF. The point w is feasible for OPF but not for OPF-m.

infeasible for OPF-m is close to the voltage upper bound since $v_i > \bar{v}_i - \varepsilon$ for some $i \in \mathcal{N}^+$. Such points are perhaps undesirable for robust operation.

Definition 3. *The value ε defined in (18) is called the modification gap.*

We demonstrate that the modification gap ε is small for all test networks through Monte-Carlo simulations. Note that ε is difficult to compute since the objective function in (18) is not concave and the constraints in (18) are not convex. We choose 1000 samples of s , calculate the corresponding (S, v, ℓ, s_0) by solving power flow (1a)–(1d) (using the *forward backward sweep* algorithm [37]) for each s , and compute $\varepsilon(s) := \|\hat{v}(s) - v\|_\infty$ if $(s, S, v, \ell, s_0) \in \mathcal{F}_{\text{OPF}}$. We use the maximum $\varepsilon(s)$ over the samples as an estimate for ε . The estimated modification gap ε^{set} we obtained for different test networks are listed in Table III. For example, $\varepsilon^{\text{set}} = 0.0362$ for the IEEE 13-bus network, in which case the voltage constraints are $0.81 \leq v_i \leq 1.21$ for OPF and $0.81 \leq v_i \leq 1.1738$ for OPF- ε (assuming $\varepsilon = \varepsilon^{\text{set}}$).

VII. CONCLUSION

We have proved that SOCP is exact if Conditions C1 and C2 hold. C1 can be checked a priori, and follows from the physical intuition that all upstream power flows should increase if the power loss on a line is reduced. C2

requires that optimal power injections lie in a region ($\mathcal{S}_{\text{volt}}$) where voltage upper bounds do not bind. C2 depends on SOCP solutions and cannot be checked a priori, but holds automatically after imposing the additional constraint that power injections lie in $\mathcal{S}_{\text{volt}}$. This result unifies and generalizes our prior works [31], [32].

We have proposed a modified OPF problem by imposing the additional constraint that power injections lie in $\mathcal{S}_{\text{volt}}$ such that C2 holds automatically. The modified OPF problem has an exact SOCP relaxation if C1 holds. We have also proved that SOCP has at most one solution if it is convex and exact.

Empirical studies have verified that SOCP is computationally efficient, that C1 holds with large margin, and that the feasible sets of OPF and OPF-m are close for the IEEE 13-, 34-, 37-, 123-bus networks and two real-world networks.

REFERENCES

- [1] J. Carpentier, "Contribution to the economic dispatch problem," *Bulletin de la Societe Francoise des Electriciens*, vol. 3, no. 8, pp. 431–447, 1962.
- [2] B. Stott and O. Alsac, "Fast decoupled load flow," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-93, no. 3, pp. 859–869, 1974.
- [3] O. Alsac, J. Bright, M. Prais, and B. Stott, "Further developments in Ip-based optimal power flow," *IEEE Transactions on Power Systems*, vol. 5, no. 3, pp. 697–711, 1990.
- [4] B. Stott, J. Jardim, and O. Alsac, "Dc power flow revisited," *IEEE Transactions on Power Systems*, vol. 24, no. 3, pp. 1290–1300, 2009.
- [5] Y. Xiao, Y. Song, and Y. Sun, "Power flow control approach to power systems with embedded FACTS devices," *Power Systems, IEEE Transactions on*, vol. 17, no. 4, pp. 943–950, 2002.
- [6] K. Turitsyn, P. Sulc, S. Backhaus, and M. Chertkov, "Local control of reactive power by distributed photovoltaic generators," in *IEEE SmartGridComm*, 2010, pp. 79–84.
- [7] G. C. Contaxis, C. Delkis, and G. Korres, "Decoupled optimal power flow using linear or quadratic programming," *IEEE Transactions on Power Systems*, vol. 1, no. 2, pp. 1–7, 1986.
- [8] W. Min and L. Shengsong, "A trust region interior point algorithm for optimal power flow problems," *International Journal on Electrical Power and Energy Systems*, vol. 27, no. 4, pp. 293–300, 2005.
- [9] A. A. Sousa and G. L. Torres, "Robust optimal power flow solution using trust region and interior methods," *IEEE Transactions on Power Systems*, vol. 26, no. 2, pp. 487–499, 2011.
- [10] E. C. Baptista, E. A. Belati, and G. R. M. da Costa, "Logarithmic barrier-augmented lagrangian function to the optimal power flow problem," *International Journal on Electrical Power and Energy Systems*, vol. 27, no. 7, pp. 528–532, 2005.
- [11] G. L. Torres and V. H. Quintana, "An interior-point method for nonlinear optimal power flow using voltage rectangular coordinates," *IEEE Transactions on Power Systems*, vol. 13, no. 4, pp. 1211–1218, 1998.
- [12] R. A. Jabr, "A primal-dual interior-point method to solve the optimal power flow dispatching problem," *Optimization and Engineering*, vol. 4, no. 4, pp. 309–336, 2003.
- [13] F. Capitanescu, M. Glavic, D. Ernst, and L. Wehenkel, "Interior-point based algorithms for the solution of optimal power flow problems," *Electric Power System Research*, vol. 77, no. 5-6, pp. 508–517, 2007.
- [14] X. Bai, H. Wei, K. Fujisawa, and Y. Yang, "Semidefinite programming for optimal power flow problems," *International Journal of Electric Power & Energy Systems*, vol. 30, no. 6, pp. 383–392, 2008.
- [15] J. Lavaei and S. H. Low, "Zero duality gap in optimal power flow problem," *IEEE Transactions on Power Systems*, vol. 27, no. 1, pp. 92–107, 2012.
- [16] D. K. Molzahn, J. T. Holzer, B. C. Lesieutre, and C. L. DeMarco, "Implementation of a large-scale optimal power flow solver based on semidefinite programming," *Power Systems, IEEE Transactions on*, vol. PP, no. 99, pp. 1–12, 2013.
- [17] R. Jabr, "Radial distribution load flow using conic programming," *IEEE Transactions on Power Systems*, vol. 21, no. 3, pp. 1458–1459, 2006.

- [18] M. Farivar, C. R. Clarke, S. H. Low, and K. M. Chandy, "Inverter var control for distribution systems with renewables," in *IEEE SmartGridComm*, 2011, pp. 457–462.
- [19] M. Farivar and S. Low, "Branch flow model: Relaxations and convexification. (part I,II)," *IEEE Transactions on Power Systems*, vol. 28, no. 3, pp. 2554–2572, 2013.
- [20] M. E. Baran and F. F. Wu, "Optimal capacitor placement on radial distribution networks," *IEEE Transactions on Power Delivery*, vol. 4, no. 1, pp. 725–734, 1989.
- [21] —, "Optimal sizing of capacitors placed on a radial distribution systems," *IEEE Transactions on Power Delivery*, vol. 4, no. 1, pp. 735–743, 1989.
- [22] S. Sojoudi and J. Lavaei, "Physics of power networks makes hard optimization problems easy to solve," in *IEEE Power & Energy Society General Meeting*, 2012, pp. 1–8.
- [23] S. Bose, S. Low, and K. Chandy, "Equivalence of branch flow and bus injection models," in *Allerton*, 2012.
- [24] B. Lesieutre, D. Molzahn, A. Borden, and C. L. DeMarco, "Examining the limits of the application of semidefinite programming to power flow problems," in *Allerton*, 2011, pp. 1492–1499.
- [25] S. Bose, D. F. Gayme, S. Low, and K. M. Chandy, "Optimal power flow over tree networks," in *Communication, Control, and Computing (Allerton), 2011 49th Annual Allerton Conference on*. IEEE, 2011, pp. 1342–1348.
- [26] S. Bose, D. Gayme, S. Low, and K. Chandy, "Quadratically constrained quadratic programs on acyclic graphs with application to power flow," *arXiv:1203.5599*, 2012.
- [27] B. Zhang and D. Tse, "Geometry of injection regions of power networks," *IEEE Transactions on Power Systems*, no. 2, pp. 788–797, 2013.
- [28] S. Sojudi and J. Lavaei, "Semidefinite relaxation for nonlinear optimization over graphs with application to power systems," *Preprint available at http://www.ee.columbia.edu/~lavaei/Opt_Over_Graph.pdf*, 2013.
- [29] J. Lavaei, D. Tse, and B. Zhang, "Geometry of power flows and optimization in distribution networks," *arXiv preprint arXiv:1204.4419*, 2012.
- [30] A. Lam, B. Zhang, and D. N. Tse, "Distributed algorithms for optimal power flow problem," in *IEEE CDC*, 2012, pp. 430–437.
- [31] L. Gan, N. Li, U. Topcu, and S. H. Low, "On the exactness of convex relaxation for optimal power flow in tree networks," in *IEEE CDC*, 2012, pp. 465–471.
- [32] —, "Optimal power flow in distribution networks," in *IEEE CDC*, 2013.
- [33] M. E. Baran and F. F. Wu, "Network reconfiguration in distribution systems for loss reduction and load balancing," *IEEE Transactions on Power Delivery*, vol. 4, no. 2, 1989.
- [34] IEEE distribution test feeders, available at <http://ewh.ieee.org/soc/pes/dsacom/testfeeders/>.
- [35] M. Farivar, R. Neal, C. Clarke, and S. Low, "Optimal inverter var control in distribution systems with high pv penetration," in *PES General Meeting*, 2012, pp. 1–7.
- [36] Southern California Edison, available at <http://www.sce.com/>.
- [37] W. H. Kersting, *Distribution system modeling and analysis*. CRC press, 2012.

APPENDIX A

PROOF OF LEMMA 1

Let (s, S, v, ℓ, s_0) satisfy (1a)–(1c) and $\ell \geq 0$ componentwise. It follows from (1a) that

$$S_{ij} = s_i + \sum_{h: h \rightarrow i} (S_{hi} - z_{hi} \ell_{hi}) \leq s_i + \sum_{h: h \rightarrow i} S_{hi}$$

for $(i, j) \in \mathcal{E}$. On the other hand, $\hat{S}_{ij}(s)$ is the solution of

$$\hat{S}_{ij} = s_i + \sum_{h: h \rightarrow i} \hat{S}_{hi}$$

for $(i, j) \in \mathcal{E}$. By induction from the leaf lines, one can show that $S_{ij} \leq \hat{S}_{ij}(s)$ for $(i, j) \in \mathcal{E}$.

It follows from (1c) that

$$v_i - v_j = 2\text{Re}(\bar{z}_{ij}S_{ij}) - |z_{ij}|^2\ell_{ij} \leq 2\text{Re}(\bar{z}_{ij}S_{ij}) \leq 2\text{Re}(\bar{z}_{ij}\hat{S}_{ij}(s))$$

for $(i, j) \in \mathcal{E}$. Sum up the inequalities over \mathcal{P}_i to obtain

$$v_i - v_0 \leq 2 \sum_{(j,k) \in \mathcal{P}_i} \text{Re}(\bar{z}_{jk}\hat{S}_{jk}(s)),$$

i.e., $v_i \leq \hat{v}_i(s)$, for $i \in \mathcal{N}$.

APPENDIX B

PROOF OF THEOREM 1

The proof idea of Theorem 1 has been illustrated via a 3-bus network in Section III-C. Now we present the proof of Theorem 1 for general tree networks. Assume that f_0 is strictly increasing, and that C1 and C2 hold. If SOCP is not exact, then there exists an SOCP solution $w = (s, S, v, \ell, s_0)$ that violates (5d). We will construct another feasible point $w' = (s', S', v', \ell', s'_0)$ of SOCP that has a smaller objective value than w . This contradicts the optimality of w , and therefore SOCP is exact.

Construction of w'

The construction of w' is as follows. Since w violates (5d), there exists a leaf bus $l \in \mathcal{L}$ with $m \in \{1, \dots, n_l\}$ such that w satisfies (5d) on $(l_1, l_0), \dots, (l_{m-1}, l_{m-2})$ and violates (5d) on (l_m, l_{m-1}) . Without loss of generality, assume $l_k = k$ for $k = 0, \dots, m$ as in Fig. 10. Then

$$\ell_{m,m-1} > \frac{|S_{m,m-1}|^2}{v_m}, \quad \ell_{k,k-1} = \frac{|S_{k,k-1}|^2}{v_k} \text{ for } k = 1, \dots, m-1. \quad (19)$$




Fig. 10. Bus l is a leaf bus, with $l_k = k$ for $k = 0, \dots, m$. Equality (5d) is satisfied on $[0, m-1]$, but violated on $[m-1, m]$.

One can then construct $w' = (s', S', v', \ell', s'_0)$ as in Algorithm 1. The construction consists of three steps:

- S1 In the initialization step, s', ℓ' outside path \mathcal{P}_m , and S' outside path \mathcal{P}_{m-1} are initialized as the corresponding values in w . Since $s' = s$, the point w' satisfies (5e). Furthermore, since $\ell'_{ij} = \ell_{ij}$ for $(i, j) \notin \mathcal{P}_m$ and $S'_{ij} = S_{ij}$ for $(i, j) \notin \mathcal{P}_{m-1}$, the point w' also satisfies (5a) for $(i, j) \notin \mathcal{P}_{m-1}$.
- S2 In the forward sweep step, $\ell'_{k,k-1}$ and $S'_{k-1,k-2}$ are recursively constructed for $k = m, \dots, 1$ by alternatively applying (5d) (with v' replaced by v) and (5a)/(5b). Hence, w' satisfies (5a) for $(i, j) \in \mathcal{P}_{m-1}$ and (5b).

Algorithm 1 Construct a feasible point

Input: an SOCP solution $w = (s, S, v, \ell, s_0)$ that violates (5d), a leaf bus $l \in \mathcal{L}$ with $1 \leq m \leq n_l$ such that (19)

holds (assume $l_k = k$ for $k = 0, \dots, m$ without loss of generality).

Output: $w' = (s', S', v', \ell', s'_0)$.

1: Initialization. (Construct s', ℓ' outside \mathcal{P}_m , and S' outside \mathcal{P}_{m-1} .)

keep s : $s' \leftarrow s$;

keep ℓ outside path \mathcal{P}_m : $\ell'_{ij} \leftarrow \ell_{ij}$ for $(i, j) \notin \mathcal{P}_m$;

keep S outside path \mathcal{P}_{m-1} : $S'_{ij} \leftarrow S_{ij}$ for $(i, j) \notin \mathcal{P}_{m-1}$;

2: Forward sweep. (Construct ℓ' on \mathcal{P}_m , S' on \mathcal{P}_{m-1} , and s'_0 .)

for $k = m, m-1, \dots, 1$ **do**

$$\ell'_{k,k-1} \leftarrow |S'_{k,k-1}|^2/v_k;$$

$$S'_{k-1,k-2} \leftarrow s_{k-1} \mathbb{1}_{k \neq 1} + \sum_{j: j \rightarrow k-1} (S'_{j,k-1} - z_{j,k-1} \ell'_{j,k-1});$$

end for

$$s'_0 \leftarrow -S'_{0,-1};$$

3: Backward sweep. (Construct v' .)

$$v'_0 \leftarrow v_0;$$

$$\mathcal{N}_{\text{visit}} = \{0\};$$

while $\mathcal{N}_{\text{visit}} \neq \mathcal{N}$ **do**

find $i \notin \mathcal{N}_{\text{visit}}$ and $j \in \mathcal{N}_{\text{visit}}$ such that $i \rightarrow j$;

$$v'_i \leftarrow v'_j + 2\text{Re}(\bar{z}_{ij} S'_{ij}) - |z_{ij}|^2 \ell'_{ij};$$

$$\mathcal{N}_{\text{visit}} \leftarrow \mathcal{N}_{\text{visit}} \cup \{i\};$$

end while

S3 In the backward sweep step, v'_i is recursively constructed from bus 0 to leaf buses by applying (5c) consecutively. Hence, the point w' satisfies (5c).

The point w' satisfies another important property given below.

Lemma 2. *The point w' satisfies $\ell'_{ij} \geq |S'_{ij}|^2/v_i$ for $(i, j) \in \mathcal{E}$.*

Proof. When $(i, j) \notin \mathcal{P}_m$, it follows from Step S1 that $\ell'_{ij} = \ell_{ij} \geq |S_{ij}|^2/v_i = |S'_{ij}|^2/v_i$. When $(i, j) \in \mathcal{P}_m$, it follows from Step S2 that $\ell'_{ij} = |S'_{ij}|^2/v_i$. This completes the proof of Lemma 2. \square

Lemma 2 implies that if $v' \geq v$, then w' satisfies (6).

Feasibility and Superiority of w'

We will show that w' is feasible for SOCP and has a smaller objective value than w . This result follows from Claims 3 and 4.

Claim 3. $C1 \Rightarrow S'_{k,k-1} > S_{k,k-1}$ for $k = 0, \dots, m-1 \Rightarrow v' \geq v$.

Claim 3 is proved later in this appendix. Here we illustrate with Fig. 11 that $S'_{k,k-1} > S_{k,k-1}$ for $k = 0, \dots, m-1$ seems natural to hold. Note that $S'_{m,m-1} = S_{m,m-1}$ and that $\ell'_{m,m-1} = |S'_{m,m-1}|^2/v_m = |S_{m,m-1}|^2/v_m <$




Fig. 11. Illustration of $S'_{k,k-1} > S_{k,k-1}$ for $k = 0, \dots, m-1$.

$\ell_{m,m-1}$. Define $\Delta w = (\Delta s, \Delta S, \Delta v, \Delta \ell, \Delta s_0) = w' - w$, then $\Delta \ell_{m,m-1} < 0$ and therefore

$$\Delta S_{m-1,m-2} = \Delta S_{m,m-1} - z_{m,m-1} \Delta \ell_{m,m-1} = -z_{m,m-1} \Delta \ell_{m,m-1} > 0. \quad (20)$$

Intuitively, after increasing $S_{m-1,m-2}$, upstream reverse power flow $S_{k,k-1}$ is likely to increase for $k = 0, \dots, m-2$.

C1 is a condition that ensures $S_{k,k-1}$ to increase for $k = 0, \dots, m-1$.

Claim 4. $C2 \Rightarrow v' \leq \bar{v}$.

Proof. When C2 holds, it follows from Lemma 1 that $v' \leq \hat{v}(s') = \hat{v}(s) \leq \bar{v}$. \square

It follows from Claims 3 and 4 that $v \leq v \leq v' \leq \bar{v}$, and therefore w' satisfies (5f). Besides, it follows from Lemma 2 that $\ell'_{ij} \geq |S'_{ij}|^2/v_i \geq |S_{ij}|^2/v'_i$ for $(i, j) \in \mathcal{E}$, i.e., w' satisfies (6). Hence, w' is feasible for SOCP. Furthermore, w' has a smaller objective value than w because

$$\sum_{i \in \mathcal{N}} f_i(\text{Re}(s'_i)) - \sum_{i \in \mathcal{N}} f_i(\text{Re}(s_i)) = f_0(-\text{Re}(S'_{0,-1})) - f_0(-\text{Re}(S_{0,-1})) < 0.$$

This contradicts with the optimality of w , and therefore SOCP is exact. To complete the proof, we are left to prove Claim 3.

Proof of Claim 3

First show that C1 implies $\Delta S_{k,k-1} > 0$ for $k = 0, \dots, m-1$. Recall that $S = P + \mathbf{i}Q$ and that $u_i = (r_{ij} \ x_{ij})^T$. It follows from (20) that

$$(\Delta P_{m-1,m-2} \ \Delta Q_{m-1,m-2})^T = -u_m \Delta \ell_{m,m-1} > 0.$$

For any $k \in \{1, \dots, m-1\}$, one has

$$\Delta S_{k-1,k-2} = \Delta S_{k,k-1} - z_{k,k-1} \Delta \ell_{k,k-1} = \Delta S_{k,k-1} - z_{k,k-1} \frac{|S'_{k,k-1}|^2 - |S_{k,k-1}|^2}{v_k},$$

which is equivalent to

$$\begin{pmatrix} \Delta P_{k-1,k-2} \\ \Delta Q_{k-1,k-2} \end{pmatrix} = B_k \begin{pmatrix} \Delta P_{k,k-1} \\ \Delta Q_{k,k-1} \end{pmatrix}$$

where

$$B_k = I - \frac{2}{v_k} \begin{pmatrix} r_{k,k-1} \\ x_{k,k-1} \end{pmatrix} \begin{pmatrix} \frac{P_{k,k-1} + P'_{k,k-1}}{2} & \frac{Q_{k,k-1} + Q'_{k,k-1}}{2} \end{pmatrix}.$$

Hence, one has

$$(\Delta P_{k-1,k-2} \ \Delta Q_{k-1,k-2})^T = -B_k B_{k+1} \cdots B_{m-1} u_m \Delta \ell_{m,m-1}$$

for $k = 1, \dots, m$. To show that $\Delta S_{k,k-1} > 0$ for $k = 0, \dots, m-1$, it suffices to show that $B_k \cdots B_{m-1} u_m > 0$ for $k = 1, \dots, m$.

C1 implies that $\underline{A}_s \cdots \underline{A}_{t-1} u_t > 0$ for $1 \leq s \leq t \leq m$. One also has $B_k - \underline{A}_k = u_k b_k^T$ where

$$b_k = \begin{pmatrix} \frac{2\hat{P}_{k,k-1}^+(\bar{p})}{v_k} - \frac{P_{k,k-1} + P'_{k,k-1}}{v_k} & \frac{2\hat{Q}_{k,k-1}^+(\bar{q})}{v_k} - \frac{Q_{k,k-1} + Q'_{k,k-1}}{v_k} \end{pmatrix}^T \geq 0$$

for $k = 1, \dots, m-1$. To show that $B_k \cdots B_{m-1} u_m > 0$ for $k = 1, \dots, m$, we prove the following lemma.

Lemma 3. *Given $m \geq 1$ and $d \geq 1$. Let $\underline{A}_1, \dots, \underline{A}_{m-1}, A_1, \dots, A_{m-1} \in \mathbb{R}^{d \times d}$ and $u_1, \dots, u_m \in \mathbb{R}^d$ satisfy*

- $\underline{A}_s \cdots \underline{A}_{t-1} u_t > 0$ when $1 \leq s \leq t \leq m$;
- there exists $b_k \in \mathbb{R}^d$ that satisfies $b_k \geq 0$ and $A_k - \underline{A}_k = u_k b_k^T$, for $k = 1, \dots, m-1$.

Then

$$A_s \cdots A_{t-1} u_t > 0 \tag{21}$$

when $1 \leq s \leq t \leq m$.

Proof. We prove that (21) holds when $1 \leq t \leq s \leq m$ by mathematical induction on $t-s$.

- i) When $t-s=0$, one has $A_s \cdots A_{t-1} u_t = u_t = \underline{A}_s \cdots \underline{A}_{t-1} u_t > 0$.
- ii) Assume that (21) holds when $t-s=0, 1, \dots, K$ ($0 \leq K \leq m-2$). When $t-s=K+1$, one has

$$\begin{aligned} A_s \cdots A_k \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t &= A_s \cdots A_{k-1} \underline{A}_k \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t + A_s \cdots A_{k-1} (A_k - \underline{A}_k) \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t \\ &= A_s \cdots A_{k-1} \underline{A}_k \cdots \underline{A}_{t-1} u_t + A_s \cdots A_{k-1} u_k b_k^T \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t \\ &= A_s \cdots A_{k-1} \underline{A}_k \cdots \underline{A}_{t-1} u_t + (b_k^T \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t) A_s \cdots A_{k-1} u_k \end{aligned}$$

for $k = s, \dots, t-1$. Since $b_k \geq 0$ and $\underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t > 0$, the term $b_k^T \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t \geq 0$. According to induction hypothesis, $A_s \cdots A_{k-1} u_k > 0$. Hence,

$$A_s \cdots A_k \underline{A}_{k+1} \cdots \underline{A}_{t-1} u_t \geq A_s \cdots A_{k-1} \underline{A}_k \cdots \underline{A}_{t-1} u_t$$

for $k = s, \dots, t-1$. By substituting $k = t-1, \dots, s$ in turn, one obtains

$$A_s \cdots A_{t-1} u_t \geq A_s \cdots A_{t-2} \underline{A}_{t-1} u_t \geq \cdots \geq \underline{A}_s \cdots \underline{A}_{t-1} u_t > 0,$$

i.e., (21) holds when $t-s=K+1$.

According to (i) and (ii), (21) holds when $t-s=0, \dots, m-1$. This completes the proof of Lemma 3. \square

Lemma 3 implies that $B_s \cdots B_{t-1} u_t > 0$ when $1 \leq s \leq t \leq m$. In particular, $B_k \cdots B_{m-1} u_m > 0$ for $k = 1, \dots, m$, and therefore $\Delta S_{k,k-1} > 0$ for $k = 0, \dots, m-1$.

Next show that $\Delta S_{k,k-1} > 0$ for $k = 0, \dots, m-1$ implies $v' \geq v$. Note that $\Delta S_{ij} = 0$ when $(i, j) \notin \mathcal{P}_{m-1}$ and $\Delta \ell_{ij} = 0$ when $(i, j) \notin \mathcal{P}_m$. It follows from (5c) that

$$\Delta v_i - \Delta v_j = 2\text{Re}(\bar{z}_{ij} \Delta S_{ij}) - |z_{ij}|^2 \Delta \ell_{ij} = 0$$

when $(i, j) \notin \mathcal{P}_m$. When $(i, j) \in \mathcal{P}_m$, one has $(i, j) = (k, k-1)$ for some $k \in \{1, \dots, m\}$, and therefore

$$\begin{aligned} \Delta v_i - \Delta v_j &= 2\text{Re}(\bar{z}_{k,k-1} \Delta S_{k,k-1}) - |z_{k,k-1}|^2 \Delta \ell_{k,k-1} \\ &\geq \text{Re}(\bar{z}_{k,k-1} \Delta S_{k,k-1}) - |z_{k,k-1}|^2 \Delta \ell_{k,k-1} \\ &= \text{Re}(\bar{z}_{k,k-1} (\Delta S_{k,k-1} - z_{k,k-1} \Delta \ell_{k,k-1})) \\ &= \text{Re}(\bar{z}_{k,k-1} \Delta S_{k-1,k-2}) > 0. \end{aligned}$$

Hence, $\Delta v_i \geq \Delta v_j$ whenever $(i, j) \in \mathcal{E}$. Add the inequalities over path \mathcal{P}_i to obtain $\Delta v_i \geq \Delta v_0 = 0$ for $i \in \mathcal{N}^+$, i.e., $v' \geq v$. This completes the proof of Claim 3.

APPENDIX C

PROOF OF PROPOSITION 1

Let \underline{A} and \underline{A}' denote the matrices with respect to (\bar{p}, \bar{q}) and (\bar{p}', \bar{q}') respectively, i.e., denote

$$\underline{A}'_i = I - \frac{2}{\underline{v}_i} u_i \left(\hat{P}_{ij}^+(\bar{p}') \hat{Q}_{ij}^+(\bar{q}') \right) \text{ and } \underline{A}_i = I - \frac{2}{\underline{v}_i} u_i \left(\hat{P}_{ij}^+(\bar{p}) \hat{Q}_{ij}^+(\bar{q}) \right)$$

for $(i, j) \in \mathcal{E}$. When $(\bar{p}, \bar{q}) \leq (\bar{p}', \bar{q}')$, one has $\underline{A}_{l_k} - \underline{A}'_{l_k} = u_{l_k} b_{l_k}^T$ where

$$b_{l_k} = \frac{2}{\underline{v}_{l_k}} \begin{pmatrix} \hat{P}_{l_k l_{k-1}}^+(\bar{p}') - \hat{P}_{l_k l_{k-1}}^+(\bar{p}) \\ \hat{Q}_{l_k l_{k-1}}^+(\bar{q}') - \hat{Q}_{l_k l_{k-1}}^+(\bar{q}) \end{pmatrix} \geq 0$$

for any $l \in \mathcal{L}$ and any $k \in \{1, \dots, n_l\}$.

If $\underline{A}'_{l_s} \cdots \underline{A}'_{l_{t-1}} u_{l_t} > 0$ for any $l \in \mathcal{L}$ and any s, t such that $1 \leq s \leq t \leq n_l$, then it follows from Lemma 3 that $\underline{A}_{l_s} \cdots \underline{A}_{l_{t-1}} u_{l_t} > 0$ for any $l \in \mathcal{L}$ any s, t such that $1 \leq s \leq t \leq n_l$. This completes the proof of Proposition 1.

APPENDIX D

PROOF OF THEOREM 3

Assume that f_i is convex for $i \in \mathcal{N}$, that \mathcal{S}_i is convex for $i \in \mathcal{N}^+$, that SOCP-m is exact, and that SOCP-m has at least one solution. Let $\tilde{w} = (\tilde{s}, \tilde{S}, \tilde{v}, \tilde{\ell}, \tilde{s}_0)$ and $\hat{w} = (\hat{s}, \hat{S}, \hat{v}, \hat{\ell}, \hat{s}_0)$ denote two arbitrary SOCP-m solutions. It suffices to show that $\tilde{w} = \hat{w}$.

Since SOCP-m is exact, $\tilde{v}_i \tilde{\ell}_{ij} = |\tilde{S}_{ij}|^2$ and $\hat{v}_i \hat{\ell}_{ij} = |\hat{S}_{ij}|^2$ for $(i, j) \in \mathcal{E}$. Define $w := (\tilde{w} + \hat{w})/2$. Since SOCP-m is convex, w also solves SOCP-m. Hence, $v_i \ell_{ij} = |S_{ij}|^2$ for $(i, j) \in \mathcal{E}$. Substitute $v_i = (\tilde{v}_i + \hat{v}_i)/2$, $\ell_{ij} = (\tilde{\ell}_{ij} + \hat{\ell}_{ij})/2$, and $S_{ij} = (\tilde{S}_{ij} + \hat{S}_{ij})/2$ to obtain

$$\hat{S}_{ij} \tilde{S}_{ij}^H + \tilde{S}_{ij} \hat{S}_{ij}^H = \hat{v}_i \tilde{\ell}_{ij} + \tilde{v}_i \hat{\ell}_{ij}$$

for $(i, j) \in \mathcal{E}$. The right hand side

$$\hat{v}_i \tilde{\ell}_{ij} + \tilde{v}_i \hat{\ell}_{ij} = \hat{v}_i \frac{|\tilde{S}_{ij}|^2}{\tilde{v}_i} + \tilde{v}_i \frac{|\hat{S}_{ij}|^2}{\hat{v}_i} \geq 2|\tilde{S}_{ij}||\hat{S}_{ij}|,$$

and the equality is attained if and only if $|\tilde{S}_{ij}|/\tilde{v}_i = |\hat{S}_{ij}|/\hat{v}_i$. The left hand side

$$\hat{S}_{ij} \tilde{S}_{ij}^H + \tilde{S}_{ij} \hat{S}_{ij}^H \leq 2|\tilde{S}_{ij}||\hat{S}_{ij}|,$$

and the equality is attained if and only if $\angle \hat{S}_{ij} = \angle \tilde{S}_{ij}$. Hence, $\tilde{S}_{ij}/\tilde{v}_i = \hat{S}_{ij}/\hat{v}_i$ for $(i, j) \in \mathcal{E}$.

Introduce $\hat{v}_0 := \tilde{v}_0 := v_0$ and define $\eta_i := \hat{v}_i/\tilde{v}_i$ for $i \in \mathcal{N}$, then $\eta_0 = 1$ and $\hat{S}_{ij} = \eta_i \tilde{S}_{ij}$ for $(i, j) \in \mathcal{E}$. Hence,

$$\hat{\ell}_{ij} = \frac{|\hat{S}_{ij}|^2}{\hat{v}_i} = \frac{|\eta_i \tilde{S}_{ij}|^2}{\eta_i \tilde{v}_i} = \eta_i \frac{|\tilde{S}_{ij}|^2}{\tilde{v}_i} = \eta_i \tilde{\ell}_{ij}$$

and therefore

$$\eta_j = \frac{\hat{v}_j}{\tilde{v}_j} = \frac{\hat{v}_i - 2\text{Re}(z_{ij}^H \hat{S}_{ij}) + |z_{ij}|^2 \hat{\ell}_{ij}}{\tilde{v}_i - 2\text{Re}(z_{ij}^H \tilde{S}_{ij}) + |z_{ij}|^2 \tilde{\ell}_{ij}} = \eta_i$$

for $(i, j) \in \mathcal{E}$. Since the network $(\mathcal{N}, \mathcal{E})$ is connected, $\eta_i = \eta_0 = 1$ for $i \in \mathcal{N}$. This implies $\hat{w} = \tilde{w}$ and completes the proof of Theorem 3.

APPENDIX E

PROOF OF THEOREM 4

Theorem 4 follows from Claims 5–9.

Claim 5. Assume that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. If $\hat{P}_{ij}(\bar{p}) \leq 0$, $\hat{Q}_{ij}(\bar{q}) \leq 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$, then C1 holds.

Proof. If $\hat{P}_{ij}(\bar{p}) \leq 0$, $\hat{Q}_{ij}(\bar{q}) \leq 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$, then $\underline{A}_{l_k} = I$ for any $l \in \mathcal{L}$ and any $k \in \{1, \dots, n_l - 1\}$. It follows that $\underline{A}_{l_s} \cdots \underline{A}_{l_{t-1}} u_t = u_t > 0$ for any $l \in \mathcal{L}$ and any s, t such that $1 \leq s \leq t \leq n_l$, i.e., C1 holds. \square

Claim 6. Assume that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \text{Re}(s) \leq \bar{p}_i, \text{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. If $r_{ij}/x_{ij} = r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$, and $\underline{v}_i - 2r_{ij}\hat{P}_{ij}^+(\bar{p}) - 2x_{ij}\hat{Q}_{ij}^+(\bar{q}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$, then C1 holds.

Proof. Assume that $r_{ij}/x_{ij} = r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$, and that $\underline{v}_i - 2r_{ij}\hat{P}_{ij}^+(\bar{p}) - 2x_{ij}\hat{Q}_{ij}^+(\bar{q}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$. Fix an arbitrary $l \in \mathcal{L}$, and assume $l_k = k$ for $k = 0, \dots, n_l$ without loss of generality. Fix an arbitrary $t \in \{1, \dots, n_l\}$, and define $(\alpha_s \beta_s)^T := \underline{A}_s \cdots \underline{A}_{t-1} u_t$ for $s = 1, \dots, t$. Then it suffices to prove that $\alpha_s > 0$ and $\beta_s > 0$ for $s = 1, \dots, t$. In particular, we prove

$$\alpha_s > 0, \beta_s > 0, \alpha_s/\beta_s = r_{10}/x_{10} \tag{22}$$

inductively for $s = t, t-1, \dots, 1$. Define $\eta := r_{10}/x_{10}$ and note that $r_{ij}/x_{ij} = \eta$ for $(i, j) \in \mathcal{E}$.

i) When $s = t$, one has $\alpha_s = r_{t,t-1}$, $\beta_s = x_{t,t-1}$, and $\alpha_s/\beta_s = \eta$. Therefore (22) holds.

ii) Assume that (22) holds for $s = k$ ($2 \leq k \leq t$), then $(\alpha_k \ \beta_k)^T = cu_{k-1}$ for some $c \in \mathbb{R}$. It follows that

$$\begin{aligned} \begin{pmatrix} \alpha_{k-1} \\ \beta_{k-1} \end{pmatrix} &= \left[I - \frac{2}{\underline{v}_{k-1}} u_{k-1} \begin{pmatrix} \hat{P}_{k-1,k-2}^+(\bar{p}) & \hat{Q}_{k-1,k-2}^+(\bar{q}) \end{pmatrix} \right] \begin{pmatrix} \alpha_k \\ \beta_k \end{pmatrix} \\ &= \left(1 - \frac{2}{\underline{v}_{k-1}} \begin{pmatrix} \hat{P}_{k-1,k-2}^+(\bar{p}) & \hat{Q}_{k-1,k-2}^+(\bar{q}) \end{pmatrix} u_{k-1} \right) \begin{pmatrix} \alpha_k \\ \beta_k \end{pmatrix} \\ &= \frac{1}{\underline{v}_{k-1}} \left(\underline{v}_{k-1} - 2r_{k-1,k-2} \hat{P}_{k-1,k-2}^+(\bar{p}) - 2x_{k-1,k-2} \hat{Q}_{k-1,k-2}^+(\bar{q}) \right) \begin{pmatrix} \alpha_k \\ \beta_k \end{pmatrix} > 0 \end{aligned}$$

and $\alpha_{k-1}/\beta_{k-1} = \alpha_k/\beta_k = \eta$. Hence, (22) holds for $s = k - 1$.

According to (i) and (ii), (22) holds for $s = t, t - 1, \dots, 1$. This completes the proof of Claim 6. \square

Claim 7. Assume that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \operatorname{Re}(s) \leq \bar{p}_i, \operatorname{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. If $r_{ij}/x_{ij} \geq r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$, and $\hat{P}_{ij}(\bar{p}) \leq 0$, $\underline{v}_i - 2x_{ij} \hat{Q}_{ij}^+(\bar{q}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$, then C1 holds.

Proof. Assume that $r_{ij}/x_{ij} \geq r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$, and that $\hat{P}_{ij}(\bar{p}) \leq 0$, $\underline{v}_i - 2x_{ij} \hat{Q}_{ij}^+(\bar{q}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$. Fix an arbitrary $l \in \mathcal{L}$, and assume $l_k = k$ for $k = 0, \dots, n_l$ without loss of generality. Fix an arbitrary $t \in \{1, \dots, n_l\}$, and define $(\alpha_s \ \beta_s)^T := \underline{A}_s \cdots \underline{A}_{t-1} u_t$ for $s = 1, \dots, t$. Then it suffices to prove that $\alpha_s > 0$ and $\beta_s > 0$ for $s = 1, \dots, t$. In particular, we prove

$$\alpha_s > 0, \beta_s > 0, \alpha_s/\beta_s \geq r_{t,t-1}/x_{t,t-1} \quad (23)$$

inductively for $s = t, t - 1, \dots, 1$.

i) When $s = t$, one has $\alpha_s = r_{t,t-1}$, $\beta_s = x_{t,t-1}$, and $\alpha_s/\beta_s = r_{t,t-1}/x_{t,t-1}$. Therefore (23) holds.

ii) Assume that (23) holds for $s = k$ ($2 \leq k \leq t$). Noting that $\hat{P}_{k-1,k-2}^+(\bar{p}) = 0$, one has

$$\begin{aligned} \begin{pmatrix} \alpha_{k-1} \\ \beta_{k-1} \end{pmatrix} &= \left[I - \frac{2}{\underline{v}_{k-1}} u_{k-1} \begin{pmatrix} \hat{P}_{k-1,k-2}^+(\bar{p}) & \hat{Q}_{k-1,k-2}^+(\bar{q}) \end{pmatrix} \right] \begin{pmatrix} \alpha_k \\ \beta_k \end{pmatrix} \\ &= \begin{pmatrix} \alpha_k \\ \beta_k \end{pmatrix} - \frac{2}{\underline{v}_{k-1}} u_{k-1} \hat{Q}_{k-1,k-2}^+(\bar{q}) \beta_k. \end{aligned}$$

Hence, $\beta_{k-1} = \frac{1}{\underline{v}_{k-1}} \left(\underline{v}_{k-1} - 2x_{k-1,k-2} \hat{Q}_{k-1,k-2}^+(\bar{q}) \right) \beta_k > 0$. Then,

$$\begin{aligned} \alpha_{k-1} &= \alpha_k - \frac{2r_{k-1,k-2} \hat{Q}_{k-1,k-2}^+(\bar{q})}{\underline{v}_{k-1}} \beta_k \\ &\geq \left(\frac{r_{t,t-1}}{x_{t,t-1}} - \frac{2r_{k-1,k-2} \hat{Q}_{k-1,k-2}^+(\bar{q})}{\underline{v}_{k-1}} \right) \beta_k \\ &\geq \frac{r_{t,t-1}}{x_{t,t-1}} \left(1 - \frac{2x_{k-1,k-2} \hat{Q}_{k-1,k-2}^+(\bar{q})}{\underline{v}_{k-1}} \right) \beta_k = \frac{r_{t,t-1}}{x_{t,t-1}} \beta_{k-1} > 0. \end{aligned}$$

The second inequality is due to $r_{k-1,k-2}/x_{k-1,k-2} \leq r_{t,t-1}/x_{t,t-1}$. Hence, (23) holds for $s = k - 1$.

According to (i) and (ii), (23) holds for $s = t, t - 1, \dots, 1$. This completes the proof of Claim 7. \square

Claim 8. Assume that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \operatorname{Re}(s) \leq \bar{p}_i, \operatorname{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. If $r_{ij}/x_{ij} \leq r_{jk}/x_{jk}$ for any $(i, j), (j, k) \in \mathcal{E}$, and $\hat{Q}_{ij}(\bar{q}) \leq 0$, $\underline{v}_i - 2r_{ij}\hat{P}_{ij}^+(\bar{p}) > 0$ for any $(i, j) \in \mathcal{E}$ such that $i \notin \mathcal{L}$, then C1 holds.

Proof. The proof of Claim 8 is similar to that of Claim 7, and omitted for brevity. \square

Claim 9. Assume that there exists \bar{p}_i and \bar{q}_i such that $\mathcal{S}_i \subseteq \{s \in \mathbb{C} \mid \operatorname{Re}(s) \leq \bar{p}_i, \operatorname{Im}(s) \leq \bar{q}_i\}$ for $i \in \mathcal{N}^+$. If

$$\begin{pmatrix} \prod_{(k,l) \in \mathcal{P}_j} \left(1 - \frac{2r_{kl}\hat{P}_{kl}^+(\bar{p})}{\underline{v}_k}\right) & - \sum_{(k,l) \in \mathcal{P}_j} \frac{2r_{kl}\hat{Q}_{kl}^+(\bar{q})}{\underline{v}_k} \\ - \sum_{(k,l) \in \mathcal{P}_j} \frac{2x_{kl}\hat{P}_{kl}^+(\bar{p})}{\underline{v}_k} & \prod_{(k,l) \in \mathcal{P}_j} \left(1 - \frac{2x_{kl}\hat{Q}_{kl}^+(\bar{q})}{\underline{v}_k}\right) \end{pmatrix} \begin{pmatrix} r_{ij} \\ x_{ij} \end{pmatrix} > 0 \quad (24)$$

for $(i, j) \in \mathcal{E}$, then C1 holds.

The following lemma is used in the proof of Claim 9.

Lemma 4. Given $i \geq 1$; $c, d, e, f \in \mathbb{R}^i$ such that $0 < c \leq 1$, $d \geq 0$, $e \geq 0$, and $0 < f \leq 1$ componentwise; and $u \in \mathbb{R}^2$ that satisfies $u > 0$. If

$$\begin{pmatrix} \prod_{j=1}^i c_j & - \sum_{j=1}^i d_j \\ - \sum_{j=1}^i e_j & \prod_{j=1}^i f_j \end{pmatrix} u > 0, \quad (25)$$

then

$$\begin{pmatrix} c_j & -d_j \\ -e_j & f_j \end{pmatrix} \dots \begin{pmatrix} c_i & -d_i \\ -e_i & f_i \end{pmatrix} u > 0 \quad (26)$$

for $j = 1, \dots, i$.

Proof. Lemma 4 can be proved by mathematical induction on i .

i) When $i = 1$, Lemma 4 is trivial.

ii) Assume that Lemma 4 holds for $i = K$ ($K \geq 1$). When $i = K + 1$, if

$$\begin{pmatrix} \prod_{j=1}^i c_j & - \sum_{j=1}^i d_j \\ - \sum_{j=1}^i e_j & \prod_{j=1}^i f_j \end{pmatrix} u > 0,$$

one can prove that (26) holds for $j = 1, \dots, K + 1$ as follows.

First prove that (26) holds for $j = 2, \dots, K + 1$. The idea is to construct some $c', d', e', f' \in \mathbb{R}^K$ and apply the induction hypothesis. The construction is

$$\begin{aligned} c' &= (c_2, c_3, \dots, c_{K+1}), & d' &= (d_2, d_3, \dots, d_{K+1}), \\ e' &= (e_2, e_3, \dots, e_{K+1}), & f' &= (f_2, f_3, \dots, f_{K+1}). \end{aligned}$$

Clearly, c', d', e', f' satisfies $0 < c' \leq 1$, $d' \geq 0$, $e' \geq 0$, $0 < f' \leq 1$ componentwise and

$$\begin{pmatrix} \prod_{j=1}^K c'_j & -\sum_{j=1}^K d'_j \\ -\sum_{j=1}^K e'_j & \prod_{j=1}^K f'_j \end{pmatrix} u = \begin{pmatrix} \prod_{j=2}^{K+1} c_j & -\sum_{j=2}^{K+1} d_j \\ -\sum_{j=2}^{K+1} e_j & \prod_{j=2}^{K+1} f_j \end{pmatrix} u \geq \begin{pmatrix} \prod_{j=1}^{K+1} c_j & -\sum_{j=1}^{K+1} d_j \\ -\sum_{j=1}^{K+1} e_j & \prod_{j=1}^{K+1} f_j \end{pmatrix} u > 0.$$

Apply the induction hypothesis to obtain that

$$\begin{pmatrix} c'_j & -d'_j \\ -e'_j & f'_j \end{pmatrix} \cdots \begin{pmatrix} c'_K & -d'_K \\ -e'_K & f'_K \end{pmatrix} u > 0$$

for $j = 1, \dots, K$, i.e., (26) holds for $j = 2, \dots, K + 1$.

Next prove that (26) holds for $j = 1$. The idea is still to construct some $c', d', e', f' \in \mathbb{R}^K$ and apply the induction hypothesis. The construction is

$$\begin{aligned} c' &= (c_1 c_2, c_3, \dots, c_{K+1}), & d' &= (d_1 + d_2, d_3, \dots, d_{K+1}), \\ e' &= (e_1 + e_2, e_3, \dots, e_{K+1}), & f' &= (f_1 f_2, f_3, \dots, f_{K+1}). \end{aligned}$$

Clearly, c', d', e', f' satisfies $0 < c' \leq 1$, $d' \geq 0$, $e' \geq 0$, $0 < f' \leq 1$ componentwise and

$$\begin{pmatrix} \prod_{j=1}^K c'_j & -\sum_{j=1}^K d'_j \\ -\sum_{j=1}^K e'_j & \prod_{j=1}^K f'_j \end{pmatrix} u = \begin{pmatrix} \prod_{j=1}^{K+1} c_j & -\sum_{j=1}^{K+1} d_j \\ -\sum_{j=1}^{K+1} e_j & \prod_{j=1}^{K+1} f_j \end{pmatrix} u > 0.$$

Apply the induction hypothesis to obtain

$$v'_2 := \begin{pmatrix} c'_2 & -d'_2 \\ -e'_2 & f'_2 \end{pmatrix} \cdots \begin{pmatrix} c'_K & -d'_K \\ -e'_K & f'_K \end{pmatrix} u > 0, \quad v'_1 := \begin{pmatrix} c'_1 & -d'_1 \\ -e'_1 & f'_1 \end{pmatrix} \cdots \begin{pmatrix} c'_K & -d'_K \\ -e'_K & f'_K \end{pmatrix} u > 0.$$

It follows that

$$\begin{aligned} \begin{pmatrix} c_1 & -d_1 \\ -e_1 & f_1 \end{pmatrix} \cdots \begin{pmatrix} c_{K+1} & -d_{K+1} \\ -e_{K+1} & f_{K+1} \end{pmatrix} u &= \begin{pmatrix} c_1 & -d_1 \\ -e_1 & f_1 \end{pmatrix} \begin{pmatrix} c_2 & -d_2 \\ -e_2 & f_2 \end{pmatrix} \begin{pmatrix} c_3 & -d_3 \\ -e_3 & f_3 \end{pmatrix} \cdots \begin{pmatrix} c_{K+1} & -d_{K+1} \\ -e_{K+1} & f_{K+1} \end{pmatrix} u \\ &= \begin{pmatrix} c_1 & -d_1 \\ -e_1 & f_1 \end{pmatrix} \begin{pmatrix} c_2 & -d_2 \\ -e_2 & f_2 \end{pmatrix} v'_2 \\ &= \begin{pmatrix} c_1 c_2 + d_1 e_2 & -c_1 d_2 - d_1 f_2 \\ -e_1 c_2 - f_1 e_2 & f_1 f_2 + e_1 d_2 \end{pmatrix} v'_2 \\ &\geq \begin{pmatrix} c_1 c_2 & -d_2 - d_1 \\ -e_1 - e_2 & f_1 f_2 \end{pmatrix} v'_2 \\ &= \begin{pmatrix} c'_1 & -d'_1 \\ -e'_1 & f'_1 \end{pmatrix} v'_2 = v'_1 > 0, \end{aligned}$$

i.e., (26) holds for $j = 1$.

To this end, we have proved that (26) holds for $j = 1, \dots, K + 1$, i.e., Lemma 4 also holds for $i = K + 1$.

According to (i) and (ii), Lemma 4 holds for $i \geq 1$. \square

Proof of Claim 9. Fix an arbitrary $l \in \mathcal{L}$, and assume $l_k = k$ for $k = 0, \dots, n_l$ without loss of generality. Fix an arbitrary $t \in \{1, \dots, n_l\}$, then it suffices to prove that $\underline{A}_s \cdots \underline{A}_{t-1} u_t > 0$ for $s = 1, \dots, t$. Denote $r_k := r_{k, k-1}$ and $S_k := S_{k, k-1}$ for $k = 1, \dots, t$ for brevity.

Substitute $(i, j) = (k, k - 1)$ in (24) to obtain

$$\begin{pmatrix} \prod_{s=1}^{k-1} \left(1 - \frac{2r_s \hat{P}_s^+}{v_s} \right) & - \sum_{s=1}^{k-1} \frac{2r_s \hat{Q}_s^+}{v_s} \\ - \sum_{s=1}^{k-1} \frac{2x_s \hat{P}_s^+}{v_s} & \prod_{s=1}^{k-1} \left(1 - \frac{2x_s \hat{Q}_s^+}{v_s} \right) \end{pmatrix} \begin{pmatrix} r_k \\ x_k \end{pmatrix} > 0 \quad (27)$$

for $k = 1, \dots, t$. Hence,

$$\prod_{s=1}^{k-1} \left(1 - \frac{2r_s \hat{P}_s^+}{v_s} \right) r_k > \sum_{s=1}^{k-1} \frac{2r_s \hat{Q}_s^+(\bar{q})}{v_s} x_k \geq 0$$

for $k = 1, \dots, t$. It follows that $1 - 2r_k \hat{P}_k^+ / v_k > 0$ for $k = 1, \dots, t - 1$. Similarly, $1 - 2x_k \hat{Q}_k^+ / v_k > 0$ for $k = 1, \dots, t - 1$. Then, substitute $k = t$ in (27) and apply Lemma 4 to obtain

$$\begin{pmatrix} 1 - \frac{2r_s \hat{P}_s^+}{v_s} & - \frac{2r_s \hat{Q}_s^+}{v_s} \\ \frac{v_s}{2x_s \hat{P}_s^+} & 1 - \frac{2x_s \hat{Q}_s^+}{v_s} \end{pmatrix} \cdots \begin{pmatrix} 1 - \frac{2r_{t-1} \hat{P}_{t-1}^+(\bar{p})}{v_{t-1}} & - \frac{2r_{t-1} \hat{Q}_{t-1}^+(\bar{q})}{v_{t-1}} \\ - \frac{v_{t-1}}{2x_{t-1} \hat{P}_{t-1}^+(\bar{p})} & 1 - \frac{2x_{t-1} \hat{Q}_{t-1}^+(\bar{p})}{v_{t-1}} \end{pmatrix} \begin{pmatrix} r_t \\ x_t \end{pmatrix} > 0$$

for $s = 1, \dots, t$, i.e., $\underline{A}_s \cdots \underline{A}_{t-1} u_t > 0$ for $s = 1, \dots, t$. This completes the proof of Claim 9. \square