

# Performance Assessment of Bacterial Foraging based Power System Stabilizer in Multi-Machine Power System

**Nader M.A. Ibrahim**

Faculty of Industrial Education-Suez University/Electrical Department, Suez, Egypt  
 E-mail: Nader.Ibrahim@suezuniv.edu.eg.

**Basem E. Elnaghi**

Faculty of Engineering-Suez Canal University / Electrical Engineering Department, Ismailia, Egypt  
 E-mail: basem\_elhady@yahoo.com

**Hamed A. Ibrahim**

Faculty of Industrial Education-Suez University/Electrical Department, Suez, Egypt  
 E-mail: hamed\_4a@yahoo.com

**Hossam E.A. Talaat**

Electrical Engineering Department, Faculty of Engineering & Technology-Future University in Egypt, Cairo, Egypt  
 E-mail: hossam.eldeen@fue.edu.eg

Received: 16 September 2018; Accepted: 31 October 2018; Published: 08 July 2019

**Abstract**—This paper describes the process of power system stabilizer (PSS) optimization by using bacterial foraging (BG) to improve the power system stability and damping out the oscillation during large and small disturbances in a multi-machine power system. The proposed PSS type is P. Kundur (Lead-Lag) with speed deviation as the input signal. BG used to optimize the PSS gains. The proposed BG based delta w lead-lag PSS (P. Kundur structure) (BG-PSS) evaluated in the well-known benchmark simulation problem P. Kundur 4-machines 11-buses 2-areas power system. The BG-PSS compared with MB-PSS with simplified settings: IEEE@ type PSS4B according to IEEE Std. 421.5, Conventional Delta w PSS (as the proposed PSS without optimization) from P. Kundur, and Conventional Acceleration Power (Delta Pa) PSS to demonstrate its robustness and superiority versus the three PSSs types to damp out the inter-area oscillations in a multi-machine power system. The damping ratio and the real part of the eigenvalues used as the fitness function in the optimization process. The nonlinear simulation results obtained in the MATLAB / SIMULINK environment prove that the proposed PSS is highly effective, robust, & superior to the other used controllers in restrictive the inter-area oscillation in a large power system & to maintain the wide-area stability of the system. Also, the performance indices eigenvalue analysis, peak overshoot, settling time, and steady-state error used to validate the superior oscillation damping and fast recovered transient dynamic behavior over the three considered controllers.

**Index Terms**—Multi-machine power system model, artificial intelligent, power system stabilizer optimization, bacterial foraging technique, performance indices.

## NOMENCLATURE

$\delta'$ : The differentiation of rotor angle deviation.  
 $\omega_r$ : Rotor speed.  
 $\omega_0$ : The rated rotor speed in elec.  $\text{Rad/Sec} = 22\pi f_0$   
 $P_m$ : The mechanical power.  
 $P_e$ : Electrical power  
 $D$ : Damping coefficient.  
 $K_D$ : Damping constant.  
 $M$ : Inertia coefficient.  
 $e'_q - e'_d$ : Differentiation of (q & d)-axis transient voltage respectively.  
 $X_d - X_q$ : (d & q)-axis synchronous reactance respectively.  
 $X'_d - X'_q$ : (d & q)-axis transient reactance respectively.  
 $T'_{do} - T'_{qo}$ : (d & q)- axis open circuit transient time constant respectively.  
 $T''_{do} - T''_{qo}$ : (d & q)- axis open circuit sub-transient time constant respectively.  
 $i_d - i_q$ : The stator phase currents of dq transformation.  
 $K_1: K_1$ : Constants of the linearized model.  
 $U$ : The vector of inputs to the system  
 $\Delta$ : Linearized incremental quantity  
 $T_M$ : Mechanical torque.

$K_A$  : Voltage regulator gain.  
 $T_A$  : Voltage regulator time constants.  
 $K_{STAB}$  : Lead-lag stabilizer gain.  
 $T_1, T_4$  : Lead-lag controller time constants.  
 $T_{CH}$  : Steam chest time constant.  
 $T_{RH}$  : Reheat time constant.  
 $T_{CO}$  : Crossover time constant.  
 $F_{HP}$  : High pressure turbine power fraction.  
 $F_{IP}$  : Intermediate pressure turbine power fraction.  
 $F_{LP}$  : Low pressure turbine power fraction.  
 $P_{GV}$  : Power at gate or valve outlet.  
 $P_0$  : Initial mechanical power of the speed governor.  
 $P_{UP} - P_{DOWN}$  : Limits of rate of change of power imposed by control valve rate limits.  
 $P_{MAX} - P_{MIN}$  : Power limits imposed by valve travel.

## I. INTRODUCTION

Large interconnected power systems are complex and contain a large number of dissimilar dynamic components and devices that connected to each other to provide the electric service to the customer through the wide area. This widespread area requires isolated systems with different operating points and conditions due to economical operations cost [1].

Bulk power transfer in interconnected systems through long weak transmission lines leads to inter-area oscillation from 0.1 to 0.7 Hz. Additionally, the isolated systems suffering from local mode from 0.7 to 2 Hz. These low-frequency oscillations (LFOs) may disturb the system operation and limit the bulk power transfer and may lead to interconnected system separation and blackout [2, 3].

Automatic Voltage Regulator (AVR) with high gain used as a solution to the LFOs, when applied in the excitation system which may cause carries an unfavorable effect upon the dynamic stability of the system by reducing the damping torque. A conventional power system stabilizer (CPSS) used to add a stabilizing signal to the AVR to increase the damping torque and improve the system stability [4, 5].

The CPSS composed of two stages. The gain stage, and the lead-lag stage, generally beside the washout filter with speed deviation as the input signal. In general, the CPSS strongly damps the local mode easily in some cases, but needs enhancements to generally damp LFOs types. This enhancement classified into three sets [6, 7].

Firstly, tuning CPSS parameters to optimize its performance using Meta-heuristic algorithms as in Strength Pareto Evolutionary Algorithm [8], cultural algorithms [9], Quasi-oppositional symbiotic organism search (QOSS) [10], & Salp Swarm Algorithm [11], moreover, artificial intelligent techniques as the BAT optimization algorithm (BATO) [12], Genetic Programming [13], ant lion's optimizer [14], and Bio-inspired Algorithms [1, 15].

Researchers found some lacks in GA performance, which looked at the application with greatly epistatic objective functions. Also, the hasty convergence of GA reduces its act and decreases the search capability [13, 15]

Secondly, PSS design, by robust & evolutionary control techniques as  $H^\infty$  control [16, 17], quantitative feedback theory [18], & sliding mode [19]. Thirdly, researchers work to enhance PSS performance by changing its structure, optimal and a suboptimal power system stabilizer [20], fractional-order proportional-integral-differential (FOPID) controller [21], multi-band PSS [7, 22].

The use of adaptive control solves the problem of the robust control in a linear system, which contain parameters are unknown and changing with time. The adaptation in a nonlinear system need more calculation than the linear system. So, through the parameter valuation step, the state can escape to infinity in finite time. That makes it a very complicated challenge for the adaptive system [6, 8].

Generally, CPSS optimization methods in the first category have advantages over the other two categories, that the CPSS structure is simple and by tuning is robust and guarantee system stability improvement without a heavy mathematical effort in the adaptation process which may delay the signal of the PSS in the second category and without increasing the structure of the CPSS as in the third category [7].

In this paper, the bacterial foraging algorithm used to optimize the parameter of the P. Kundur (Lead-Lag) PSS with speed deviation as input. The power system analyzed by using a power system analysis toolbox (PSAT). Eigenvalue analysis, settling time, maximum overshoot, & steady-state error indices used to confirm the robustness of the BG-PSS. Small & large disturbances used as the test condition to compare the performance of the BG-PSS with the three PSS MB-PSS with simplified settings: IEEE@ type PSS4B according to IEEE Std. 421.5, Conventional Delta w PSS from P. Kundur, and Conventional Acceleration Power (Delta Pa) PSS to demonstrate its robustness.

The paper outlines: Section II power system model and PSS structure. Section III power system analysis. Section IV optimization technique. Section V simulation. Finally, section VI conclusion.

## II. POWER SYSTEM MODEL AND PSS STRUCTURE

### A. Power system model

The power system model which used as a simulation problem is P. Kundur 4-machines 11-buses 2-areas power system. Fig.1., shown the one-line diagram of the system which its full details illustrated in [23].

The multi-machine system model described as differential equations, which stemmed from the model of the different devices that connected to each other as the generators, excitation systems, and controllers. In this work, the generators modeled by way of a d-q axis by using the 6-order model, and can be described by the following six differential equations [24]:

$$\delta_i' = \omega_{ri} - \omega_{oi} \quad (1)$$

$$\omega_{ri} = \frac{(P_{mi} - P_{ei} - D_i(\omega_{ri} - 1))}{M_i} \quad (2)$$

$$e'_{qi} = \frac{\left(-e'_{qi} - \left(X_{di} - X'_{di} - \frac{T''_{doi} X''_{di}}{T_{doi} X'_{di}} (X_{di} - X'_{di})\right) i_{di}\right)}{T''_{doi}} \quad (3)$$

$$e'_{di} = \frac{\left(-e'_{di} + \left(X_{qi} - X'_{qi} - \frac{T''_{qoi} X''_{qi}}{T_{qoi} X'_{qi}} (X_{qi} - X'_{qi})\right) i_{qi}\right)}{T''_{qoi}} \quad (4)$$

$$e''_{qi} = \frac{\left(-e''_{qi} + e'_{di} - \left(X'_{di} - X''_{di} + \frac{T''_{doi} X''_{di}}{T_{doi} X'_{di}} (X_{di} - X'_{di})\right) i_{di}\right)}{T''_{doi}} \quad (5)$$

$$e''_{di} = \frac{\left(-e''_{di} + e'_{qi} + \left(X'_{qi} - X''_{qi} + \frac{T''_{qoi} X''_{qi}}{T_{qoi} X'_{qi}} (X_{qi} - X'_{qi})\right) i_{qi}\right)}{T''_{qoi}} \quad (6)$$

All generators in the system connected to tandem compound, single reheat prime mover steam turbine connected to speed governing system. The details of the speed governor and the steam turbine clarified in the IEEE committee report [25].

Fig.2., (A & B) has shown the speed governor system for the steam turbine, and the tandem compound, single reheat prime mover steam turbine respectively. The voltage regulator type is DC1A excitation system model shown in fig.3. The details of the regulator revealed in the IEEE excitation model report IEEE Std. 412.5-2005 [26].

The Heffron-Philips block diagram for the multi-machine power system without PSS shown in fig.4. The block diagram, firstly, proposed in [27]. The constants are the interaction between the generators; the constants equations proved & discussed in [28].






Fig.1. The one-line diagram of two area 4-machine 11-bus system.



(A)



(B)

Fig.2. The dynamic models of: (A) The speed governor system for steam turbine & (B) The tandem compound, single reheat prime mover steam turbine.




Fig.3. Type-DC1A-DC commutator exciter.




Fig.4. Heffron-Philips block diagram of multi-machine power system without PSS.

### B. Power system stabilizer

The function of the power system stabilizer (PSS) is to add damping torque according to the generator rotor oscillation by adding it to the AVR signal in the generator excitation system [23]. In this paper, the PSS type used is Delta w PSS P. Kundur (Lead-Lag) with speed deviation as input signal shown in fig.5., the data of the stabilizer described in [23].

The optimized parameters are the stabilizer gain  $K_{STAB}$ , and the time constants  $T_1$ ,  $T_2$ , &  $T_4$ . The washout time constant  $T_w$  selects to be 10 Sec. The time constants  $T_1$  &  $T_3$  considered as lead time constants equal to each other. Where, the time constants  $T_2$  &  $T_4$  are considered as lag time constants also, equal to each other.

### III. POWER SYSTEM ANALYSIS

The power system analysis process depends on the power system analysis toolbox (PSAT) version 2.1.8

which created by F. Milano and available for a free charge at [29]. The PSAT is a MATLAB toolbox used for static and dynamic analysis of the electric power system. The PSAT has its own built-in library to draw the power system.

Table 1. displays the Eigenvalue analysis of the system state matrix which computed by PSAT toolbox, and the dominant state variable that has high participation value in each mode.

Table 1. reveals that the power system without PSS suffered from one inter-area mode, which has a frequency with 0.550 Hz. And damping ratio 0.035, and two local modes with frequency 1.13, & 1.15 with damping ratio 0.112, & 0.115 respectively.




Fig.5.The block diagram of P. Kundur (Lead-Lag) PSS.

Table 1. System modes without PSS

Eigenvalues		Frequency	Damping Ratio	Most Associated States
Real	Imaginary			
-0.78901	±7.1401	1.13638	0.1098	$\Delta\omega_2, \Delta\delta_2$
-0.84036	±7.2535	1.154431	0.11508	$\Delta\omega_4, \Delta\delta_4$
-0.13319	±3.4215	0.54454	0.038897	$\Delta\omega_3, \Delta\delta_3$

Furthermore, from the Eigenvalue, there are three swing modes, one inter-area, and two local modes. The two local modes accepted because of their damping ratio higher than 5%, which means the system is stable when exposed to this problem. However, the inter-area mode has a 0.035 restraining ratio, which makes the system goes to unstable and required additional damping torque from PSS to damp out this oscillation as quickly as possible.


The most associated variable called also the dominant variable. Its variables have a high participation factor in the dominant modes.

Fig.6., shown the compass plot for the mode shapes of the rotor angle modes. These mode shapes drawn from the right Eigenvectors which computed from the system Eigenvalues in the modes comprise a swing mode only.


The mode shape with a 1.13 Hz frequency is a local mode, with a generator G1 swing against the G2 in area 1. The local mode that has a 1.15 Hz frequency generates by the G3 swing in contrast to G4 in area 2. The third mode that produces a frequency of 0.55 Hz is an inter-area mode, which caused when the generators G1 & G2 in area 1 swing counter to the G3, and G4 in area 2.

The inter-area mode with damping ratio 0.03 is the most danger stability problems of the three swing modes that happens in this problem because this mode wouldn't be stable without the reaction of robust PSS against this LFO. Otherwise, the other two local modes which have a damping ratio higher than 0.05 can easily & shortly damped.

It's clear that from the summarized Eigenvalues & the mode shapes of the analyzed system without PSS (with manual excitation), the system is sensitive to any disturbance and can easily separate to isolated areas, which may expose the system to fully blackout.



(a) Local mode  $f = 1.1324\text{Hz}, \xi = 0.1128$  (b) Local mode  $f = 1.1545\text{Hz}, \xi = 0.11556$



(c) Inter-area mode  $f = 0.5504\text{Hz}, \xi = 0.035084$

Fig.6. The compass plot of the swing modes.

#### IV. OPTIMIZATION TECHNIQUE

The optimization technique used in this paper is an artificial intelligence technique called Bacterial Foraging Optimization Algorithm (BG) which, firstly, proposed by Passion in 2002. The BG based on the social foraging behavior Escherichia Coli (E. Coli) bacteria simulate the process of searching for foods in the human intestine [30]. The BG algorithm process involves four consecutive steps chemotaxis, swarming, reproduction, and elimination-dispersal [30].

In this paper, the BG toolbox used to consider as groups of M-files working in MATLAB background, which freely located at the Math-Work site [31].

The process of optimization depends on using the following (A) matrix which computed by state-space analysis from the Heffron-Phillip's block diagram of the multi-machine power system shown in fig.4. when connected to a lead-lag PSS shown in fig.5. The input of the CPSS is  $\Delta\omega_i$ , and the output signal of the CPSS used as input to the AVR block.

$$A = \begin{bmatrix} A_{11} & A_{12} & A_{13} & A_{14} \\ A_{21} & A_{22} & A_{23} & A_{24} \\ A_{31} & A_{32} & A_{33} & A_{34} \\ A_{41} & A_{42} & A_{43} & A_{44} \end{bmatrix} \quad (7)$$

The first row of the combined full (A) matrix represents the first generator G1. Equation from 8 to 11 the full details of the first row of the (A) full matrix which define the self-matrix of the G1 at A11, and the

effect of the other generators on it at (A12, A13, A14). It's easy to derive the other rows of the (A) matrix as G1. The (A) matrix used as a function in the MATLAB, then these functions called from the BG M-file to search for the optimized value of the fifth parameters mentioned in the previous section. The optimized parameters showed in table 2.

$$A_{11} = \begin{bmatrix} 0 & \omega_0 & 0 & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{111}}{M_1} & 0 & \frac{-K_{211}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{411}}{T'_{do}} & 0 & \frac{-1}{K_{311}T'_{do}} & \frac{1}{T'_{do}} & 0 & 0 & 0 & 0 \\ \frac{-K_A K_{511}}{T_A} & 0 & \frac{-K_A K_{611}}{T_A} & \frac{-1}{T_A} & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{111}}{M_1} & 0 & \frac{-K_{\omega} K_{211}}{M_1} & 0 & \frac{-1}{T_{\omega}} & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{111} T_1}{M_1 T_2} & 0 & \frac{-K_{\omega} K_{211} T_1}{M_1 T_2} & 0 & \frac{T_{\omega} - T_1}{T_{\omega} T_2} & \frac{-1}{T_2} & 0 & 0 \\ \frac{-K_{\omega} K_{111} T_1 T_3}{M_1 T_2 T_4} & 0 & \frac{-K_{\omega} K_{211} T_1 T_3}{M_1 T_2 T_4} & 0 & \frac{T_3 T_{\omega} - T_3 T_1}{T_{\omega} T_2 T_4} & \frac{T_2 - T_3}{T_4 T_2} & \frac{-1}{T_4} & 0 \end{bmatrix} \quad (8)$$

$$A_{12} = \begin{bmatrix} 0 & \omega_0 & 0 & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{112}}{M_1} & 0 & \frac{-K_{212}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{412}}{T'_{do}} & 0 & \frac{-1}{K_{312}T'_{do}} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_A K_{512}}{T_A} & 0 & \frac{-K_A K_{612}}{T_A} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{112}}{M_1} & 0 & \frac{-K_{\omega} K_{212}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{112} T_1}{M_1 T_2} & 0 & \frac{-K_{\omega} K_{212} T_1}{M_1 T_2} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{113} T_1 T_3}{M_1 T_2 T_4} & 0 & \frac{-K_{\omega} K_{212} T_1 T_3}{M_1 T_2 T_4} & 0 & 0 & 0 & 0 & 0 \end{bmatrix} \quad (9)$$

$$A_{12} = \begin{bmatrix} 0 & \omega_0 & 0 & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{114}}{M_1} & 0 & \frac{-K_{214}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{414}}{T'_{do}} & 0 & \frac{-1}{K_{314}T'_{do}} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_A K_{514}}{T_A} & 0 & \frac{-K_A K_{614}}{T_A} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{114}}{M_1} & 0 & \frac{-K_{\omega} K_{214}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{114} T_1}{M_1 T_2} & 0 & \frac{-K_{\omega} K_{214} T_1}{M_1 T_2} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{114} T_1 T_3}{M_1 T_2 T_4} & 0 & \frac{-K_{\omega} K_{214} T_1 T_3}{M_1 T_2 T_4} & 0 & 0 & 0 & 0 & 0 \end{bmatrix} \quad (11)$$

$$A_{12} = \begin{bmatrix} 0 & \omega_0 & 0 & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{113}}{M_1} & 0 & \frac{-K_{213}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{413}}{T'_{do}} & 0 & \frac{-1}{K_{313}T'_{do}} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_A K_{513}}{T_A} & 0 & \frac{-K_A K_{613}}{T_A} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{113}}{M_1} & 0 & \frac{-K_{\omega} K_{213}}{M_1} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{113} T_1}{M_1 T_2} & 0 & \frac{-K_{\omega} K_{213} T_1}{M_1 T_2} & 0 & 0 & 0 & 0 & 0 \\ \frac{-K_{\omega} K_{113} T_1 T_3}{M_1 T_2 T_4} & 0 & \frac{-K_{\omega} K_{213} T_1 T_3}{M_1 T_2 T_4} & 0 & 0 & 0 & 0 & 0 \end{bmatrix} \quad (10)$$

Table 2. shows the optimized parameters that obtained when depending on maximizing the minimum damping ratio fitness function that helps the BG in optimizing the values better than minimizing the maximum real part of the eigenvalue fitness function. This optimized lead-lag PSS by using BG tested in the multi-machine power system to prove its robustness.

Table 2. The CPSS optimized parameters by using BG Algorithm.

The parameter	The optimized Value
$K_{STAB}$	48.6813
$T_1, T_3$	0.036479 Sec.
$T_2, T_4$	0.01 Sec.

Performance of Three PSS for Interarea Oscillations




Fig.7. The Simulink multi-machine power system.

V. SIMULATION WORK

The simulation process depends on the most popular P. KUNDUR 4-machines 11-buses 2-areas system connected by a tie transmission line 220Km length, which proposed, firstly, as a stability problem in [23].

Also, edited by changing the reference generator from G3 to G2, which considered as the slack machine, the load voltage profile improved closer to unity by installing 187 MVAR. Capacitors in each area, and transmission & generator loss varied depending on the lines & generators details to be adequate in the MATLAB program as in [32]. This power system problem after editing founded as a demo called “performance of three PSS for inter-area oscillations” can select from (SimPowerSys) help tap into the MATLAB program.

The demo also proposed three PSS to investigate its performance against small and large signal stability tests. The test result showed that the multi-band (MB-PSS) with simplified settings: IEEE® type PSS4B according to IEEE Std 421.5 proposed in [26] robust & superior than Conventional Delta w PSS from P. Kundur (lead-lag PSS) and Conventional Acceleration Power (Delta Pa) PSS. All the previous three PSS data showed in [32]. The construction of the proposed PSS is the same of the second and third lead-lag PSS, but with (Delta w) as the input signal as the second PSS.

The simulation process consists of two steps small and large signal performance assessment. Fig.7., shown the Simulink multi-machine power system which used in simulation steps.

A. Small signal stability assessment

In this stage, the reference voltage of generator G1 will be increased by 5% since 12-cycles (from 1 to 1.2 Sec.). The effect of increasing the voltage magnitude of G1 by 5% of the bulk power transferred when the system without PSS shown in fig. 8.




Fig.8. The effect of small signal test on the bulk power transferred when the system without PSS.




Fig.9. The response of the system without PSS to the voltage magnitude of G1 increase by 5% for 12-cycles (A) Speed deviation of the four generators & (B) Terminal voltage of the four generators.

Fig.9., (A & B) showed the speed deviation and the terminal voltage of the four generators after the reference voltage of generator G1 will be increased by 5% for 12-cycles without PSS, respectively.

The system response without PSS to the small signal assessment in the previous three figures displays that the system becomes unstable when exposed to these conditions. That is also, cleared from the Eigenvalue analysis the system is unstable without PSS.

Fig.10., shown the effect of increasing the voltage magnitude of G1 by 5% for 12-cycles (from 1 to 1.2 Sec.) on the bulk power transferred when the system connected to BG based delta w lead-lag PSS (BG-PSS) in comparison to the system connected to the other three PSS: MB-PSS, Delta w lead-lag PSS, and Conventional Acceleration Power (Delta Pa) lead-lag PSS. Table 3. labels the LFO signal characteristics from fig.10.




Fig.10. The effect of the small disturbance on the bulk power transferred when the system connected to BG-PSS in comparison to the system connected to the other three PSS: MB-PSS, Delta w lead-lag PSS, and Conventional Acceleration Power (Delta Pa) lead-lag PSS.

Table 3. The characteristics of bulk power transfer oscillation.

PSS Types	Max. & Min. Overshoots In Percentage	Settling Time Sec.	Steady-State Error MW
MB-PSS	+4.0224% -35.8510%	5.9450	+0.1286%
Delta w Lead-Lag PSS	+4.3198% -10.0208%	4.9934	+0.0354%
Delta Pa Lead-Lag PSS	+3.9908% -5.8564%	9.3024	+0.0763%
BG Based lead-lag PSS	+3.7961% -6.7300%	3.0601	+0.0020%

Fig.10., and table 3. shreds of evidence that the using of BG-PSS is robustness & superior to the other three PSS. That is because the maximum overshoot & the settling time in the bulk power transferred are smaller than the other three PSSs.

The steady-state error value in the case of the proposed BG-PSS is the closest to 413MW (the initial power transferred from area1 to area2), while its higher than the initial value by 1.9855e-005%.

Fig.11., shown the speed deviation of G1 against increasing the voltage magnitude of G1 by 5% for 12-cycles when the system connected to BG-PSS in

comparison to the system connected to the other three PSS: MB-PSS, Delta w lead-lag PSS, and Conventional Acceleration Power (Delta Pa) lead-lag PSS. Table 4. describes the LFO signal characteristics from fig.11.




Fig.11. The system speed deviation response to the small disturbance when the system connected to BG-PSS in comparison to the system connected to the other three PSS: MB-PSS, Delta w lead-lag PSS, and Conventional Acceleration Power (Delta Pa) lead-lag PSS.

Table 4. The characteristics of the speed deviation oscillation.

PSS Types	Max. & Min. Overshoot.	Settling Time Sec.	Steady-State Error
MB-PSS	+1.748e-4 -8.7674e-4	4.3624	-9.2822e-5
Delta w Lead-Lag PSS	5.046e-4 -0.0012	5.3583	-5.733e-5
Delta Pa Lead-Lag PSS	6.498e-5 -8.739e-4	19.5755	-7.852e-5
BG Based lead-lag PSS	+1.751e-4 -7.557e-4	5.8994	-4.8344e-5

As displayed in fig.11., and table 4, the Delta Pa Lead-Lag PSS has a poor settling time and the highest maximum overshoot, so that its weakest PSS. The BG-PSS & the MB-PSS are stronger than the other two PSS, but the MB-PSS have a greater frequency, the worst in steady-state error, and its maximum overshoot higher than the proposed BG-PSS.

So, it's clear that the proposed BG-PSS is superior to the other three PSS and have the best performance in damping the small signal stability in comparison with the other PSSs.

Fig.12., shows the effect of growing the voltage magnitude of G1 by 5% for 12-cycles on the terminal voltage of generator G1 when the system connected to BG-PSS in comparison to the system connected to the other three PSS: MB-PSS, Delta w lead-lag PSS, and Conventional Acceleration Power (Delta Pa) lead-lag PSS. Table 5 terms the LFO signal characteristics of fig.12.

Table 5. and Fig.12., demonstrate that the proposed BG-PSS have the smallest settling time & maximum overshoots, which are the most important indices because the long settling time as the delta Pa Lead-Lag PSS makes the system exposed to LFOs problem the long time, and it may go to be unstable. Also, the highest maximum overshoot clarifies the PSS weakness in damp any LFOs oscillation especially the present criteria inter-area oscillation.




Fig.12. The effect of small disturbance on the terminal voltage of G1 when the system connected to BG-PSS in comparison to the system connected to the other three PSS: MB-PSS, Delta w lead-lag PSS, and Conventional Acceleration Power (Delta Pa) lead-lag PSS.

Table 5. The characteristics of the G1 terminal voltage oscillation.

PSS Types	Maximum Overshoot P.U.	Settling Time Sec.	Steady-State Error P.U.
MB-PSS	1.0330 0.9970	5.8000	1.0001
Delta w Lead-Lag PSS	1.0403 0.9972	3.0530	1.00002
Delta P <sub>a</sub> Lead-Lag PSS	1.0320 0.9959	9.5635	1.000025
BG Based lead-lag PSS	1.0299 0.9929	2.9182	1.00001

The small signal assessment illustrates that the proposed BG-PSS stronger than the other three PSS in damp the inter-area oscillation. On the other hand, the delta w lead-lag and delta Pa lead-lag PSSs are the weakest in damp the inter-area oscillation, respectively.

So, in the next section (the large signal assessment) the delta w lead-lag and delta Pa lead-lag PSSs neglected to simplify and clarify the graphs.

**B. Large signal assessment**

In this section of PSS testing the large signal assessment applied to the proposed BG-PSS and the MB-PSS only. In this step, the PSSs tested against three-phase fault cleared in 8 cycles by opening the breaker (1 & 2) which located at the middle of one of the tie transmission lines.

This assessment tests the robustness of the PSSs with veneration to changing operating condition, which makes it a very rough test to show the PSSs superiority.

Fig.13., shows the effect of clearing three-phase fault after 8 cycles on the bulk power transferred from the area (1) to the area (2) when the system connected to BG-PSS in comparison to the system connected to the MB-PSS. Table 6 defines the LFO signal characteristics from fig.13.

Fig.13., and Table 6. confirm that the proposed BG-PSS have the largest maximum overshoot, but the MB-PSS swinging in a large range between the min. & max. Overshoot values which make the system highly exposed to go too unstable. Moreover, the steady-state error in the BG-PSS case is the closest & higher than the initial power transferred value (413MW) from the area (1) to area (2).




Fig.13. The effect of clearing three-phase fault after 8-cycles on the bulk power transferred when the system connected to BG-PSS in comparison to the MB-PSS.

Table 6. The characteristics of the bulk power transfer oscillation.

PSS Types	Max. & Min Overshoot MW	Settling Time Sec.	Steady-State Error In Percentage
MB-PSS	+12.2929% -52.47%	10.6787	-3.8354%
BG Based lead-lag PSS	+14.3543% -8.6722%	13.6240	+1.1792%

But there is a problem in the case of using MB-PSS against this test that the power transferred is limited by 3.83% of the normal value, which means that the MB-PSS doesn't improve the system stability sufficiently, because the inter-area oscillation essentially limits the bulk power transfer and the MB-PSS can't give back the power to its normal (initial) amplitude to make the system work adequately by serving the load with the required power level.




Fig.14. The system speed deviation response of clearing three phase fault after 8-cycles when the system connected to BG-PSS in comparison to the MB-PSS.

Table 7. The characteristics of the speed deviation oscillation.

PSS Types	Max. & Min Overshoot	Settling Time Sec.	Steady-State Error
MB-PSS	0.0035 -0.0017	18.7186	2.8374e-3
BG Based lead-lag PSS	0.0029 -0.0028	17.4077	1.203e-3

Fig.14., illustrates the speed deviation of G1 response against clearing three-phase fault after 8-cycles when the four generators in the system connected to the BG-PSS



and MB-PSS. Table 7. describes the LFO signal characteristics from fig.14.

Table 7. and Fig.14., prove that the BG-PSS is the stronger, while its compromise the smallest settling time and the steady-state error closest to zero, and the speed deviation in its case swings in the smaller range between Max. & Min. overshoots than the MB-PSS.

Fig.15., shows the effect of clearing three-phase fault after 8-cycles on the terminal voltage of generator G1 when all the generators in the system connected to BG-PSS versus the MB-PSS. Table 8 explains the LFO signal characteristics from Fig.15.




Fig.15. The effect of clearing three-phase fault after 8-cycles on the terminal voltage of generator G1 when the system connected to BG-PSS in comparison to the MB-PSS.

Table 8. The characteristics of the G1 terminal voltage oscillation.

PSS Types	Max. & Min Overshoot	Settling Time Sec.	Steady-State Error
MB-PSS	1.1510 0.9536	11.9181	0.992
BG Based lead-lag PSS	1.1634 0.9606	12.5431	1.0186

From table 8. and Fig. 15. shows that the steady-state error in the two cases is diverse from the initial value which is unity per unit because it's normally to go to a new operating point after the SC because one of the two tie lines (which connect the two areas) opened.

But the important object is the level of the power transferred because if the required power doesn't transport from the area (1) to the area (2) the loads on area (2) wouldn't serve satisfactorily.

The important problem is that the limited value of power in the case of the MB-PSS (3.83%) not a high value which makes the system goes to isolation the blackout in some parts, but if the SC occurred than the used test, it can happen. Continuously, the tests demonstrate that the MB-PSS does not improve the power system stability sufficiently when compared to the proposed BG based lead-lag PSS.

Finally, the goals of this work attained by using the BG to optimize the delta w lead-lag PSS (P. Kundur construction), makes it superior to the other three PSSs and make it more robust in damping the inter-area oscillation which improves the overall system stability effectively.

## VI. CONCLUSION

This paper proposed the using of the bacterial foraging algorithm (BG) to optimize the parameter of the delta w lead-lag power system stabilizer (PSS) (P. Kundur structure). Delta w means the speed deviation is the input signal to the PSS. The objective of this proposal is to improve this PSS performance in damping the inter-area oscillation and improve the system stability.

The well-known P. Kundur multi-machine 4-generators 11-buses 2-areas workbench system in the MATLAB program used to test the BG based lead-lag PSS. The system analyzed by using the Power System Analysis Toolbox (PSAT) in MATLAB platform. The state-space analysis used to compute the (A) matrix from the Heffron-Phillips multi-machine power system block diagram to use it in the PSS parameter optimization.

The test procedure applied on the MATLAB / SIMULINK in two test parts firstly small signal assessment by increasing the reference voltage of generator G1 by 5% for 12-cycles. Secondly the large signal assessment by clearing three-phase short circuit after 8-cycles by opening one of the two tie lines which connected the system which makes it goes to a new point and strongly test the proposed PSS.

The proposed BG based lead-lag PSS compared with this three PSS: the multi-band (MB) PSS with simplified settings: IEEE® type PSS4B according to IEEE Std 421.5, the Conventional Delta w PSS (as the proposed PSS without optimization) from P. Kundur, and the Conventional Acceleration Power (Delta Pa) PSS to demonstrate its robustness & superiority versus the three PSSs types to damp out the inter-area oscillations in multi-machine power system.

The Eigenvalue analysis, settling time, rise time, steady-state error, and the maximum overshoot used as indices to demonstrate the robustness and superiority in damping the inter-area oscillation against the other three PSSs.

Also, the result of simulation & by depending on the used indices the proposed BG based lead-lag PSS founded to be robust & superior to the other three PSS in damping the inter-area oscillation. Final, the proposed PSS improves the overall system stability by robustly damp and omit the effect of the small and large signal tests in comparison to the other three PSSs.

## REFERENCES

- [1] E. L. Miotto; P. Bueno ; E. D.Fortes; & etc., "Coordinated Tuning of the Parameters of PSS and POD Controllers Using Bioinspired Algorithms," *IEEE Trans. on Ind. App.*, vol. 54, no. 4, pp. 3845 - 3857, July-Aug. 2018.
- [2] P. Dey; A. Bhattacharya; & etc., "Parameter tuning of power system stabilizer using a meta-heuristic algorithm," in *2017 Sec. Inter. Conf. on Elec., Comp. & Comm. Tech. (ICECCT)*, Coimbatore, India, 22-24 Feb. 2017.
- [3] A. Salgotra; & S. Pan, "Model based PI power system stabilizer design for damping low frequency oscillations in power systems," *ISA Trans.*, vol. 76, pp. 110-121, May 2018.

- [4] D.K.Sambariya, & R. Prasad, "Robust tuning of power system stabilizer for small signal stability enhancement using metaheuristic bat algorithm," *Inter. Jour. of Elec. Power & Ener. Sys.*, vol. 61, pp. 229-238, Oct. 2014.
- [5] Nader M.A. Ibrahim, Hossam E. M. Attia, & etc., "Modified particle swarm optimization based proportional-derivative power system stabilizer," *I.J. Intel. Sys. & App.*, vol. 7, no. 3, pp. 62-76, Feb. 2015.
- [6] W. Peresalvo, C. Silva, & etc., "Gradient based hybrid metaheuristics for robust tuning of power system stabilizers," *Inter. Jour. of Elec. Power & Ener. Sys.*, vol. 95, pp. 47-72, Feb. 2018.
- [7] H. K. Abdulkhader, J. Jacob, & etc., "Fractional-order lead-lag compensator-based multi-band power system stabiliser design using a hybrid dynamic GA-PSO algorithm," *IET Gene., Trans. & Dist.*, vol. 12, no. 13, pp. 3248 - 3260, 19 July 2018.
- [8] M. Khaleghi, M. Mohammadian, & etc., "Design of two power system stabilizers coordinately based on Strength Pareto Evolutionary Algorithm," in *2009 4th IEEE Conf. on Ind. Electro. & App.*, Xi'an, China, 25-27 May 2009.
- [9] A. Khodabakhshian, & R. Hemmati, "Multi-machine power system stabilizer design by using cultural algorithms," *Inter. Jour. of Elec. Power & Ener. Sys.*, vol. 44, no. 1, pp. 571-580, Jan. 2013.
- [10] P. Dey, A. Bhattacharya, & etc., "Parameter tuning of power system stabilizer using a meta-heuristic algorithm," in *2017 Sec. Inter. Conf. on Elec., Comp. and Comm. Tech. (ICECCT)*, Coimbatore, India, 22-24 Feb. 2017.
- [11] S. Ekinici, & B. Hekimoglu, "Parameter optimization of power system stabilizer via Salp Swarm algorithm," in *2018 5th Inter. Conf. on Elec. and Electr. Eng. (ICEEE)*, Istanbul, Turkey, 3-5 May 2018.
- [12] N. N. Islam, M. A. Hannan, & etc., "Power system stabilizer design using BAT optimization algorithm in multimachine power system," in *2013 IEEE Stu. Conf. on Rese. & Dev.*, Putrajaya, Malaysia, 16-17 Dec. 2013.
- [13] M. Shafiullah, M. J. Rana, & etc., "Online tuning of power system stabilizer employing genetic programming for stability enhancement," *Jour. of Elec. Sys. & Inf. Tech.*, 11 April 2018.
- [14] T. Špoljarić, & I. Pavić, "Performance analysis of an ant lion optimizer in tuning generators' excitation controls in multi machine power system," in *2018 41st Inter. Conven. on Inf. & Comm. Tech., Electr. & Micr. (MIPRO)*, Opatija, Croatia, 21-25 May 2018.
- [15] Rahman, & J. M. Saleh, "Hybrid bio-Inspired computational intelligence techniques for solving power system optimization problems: A comprehensive survey," *Applied Soft Computing*, vol. 69, pp. 72-130, Aug. 2018.
- [16] F. Dib, & I. Boumhidi, "Optimal  $H_\infty$  control without reaching phase with the differential evolution PID based on PSS for multi-machine power system," in *2015 Intel. Sys. & Comp. Vis. (ISCV)*, Fez, Morocco, 25-26 March 2015.
- [17] K. B. Meziane, & I. Boumhidi, "An interval type-2 fuzzy logic PSS with the optimal  $H_\infty$  tracking control for multi-machine power system," in *2015 Intel. Sys. & Comp. Vis. (ISCV)*, Fez, Morocco, 25-26 March 2015.
- [18] A.F. Okou, M. Kelemen, & etc., "Towards a systematic procedure to design robust power system stabilizers," in *2000 Power Eng. Soci. Summer Meet. (Cat. No.00CH37134)*, Seattle, WA, USA, 16-20 July 2000.
- [19] K. Saoudi, Z. Bouchama, & etc., "Design of a robust PSS using an indirect adaptive type-2 fuzzy sliding mode for a multi-machine power system," in *2016 8th Inter. Conf. on Model., Identi. & Cont. (ICMIC)*, Algiers, Algeria, 15-17 Nov. 2016.
- [20] J. Talaq, "Optimal power system stabilizers for multi machine systems," *Inter. Jour. of Elec. Power & Ener. Sys.*, vol. 43, no. 1, pp. 793-803, Dec. 2012.
- [21] J. Morsali, R. Kazemzadeh, & etc., "Introducing FOPID-PSS to increase small-signal stability of multi-machine power system," in *2015 23rd Iran. Conf. on Elec. Eng.*, Tehran, Iran, 10-14 May 2015.
- [22] B. Dhoub, A. Kahouli, & etc., "A comparative study of performance of multi-band and conventional power system stabilizers to improve transient stability of multimachine power system," in *2016 17th Inter. Con. on Sci. & Techni. of Auto. Cont. & Comp. Eng. (STA)*, Sousse, Tunisia, 19-21 Dec. 2016.
- [23] P. Kundur, *Power System Stability and Control*, New York USA: McGraw-Hill, Inc., 1994.
- [24] A.R.Fereidounia, B.Vahidi, & etc., "Improvement of low frequency oscillation damping by allocation and design of power system stabilizers in the multi-machine power system," *Inter. Jour. of Elec. Power & Ener. Sys.*, vol. 52, pp. 207-220, Nov. 2013.
- [25] C. Report, "Dynamic Models for Steam and Hydro Turbines in Power System Studies," *IEEE Trans. on Power Appar. & Sys.*, Vols. PAS-92, no. 6, pp. 1904 - 1915, Nov. 1973.
- [26] Editors, "421.5-2005 - IEEE Recommended Practice for Excitation System Models for Power System Stability Studies," 21 Apr. 2006, IEEE.
- [27] Y. Y. Hsu, & C. L. Chen, "Identification of optimum location for stabiliser applications using participation factors," *IEE Proc. C - Generation, Transm. & Distr.*, vol. 134, no. 3, pp. 238 - 244, May 1987.
- [28] F. P. Demello, & C. Concordia, "Concepts of Synchronous Machine Stability as Affected by Excitation Control," *IEEE Trans. on Power Appar. & Sys.*, Vols. PAS-88, no. 4, pp. 316 - 329, Apr. 1969.
- [29] F. Milano, "Federico Milano's Webpage," University College Dublin, 6 Jan. 2013. [Online]. Available: <http://faraday1.ucd.ie/psat.html>. [Accessed 15 May 2018].
- [30] P. K. Ray, S. R. Paital, & etc., "Swarm and bacterial foraging based optimal power system stabilizer for stability improvement," in *2016 IEEE Regi. 10 Conf. (TENCON)*, Singapore, Singapore, 22-25 Nov. 2016.
- [31] w. korani, "File Exchange," Mathworks, 9 Jun. 2008.
- [32] [Online]. Available: <https://www.mathworks.com/matlabcentral/fileexchange/20217-bacterial-foraging>. [Accessed 10 May 2018].
- [33] M. Klein, G. J. Rogers, & etc., "Analytical investigation of factors influencing PSS performance," *IEEE Trans. on EC*, vol. 7, no. 3, pp. 382-390, Sep. 1992.

### Authors' Profiles



**Nader M.A. Ibrahim** was born in Alexandria in Egypt, on 13 October, 1986. He received his B.Sc. & M.Sc. degrees in electrical power systems and machines department in Faculty of Industrial Education from Suez Canal University, Suez, Egypt during 2009 and 2015 respectively. Eng. Nader registered PhD in electrical power systems and machines control. Currently, he is Assistant Lecturer in

electrical department at the Faculty of Industrial Education, Suez University, Suez, Egypt. His research interests are power system stability and operation, machine control, wide-area damping control, online and digital control in machines, applications of artificial intelligent techniques, like particle swarm optimization (PSO). His email is: Nader.ibrahem@suezuniv.edu.eg



**Basem E. Elnaghi** received the B.Sc. degree in electrical engineering from Suez Canal University, Port Said, Egypt, in 2003, the M.Sc. degree in electrical engineering from Suez Canal University, Port Said, Egypt, in 2009, and the Ph.D. degree in electrical engineering from Port Said University, Port Said, Egypt, in 2015. He is currently an Assistant Professor in the Electrical Engineering Department, Suez Canal University, Ismailia, Egypt.



**Hamed A. Ibrahim Emam** received the B.Sc. and M.Sc. degree in electronic engineering from Menofia University, El-Menofia, Egypt in 1992 and 2001 respectively. Dr. Hamed received the Ph. D. degree from Université de Versailles, France in 2010. He is a member of Faculty of Industrial Education, Suez University, Suez, Egypt since 2010 until now. His research interests are in the area of renewable energy sources, power electronics, dynamic modeling, robotic, fuzzy systems, and neural network.



**Hossam E.A. Talaat** received the B.Sc. and M.Sc. degrees from Ain Shams University, Cairo, Egypt in 1975 and 1980 respectively, and his Ph.D. degree from University of Grenoble, France in 1986. During 1999-2001. He is a reviewer of many international journals (IEEE, IET, Electric Power System Research, Electrical power and Energy systems, ...). He has supervised 40+ Ph.D. and M.Sc. theses in the field of power system operation, control, stability and protection. He has taught tens of undergraduate and graduate courses in this field. He has authored and co-authored more than 70 technical papers and reports. He has accomplished several research projects as PI and as the investigator. He was the reviewer of a number of academic undergraduate and postgraduate programs for Egyptian and Arabic Universities. He is the Chairman of 2 IEC committees (49&93) and was a member of the Egyptian National board of Electricity and Energy Researches– Scientific Research and Technology Academy. He is the Chairman of the Middle East Conference on Power Systems MEPCON 2014 to be held on 23th-25th December 2014. He is interested in many research areas such as: Distributed Generation and Micro grids, Application of artificial intelligence techniques (Neural Networks, Knowledge-Based systems, Genetic Algorithms, and Fuzzy Logic) to Power System analysis, control, and protection; Real time applications to electrical power systems and machines; Application of optimal and adaptive control techniques for the enhancement of power system stability. His email is: hossam\_talaat@eng.asu.edu.eg .

**How to cite this paper:** Nader M.A. Ibrahim, Basem E. Elnaghi, Hamed A. Ibrahim, Hossam E.A. Talaat, "Performance Assessment of Bacterial Foraging based Power System Stabilizer in Multi-Machine Power System", International Journal of Intelligent Systems and Applications(IJISA), Vol.11, No.7, pp.43-53, 2019. DOI: 10.5815/ijisa.2019.07.05