



Power Configuration Scheme for Battery Energy Storage Systems Considering the Renewable Energy Penetration Level

Qing Chen¹, Rui Xie¹, Yuyan Chen², Heyu Liu², Shengqi Zhang^{2*}, Fei Wang², Zhaohui Shi¹ and Bin Lin¹

¹Key Laboratory of Far-shore Wind Power Technology of Zhejiang Province, Hangzhou, China, ²Department of Mechatronic Engineering and Automation, Shanghai University, Shanghai, China

OPEN ACCESS

Edited by:

Xing He,
Shanghai Jiao Tong University, China

Reviewed by:

Zhendong Ji,
Nanjing University of Science and
Technology, China
Wenchao Miao,
The University of Hong Kong, China

*Correspondence:

Shengqi Zhang
shengqi_zhang8816@163.com

Specialty section:

This article was submitted to
Smart Grids,
a section of the journal
Frontiers in Energy Research

Received: 31 May 2021

Accepted: 14 June 2021

Published: 16 July 2021

Citation:

Chen Q, Xie R, Chen Y, Liu H, Zhang S,
Wang F, Shi Z and Lin B (2021) Power
Configuration Scheme for Battery
Energy Storage Systems Considering
the Renewable Energy
Penetration Level.
Front. Energy Res. 9:718019.
doi: 10.3389/fenrg.2021.718019

With the increase of the renewable energy penetration (REP) level in the interconnected power grid, the proportion of the grid-connected conventional synchronous generators reduces continuously, resulting in the decrease of the system inertia. The insufficient system inertia brings challenges to the system frequency stability. Battery energy storage systems (BESSs), regarded as the high-quality frequency regulation resource, play an important role in maintaining the frequency stability of the system with the high REP level. To configure the proper power of BESSs in system frequency regulation, a BESS power configuration scheme (PCS) considering the REP constraint is proposed in this paper. In particular, the process to obtain the REP boundary of the interconnected grid on the premise of system frequency stability is included in the PCS, and the optimal power configuration of the BESS is further determined on the analysis of the BESS impact on the REP boundary. Furthermore, a simulation model of the Australian five-area interconnected power grid is built in MATLAB/Simulink, and the proposed REP-constrained PCS is verified and analyzed. At last, the promising results show that the PCS can take full advantages of the BESS in frequency regulation and meet the system requirement of the frequency stability at a particular REP level.

Keywords: renewable energy penetration, battery energy storage system, interconnected power grid, system frequency stability, system inertia

INTRODUCTION

To reduce the greenhouse gas emission, replacing fossil energy generation by renewable energy generation (REG) has become an inevitable trend in the modern power grid. At the end of 2020, the capacity of the grid-connected REG including photovoltaic and wind generation reached 1300 GW, accounting for 9.4% of the total installed power generation capacity (Khan et al., 2021) all over the world. Unlike the conventional generators, REG connected to the power grid *via* power electronic converters cannot provide the system inertia and the frequency regulation support when a load disturbance occurs (De Carne et al., 2020). Meanwhile, the output of REG has high fluctuation and intermittency, which requires more active power reserves to maintain the system frequency stability. Also, the frequency stability issue becomes worse (Ortiz-Villalba et al., 2020; He et al., 2020), when REG is absorbed across control areas *via* the transmission lines in the interconnected power grid. Therefore, with the increase of the renewable energy penetration (REP) level, the frequency

instability caused by the insufficient system inertia and the active power reserve becomes a distinct threat of the interconnected power grid. In addition, the blackouts in the United Kingdom on August 9, 2019 (Li et al., 2021), and in South Australia on September 28, 2016 (Yan et al., 2018), and the DC bipolar block in the Jinsu-Jiangsu region of East China on September 19, 2015 (Rahman et al., 2017), result from the system frequency instability.

Obviously, to restrict the REP level is the most effective way to maintain the frequency stability of the low-inertia system, but a huge waste of energy is by Yan et al. (2017) and Yang et al. (2020), and the maximum power point operation is used by Ochoa and Martinez (2017), Kumar et al. (2018), and Kumar et al. (2019) to enable REG to provide frequency regulation. The photovoltaic generator and wind turbine are operated below the maximum power point with virtual inertia controllers, and the active power reserved by battery storages is applied to system frequency regulation (Kumar et al., 2018; Kumar et al., 2019). In a study by Ochoa and Martinez (2017), a neuro-fuzzy controller is utilized to adjust the output power of the photovoltaic generator for frequency regulation without energy storage. However, the regulation capacity of REG has high randomness. Recently, battery energy storage systems (BESSs) have been recognized as a high-quality frequency regulation resource by both the academics and the industrialists (Xu and Bishop, 2016; Dozein and Mancarella, 2019; Yoo et al., 2020). Therefore, to meet the frequency stability requirement of the interconnected power grid with high REP level, the research on the BESS power configuration scheme (PCS) becomes a topic of concern.

Many literature studies focus on the economy in the BESS PCS. For example, Mantar Gundogdu et al. (2018) and Zhang et al. (2019) introduced BESS profit models of the frequency regulation service in the ancillary service market of the United Kingdom and the United States. The PCS developed by Chen et al. (2018) combines the market mechanism with the probability distribution of the frequency regulation demand. BESSs are enabled to make more profit by participating in both frequency regulation and energy arbitrage (Cheng and Powell, 2018), and the corresponding PCS determines the optimal configuration by a Markov decision process according to the real-time electricity price. However, those PCSs give priority to BESS profit, and the actual demand of system frequency regulation is ignored. To sum up, the profit priority-based PCS can be hardly applied in countries without mature electricity market.

To make the best use of BESS in frequency regulation, the PCS comprehensively considers the economy and system stability as mentioned in the following references. Specifically, a configuration-operation collaborative optimization method based on the mixed integer linear programming is proposed by Quan et al. (2019), considering the overall economic optimization of equipment planning and system operation. Similarly, Pan et al. (2020) used KKT conditions to combine the economy and stability optimization problems as a single one. Also, an optimal PCS presented by He et al. (2016) considers the BESS frequency regulation performance and BESS life. An energy management and optimization method for the BESS based on the dynamic SoC limit setting is introduced by Byrne et al. (2017). Although the

system frequency stability is considered a constraint in the process of those PCSs, the system frequency instability cannot be completely avoided, as the economy optimization still has high priority.

Up to now, the research on the BESS PCS from the perspective of the system frequency stability is still insufficient. Primarily, the impact of REP level on the power system frequency stability is discussed by Meegahapola and Flynn (2010), Miller et al. (2011), and Wang et al. (2019). For example, Wang et al. (2019) indicated that the wind and photovoltaic generation can reduce the power system inertia, which further affects the frequency stability. Also, Meegahapola and Flynn (2010) and Miller et al. (2011) pointed out that areas with low system inertia face the worse frequency stability issue than other areas in the interconnected power grid, which leads to the decrease of the frequency nadir and severer frequency fluctuations under the same active power disturbances. Meanwhile, the frequency deviations within a certain range are allowed, and the standards of some countries have been given by Sun et al. (2020). Therefore, it is valuable to further explore the influence factors of frequency stability and the REP boundary of the interconnected grid.

Furthermore, BESSs play a positive role in improving the frequency regulation performance of the system. For example, a control strategy is introduced by Wen et al. (2016) in that fast-response BESS devices are used to maintain the frequency dynamic safety. Also, an adaptive SoC feedback control is designed by Tan and Zhang (2017), and BESSs are able to be applied in the coordinate control of the multi-timescale frequency deviations of the wind power plant. However, BESSs have a certain power in those research studies, and the quantitative analysis of the impact of BESSs on frequency stability is not included.

Therefore, the BESS PCS considering the REP constraint for the interconnected power grid is proposed in this paper. In detail, an REP boundary calculation method is presented on the condition of the system frequency stability. Also, the influence of BESS on the system frequency stability is quantified. Finally, the optimal BESS power configuration is achieved to enable the system meeting a particular REP level. The proposed PCS for the BESS can improve the renewable energy absorbing consumption in the interconnected power grid effectively. Meanwhile, the PCS can configure BESS power according to the actual requirement of system frequency regulation, which is beneficial to improving the comprehensive utilization rate of the BESS.

The rest of this paper is organized as follows. The framework of the interconnected power grid including the BESS is introduced in *Framework of the Interconnected Power Grid Considering BESS*. In *Operation of the Penetration Level-Constrained PCS for BESS*, the details about the REP-constrained PCS for the BESS are presented, and the performance of the proposed PCS is simulated in the Australian five-area power grid in *Simulation and Discussion*. This paper is summarized in *Conclusion*.

FRAMEWORK OF THE INTERCONNECTED POWER GRID CONSIDERING BESS

The equivalent dynamic model of the control area as shown in **Figure 1** consists of several generators and BESSs. The model of




FIGURE 1 | Dynamic model of a control area belonging to the interconnected power grid including the BESS PCS.




FIGURE 2 | Dynamic models of frequency regulation units. (A) Dynamic model of Thermal Gen. (B) Dynamic model of Hydro Gen. (C) Dynamic model of the BESS.

the BESS can be equivalent to a first-order inertia block, according to Ramalingam et al. (2018) and Calero et al. (2021), and the conventional generator is constructed referring to Liang et al. (2018). Also, the frequency deviations Δf caused by the inertial response and frequency regulation from generators and BESSs. As a part of frequency regulation, the droop coefficients of Thermal Gen, Hydro Gen, and BESSs are denoted R_{tg} , R_{hg} , and

R_B , respectively. Particularly, the participation of the BESS in frequency regulation is indicated by the configuration factor α , which can be deduced by the BESS PCS. In addition, P_{AGC} denotes the automatic generation control signal, M and D are the inertial constant and damping coefficient, and ΔP_L denotes the net load power fluctuations. ΔP_{tg} , ΔP_{hg} , and P_B denote the output power of Thermal Gen, Hydro Gen, and BESSs for frequency regulation. Note that P_B in Figure 1 is under

constrains of the optimal power configuration for the BESS. More details of the control area model are shown below.

Dynamic Model of the Conventional Generators

The principles of Thermal Gen and Hydro Gen in frequency regulation are similar, but the dynamic models of those two Gens are different because of the different mechanical structures. The simplified dynamic model of Thermal Gen is shown in **Figure 2A** (Zhang et al., 2017), which consists of a governor and a steam turbine. In detail, the dynamic model of the governor consists of three parts: the frequency regulation dead zone, the droop coefficient, and the response delay, while the output is the opening change ΔY representing the steam valve of the steam turbine. The governor of Thermal Gen can determine whether the generator participates in frequency regulation by measuring the system frequency deviations, as long as Δf cross the frequency dead band. Also, the governor can determine the adjustment degree of the control valve by setting the droop coefficient R_{tg} and the primary frequency regulation range according to the droop characteristics of the generator. The response delay of the governor is simulated as a first-order inertia model, and T_{ig} is the time constant of the governor. Meanwhile, in the model of the steam turbine, T_{ch} , T_{rh} , and F_{hp} are the adjustment response time, the time constant, and the gain coefficient of the reheater, respectively. Finally, the output value of the frequency regulation power ΔP_{tg} is obtained considering the operation boundary of the generator.

Similarly, the dynamic model of Hydro Gen is composed of the governor and the hydro turbine, as shown in **Figure 2B**. Specifically, the governor consists of the frequency regulation dead zone, the droop coefficient, and the response delay. Referring to Alhejaj and Gonzalez-Longatt (2017), the transient parameters T_r and R_t are used to simulate the reverse variation of the mechanical power caused by the mechanical inertia of water. Also, T_w represents the required time for the water accelerating from standstill to velocity V_0 in the hydro turbine model. At last, according to the above analysis, the transfer functions G_{tg} and G_{hg} of Thermal Gen and Hydro Gen can be derived as follows:

$$G_{tg}(s) = \frac{\Delta P_{tg}(s)}{\Delta f(s)} = -\frac{1 + sF_{hp}T_{rh}}{R_{tg}(1 + sT_{ig})(1 + sT_{ch})(1 + sT_{rh})}, \quad (1)$$

$$G_{hg}(s) = \frac{\Delta P_{hg}(s)}{\Delta f(s)} = -\frac{(1 + sT_r)(1 - sT_w)}{R_{hg}(1 + sT_{hg})[1 + sT_r(R_t + R_p)](1 + 0.5sT_w)}. \quad (2)$$

Dynamic Model of BESS

To represent the external characteristics of the BESS participating in the load frequency control, the dynamic model of the BESS can be expressed as a first-order inertial control block in **Figure 2C**. In the model, T_B is the time constant used to describe the response time delay of the BESS (Kundur et al., 1994). Meanwhile, the

droop coefficient $1/R_B$ represents the proportional relationship between the BESS frequency regulation power and the system frequency deviations. Also, the blocks describing the BESS charging and discharging power range and BESS capacity boundaries are added. At last, the transfer function of BESS G_B is shown as

$$G_B(s) = \frac{P_B(s)}{\Delta f(s)} = -\frac{1}{R_B(1 + sT_B)}. \quad (3)$$

OPERATION OF THE PENETRATION LEVEL-CONSTRAINED PCS FOR BESS

The REP level-constrained PCS can dynamically determine the BESS frequency regulation power configuration coefficient α , based on the REP level the power system is required to absorb and the frequency stability requirements. And the PCS can further realize the power configuration of the BESS participating in system frequency regulation. The process of the REP level-constrained PCS is shown in **Figure 3**. In general, the PCS for the BESS includes the system REP level calculation (RLC) block and BESS power configuration (BPC) block. More details about the proposed PCS are introduced below.

REP Level Calculation Block

In the interconnected power grid, the power mismatch between the generation and the load leads to the system frequency deviations, which is the key index of the system stability. The traditional generators can stop the frequency drop (Δf^{nadir}) and stabilize the frequency around the nominal value (50 or 60 Hz) after a short while, through their own inertia control and the frequency regulation control. To meet the severe active power unbalance of the power system, the under/overload-shedding mechanisms are triggered to maintain the system frequency stability.

Primarily, the conventional generators contribute to the system inertia, as their rotational speed is synchronous to the system frequency. Also, the relationship between the mechanical power, the electrical power, and the rotation speed of the synchronous generator is shown in **Eq. 4**. The expression of the system inertia is shown in **Eqs 5, 6**, which is a function of ω_r . The change of the generator's electric output power ΔP_E caused by the system load fluctuation is shown in **Eq. 7**. Also, the change of ΔP_E further results in the shift of the generator speed, which further causes the frequency fluctuation of the control area. Furthermore, the influence of load fluctuations and system inertia on the system frequency deviations can be deduced in **Eq. 8** from **Eqs 4, 7**. In summary, the synchronous generator can effectively smooth the system frequency drop (Δf^{nadir}) due to the rotational inertia generated by its own mechanical structure:

$$\Delta P(s) = \Delta P_G(s) - \Delta P_E(s) = Ms\Delta\omega(s), \quad (4)$$

$$M = 2H, \quad (5)$$

$$H = \frac{j\omega_r^2}{P_G}, \quad (6)$$




FIGURE 3 | Process of the penetration level-constrained PCS for the BESS.

$$\Delta P_E(s) = \Delta P_L(s) + \Delta P_{Lf}(s) = \Delta P_L(s) + D\Delta\omega(s), \quad (7)$$

$$\frac{\Delta\omega(s)}{\Delta P_G(s) - \Delta P_L(s)} = \frac{1}{D + sM} \quad (8)$$

$$\Delta P_G(s) = \Delta P_{tg}(s) + \Delta P_{hg}(s), \quad (9)$$

where ΔP_G is the mechanical power change of the conventional generators and the corresponding ΔP_E is the electromagnetic power; $\Delta P_{tg}(s)$ and $\Delta P_{hg}(s)$ are the output values of frequency regulation power of Thermal Gen and Hydro Gen, respectively; M is the sum of generator inertia constants in the control area; $\Delta\omega$ is the angular frequency deviation of the generator; ΔP_L is the load fluctuation; $\Delta P_{Lf}(s)$ is the frequency-sensitive load change; and D is the system load damping constant.

Unlike the conventional generator, renewable energy generation is unable to participate in frequency regulation because renewable energy generation does not have the rotational inertia and usually operates on its maximum power point. Meanwhile, with the increase of the REP level, the proportion of the traditional generators decreases. In other words, a downward trend in the overall inertia level of the power system leads to the insufficient frequency regulation capabilities and the instability of the system frequency.

Therefore, the interconnected power grid has a limitation of REP.

The RLC block is used to calculate the REP boundary that the interconnected grid can withstand under the premise of system frequency stability. As shown in Figure 3, the PLC block sets the load condition in advance according to the power system parameters and introduces a large load disturbance to test the frequency stability. To observe the REP boundary, a series of tests about whether the system frequency deviations exceed the limitation under the same load disturbance event are applied by increasing the REP level step by step. Thus, the maximum REP level in a certain load condition is obtained. Furthermore, several typical load conditions are introduced one by one, and the maximum REP level of each load condition is determined. At last, the minimum REP level of the interconnected power grid is obtained by comparing the maximum REP levels in different load conditions.

BESS Power Configuration

A virtual droop control strategy is usually adopted for the BESS in the primary frequency regulation. In other words, the BESS can imitate the droop characteristic of the generator in response to the system frequency deviation. The dynamic model of the BESS




FIGURE 4 | Amplitude–frequency characteristic curve.

including the virtual droop control strategy is introduced in **Figure 2C**. For the same frequency deviation, the power from the BESS P_B can be adjusted by the BESS power configuration coefficient α , and the influence of BESS on the frequency stability can be deduced in **Eq. 10**. Furthermore, the system amplitude–frequency characteristic functions can be written in **Eqs 11, 12**, respectively, representing the system with and without BESS. The corresponding amplitude–frequency characteristic curves are shown in **Figure 4**. In detail, the amplitudes are very small or relatively close when the frequency deviations are caused by the low-frequency or high-frequency load fluctuations, no matter whether BESSs are involved. However, the amplitude of $H_B(s)$ is obviously smaller than that of $H_G(s)$ when the middle-frequency load fluctuations occur. Also, a larger α leads to a smaller amplitude of $H_B(s)$. Therefore, the frequency deviation suppression effect brought by load fluctuations in the middle-frequency band is stronger, with the increase of the configuration coefficient α :

$$\begin{aligned} \Delta f(s) &= \frac{\Delta P_{ig}(s) + \Delta P_{hg}(s) + P_B(s) - \Delta P_L(s)}{D + sM} \\ &= \frac{-\Delta P_L(s)}{D + sM - G_{ig} - G_{hg} - \alpha G_B}, \end{aligned} \quad (10)$$

$$H_B(s) = \frac{\Delta f(s)}{\Delta P_L(s)} = \frac{1}{D + sM - G_{ig} - G_{hg} - \alpha G_B}, \quad (11)$$

$$H_G(s) = \frac{\Delta f(s)}{\Delta P_L(s)} = \frac{1}{D + sM - G_{ig} - G_{hg}}. \quad (12)$$

Based on the above theoretical analysis, the BESS participating in the primary frequency regulation can improve the ability of the power system to cope with the load deviations effectively. In this way, the aim of the REP level of the interconnected power grid can be guaranteed, and the system frequency deviation can always meet the system stability requirement when the load disturbance occurs under a certain configuration coefficient α . Thus, the optimal power configuration of the BESS can be deduced according to the configuration coefficient α .

The BPC block is used to calculate the minimum BESS charge and discharge power that can enable the control area to meet the

aim of the REP level and frequency stability. As shown in **Figure 3**, the necessity of involving the BESS in frequency regulation is determined in the first place, by comparing whether the maximum REP levels are larger than the aim of the REP level of the control area. The BESS power configuration coefficient α is gradually increased, when the aim of the REP level cannot be met. A series of tests are applied until the system frequency stability of the control area with the target REP level is satisfied. Finally, according to the proper power configuration coefficient α , the optimal BESS power configuration that meets the frequency stability of the region is obtained.

SIMULATION AND DISCUSSION

The Australian power grid is regarded as one of the longest interconnected power grids, as shown in **Figure 5**, and can be generally simplified as a 5-area 14-bus system. The maximum power generation capacity of the system is 25,430 MW, while the maximum load demand is 24,800 MW. According to the Australian state layout, Area #2 (New South Wales) and Area #3 (Victoria) are typical load centers and Area #4 (Queensland) and Area #5 (South Australia) are rich in solar energy and wind energy resources, respectively. Thus, the feasibility of the REP level–constrained PCS for the BESS is verified based on the Australian power grid, as it is a typical interconnected power grid with high REP.

The dynamic model of the Australian interconnected power grid in MATLAB/Simulink is shown in **Figure 6** based on the system data (Gibbard and Vowles, 2010) in **Table 1**, including the traditional generators, renewable generators, and BESSs in each area. To consider the actual operation of the Australian power grid, five typical load scenarios (Gibbard and Vowles, 2010) are formulated in **Table 2**, which are the peak scenario, heavy scenario, medium heavy scenario, medium scenario, and light scenario. Furthermore, a positive P_{42} means the active power flows from Area #4 to Area #2, and the negative one means the opposite power flow. P_{21} , P_{13} , and P_{35} follow the same rules. In addition, Area #2 and Area #4 are chosen as examples to configure the BESS verifying the influence of BESS on system frequency control in the load center and the renewable generation center.

Feasibility of RLC Block

Based on the former theoretical analysis, the inertia of the control area decreases with the increase of the REP level, which results in the system frequency instability. In the simulation, a fixed step load disturbance of $\pm 5\%$ p.u. occurred in the control area, and none of frequency deviations exceeding ± 0.25 Hz is defined as the system frequency stability. Also, the frequency recovery time is neglected as the indication of the system frequency stability because the response time of the BESS is faster than that of the traditional generators. The REP boundary of the control area is calculated by increasing the REP level of Area #2 and Area #4 from 0 gradually, until the constraint of frequency stability is no longer satisfied. In the heavy load scenario, the frequency deviations of the load center Area #2 and the renewable generation center Area #4 are shown in **Figures 7A,B**, while the performance of the frequency fluctuations is indicated in **Tables 3, 4**.




FIGURE 5 | Australian 5-area 14-bus power grid.

In detail, the system frequency of the load center Area #2 becomes unstable when the REP level reaches 5%, and the REP boundary of the area is 5%. Similarly, the renewable generation center Area #4 has an REP boundary of 9%. Thus, with the

decrease of the system inertia, Δf^{nadir} continues to approach the system stability limit ± 0.25 Hz. Also, the rate of change of frequency and the time to achieve the frequency recovery increase.




FIGURE 6 | Dynamic model of the Australian five-area power grid.

TABLE 1 | Characteristic parameters of the Australian five-area power grid.

	Area #1	Area #2	Area #3	Area #4	Area #5
V	1.0p.u.	1.0p.u.	1.0p.u.	1.0p.u.	1.0p.u.
D	1.0	1.0	1.0	1.0	1.0
R	4.0%	4.0%	4.0%	4.0%	4.0%
T_{ig}	0.2	0.2	0.2	0.2	0.2
T_{ch}	0.3	0.3	0.3	0.3	0.3
T_{in}	7	7	7	7	7
F_{HP}	0.3	0.3	0.3	0.3	0.3
T_{ng}	0.2	0.2	0.2	0.2	0.2
T_w	1.0	1.0	1.0	1.0	1.0
T_r	5.0	5.0	5.0	5.0	5.0
R_p	4.0%	4.0%	4.0%	4.0%	4.0%
R_t	0.38	0.38	0.38	0.38	0.38
ACE	-0.3	-0.3	-0.3	-0.3	-0.3
G	25	25	25	25	25
B	26	26	26	26	26

Specifically, Area #4 and Area #2 are regarded as the renewable generation center and the load center, respectively, and the grid-connected traditional generators in the heavy load scenario

TABLE 2 | Power transmission under different load scenarios (p.u.).

	Peak	Heavy	Medium heavy	Medium	Light
P_{42}	-5.0	5.0	-5.0	3.0	-2.0
P_{21}	-15.2	11.34	-11.2	7.4	4.7
P_{13}	10.0	10.0	-10.0	-2.0	2.0
P_{35}	2.5	5.0	-5.0	2.5	2.0

provide more system inertia in the renewable generation center Area #4. Meanwhile, Area #2 transfers more power to the load center through the tie line, and part of the renewables is absorbed actually in the load center Area #2. Thus, the boundary of the REP level of the renewable generation center Area #4 is higher than that of the load center Area #2.

Furthermore, as the REP level of the load center is set to 5%, Area #2 can meet the requirements of frequency stability in the heavy load scenario. Another four load scenarios from Table 2 are tested, and the frequency fluctuations are shown in Figure 8A. The maximum Δf^{maxdir} of Area #2 does not exceed ± 0.25 Hz in





TABLE 3 | Frequency response performance of Area #2 under different REP levels.

Area #2	5% REP level	10% REP level	20% REP level
Inertia level	5.7228	5.4216	4.8192
Minimum frequency deviation (Hz)	-0.2492	-0.2558	-0.2708
Maximum frequency deviation (Hz)	0.08958	0.09307	0.1022
Peak frequency time (s)	2.928	2.901	2.847

TABLE 4 | Frequency response performance of Area #4 under different REP levels.

Area #4	5% REP level	9% REP level	20% REP level
Inertia level	5.8672	5.6202	4.9408
Minimum frequency deviation (Hz)	-0.2460	-0.2511	-0.2670
Maximum frequency deviation (Hz)	0.06855	0.07007	0.07638
Peak frequency time (s)	3.010	2.986	2.920




heavy and medium load scenarios but goes across the limitation in peak, medium heavy, and light scenarios. Similarly, considering the REP level of the renewable generation center Area #4 as 9%, the simulation results of five different load scenarios are shown in **Figure 8B**. Similar simulation results are obtained such that the REP boundary of a control area changes according to the load scenarios.

At last, considering the comprehensive effectiveness of the system inertia and load scenarios on the system frequency stability, the REP boundaries of five control areas are shown in **Table 5**, according to the calculation process of the RLC block. Obviously, the REP level cannot be satisfied in both load centers and renewable generation centers, and it is necessary to configure the BESS to improve the REP level.

TABLE 5 | REP boundary of each control area.

	Peak (%)	Heavy (%)	Medium heavy (%)	Medium (%)	Light (%)	Penetration boundary (%)
Area #1	5	15	2	4	14	2
Area #2	1	5	1	6	3	1
Area #3	2	10	2	3	11	2
Area #4	2	9	2	7	3	2
Area #5	10	12	3	16	15	3

**FIGURE 9** | Frequency fluctuations considering different BESS configuration coefficients. **(A)** Frequency fluctuations of Area #2 considering different BESS configuration coefficients. **(B)** Frequency fluctuations of Area #4 considering different BESS configuration coefficients.**TABLE 6** | Parameters of BESS power configuration for five control areas.

	Initial penetration boundary (%)	Target penetration (%)	Configuration coefficient	BESS power configuration (p.u.)
Area #1	2	5	0.04	± 0.03012
Area #2	1	5	0.07	± 0.04538
Area #3	2	5	0.06	± 0.04558
Area #4	2	10	0.05	± 0.03890
Area #5	3	10	0.04	± 0.03716

Performance of BPC Block

Based on the former theoretical analysis, BESSs have high control accuracy and fast response speed, which can improve the system frequency stability by mitigating the frequency deviation quickly. To verify the effectiveness of the BPC block, optimal BESS power is configured in both the load center and the renewable energy generation center.

The target of the REP levels of load centers and renewable generation centers is set to 5 and 10%, respectively. According to the results in **Table 3**, the smallest REP levels of Area #2 and Area #4 occur under the medium heavy load scenario. Thus, to achieve the setting REP level, BPC block calculation is applied by increasing the configuration coefficient α gradually, and the simulation results of the frequency fluctuations are shown in **Figures 9A,B**.

In particular, the maximum Δf^{nadir} of Area #2 and Area #4 exceeds the frequency limitation, if BESSs are not equipped in areas. Meanwhile, the maximum Δf^{nadir} decreases gradually and reaches within ± 0.25 Hz eventually with the increase of BESS

configuration coefficients. The system frequency fluctuations are mitigated in a shorter period. Thus, the performance of system frequency regulation improves significantly with BESS involvement. Finally, the configuration parameters of BESSs are obtained based on the target REP levels, and the results are shown in **Table 6**. To sum up, the target REP levels are achieved by the proposed PCS for the BESS.

CONCLUSION

This paper proposes a BESS PCS considering the REP constraint on the premise of system frequency stability. At the beginning, the dynamic models of Thermal Gen, Hydro Gen, and BESSs are established. The REP-constrained PCS can dynamically determine the BESS power configuration by comparing the target REP levels and the REP boundaries of each control area in different load scenarios. A model of the Australian five-area interconnected power grid is established in

MATLAB/Simulink to verify the effectiveness of the PCS, and the suggested BESS power for each control area is obtained. Therefore, high REP level can be achieved in the future, as the BESS mitigates the system frequency fluctuations effectively, and the proposed PCS indicates the optimal BESS power. In addition, the implementation of the BESS is not only for frequency regulation but also for the way to configure BESS power in multiple purposes, which will be discussed in further work.

DATA AVAILABILITY STATEMENT

The original contributions presented in the study are included in the article/supplementary material, and further inquiries can be directed to the corresponding author.

REFERENCES

- Alhejaj, S. M., and Gonzalez-Longatt, F. M. (2016). "Impact of Inertia Emulation Control of Grid-Scale BESS on Power System Frequency Response," in 2016 Int. Conf. Students Appl. Eng. ICSAE (IEEE), 254–258. doi:10.1109/ICSAE.2016.7810198
- Byrne, R. H., Nguyen, T. A., Copp, D. A., Chalamala, B. R., and Gyuk, I. (2018). Energy Management and Optimization Methods for Grid Energy Storage Systems. *IEEE Access* 6, 13231–13260. doi:10.1109/ACCESS.2017.2741578
- Calero, F., Canizares, C. A., and Bhattacharya, K. (2021). Dynamic Modeling of Battery Energy Storage and Applications in Transmission Systems. *IEEE Trans. Smart Grid* 12, 589–598. doi:10.1109/TSG.2020.3016298
- Chen, P., Tao, S., Xiao, X., and Li, L. (2018). Uncertainty Level of Voltage in Distribution Network: An Analysis Model with Elastic Net and Application in Storage Configuration. *IEEE Trans. Smart Grid* 9, 2563–2573. doi:10.1109/TSG.2016.2614547
- Cheng, B., and Powell, W. (2016)1997–2005). Co-Optimizing Battery Storage for the Frequency Regulation and Energy Arbitrage Using Multi-Scale Dynamic Programming. *IEEE Trans. Smart Grid* 9, 1. doi:10.1109/TSG.2016.2605141
- De Carne, G., Buticchi, G., Liserre, M., and Vournas, C. (2020). "Real-Time Primary Frequency Regulation Using Load Power Control by Smart Transformers," in 2020 IEEE Power & Energy Society General Meeting (PESGM) (IEEE), 1. doi:10.1109/PESGM41954.2020.9281635
- Dozein, M. G., and Mancarella, P. (2019). "Frequency Response Capabilities of Utility-Scale Battery Energy Storage Systems, with Application to the August 2018 Separation Event in Australia," in 2019 9th International Conference on Power and Energy Systems (ICPES) (IEEE), 1–6. doi:10.1109/ICPES47639.2019.9105646
- Gibbard, M., and Vowles, D. (2010). *Simplified 14-generator Model of the SE Australian Power System*.
- He, G., Chen, Q., Kang, C., Pinson, P., and Xia, Q. (2016). Optimal Bidding Strategy of Battery Storage in Power Markets Considering Performance-Based Regulation and Battery Cycle Life. *IEEE Trans. Smart Grid* 7, 2359–2367. doi:10.1109/TSG.2015.2424314
- He, X., Chu, L., Qiu, R. C., Ai, Q., Ling, Z., and Zhang, J. (2020). Invisible Units Detection and Estimation Based on Random Matrix Theory. *IEEE Trans. Power Syst.* 35, 1846–1855. doi:10.1109/TPWRS.2019.2935739
- Khan, F. H., Pal, T., Kundu, B., and Roy, R. (2021). "Wind Energy: A Practical Power Analysis Approach," in 2021 Innovations in Energy Management and Renewable Resources (52042) (IEEE), 1–6. doi:10.1109/IEMRE52042.2021.9386754
- Kumar, N., Hussain, I., Singh, B., and Panigrahi, B. K. (2018). Self-Adaptive Incremental Conductance Algorithm for Swift and Ripple-free Maximum Power Harvesting from PV Array. *IEEE Trans. Ind. Inf.* 14, 2031–2041. doi:10.1109/TII.2017.2765083
- Kumar, N., Singh, B., and Panigrahi, B. K. (2019). Integration of Solar PV with Low-Voltage Weak Grid System: Using Maximize-M Kalman Filter and Self-Tuned P&O Algorithm. *IEEE Trans. Ind. Electron.* 66, 9013–9022. doi:10.1109/TIE.2018.2889617
- Kundur, P., Balu, N. J., and Lauby, M. G. (1994). *Power System Stability and Control*. New York, NY, USA: McGraw-Hill Education.
- Li, T., Li, Y., Li, S., and Zhang, W. (2021). Research on Current-Limiting Control Strategy Suitable for Ground Faults in AC Microgrid. *IEEE J. Emerg. Sel. Top. Power Electron.* 9, 1736–1750. doi:10.1109/JESTPE.2020.2983726
- Liang, C., Wang, P., Han, X., Qin, W., Jia, Y., and Yuan, T. (2018). Battery Energy Storage Selection Based on a Novel Intermittent Wind Speed Model for Improving Power System Dynamic Reliability. *IEEE Trans. Smart Grid* 9, 6084–6094. doi:10.1109/TSG.2017.2703578
- Mantar Gundogdu, B., Nejad, S., Gladwin, D. T., Foster, M. P., and Stone, D. A. (2018). A Battery Energy Management Strategy for U.K. Enhanced Frequency Response and Triad Avoidance. *IEEE Trans. Ind. Electron.* 65, 9509–9517. doi:10.1109/TIE.2018.2818642
- Meegahapola, L., and Flynn, D. (2010). "Impact on Transient and Frequency Stability for a Power System at Very High Wind Penetration," in IEEE PES Gen. Meet. PES, Minneapolis, MN, USA (IEEE), 1–8. doi:10.1109/PES.2010.5589908
- Miller, N. W., Clark, K., and Shao, M. (2011). "Frequency Responsive Wind Plant Controls: Impacts on Grid Performance," in 2011 IEEE Power and Energy Society General Meeting (IEEE), 1–8. doi:10.1109/PES.2011.6039137
- Ochoa, D., and Martinez, S. (2017). Fast-Frequency Response provided by DFIG-Wind Turbines and its Impact on the Grid. *IEEE Trans. Power Syst.* 32, 4002–4011. doi:10.1109/TPWRS.2016.2636374
- Ortiz-Villalba, D., Rahmann, C., Alvarez, R., Canizares, C. A., and Strunck, C. (2020). Practical Framework for Frequency Stability Studies in Power Systems with Renewable Energy Sources. *IEEE Access* 8, 202286–202297. doi:10.1109/ACCESS.2020.3036162
- Pan, G., Gu, W., Lu, Y., Qiu, H., Lu, S., and Yao, S. (2020). Optimal Planning for Electricity-Hydrogen Integrated Energy System Considering Power to Hydrogen and Heat and Seasonal Storage. *IEEE Trans. Sustain. Energy.* 11, 2662–2676. doi:10.1109/TSTE.2020.2970078
- Quan, R., Li, G., Jin, G., Liu, Z., and Chen, Q. (2019). "Multi-objective Optimal Dispatch Method Based on Source-Network-Load-Storage Interaction System for DC Distribution Network," in IET Conf. Publ, Shanghai, China (IET), 1–8. doi:10.1049/cp.2019.0363
- Rahman, K. M. J., Munnee, M. M., and Khan, S. (2016). "Largest Blackouts Around the World: Trends and Data Analyses," in WIECON-ECE 2016 - 2016 IEEE Int. WIE Conf. Electr. Comput. Eng., Pune, India (IEEE), 155–159. doi:10.1109/WIECON-ECE.2016.8009108
- Ramalingam, G., Choudhary, A. K., and Mikkili, S. (2018). "Modeling and Analysis of a PV-Based Shunt Active Filter with BESS for Power Quality Enhancement under Dynamic Load Conditions," in INDICON 2018 - 15th IEEE India Counc. Int. Conf. 0, Coimbatore, India (IEEE). doi:10.1109/INDICON45594.2018.8987181
- Sun, M., Xie, G., Chen, L., Liu, Y., Li, X., and Min, Y. (2020). "Study on the Necessity and Role of Inertia in Power System Frequency Response," in 2020 IEEE 4th Conference on Energy Internet and Energy System Integration (EI2) (IEEE), 155–159. doi:10.1109/EI250167.2020.9347330

AUTHOR CONTRIBUTIONS

QC proposed the concept of the project, and FW acted as the project administrator. YC and HL designed the system model and established the details of the power configuration scheme. ZS and BL analyzed the data and carried out the simulation. RX and SZ contributed to funding acquisition and writing the paper. All authors approved the submitted version.

FUNDING

This work was supported by the Key Laboratory Open Fund of Far-shore Wind Power Technology of Zhejiang Province (ZOE2020008) and the Jianguo Natural Science Foundation (BK20180391).

- Tan, J., and Zhang, Y. (2017). Coordinated Control Strategy of a Battery Energy Storage System to Support a Wind Power Plant Providing Multi-Timescale Frequency Ancillary Services. *IEEE Trans. Sustain. Energ.* 8, 1140–1153. doi:10.1109/TSTE.2017.2663334
- Wang, D., Rueda Torres, J. L., Perilla, A., Rakhshani, E., Palensky, P., and Van Der Meijden, M. A. A. M. (2019). *Enhancement of Transient Stability in Power Systems with High Penetration Level of Wind Power Plants*. IEEE Milan PowerTech, 2–7. doi:10.1109/PTC.2019.8810696
- Wen, Y., Li, W., Huang, G., and Liu, X. (2016). Frequency Dynamics Constrained Unit Commitment with Battery Energy Storage. *IEEE Trans. Power Syst.* 31, 5115–5125. doi:10.1109/TPWRS.2016.2521882
- Xu, X., Bishop, M., Bishop, M., Donna G, O., and Chen, H. (2016). Application and Modeling of Battery Energy Storage in Power Systems. *Csee Jpes* 2, 82–90. doi:10.17775/cseejpes.2016.00039
- Yan, B., Luh, P. B., Warner, G., Zhang, P., and Member, S. (2017). Operation and Design Optimization of Microgrids with Renewables. *IEEE Trans. Automat. Sci. Eng.* 14, 573–585. doi:10.1109/TASE.2016.2645761
- Yan, R., Masood, N.-A., Kumar Saha, T., Bai, F., and Gu, H. (2018). The Anatomy of the 2016 South Australia Blackout: A Catastrophic Event in a High Renewable Network. *IEEE Trans. Power Syst.* 33, 5374–5388. doi:10.1109/TPWRS.2018.2820150
- Yang, B., Cao, X., Cai, Z., Yang, T., Chen, D., Gao, X., et al. (2020). Unit Commitment Comprehensive Optimal Model Considering the Cost of Wind Power Curtailment and Deep Peak Regulation of Thermal Unit. *IEEE Access* 8, 71318–71325. doi:10.1109/ACCESS.2020.2983183
- Yoo, Y., Jung, S., and Jang, G. (2020). Dynamic Inertia Response Support by Energy Storage System with Renewable Energy Integration Substation. *J. Mod. Power Syst. Clean. Energ.* 8, 260–266. doi:10.35833/MPCE.2018.000760
- Zhang, G., Ela, E., and Wang, Q. (2019). Market Scheduling and Pricing for Primary and Secondary Frequency Reserve. *IEEE Trans. Power Syst.* 34, 2914–2924. doi:10.1109/TPWRS.2018.2889067
- Zhang, S., Mishra, Y., and Shahidehpour, M. (2017). Utilizing Distributed Energy Resources to Support Frequency Regulation Services. *Appl. Energ.* 206, 1484–1494. doi:10.1016/j.apenergy.2017.09.114

Conflict of Interest: The authors declare that the research was conducted in the absence of any commercial or financial relationships that could be construed as a potential conflict of interest.

Copyright © 2021 Chen, Xie, Chen, Liu, Zhang, Wang, Shi and Lin. This is an open-access article distributed under the terms of the Creative Commons Attribution License (CC BY). The use, distribution or reproduction in other forums is permitted, provided the original author(s) and the copyright owner(s) are credited and that the original publication in this journal is cited, in accordance with accepted academic practice. No use, distribution or reproduction is permitted which does not comply with these terms.

NOMENCLATURE

ACE Area control error	Rtg Droop coefficients of Thermal Gen
B Secondary frequency regulation coefficient	TB Time constant used to describe the response time delay of the BESS
BESS Battery energy storage system	Tch Adjustment response time of the reheater
BPC BESS power configuration	T_{hg} Time constant of the hydro governor
D Load damping coefficient	Ti Synchronizing torque coefficient between adjacent areas
Fhp Gain coefficient of the reheater	Tr Transient parameters used to simulate the mechanical inertia of water
Δf^{nadir} Frequency drop	Trh Time constant of the reheater
G Governor constant	Ttg Time constant of the thermal governor
GB Transfer function of the BESS	Tw Required time for the water accelerating from standstill to velocity V_0 in the hydro turbine model
Ghg Transfer functions of Hydro Gen	V Voltage magnitude
Gtg Transfer functions of Thermal Gen	α Energy storage configuration factor
H Inertia constant of the synchronous generator	Δf Frequency deviations
HB(s) Amplitude–frequency characteristic function with the BESS	Δf_i Frequency deviations in the i th adjacent area
HG(s) Amplitude–frequency characteristic function without BESS	PB Output value of the frequency regulation power of the BESS
M Generator inertia constant	ΔPE Electrical power variation of the generator set
PAGC Automatic generation control signal	ΔPG Mechanical power variation of the generator set
PCS Power configuration scheme	ΔPhg Output value of the frequency regulation power of Hydro Gen
R Speed regulation constant	ΔPL Net load power fluctuations
RB Droop coefficients of the BESS	$\Delta PL(s)$ Frequency-sensitive load change
REG Renewable energy generation	ΔPtg Output value of the frequency regulation power of Thermal Gen
REP Renewable energy penetration	$\Delta Ptie$ Power exchanged from other areas through the tie lines
Rhg Droop coefficients of Hydro Gen	ΔY Opening variation of the steam valve of the steam turbine
RLC REP level calculation	$\Delta \omega$ Generator angular frequency deviation
Rt Transient parameters used to simulate the reverse variation of the mechanical power	ωr Generator rotor speed