

Conf-780808--15

LA-UR-78-1571

TITLE: A SIMPLE TECHNIQUE OF ESTIMATING THE PERFORMANCE OF PASSIVE SOLAR HEATING SYSTEMS

AUTHOR(S): J. D. Balcomb and R. D. McFarland

SUBMITTED TO: 1978 ISES Conference, Denver, Colorado
August, 1978

MASTER

By acceptance of this article for publication, the publisher recognizes the Government's (license) rights in any copyright and the Government and its authorized representatives have unrestricted right to reproduce in whole or in part said article under any copyright secured by the publisher.

The Los Alamos Scientific Laboratory requests that the publisher identify this article as work performed under the auspices of the USERDA.



An Affirmative Action/Equal Opportunity Employer

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Begin text of second and succeeding pages here

BEGIN IN A SIMPLE TECHNIQUE OF ESTIMATING
THE PERFORMANCE OF PASSIVE SOLAR
HEATING SYSTEMS

by

J. D. Balcomb and R. D. McFarland
Los Alamos Scientific Laboratory
Los Alamos, NM 87545

ABSTRACT

A method is presented for estimating the annual solar performance of a building using a passive thermal storage wall of the Trombe wall or water wall type with or without night insulation. Tables of performance parameters are given for 84 cities. The method is accurate to + 3% as compared with hour-by-hour computer simulations.

PROCEDURE

A simple procedure has been devised for predicting the performance of solar heated structures of the thermal storage wall type. The method was originally developed for estimating performance of active systems [1] but proves to be even more accurate for the analysis of passive systems.

The correlation procedure used, called the monthly solar load ratio method, is based on the premise that the monthly solar heating fraction can be correlated with the ratio of monthly solar energy absorbed by the solar wall to the total building monthly thermal load. The correlation procedure is described in detail in Ref. [2].

Data have been obtained for 84 cities for the monthly solar radiation on a horizontal surface and for the monthly heating degree-days. Based on these data and on the correlations of the monthly solar load ratio method, tables of solar heating performance have been prepared for the 84 cities. The tables have been prepared for a specific set of reference passive solar systems as follows:

- Vertical, south-facing glass
- Wall absorptance = 1.0
- Ground reflectance = 0.3
- No shading
- Thermal Storage = 45 BTU/°F ft² of glazing
- Trombe wall has vents with back draft dampers
- Double Glazing (normal transmittance = 0.747)
- Temperature range in building = 65 to 75°F
- Other building mass is negligible
- Night insulation (when used) is R9;
- 5:00 p.m. to 8:00 a.m.
- Wall to room conductance = 1.0 BTU/hr °F ft²
- Trombe wall properties: K = 1.0 BTU/ft hr °F
- ρC = 30 BTU/ft³ °F

Step 1

Estimate the Building Loss Coefficient (BLC) in BTU/degree-day. This is the sum of the building skin conductance plus infiltration. It is the extra energy required (BTU) per day for each additional 1°F increase in temperature difference between the building interior and outside. It can be calculated from the sum of the UxA values for the exterior areas of the building plus infiltration. IMPORTANT--in calculating the Building Loss Coefficient, the passive thermal storage wall should not be included in the load.

Step 2

Calculate the building Load Collector Ratio (LCR) defined as follows:

$$\text{Load Collector Ratio} = \frac{\text{Building Loss Coefficient (BTU/DD)}}{\text{Solar Collection Area (ft}^2\text{)}}$$

In calculating the Load Collector Ratio the solar collection area used should be the net glazed area (the actual solar collection aperture) and not the gross area of the solar wall.

Step 3

Go to Table 1 and locate the city of interest and the wall type of interest. If the Load Collector Ratio determined in Step 2 corresponds exactly to one of the values of Solar Heating Fraction (SHF) listed in the table, then this is the desired answer. If not, one needs to interpolate in the table. The meaning of a Solar Heating Fraction is ambiguous when applied to a passive solar building. What is the building being compared with? As used herein, the SHF is the fraction of the degree-days times the Building Loss Coefficient) which is supplied by the solar wall. The wall is not credited with the heat used to supply its own steady-state load since a "normal" south wall would presumably have a much lower loss coefficient and would inevitably benefit from solar gains, even if they are unintentional.

The auxiliary used is a less ambiguous peg point, leaving the basis of comparison up to the user.

Step 4 (Continued from preceding pages here)

The annual auxiliary energy required to maintain the building at a minimum temperature of 65°F can be estimated from the following equation:

$$\text{Auxiliary Energy, BTU/yr} = (1 - \text{SHF}) \times \left(\frac{\text{Annual Heating Degree-Days}}{\text{Day}} \right) \times \left(\frac{\text{Building Loss Coefficient, BTU/Degree-Day}}{\text{Day}} \right)$$

EXAMPLE

A 72' x 24' building in Dodge City, Kansas is to be constructed with a 309 sq ft water wall on the south side. The water wall will contain 45 lbs of water per sq ft of south glazing for a total of 13,500 lbs of water or 1618 gallons. The wall is double glazed with normal sealed glass units which have a net transmittance of 0.74 for sunlight striking the glass perpendicularly. Other than the thermal storage wall, the building is of light frame construction with little additional mass. It is desired to estimate the annual solar heating contribution.

(Step 1) The Building Loss Coefficient is estimated as follows:

Skin Conduction:

Surface Type	Area ft ²	U-Value BTU/ft ² °F hr	UxA BTU/°F hr
Water Wall	309	(not included in BLC)	
Opaque Walls	1107	0.07	77.5
Windows (E,W,N)	120	0.55	66.0
Roof	1728	0.05	86.4
Floor	1728	0.05	86.4

Building Skin Conductance = 316.3

Infiltration:

(12320 ft³) (1/2 ACH) (0.018) = 110.9

Total: Building Loss Coefficient = 427.2 BTU/hr°F
= 10250 BTU/DD

The building is tightly sealed and equipped with an air-lock entry and thus the infiltration can probably be held to the minimum recommended level of 1/2 air change per hour.

(Step 2) The building south wall is glazed with 18 standard patio door size sealed double glass units each with a net effective exposed area of 75 x 33 in. for a total of 509 sq ft of collection area. Thus the Load Collector Ratio is 10250/309 = 33.2 BTU/degree-day-sq ft.

(Step 3) In the table for Dodge City, Kansas we find the following entries for the case of a water wall without night insulation:

SHF	0.30	0.40	0.50	0.60
LCR	61	43	31	23

Our Load Collector Ratio of 33.2 lies between the two values of 0.40 and 0.50 Solar Heating Fraction.

SHF = 0.48

The energy saved by the installation of the solar wall is estimated as (0.48)(10250)(4986) = 24.5 MBTU/yr. The energy actually supplied by the solar wall will be greater than this since the room temperature will frequently be above 65°F.

(Step 4) The auxiliary energy can be estimated as:

Auxiliary Energy = (1-0.48)(10250)(4986) = 26.6 MBTU/yr.

VARIATIONS FROM THE ASSUMED REFERENCE SYSTEMS

The monthly solar load ratio curves which have been determined are for the specific reference systems as defined. If it is desired to estimate the performance of a system which is different than one of these reference systems, then it is necessary to make a correction. The most reliable way of doing this is to refer to results of hour-by-hour calculations which are made for a specific system varying only the parameter of interest. Quite a few such calculations have been made by LASL and have been published. [3,4] These describe the effect of water mass in a water wall, the effect of using or not using the vents in the Trombe wall, the effect of thickness of a Trombe wall, and the effect of different thermal conductivities of the material.

The recommended procedure is to make a calculation for the reference case and then to adjust that value up or down.

REFERENCES

1. J. D. Balcomb and J. C. Hedstrom, "A Simplified Method for Calculating Required Solar Collector Array Size for Space Heating," Proceedings, 1976 ISSES Annual Meeting, Vol. 4, Winnipeg, Canada, Aug. 15-20, 1976. See also: ERDA's Pacific Regional Solar Heating Handbook, Nov. 1976.
2. J. D. Balcomb and R. D. McFarland, "A Simple Empirical Method for Estimating the Performance of a Passive Solar Heated Building of the Thermal Storage Wall Type," Proceedings of the 2nd National Passive Solar Conference, Philadelphia, PA, March 16-18, 1978.
3. J. D. Balcomb, et al., "Simulation Analysis of Passive Solar Heated Buildings--Preliminary Results," Solar Energy, Vol. 19, pp 277-282 (1977).
4. J. D. Balcomb, J. C. Hedstrom and R. D. McFarland, "Passive Solar Heating of Buildings." Printed in SAND-77-1204 and also Solar Architecture, Ann Arbor Science (1977).

AMERICAN SECTION OF INTERNATIONAL SOLAR ENERGY SOCIETY, INC.

77% Copy Reduction for 7 inch x 9 inch Surface on 8.5 inch x 11 inch Page

TABLE I: PERFORMANCE PARAMETERS FOR PASSIVE SOLAR HEATING SYSTEMS USING THERMAL STORAGE WALLS
Load Collector Ratio (BTU/DD-ft²) for particular values of Solar Heating Fraction (SHF)

Page, Arizona	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Apalachicola, Florida	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
6332 DD 37°N	WW	196	88	54	37	27	19	13	7		1308 DD 30°N	WW	700	322	204	145	110	85	65	48	32
	WWNI	312	145	91	65	49	38	29	22	15		WWNI	956	444	281	203	155	123	97	75	53
	TW	135	94	56	37	25	17	11	6			TW	635	313	194	133	95	71	51	35	24
	TWNI	304	141	89	63	46	35	26	18	12		TWNI	906	420	266	189	142	108	82	61	42
Phoenix, Arizona 1765 DD 33°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Gainesville, Florida 1239 DD 30°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	626	294	188	135	102	78	60	44	29		WW	731	333	212	152	115	90	69	51	35
	WWNI	863	407	261	189	145	114	90	69	49		WWNI	1000	457	292	211	162	127	102	79	56
	TW	577	287	179	123	88	64	47	33	21		TW	662	326	202	139	100	73	54	39	25
TWNI	819	386	247	176	132	101	76	56	38	TWNI	943	435	276	197	148	113	86	64	44		
Tucson, Arizona 1800 DD 32°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Tallahassee, Florida 1485 DD 30°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	631	291	184	132	100	77	59	43	29		WW	621	285	179	128	97	75	57	42	29
	WWNI	871	403	256	185	142	112	89	63	49		WWNI	857	397	249	180	133	109	87	67	48
	TW	578	284	176	121	87	63	46	33	21		TW	563	279	172	117	84	61	45	32	21
TWNI	825	383	243	173	130	99	75	56	38	TWNI	809	376	237	169	127	97	73	54	37		
Little Rock, Arkansas 3219 DD 35°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Tampa, Florida 683 DD 28°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	239	108	66	46	33	24	17	11			WW	1147	573	374	272	210	166	129	99	69
	WWNI	365	172	107	76	57	44	35	26	18		WWNI	1520	760	500	365	283	227	182	141	102
	TW	232	112	67	44	30	21	14	9			TW	1059	548	351	245	179	134	100	73	49
TWNI	356	165	103	73	54	40	30	22	14	TWNI	1443	717	467	339	258	199	152	114	80		
Davis, California 2572 DD 39°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Atlanta, Georgia 2961 DD 34°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	409	187	115	79	57	42	30	21	11		WW	301	136	83	58	43	31	23	15	8
	WWNI	585	272	170	120	89	68	52	39	26		WWNI	448	207	129	91	69	54	42	32	22
	TW	376	183	111	74	51	36	25	16	9		TW	206	133	83	55	36	27	18	12	7
TWNI	556	259	161	112	82	61	45	32	21	TWNI	431	198	123	87	64	48	36	26	17		
El Centro, California 1458 DD 33°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Boise, Idaho 5809 DD 44°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	1029	482	301	214	161	125	97	72	50		WW	185	83	49	31	20	12	6		
	WWNI	1375	649	407	290	221	175	139	107	77		WWNI	299	139	80	59	43	31	23	16	10
	TW	916	458	284	194	143	103	75	54	36		TW	182	86	50	31	20	12	6		
TWNI	1294	608	382	270	202	154	117	87	60	TWNI	290	135	83	56	40	29	21	14	8		
Fresno, California 2492 DD 37°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Lemont (AHL) Illinois 6155 DD 42°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	405	186	113	77	55	40	29	19	10		WW	120	51	29	18	11				
	WWNI	577	271	168	117	87	66	50	37	25		WWNI	219	100	61	42	31	24	18	11	8
	TW	370	181	109	72	49	34	24	15	8		TW	129	59	33	20	12	7			
TWNI	550	257	159	110	79	59	43	31	20	TWNI	216	93	61	42	30	22	16	11	7		
Inyarn, California 3528 DD 35°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Indianapolis, Indiana 5699 DD 40°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	453	209	129	90	66	50	37	26	16		WW	136	58	33	21	14	7			
	WWNI	641	300	188	132	100	77	59	46	32		WWNI	239	109	67	46	34	27	19	14	9
	TW	419	204	124	84	59	42	30	20	12		TW	142	65	37	23	14	8			
TWNI	613	284	177	124	92	69	52	38	25	TWNI	235	107	65	45	33	24	17	12	7		
Los Angeles, California 2061 DD 34°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Ames, Iowa 6548 DD 42°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	763	362	225	158	118	91	70	52	35		WW	117	50	29	18	11				
	WWNI	1032	498	310	219	165	131	103	80	57		WWNI	215	99	61	42	31	23	18	12	8
	TW	687	344	213	145	103	75	55	39	26		TW	127	58	33	20	12	6			
TWNI	979	464	291	205	153	116	88	65	45	TWNI	213	98	60	41	30	22	16	11	7		
Riverside, California 1003 DD 34°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Dodg City, Kansas 4085 DD 38°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	767	356	224	160	121	94	72	53	36		WW	214	99	61	43	31	23	16	10	
	WWNI	1039	488	308	221	167	134	106	82	58		WWNI	335	160	101	72	54	42	33	25	17
	TW	692	344	214	146	105	77	56	40	26		TW	214	104	63	41	28	20	13	8	
TWNI	984	459	290	207	155	118	90	67	46	TWNI	327	154	97	69	51	38	29	21	14		
Santa Maria, California 2967 DD 35°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Manhattan, Kansas 5182 DD 39°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	544	272	176	126	95	74	55	41	27		WW	165	74	44	30	21	14	8		
	WWNI	752	376	247	179	137	108	86	66	46		WWNI	274	120	80	56	42	32	25	18	12
	TW	514	264	167	115	83	61	44	31	20		TW	159	80	47	30	20	13	8		
TWNI	720	358	231	166	126	96	73	54	36	TWNI	269	125	78	54	40	30	22	15	10		
Granby, Colorado 5524 DD 40°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Lexington, Kentucky 4603 DD 39°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	196	90	56	39	28	20	14	8			WW	143	67	36	24	18	10			
	WWNI	313	146	94	67	51	40	31	23	15		WWNI	216	114	70	49	36	24	21	15	10
	TW	197	95	59	39	28	21	12	7			TW	148	70	40	25	16	10	5		
TWNI	303	143	91	65	48	36	27	19	13	TWNI	242	112	69	48	35	25	19	13	8		
Grand Junction, Colorado 8441 DD 39°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Lake Charles, Louisiana 1459 DD 30°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
	WW	199	92	58	39	28	20	13	8			WW	522	239	152	109	82	63	48	35	23
	WWNI	317	150	95	67	51	39	30	22	15		WWNI	730	335	214	155	113	94	74	57	47
	TW	201	97	58	39	26	17	11	6			TW	481	237	145	100	71	52	38	25	17
TWNI	310	145	91	64	48	36	26	19	12	TWNI	635	322	204	146	109	83	63	46	32		
Washington, D. C. 4224 DD 39°N	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	Shreveport, Louisiana 2194 DD 32°N	SHF	0.1	0.2	0.3	0.4	0.5	0			

AMERICAN SECTION OF INTERNATIONAL SOLAR ENERGY SOCIETY, INC.

77% Copy Reduction for 7 inch x 9 inch Surface on 8.5 inch x 11 inch Page

TABLE I: PERFORMANCE PARAMETERS FOR PASSIVE SOLAR HEATING SYSTEMS USING THERMAL STORAGE WALLS (CONT.)
Load Collector Ratio (BTU/DD-ft²) for particular values of Solar Heating Fraction (SHF)

AGE HERE IN ALL CAPITALS

Location	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
Astoria, Oregon	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
512A DD	WW	207	90	59	39	26	17	9		
	WNH	322	158	99	69	50	37	27	19	11
	TW	205	99	59	38	25	16	9		
45°N	TWNI	315	152	95	65	47	34	24	16	9
Corvallis, Oregon	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
4726 DD	WW	224	96	57	37	24	16	9		
	WNH	352	158	97	67	48	36	26	18	11
	TW	217	100	58	36	24	15	9		
45°N	TWNI	341	153	93	63	45	33	23	16	9
Madford, Oregon	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
5008 DD	WW	188	83	49	31	20	12			
	WNH	308	139	86	59	43	31	23	16	9
	TW	186	87	50	31	20	12	6		
42°N	TWNI	296	136	83	57	40	29	21	14	8
State College, Pennsylvania	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
5934 DD	WW	117	50	28	18	11				
	WNH	214	98	61	42	31	23	17	12	7
	TW	116	58	33	20	12	6			
41°N	TWNI	213	97	60	41	30	22	16	11	6
Newport, Rhode Island	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
5804 DD	WW	150	66	40	27	19	12	7		
	WNH	256	118	74	52	39	30	23	17	11
	TW	156	74	43	27	18	11	7		
41°N	TWNI	251	116	72	51	37	28	20	14	9
Charleston, South Carolina	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
2033 DD	WW	442	204	127	90	67	52	39	28	16
	WNH	624	295	184	132	100	79	63	48	34
	TW	407	202	124	84	59	43	31	21	13
33°N	TWNI	594	279	176	124	93	71	53	39	27
Rapid City, South Dakota	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
7345 DD	WW	149	67	40	26	18	11	6		
	WNH	253	118	74	52	39	30	22	16	10
	TW	155	73	43	27	17	11	6		
Nashville, Tennessee	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
3578 DD	WW	227	99	59	40	28	20	13	8	
	WNH	355	161	98	68	51	39	30	21	15
	TW	219	103	61	39	26	18	11	7	
36°N	TWNI	343	155	95	64	48	36	27	19	12
Oak Ridge, Tennessee	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
3817 DD	WW	204	90	54	36	26	19	12	8	
	WNH	325	149	92	64	48	37	29	21	14
	TW	201	95	56	36	24	16	10	6	
36°N	TWNI	315	145	89	62	45	34	25	18	11
Brownsville, Texas	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
600 DD	WW	1052	526	348	254	194	151	117	88	60
	WNH	1399	700	465	342	265	209	165	127	90
	TW	976	506	324	226	165	123	91	66	44
26°N	TWNI	1330	664	435	315	238	183	140	104	71
El Paso, Texas	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
2700 DD	WW	431	205	129	92	69	52	39	28	18
	WNH	606	295	187	134	103	80	63	48	34
	TW	402	202	125	85	60	44	31	22	13
32°N	TWNI	582	279	178	126	94	72	54	40	27
Fort Worth, Texas	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
2405 DD	WW	364	171	108	76	57	43	32	23	14
	WNH	526	251	159	115	87	69	54	41	27
	TW	344	171	106	71	50	36	26	17	10
33°N	TWNI	503	239	152	108	81	61	46	34	23
Midland, Texas	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
2591 DD	WW	385	184	115	82	61	47	35	25	16
	WNH	548	267	169	121	91	73	57	44	31
	TW	362	182	113	76	54	39	29	19	12
32°N	TWNI	527	253	161	115	86	65	49	36	24
San Antonio, Texas	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
1546 DD	WW	547	253	159	114	86	65	50	37	24
	WNH	782	355	224	162	124	98	78	60	42
	TW	501	248	154	104	75	54	40	29	18
30°N	TWNI	722	337	213	152	114	87	66	49	33
Flaming Gorge, Utah	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
6929 DD	WW	170	79	49	33	23	16	10	5	
	WNH	277	132	84	60	45	35	27	20	13
	TW	173	84	50	33	22	15	9	5	
41°N	TWNI	272	129	82	58	43	32	24	17	11
Salt Lake City, Utah	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
6052 DD	WW	192	86	52	35	24	16	10		
	WNH	308	143	90	63	46	35	27	19	12
	TW	190	91	54	34	23	15	9	4	
41°N	TWNI	299	140	87	60	44	32	24	17	10
Burlington, Vermont	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
6269 DD	WW	80	30	15						
	WNH	171	75	46	31	23	17	12	8	4
	TW	94	41	21	11					
44°N	TWNI	172	77	46	31	22	16	11	7	4
Pullman, Washington	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
5542 DD	WW	178	78	44	27	17	9			
	WNH	291	134	82	56	40	29	21	14	8
	TW	175	81	46	28	18	10			
47°N	TWNI	282	130	79	53	37	27	19	13	7
Richland, Washington	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
5941 DD	WW	179	77	43	25	15	7			
	WNH	293	133	81	54	38	27	19	13	7
	TW	176	80	45	27	16	9			
47°N	TWNI	285	130	78	52	35	25	18	12	7
Seattle, Washington	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
4424 DD	WW	219	93	52	32	20	11			
	WNH	346	154	93	62	44	31	22	15	9
	TW	211	95	54	33	20	12	6		
48°N	TWNI	333	149	89	59	41	29	20	13	8
Spokane, Washington	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
6655 DD	WW	149	63	34	23	10				
	WNH	255	116	70	47	33	23	17	11	6
	TW	151	68	38	22	13	6			
48°N	TWNI	251	114	68	45	32	22	16	10	5
Madison, Wisconsin	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
7853 DD	WW	108	44	24	14	7				
	WNH	208	92	56	38	28	21	16	11	6
	TW	119	53	29	17	10				
43°N	TWNI	204	92	56	35	27	20	14	10	6
Lander, Wyoming	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
7870 DD	WW	183	76	47	32	22	15	9		
	WNH	267	129	82	53	43	34	25	19	12
	TW	168	81	49	31	21	14	9	4	
43°N	TWNI	264	126	80	56	41	31	23	16	10
Laramie, Wyoming	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
7381 DD	WW	157	72	44	31	22	15	10		
	WNH	263	124	79	56	43	33	26	19	13
	TW	164	79	47	31	21	14	9	4	
41°N	TWNI	259	122	77	55	41	30	23	16	10
Edmonton, Alberta	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
10268 DD	WW	93	34							
	WNH	184	83	48	31	20	13	8	4	
	TW	102	42	20						
54°N	TWNI	184	83	48	31	20	14	9	5	
Ottawa, Ontario	SHF	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
8735 DD	WW	91	35	17	7					