

# Understanding Frequency & Time Domain Polarisation Methods for the Insulation Condition Assessment of Power Transformers

T. K. Saha\*, *Senior Member IEEE*, R. Middleton *Fellow, IEEE* \*\* and  
A. Thomas\**Member IEEE*

**Abstract--** Preventive diagnosis and maintenance of transformers has become more and more useful in recent times in order to improve the reliability of electric power systems. Time domain dielectric testing techniques such as Return Voltage (RV) measurement and Polarisation-Depolarisation Current (PDC) measurement have recently been widely used as potential tools for condition assessment of transformer insulation. In the frequency domain, measurement of the dissipation factor ( $\tan\delta$ ) over a frequency range of 0.1 mHz to 1 kHz has been commonly used to assess the condition of transformer insulation. A number of transformers have been tested with these diagnostic techniques. A better understanding and analysis of the dielectric test results is only possible with a clear understanding of the physical behaviour of the insulation system in response to moisture and ageing. A circuit model, which describes the dielectric behaviour of the transformer's main insulation system, has been modelled in this paper from the frequency domain measurement data and then RV and PDC data have been simulated from the circuit model. This paper then presents discussions of frequency and time domain techniques to find the condition of transformer insulation in terms of moisture and ageing estimation.

**Index Terms--** Dielectric Response, Polarisation Depolarisation Current, Return Voltage, Dissipation Factor, Oil/paper Insulation, Ageing and Moisture Analysis, Transformer Condition Monitoring, Insulation Model Nomenclature

## I. INTRODUCTION

An oil/paper insulation system in a transformer is aged by the electrical, thermal and environmental stresses during its operation. Among these, moisture and ageing by-products strongly degrade the dielectric properties of the oil/paper insulation system within a transformer. To assess the reliability of insulation accurately, it is very valuable to know the condition of the oil and the paper separately. In recent years, new methods to assess insulation systems have been extensively used. Among them, recovery voltage and polarisation/depolarisation current measurements in the time domain [1-2, 4-5, 8, 12] and dissipation factor measurements

at 50 Hz [3] or at variable frequency range [6-8] are examples of newer methods that have been used for the diagnosis of power transformer insulation condition. The commonly known measurement technique, Frequency Domain Spectroscopy (FDS), includes the measurement of dissipation factor ( $\tan\delta$ ) over a frequency range of 0.1 mHz to 1 kHz [6-8].

The interpretation of dielectric test methods require full and exact knowledge of the relationship between basic dielectric processes and the dielectric parameters measured. The simulation of the dielectric processes gives the possibility to explain some exact relationships that may help to correctly interpret the test results. An effort has been made in this paper to understand the dielectric response of oil/paper insulation as related to its fundamental structure and its behaviour to an external electric field. This paper reports the development of an RC equivalent circuit, based on the extended Debye model, which is based on the low frequency (0.1 mHz to 1 kHz) dielectric spectroscopy measurement conducted by the IDA200 equipment [8]. The model does not require taking into account the geometry of the transformer. Examples are provided in this paper to demonstrate the effectiveness of this tool to analyse results from field measurements on transformers. The model parameters have been identified using software written in Matlab. The time domain based diagnosis using polarisation/depolarisation currents and return voltages have been estimated from the identified model components by using the developed mathematical formulations.

Simulation results have also been supported with actual time domain field test results for one transformer using the Tettex 5461 recovery voltage meter [9] to illustrate any relationship between time and frequency domain diagnostic techniques. An expert system previously developed by the first author of this paper [16] was used to diagnose the state of insulation conditions.

## II. THEORY OF POLARISATION BASED DIAGNOSIS

### II.A Frequency Domain Dielectric Spectroscopy (FDS) [7, 8, 12]

This technique is an extension of capacitance and dissipation factor ( $\tan\delta$ ) measurements normally performed at

---

T.K. Saha ([saha@itee.uq.edu.au](mailto:saha@itee.uq.edu.au)) and A Thomas ([andrew@itee.uq.edu.au](mailto:andrew@itee.uq.edu.au)) are with the School of ITEE, University of Queensland, Brisbane, QLD-4072, Australia and R. Middleton ([Richard.middleton@nuim.ie](mailto:Richard.middleton@nuim.ie)) is with the Hamilton Institute, National University of Ireland

power frequency. A sinusoidal signal is applied to the high voltage bushing and current is measured through the low voltage terminal.

If the applied voltage is an alternating signal at a frequency  $\omega$ , then the measured capacitance is a complex quantity and whose real and imaginary parts correspond directly to the real and imaginary components of the complex permittivity:

$$C(\omega) = C'(\omega) - jC''(\omega) = (A/w) \cdot (\epsilon'(\omega) - j\epsilon''(\omega)) \quad (1)$$

Where  $A$  is the plate area of the capacitance,  $\epsilon$  is the permittivity and  $w$  is the distance between two plates.  $C'(\omega)$  corresponds to the ordinary capacitance, while the imaginary component  $C''(\omega)$  represents the dielectric loss component. The tangent of the loss angle- $\delta$  (or dissipation factor) is given by equation (2).

$$\tan \delta = \frac{C''(\omega)}{C'(\omega)} \quad (2)$$

### II.B Time Domain Polarisation Measurements [10, 15]

If an insulation system with geometric capacitance  $C_0$  (measured capacitance at or near power frequency divided by  $\epsilon_r$ , the relative permittivity of the composite insulation system), composite conductivity  $\sigma$  and dielectric response function  $f(t)$  is exposed to a step voltage of magnitude  $U_0$ , the polarisation current through the insulation system can be derived as:

$$i_{pol}(t) = C_0 \cdot U_0 \cdot \left[ \frac{\sigma}{\epsilon_0} + f(t) \right] \quad (3)$$

Once the step voltage is removed and the insulation system is shorted to ground, the depolarisation current can be written as:

$$i_{depol}(t) = -C_0 \cdot U_0 \cdot [f(t) - f(t+t_1)] \quad (4)$$




Fig. 1 Principle of polarisation/depolarisation current and RV measurement

Fig. 1 shows the nature of the polarisation current after applying a DC voltage  $U_0$  and of the depolarisation current during the short circuit. At  $t=t_2$ , ground (short circuit) is removed from the insulation and a voltmeter is connected across it. When a direct voltage is applied to a dielectric for a period of time, and is then short circuited for a period lower

than the charging time, after opening the short circuit, the charge bounded by the polarisation will randomly relax and result in a voltage build up between the electrodes of the dielectric. This phenomenon is called the return/recovery voltage. The test object is charged from  $0 \leq t \leq t_1$ , grounded from  $t_1 \leq t \leq t_2$  and for  $t > t_2$  the recovery voltage is measured during the open circuit condition. The recovery voltage  $U_r$  is contained in the following equation.

$$i_r(t) = \sigma U_r(t) + \epsilon_0 \epsilon_r \frac{dU_r(t)}{dt} + \epsilon_0 U_0 (f(t) - f(t-t_1)) + \epsilon_0 \frac{d}{dt} \int_{t_2}^t f(t-\tau) U_r(\tau) d\tau \quad (5)$$

For  $t_2 < t < \infty$ , and  $U_r(t=t_2) = 0$

### II.C Modelling of Transformer Oil-Paper Insulation Using extended Debye Model from the Frequency Domain Dielectric Spectroscopy measurements

Over the last few years, several researchers [2, 4, 13, and 15] have proposed a number of equivalent circuits for modelling the transformer oil/paper insulation system for a better understanding of the dielectric response. In essence, most of the insulation models proposed so far have been derived from an extended Debye approach based on a RC-model as shown in Fig. 2. Apart from the polarisation current, conduction current flows in the insulation in the presence of an electric field.




Fig. 2 Equivalent circuit to model a linear dielectric material

The conduction current in the insulation is due to the insulation resistance  $R_0$  as shown in Fig. 2. The insulation resistance  $R_0$  can be calculated from the difference between polarisation and depolarisation currents at larger values of time given by  $[U_0 / (i_{pol} - i_{depol})]$ .  $C_0$  represents the geometric capacitance of the insulation system. The quantity  $C_0$  is the geometric capacitance of the insulation model given by  $(C_0 = C_m / \epsilon_r)$ . Where  $C_m$  is the capacitance measured between the two terminals of the insulation system under test. It can be measured with any capacitance measuring AC Bridge at, or around, the power frequency and  $\epsilon_r$  is the relative permittivity of the composite oil-paper insulation system. The parallel R-C branches are approximations of individual polarisation processes with their time constants  $R_i C_i$  and can be treated independent of each other. The representation of the

polarisation processes by parallel R-C branches allows the prediction of the response of the insulation, which rarely follows ideal Debye (i.e. non-extended) behaviour [13, 15].

The impedance of the circuit in Fig. 2 can be given by

$$Z = \frac{1}{\frac{1}{Z_0} + \frac{1}{Z_1} + \frac{1}{Z_2} + \dots + \frac{1}{Z_n}} \quad (6)$$

Where:

$$Z_0 = \frac{1}{\frac{1}{R_0} + j\omega C_0} \quad (7)$$

And :

$$Z_n = R_n + \frac{1}{j\omega C_n} \quad (8)$$

Where n is the number of parallel branches of the series R-C network. For the calculation of current, complex capacitance of the equivalent circuit has been defined by (1) from Fig. 2. For the FDS measurement,  $U_0$  would be replaced by  $U(\omega)$ , where  $U(\omega)$  is the input signal to the circuit as a function of frequency. The current is then given by (9)

$$I(\omega) = j\omega \cdot C(\omega) \cdot U(\omega) \quad (9)$$

The current can also be given by equation (10)

$$I(\omega) = \frac{U(\omega)}{Z(\omega)} = Y(\omega) \cdot U(\omega) \quad (10)$$

Using (9) and (10), (11) is derived for the calculation of the complex capacitance, which is the admittance of Fig. 2 divided by  $j\omega$ .

$$C(\omega) = Y(\omega) / j\omega \quad (11)$$

The reciprocal of the impedance  $Z(\omega)$  is then the admittance  $Y(\omega)$

$$Y(\omega) = 1/Z(\omega) \quad (12)$$

$C'(\omega)$  and  $C''(\omega)$  can be obtained by dividing the admittance by  $j\omega$ . These values can be obtained as follows.

The real and imaginary parts of the complex capacitance for the equivalent circuit Fig. 2 can be expressed as:

$$C'(\omega) = C_0 + \sum_{i=1}^n \frac{C_i}{1 + (\omega R_i C_i)^2} \quad (13)$$

$$C''(\omega) = \frac{1}{\omega R_0} + \sum_{i=1}^n \frac{\omega R_i C_i^2}{1 + (\omega R_i C_i)^2} \quad (14)$$

Now  $Z(\omega)$  can be expressed by (15),

$$Z(\omega) = \frac{1}{C(\omega)j\omega} = \frac{1}{j\omega[C'(\omega) - jC''(\omega)]} \quad (15)$$

Where  $C'(\omega)$  and  $C''(\omega)$  are given by (13) and (14) respectively.

## II.D RELATIONS between Frequency and Time Domains- problem formulation for estimating R-C parameters from the frequency domain measured data

The problem is to take measured real and imaginary parts of complex capacitance versus frequency data (i.e. FDS data) of the form:

$$\omega = \begin{bmatrix} \omega_1 \\ \omega_2 \\ \dots \\ \omega_n \end{bmatrix}, Z = \begin{bmatrix} Z_1 \\ Z_2 \\ \dots \\ Z_n \end{bmatrix} \quad (16)$$

Where  $\omega$  is a set of test frequencies (in rad/sec) and  $Z_n$  is the measured impedance at  $\omega_n$ . The objective is to fit a linear transfer function model to this data. In performing this fit, several issues need to be considered, including: the form of the model, the measure to be used in determining the best fit and constraints imposed on the model.

### II.D.1. Model Form

There are a number of different model forms used to allow data fitting. These can be transfer function based, pole-zero, state space, or other formulations. In this case, the gain, zero, pole form has been used, (Matlab 'zpk') which is as follows:

$$\hat{z}(s) = k \prod_{m=1}^N \frac{(s - z_m)}{(s - p_m)} \quad (17)$$

Where  $z_m$  and  $p_m$  are the impedance zeros and poles respectively, and  $k$  is the (high frequency) impedance. These unknown parameters are grouped into a  $(2N+1)$  dimensional vector,  $\theta^T = [k \quad -z_1 \quad \dots \quad -z_N \quad -p_1 \quad \dots \quad -p_N]$

In the form presented in (17), at high frequencies the impedance tends to a constant. Whilst in practice the geometric capacitance would typically lead to an impedance, which tends to zero. With the model form of (17), this can be achieved if one of the zeros is allowed to become very large.

### II.D.2 Criteria for Best Fit

There are a number of different criteria that may be used to determine the 'best fit' with one of the common ones being a least squares criteria:

$$J_{LS}(\theta) = \sum_{i=1}^n |z_i - \hat{z}(\theta, j\omega_i)|^2 \quad (18)$$

Where  $z_i$  is the measured complex impedance and  $\hat{z}(\theta, j\omega_i)$  is the estimated complex impedance as a function of frequency. In a statistical sense, this cost function gives optimal estimation if the measurements are subject to additive

uncorrelated Gaussian errors:  $z_i = \hat{z}(\theta^*, \omega_i) + n_i$  where  $\theta^*$  is the true set of parameters and  $n_i$  is the additive noise. On the other hand, if multiplicative errors are assumed,

$z_i = \hat{z}(\theta^*, \omega_i)(1 + n_i)$  then the least square cost function is not optimal. Instead, for small noise values, the least squares logarithmic impedance optimisation criteria was used, which is shown below:

$$J_{\log-LS}(\theta) = \sum_{i=1}^n |\log(z_i) - \log(\hat{z}(\theta, j\omega_i))|^2 \quad (19)$$

Note that the criteria in (19) gives a better measure of the match on a Bode type diagram, whereas the standard least squares cost function is more suited to a linear scaling. In particular, the standard least squares cost function, (18), tends to give a relatively good fit for large impedances, and a relatively poor signal to noise ratio, rather than a constant absolute noise.

### II.D.3 Parameter Constraints

To ensure several realistic features of the model, a number of constraints are introduced. Firstly, a nonlinear transformation of the parameters (logarithmic) is performed into new variables  $X = \log(\theta)$ . This allows for a much greater dynamic range of variables, and ensures that for any  $X$  the gain will be positive, and all poles and zeros will be negative real<sup>1</sup>. In addition, the poles and zeros are constrained as follows:

$$(-z_1) > (-p_1) > (-z_2) > (-p_2) > \dots > (-p_N) \quad (20)$$

The constraints in (20) interlace the zeros and poles and give the following desirable properties. ,  $\square > 0$  and  $\square \square$  satisfying (20) it follows that:

$$\begin{aligned} \angle \hat{z}(j\omega) &= \sum_{i=1}^N \angle \left( \frac{j\omega + (-z_i)}{j\omega + (-p_i)} \right) \\ &= \sum_{i=1}^N \angle \left( \frac{[\omega^2 + (-z_i)(-p_i)] + j\omega[(-p_i) - (-z_i)]}{\omega^2 + p_i^2} \right) \\ &\leq 0 \end{aligned} \quad (21)$$

In addition, it can also be shown that for satisfying (20):

$$\begin{aligned} \frac{\pi}{2} + \angle z(j\omega) &= \angle(j\omega z(j\omega)) \\ &= \angle \left( \frac{j\omega}{j\omega + (-p_N)} \right) + \sum_{i=1}^{N-1} \angle \left( \frac{j\omega + (-z_{i+1})}{j\omega + (-p_i)} \right) + \angle(j\omega + (-z_1)) \\ &\geq 0 + \sum_{i=1}^{N-1} \angle \left( \frac{[\omega^2 + (-z_{i+1})(-p_i)] + j\omega[(-p_i) - (-z_{i+1})]}{\omega^2 + p_i^2} \right) + 0 \\ &\geq 0 \end{aligned} \quad (22)$$

So from the combination of (21) and (22) it is clear that for any positive:

$$-\frac{\pi}{2} \leq \angle z(j\omega) \leq 0 \quad (23)$$

As expected for passive impedance is modelled on resistive and capacitive elements only. In addition to these constraints,

some other less important constraints on the relative separation etc. of pole and zeros are introduced.

### II.D.4 Formulation of the problem as a constrained minimisation

The problem of determining the model from the parameters is thus set up as a constrained minimisation problem:

Given data,  $Z$ , and a given model order,  $N$ , determine parameters  $\theta^*$  as:

$$\theta^* = \underset{\theta: \theta \text{ satisfies (10)}}{\operatorname{arg\,min}} \{J_{\log-LS}(\theta)\} \quad (24)$$

Where  $J_{\log-LS}(\theta)$  is defined in (9).

The constraints in this problem are linear, the gradient of the cost function,  $\frac{\partial J_{\log-LS}(\theta)}{\partial \theta}$ , can be computed analytically, and therefore, the Matlab function “fmincon” can be used to solve equation (24) numerically.

### II.D.5 Model Analysis

Once a model is estimated, a number of forms of analysis on this model can be performed. Note however, that due to the very wide range of time constants in the model in most cases, considerable care must be taken in handling the model. For example, conversion from zero, pole, gain form to transfer function form results in very large numerical rounding errors.

#### (a) Conversion to RC Model Form

The first form of analysis is to compute the predicted frequency response data. This can be easily performed using (for example) the Matlab “freqresp” command which computes the frequency response of a linear finite dimensional system. This command can directly take the model in the zero-pole gain form. This is also useful as a sanity check on the model fit to the data, where direct calculation gives capacitance and  $\tan\delta$  versus frequency. A second form of analysis is to convert the model to a series of parallel RC branches as shown in Fig. 2.

#### (b) Prediction of RVM/PDC Behaviour from model estimation

Another important set of tests performed are those based on time domain responses, namely, (i) Recovery Voltage (RV) and (ii) Polarisation/Depolarisation Current (PDC) Method.

To be able to handle a range of tests, and compare results, it is desirable that given a model one should be able to predict the results of various tests. This helps in model validation, and also gives greater flexibility in the testing scenario. It was therefore decided to take a model of the form given by (17), and given test conditions (charge voltage  $U_o$ , charge and discharge times  $t_1$  and  $t_2$ ) predict both the recovery voltage and the polarisation/depolarisation current waveforms. The poles/zero form of the model; (17) was used first, to create a

<sup>1</sup>Note:-it is claimed that any passive connection of positive RC elements can only result in a passive overall system, with negative real poles and zeros.

state space version of the impedance model using standard Matlab commands.

### III. INVESTIGATED TRANSFORMERS

Six transformers were tested in two power stations. Four transformers (marked with A-Gen, B-Gen, A-Aux and B-Aux) were measured in one power station and two transformers (marked with C-D) were measured in another power station. These measurements include frequency domain dielectric spectroscopy for all transformers and the Recovery Voltage measurement for only one transformer (due to time constraint provided by the customer). A summary of the transformers information is described in Table 1. Results are presented and analysed in this paper for these six transformers.

#### III.1. Measurement systems

Frequency domain dielectric spectroscopy equipment IDA200 [8] was used to measure capacitance and dissipation factor ( $\tan\delta$ ) over a frequency range of 0.1 mHz to 1 kHz. The supply voltage was 140 volts (RMS). The red (HI) connection was connected to the shorted HV terminals of the test object and the blue (LO) connection was connected to the shorted LV terminals of the transformer. The voltage over and the current through the specimen are measured with high accuracy using a voltage divider and an electrometer. The instrument earth was connected to the tank of the test object and the guard terminal was connected to the tank of the test object. Fig. 3 shows the arrangement for the frequency domain measurement.

Recovery Voltage was measured for one transformer using a Tettex 5461 RV meter [9]. For the RV measurement, all HV terminals were shorted and all LV terminals shorted and all were then grounded. The RV measurement was conducted on a 3-phase two winding type transformer. The instrument earth was connected to the tank of the transformer. Fig. 4 shows the arrangement for the RV measurement.




Fig. 3 Test arrangement of IDA 200 equipment

Table 1 Summary information of the tested transformers

Transformer Identity	MVA Rating	HV Rating (kV)	LV Rating (kV)	Date of Manufacture
A-Gen Tx	390	330	23	1991
B-Gen Tx	390	330	23	1992
A-Aux Tx	45	23	11.5	1985
B-Aux Tx	45	23	11.5	1985
C-Tx	45	23	11.5	1983
D-Tx	45	23	11.5	1983




Fig. 4 Test arrangement of Tettex 5461 equipment

A range of charging times was applied to the test specimen during the RV test. For each of these charging times the instrument performed a number of operations. A DC voltage of 2000 volts was applied to the HV terminals for the predetermined charging time, after which the HV and LV terminals were shorted for half the charging time, then the recovery voltage was measured during the open circuit condition.

## IV RESULTS & DISCUSSIONS

### IV.1 Frequency Domain Dielectric Spectroscopy

Figs. 5 and 6 respectively show the plot of  $\tan\delta$  and capacitance versus frequency for the four transformers (A-B Gen and Aux) measured in one power station. Figs. 7 and 8 respectively show the plot of  $\tan\delta$  and capacitance versus frequency for the two transformers (C and D) measured in another power station.




Fig. 5  $\tan\delta$  variations of four transformers (A, B Gen & Aux) over the frequency range of 0.1 mHz to 1 kHz




Fig. 6 Capacitance variation of four transformers (A, B Gen & Aux) over the frequency range of 0.1 mHz to 1 kHz

It was reported in [12] that the major advantage with the use of  $\tan\delta$  is its independence on test object geometry. In a previous study by the first author of this paper [14], findings from mass impregnated paper suggest that loss tangent has a minimum, which tends to increase with moisture content. A number of other researchers also correlated moisture with the minimum dissipation factor for oil/paper underground cables from the FDS measurement. The moisture content has been related with the minimum dissipation factor by some empirical relationships as in [17]. This indicates that one could attempt to directly relate the minimum of the loss tangent to certain moisture content in impregnated paper. However, this has not been reported for transformer oil-paper insulation and hence was not attempted to correlate in this paper. Summary results of frequency domain measurements from these transformers are presented in Table 2.

Table 2 Summary of frequency domain measurements

Transformer Identity	Minimum $\tan \delta$	Frequency at minimum $\tan \delta$ (Hz)
A-Gen Tx	0.0025	33
B-Gen. Tx	0.0035	10
A-Aux. Tx	0.0026	3.3
B-Aux. Tx	0.0025	3.3
C-Tx	0.0039	333.3
D-Tx	0.0041	333.3




Fig. 7  $\tan \delta$  variations of C and D transformers over the frequency range of 0.1 mHz to 1 kHz




Fig. 8 Capacitance variations of C and D transformers over the frequency range of 0.1 mHz to 1 kHz

It can be emphasised here that three transformers (A-Gen, A-Aux and B-Aux) have the lower range of minimum  $\tan \delta$  values compared to that of the B-Gen Tx, C-Tx and D-Tx transformers. This can be attributed to lower and higher moisture contents respectively. The D-Tx transformer has the highest minimum  $\tan\delta$  value among the three high  $\tan \delta$  transformers (B-Gen Tx, C-Tx and D-Tx), with an expectation of higher moisture content in this transformer than the others. The first author of this paper has extensively investigated time domain polarisation based tool for moisture assessment. In the later part of the result section, an estimation of moisture will be made from this previously developed software tool and other studies reported in [16] based on the time domain polarisation measurements.

Due to time constraints for allowable transformer outage, an RV measurement was conducted only for the B-gen transformer. The RV measured result of B-gen transformer is shown in Fig. 9 along with the simulated result based on the theory presented in the previous sections. An equivalent circuit (as in Fig. 2) is first modelled to perform this RV simulation. Similarly, RV Results for the three other transformers of the same power station are obtained from the developed simulation software and are shown in the Fig. 10. Simulation results from the other two transformers are shown in Fig. 11. The ratio of time to charging and discharging has always been two, for both measurements and simulation. Charging voltage for the RV measurement and simulation was 2000 volts dc. Summary results for these transformers are described in the Table 3.

Table 3 Summary of RV simulated results with only measurements on B generator transformer

Transformer Identity	RV Peak Max. Value (V) Measured and (corresponding charging time to peak The return voltage)	RV Peak Max. Value (V) simulated	Corresponding time of charging (s)
A-Gen Tx	Not done	520	400
B-Gen Tx	296 (200 s)	446	200
A-Aux Tx	Not done	490	1000
B-Aux Tx	Not done	440	1000
C-Tx	Not done	470	50
D-Tx	Not done	361	50




Fig. 9 RV spectra of B generator transformer and comparison with the measured results




Fig. 10 RV spectra for the A, B auxiliary and A generator transformers based on simulation from IDA data

#### IV.2 Recovery Voltage measurements and simulation

Normally the charging time to peak maximum RV voltage varies significantly for transformers with different moisture and ageing conditions [5, 6, 11, and 13]. For example, for a very dry transformer, this time could be several hundred to a thousand seconds and this becomes few to few tens of seconds for a very moist and aged transformer.

Results in Table 3 suggests that C-Tx and D-Tx transformers reached their peak RV at the shortest charging time (50 s) compared to the rest of the transformers. The B-Gen Tx has the next shortest charging time (200 s) followed by the A-Gen Tx. Simulated and measured RV magnitude showed a significance difference for the B-Gen Tx, where as the charging time to peak return voltage matches identically.




Fig. 11. RV spectra for the C and D transformers based on simulation from IDA data

#### IV.3 Simulation of Polarisation/Depolarisation Currents

An attempt is made here to simulate polarisation and depolarisation currents of these transformers. Simulation is performed using the RC parameters available from the curve fitting of IDA200 measurement data as described earlier. Once polarisation/depolarisation currents for very long times (10,000 seconds each) are available, it is possible to estimate oil and paper conductivities [10]. Results are presented in Table 4 using the concepts presented in references [10, 16]. In addition, an expert system was developed for moisture and ageing estimation by the first author of this paper, based on published results available from around the globe [16]. Based on the expert system, an attempt is also made here to find the moisture content of paper/pressboard insulation.

It can be observed from Table 4 that C-Tx and D-Tx transformers have much higher oil conductivities than those of the other four transformers. This suggests that the oil quality of these two transformers were much worse than the other transformers. The A-Gen Tx and B-Gen Tx also had higher oil conductivities than the other two auxiliary transformers at the same power station. On the other hand, the paper conductivities of C-Tx and D-Tx are also higher compared to the other four transformers. This suggests that paper ageing status of these two transformers (C and D) is in a much more degraded state than the other four.

The other four transformers have the paper conductivity in the same order, suggesting not much change in paper ageing conditions among these four transformers. Based on the conductivities of oil and paper, RVM results and the expert systems tool previously published in [16], the moisture levels of A-Gen and B-Gen transformers were 1.5%, while both auxiliary transformers A-Aux and B-Aux had a moisture level of lower than 1%. The expert system estimated 3% moisture levels for the C-Tx and D-Tx in their solid insulation.

## VI ACKNOWLEDGMENT

The authors would like to take this opportunity to thank Connell Wagner Advanced Technology Centre at Newcastle for their support in this work.

## VII REFERENCES

- [1] Leibfried, T., and Kachler, A. J.: "Insulation diagnostics on power transformers using the polarisation and depolarisation current (PDC) analysis", *Proc. IEEE International Symposium on Electrical Insulation*, pp. 170-173, 2002.
- [2] Csepes, G., Hamos, I., Brooks, I., and Karius, V.: "Practical foundations of the RVM (recovery voltage method for oil/paper insulation diagnosis)", *Proc. Conference on Electrical Insulation and Dielectric Phenomena*, vol. 1, pp. 345-355, 1998.
- [3] Shroff, D. H., and Stannett, A.W.: "A Review of Paper Aging in Power Transformers", *IEEE Proc.*, vol. 132, pt. C, no. 6, pp. 312-319, 1985.
- [4] Bogнар, A., Kalacsai, L., Csepes, G., Nemeth, E., and Schmidt, J.: "Diagnostic Tests of High Voltage Oil-Paper Insulation Systems (in Particular Transformer Insulation) Using DC Dielectrometrics", *Proc. CIGRE*, Paris Session, Paris, Paper no. 15/33-08, 1990.
- [5] Saha, T. K., Darveniza, M., Hill, D.J.T., and Le, T.T.: "Electrical and Chemical Diagnosis of Transformer Insulation, Part A: Aged Transformer Samples", *IEEE Trans. Power Delivery*, vol. 12, no. 4, pp. 1547-1554, 1997.
- [6] Ekanayake, C., Gubanski, G.M., Graczkowski, G., and Walczak K.: "Frequency response of oil impregnated pressboard and paper samples for estimating moisture in transformer insulation", *IEEE Transactions on Power Delivery*, Volume 21, Issue 3, July 2006 Page(s):1309 – 1317
- [7] Neimanis, R., Eriksson, R.: "Diagnosis of moisture in oil/paper distribution cables - Part I: Estimation of moisture content using frequency-domain spectroscopy" *IEEE Transactions on Power Delivery*, Volume 19, Issue 1, Jan. 2004 Page(s):9 - 14 GE
- [8] Energy Services, "IDA 200™, Insulation Diagnostics System", [http://www.gepower.com/prod\\_serv/products/electrical\\_test/en/downloads\\_en/ida200\\_en.pdf](http://www.gepower.com/prod_serv/products/electrical_test/en/downloads_en/ida200_en.pdf)
- [9] Tettex Instruments General catalogue part-3 "Automatic recovery voltage meter 5461 for a diagnosis of oil-paper insulation system", [http://www.haefely.com/measuring\\_diagnostics/rvm\\_docu/Connection\\_and\\_operating.pdf](http://www.haefely.com/measuring_diagnostics/rvm_docu/Connection_and_operating.pdf)
- [10] Saha, T. K., and Purkait, P.: "Investigation of polarization and depolarization current measurements for the assessment of oil-paper insulation of aged transformers", *IEEE Transactions of Dielectrics and Electrical Insulation*, Vol. 11, No. 1, Feb. 2004, pp. 144 – 154.
- [11] Saha, T. K., and Yao, Z.T.: "Experience with return voltage measurements for assessing insulation conditions in service-aged transformers", *IEEE Transactions on Power Delivery*, Vol.18, No. 1, Jan 2003, pp.128 – 135
- [12] On Behalf of CIGRE Task Force 15.01.09, "Dielectric Response Methods for Diagnosis of Power Transformers", *Electra no. 202*, pp. 25-36, 2002.
- [13] P. Jota, R.S., Islam, S. M., and Jota, F. G. : "Modelling the Polarisation in Composite Oil/Paper Insulation Systems", *IEEE Trans. Dielectrics and Electrical Insulation*, vol. 6, no. 2, pp.145-151, 1999.
- [14] Neimanis, R., Saha, T. K., and Eriksson, R.: "Determination of Moisture Content in Mass Impregnated Cable Insulation Using Low Frequency Dielectric Spectroscopy", *Proceedings of the IEEE 2000 Power Engineering Society Summer Meeting*, 16-20 July 2000, Seattle, USA, pp. 463-468.
- [15] Saha, T. K., Purkait, P., and Muller, F.: "Deriving an Equivalent Circuit of Transformer Insulation for Understanding the Dielectric response Measurements", *IEEE Transaction on Power Delivery*, Vol. 20, No. 1, pp. 149-157, January 2005.
- [16] Saha, T. K., and Purkait, P.: "An Expert System for Condition Assessment of transformer insulation Based on Dielectric response measurements", *IEEE Transactions on Power Delivery*, Vol. 19, No. 3, July 2004, pp. 1127-1134
- [17] Zaengl, W. S.: "Applications of dielectric spectroscopy in time and frequency domain for HV power equipment," *Electrical Insulation Magazine, IEEE*, vol. 19, no. 6, pp. 9-22, 2003.

Identity	Estimated oil conductivity (S/m)	Estimated pressboard/paper conductivity (S/m)	Estimated pressboard paper Moisture Content from the expert system [18]	Ranking Bad to good
A-Gen TX	$1.19 \times 10^{-12}$	$2.98 \times 10^{-14}$	1.5%	4
B-Gen TX	$1.33 \times 10^{-12}$	$5.17 \times 10^{-14}$	1.5%	3
A-Aux Tx	$5.13 \times 10^{-14}$	$5.09 \times 10^{-14}$	<1%	5
B-Aux Tx	$4.01 \times 10^{-14}$	$3.69 \times 10^{-14}$	<1%	6
C-Tx	$2.87 \times 10^{-11}$	$5.83 \times 10^{-13}$	3%	2
D-Tx	$2.55 \times 10^{-11}$	$1.55 \times 10^{-12}$	3%	1

Results from FDS measurements also showed that C-Tx and D-Tx also have the highest minimum  $\tan \delta$  among the group, followed by the B-Gen Tx. The results are consistent from both time domain and frequency domain measurements.

## V. CONCLUSIONS & DISCUSSIONS

A number of modern polarisation based dielectric diagnostics has been applied to six transformers. If the mathematical relationships between different dielectric diagnostics can be properly established, the analysis of insulation condition could be better understood.

An attempt has been made in this paper based on Matlab software to develop a circuit model, which describes the dielectric behaviour of the transformer's main insulation system. This circuit model has been modelled in this paper from the frequency domain measurement data and then RV and PDC have been simulated. An expert system has been developed in the recent past at the University of Queensland and some analyses have been presented in this paper[16]. Out of six transformers two auxiliary transformers A-Aux and B-Aux are in general found to be in dry and good insulation condition. Although two generator transformers A-Gen and B-gen (using expert system estimation) show 1.5% moisture level in solid insulation and after 11-12 years of operation this is not in an alarming state. However, the other two transformers C and D after 22 years in operation showed significant moisture levels and poor oil and paper quality. Dielectric polarisation based diagnostics can provide oil and paper insulation conductivities and can be related to moisture conditions. The confidence level of using polarisation based diagnostics can be improved with the development of a large database and possible use of expert systems. The interrelationship between different polarisation based diagnostics is now much better understood with the current software development capabilities. Research in this field is continuing and further findings will be reported in future papers.